

BEFORE THE ENVIRONMENTAL QUALITY COUNCIL
STATE OF WYOMING

In the Matter of the Appeal)
And Petition for Review of:)
BART Permit No. MD-6040)
(Jim Bridger Power Plant); and) Docket No. 10-2801
BART Permit No. MD-6042)
(Naughton Power Plant).)

**RESPONSE TO PACIFICORP'S MOTION FOR PARTIAL SUMMARY
JUDGMENT**

PacifiCorp's Revised BART applications for JB Units 1-4, 10/07

EXHIBIT 4

Final Report

BART Analysis for Jim Bridger Unit 1



Prepared For:

PacifiCorp

1407 West North Temple
Salt Lake City, Utah 84116

October 2007

Prepared By:

CH2MHILL

215 South State Street, Suite 1000
Salt Lake City, Utah 84111

Final Report

BART Analysis for Jim Bridger Unit 1

Submitted to
PacifiCorp

October 2007

CH2MHILL

Executive Summary

Background

In response to the Regional Haze Rule and Best Available Retrofit Technology (BART) regulations and guidelines, CH2M HILL was requested to perform a BART analysis for PacifiCorp's Jim Bridger Unit 1 (hereafter referred to as Jim Bridger 1). A BART analysis has been conducted for the following criteria pollutants: nitrogen oxide (NO_x), sulfur dioxide (SO₂), and particulate matter less than 10 micrometers in aerodynamic diameter (PM₁₀). The Jim Bridger Station consists of four 530-megawatt (MW) units with a total generating capacity of 2,120 MW. Because the total generating capacity of the Jim Bridger Station exceeds 750 MW, presumptive BART limits apply to Jim Bridger 1, based on the United States Environmental Protection Agency's (EPA) guidelines. Best Available Retrofit Technology emissions limits must be achieved within 5 years after the State Implementation Plan (SIP) is approved by the EPA. A compliance date of 2014 was assumed for this analysis.

In completing the BART analysis, technology alternatives were investigated and potential reductions in NO_x, SO₂, and PM₁₀ emissions rates were identified. The following technology alternatives were investigated, listed below by pollutant:

- NO_x emission controls:
 - Low-NO_x burners (LNBS) with over-fire air (OFA)
 - Rotating opposed fire air (ROFA)
 - LNBS with selective non-catalytic reduction (SNCR) system
 - LNBS with selective catalytic reduction (SCR) system
- SO₂ emission controls:
 - Optimize current operation of existing wet sodium flue gas desulfurization (FGD) system
 - Upgrade wet sodium FGD system to achieve an SO₂ emission rate of 0.10 pound (lb) per million British thermal units (MMBtu)
 - New dry FGD system
- PM₁₀ emission controls:
 - Sulfur trioxide (SO₃) injection flue gas conditioning system on existing electrostatic precipitator (ESP)
 - Polishing fabric filter

BART Engineering Analysis

The specific steps in a BART engineering analysis are identified in the Code of Federal Regulations (CFR) at 40 CFR 51, Appendix Y, Section IV. The evaluation must include:

- The identification of available, technically feasible, retrofit control options
- Consideration of any pollution control equipment in use at the source (which affects the availability of options and their impacts)
- The costs of compliance with the control options
- The remaining useful life of the facility
- The energy and non-air quality environmental impacts of compliance
- The degree of visibility improvement that may reasonably be anticipated from the use of BART

The following steps are incorporated into the BART analysis:

- Step 1 – Identify All Available Retrofit Control Technologies
- Step 2 – Eliminate Technically Infeasible Options
 - The identification of available, technically feasible, retrofit control options
 - Consideration of any pollution control equipment in use at the source (which affects the applicability of options and their impacts)
- Step 3 – Evaluate Control Effectiveness of Remaining Control Technologies
- Step 4 – Evaluate Impacts and Document the Results
 - The costs of compliance with the control options
 - The remaining useful life of the facility
 - The energy and non-air quality environmental impacts of compliance
- Step 5 – Evaluate Visibility Impacts
 - The degree of visibility improvement that may reasonably be anticipated from the use of BART

Separate analyses have been conducted for NO_x, SO₂, and PM₁₀ emissions. All costs included in the BART analyses are in 2006 dollars, and costs have not been escalated to the assumed 2014 BART implementation date.

Coal Characteristics

The main source of coal burned at Jim Bridger 1 will be the Bridger Underground Mine. Secondary sources are the Bridger Surface Mine, the Bridger Highwall Mine, the Black Butte Mine, and the Leucite Hills Mine. These coals are ranked as sub-bituminous, but are closer in

characteristics to bituminous coal in many of the parameters influencing NO_x formation. These coals have higher nitrogen content than coals from the Powder River Basin (PRB), which represent the bulk of sub-bituminous coal used in the U.S. This BART analysis has considered the higher nitrogen content and different combustion characteristics of PRB coals as compared to those coals used at Jim Bridger 1, and has evaluated the effect of these qualities on NO_x formation and achievable emission rates.

Recommendations

CH2M HILL recommends installing the following control devices, which include LNBs with OFA, upgrading the existing FGD system, and operating the existing ESP with an SO₃ flue gas conditioning system. This combination of control devices is identified as Scenario 1 throughout this report.

NO_x Emission Control

The BART presumptive NO_x limit assigned by EPA for tangentially-fired boilers burning sub-bituminous coal is 0.15 lb per MMBtu. However, as documented in this analysis, the characteristics of the Jim Bridger coals are more closely aligned with bituminous coals, with a presumptive BART NO_x limit of 0.28 lb per MMBtu.

CH2M HILL recommends the existing LNB with OFA as BART for Jim Bridger 1, based on the projected significant reduction in NO_x emissions, reasonable control costs, and the advantages of no additional power requirements or non-air quality environmental impacts. Nitrogen oxide reductions are expected to be similar to those realized at Jim Bridger 2. CH2M HILL recommends that the unit be permitted at a rate of 0.26 lb per MMBtu.

SO₂ Emission Control

CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 1, based on the significant reduction in SO₂ emissions, reasonable control costs, and the advantages of minimal additional power requirements and minimal non-air quality environmental impacts. This upgrade approach will meet the BART presumptive SO₂ limit of 0.15 lb per MMBtu.

PM₁₀ Emission Control

CH2M HILL recommends finalizing the permitting of the flue gas conditioning system to enhance the performance of the existing ESP as BART for Jim Bridger 1, based on the significant reduction in PM₁₀ emissions, reasonable control costs, and the advantages of minimal additional power requirements and no non-air quality environmental impacts.

BART Modeling Analysis

CH2M HILL used the CALPUFF modeling system to assess the visibility impacts of emissions from Jim Bridger 1 at Class I areas. The Class I areas potentially affected are located more than 50 kilometers, but less than 300 kilometers, from the Jim Bridger Plant.

The Class I areas include the following wilderness areas (WA):

- Bridger WA
- Fitzpatrick WA
- Mt. Zirkel WA

Because Jim Bridger 1 will simultaneously control NO_x, SO₂, and PM₁₀ emissions, four post-control atmospheric dispersion modeling scenarios were developed to cover the range of effectiveness for combining the individual NO_x, SO₂, and PM₁₀ control technologies under evaluation. These modeling scenarios, and the controls assumed, are as follows:

- **Scenario 1:** New LNB with OFA modifications, upgraded wet FGD system, and flue gas conditioning for enhanced ESP performance. As indicated previously, this scenario represents PacifiCorp's preliminary BART selection.
- **Scenario 2:** New LNB with OFA modifications, upgraded wet FGD system, and new polishing fabric filter.
- **Scenario 3:** New LNB with OFA modifications and SCR, upgraded wet FGD system, and flue gas conditioning for enhanced ESP performance.
- **Scenario 4:** New LNB with OFA modifications and SCR, upgraded wet FGD system, and new polishing fabric filter.

Visibility improvements for all emission control scenarios were analyzed, and the results were compared utilizing a least-cost envelope, as outlined in the *New Source Review Workshop Manual*¹.

Least-cost Envelope Analysis

EPA has adopted the Least-cost Envelope Analysis Methodology as an accepted methodology for selecting the most reasonable, cost-effective controls. Incremental cost-effectiveness comparisons focus on annualized cost and emission reduction differences between dominant alternatives. The dominant set of control alternatives is determined by generating what is called the envelope of least-cost alternatives. This is a graphical plot of total annualized costs for total emissions reductions for all control alternatives identified in the BART analysis.

To evaluate the impacts of the modeled control scenarios on the three Class I areas, the total annualized cost, cost per deciview (dV) reduction, and cost per reduction in number of days above 0.5 dV were analyzed. This report provides a comparison of the average incremental costs

¹ EPA, 1990. *New Source Review Workshop Manual*. Draft. Environmental Protection Agency. October, 1990.

between relevant scenarios for the three Class I areas; the total annualized cost versus number of days above 0.5 dV, and the total annualized cost versus 98th percentile delta-deciview (Δ dV) reduction.

Results of the least-cost envelope analysis validate the selection of Scenario 1, based on incremental cost and visibility improvements. Scenario 2 (LNB with OFA, upgraded wet FGD, and polishing fabric filter) is eliminated, because it is to the left of the curve formed by the dominant control alternative scenario, which indicates a scenario with lower improvement and/or higher costs. Scenario 3 (LNB with OFA and SCR, upgraded wet FGD, and flue gas conditioning for enhanced ESP performance) is not selected due to very high incremental costs, on the basis of both a cost per day of improvement and cost per dV reduction. While Scenario 4 (LNB with OFA and SCR, upgraded wet FGD, and polishing fabric filter) provides some potential visibility advantage over Scenario 1, the projected improvement is less than 0.5 dV, and the projected costs are excessive. Therefore, Scenario 1 represents BART for Jim Bridger 1.

Just-Noticeable Differences in Atmospheric Haze

Studies have been conducted that demonstrate only dV differences of approximately 1.5 to 2.0 dV or more are perceptible by the human eye. Deciview changes of less than 1.5 cannot be distinguished by the average person. Therefore, the modeling analysis results indicate that only minimal, if any, observable visibility improvements at the Class I areas studied would be expected under any of the control scenarios. Thus, the results indicate that even though PacifiCorp will be spending many millions of dollars at this single unit, and over \$1 billion when considering its entire coal fleet, only minimal discernable visibility improvements may result.

Contents

1.0	Introduction	1-1
2.0	Present Unit Operation	2-1
3.0	BART Engineering Analysis	3-1
3.1	Applicability	3-1
3.2	BART Process	3-1
3.2.1	BART NO _x Analysis	3-2
3.2.2	BART SO ₂ Analysis	3-14
3.2.3	BART PM ₁₀ Analysis	3-17
4.0	BART Modeling Analysis	4-1
4.1	Model Selection	4-1
4.2	CALMET Methodology	4-1
4.2.1	Dimensions of the Modeling Domain	4-1
4.2.2	CALMET Input Data	4-3
4.2.3	Validation of CALMET Wind Field	4-4
4.3	CALPUFF Modeling Approach	4-6
4.3.1	Background Ozone and Ammonia	4-6
4.3.2	Stack Parameters	4-6
4.3.3	Emission Rates	4-6
4.3.4	Post-control Scenarios	4-7
4.3.5	Modeling Process	4-9
4.3.6	Receptor Grids	4-9
4.4	CALPOST	4-9
4.5	Presentation of Modeling Results	4-10
4.5.1	Visibility Changes for Baseline vs. Preferred Scenario	4-10
5.0	Preliminary Assessment and Recommendations	5-1
5.1	Least-cost Envelope Analysis	5-1
5.1.1	Analysis Methodology	5-1
5.1.2	Analysis Results	5-9
5.2	Recommendations	5-9
5.2.1	NO _x Emission Control	5-9
5.2.2	SO ₂ Emission Control	5-9
5.2.3	PM ₁₀ Emission Control	5-9
5.3	Just-Noticeable Differences in Atmospheric Haze	5-10
6.0	References	6-1

Tables

- 2-1 Unit Operation and Study Assumptions
- 2-2 Coal Sources and Characteristics
- 3-1 Coal Characteristics Comparison
- 3-2 NO_x Control Technology Emission Rate Ranking
- 3-3 NO_x Control Cost Comparison
- 3-4 SO₂ Control Technology Emission Rates
- 3-5 SO₂ Control Cost Comparison (Incremental to Existing FGD System)
- 3-6 PM₁₀ Control Technology Emission Rates
- 3-7 PM₁₀ Control Cost Comparison (Incremental to Existing ESP)
- 4-1 User-specified CALMET Options
- 4-2 BART Model Input Data
- 4-3 Average Natural Levels of Aerosol Components
- 4-4 Costs and Visibility Modeling Results for Baseline vs. Post-control Scenarios at Class I Areas
- 5-1 Control Scenario Results for the Bridger Class I Wilderness Area
- 5-2 Control Scenario Results for the Fitzpatrick Class I Wilderness Area
- 5-3 Control Scenario Results for the Mt. Zirkel Class I Wilderness Area
- 5-4 Bridger Class I Wilderness Area Incremental Analysis Data
- 5-5 Fitzpatrick Class I Wilderness Area Incremental Analysis Data
- 5-6 Mt. Zirkel Class I Wilderness Area Incremental Analysis Data

Figures

- 3-1 Illustration of the Effect of Agglomeration on the Speed of Coal Combustion
- 3-2 Plot of Typical Nitrogen Content of Various Coals and Applicable Presumptive BART NO_x Limits
- 3-3 Plot of Typical Oxygen Content of Various Coals and Applicable Presumptive BART NO_x Limits
- 3-4 First Year Control Cost for NO_x Air Pollution Control Options
- 3-5 First Year Control Cost for PM Air Pollution Control Options
- 4-1 Jim Bridger Source-Specific Areas to be Addressed
- 4-2 Surface and Upper Air Stations Used in the Jim Bridger BART Analysis
- 5-1 Least-cost Envelope Bridger Class I WA Days Reduction
- 5-2 Least-cost Envelope Bridger Class I WA 98th Percentile Reduction
- 5-3 Least-cost Envelope Fitzpatrick Class I WA Days Reduction
- 5-4 Least-cost Envelope Fitzpatrick Class I WA 98th Percentile Reduction
- 5-5 Least-cost Envelope Mt. Zirkel Class I WA Days Reduction
- 5-6 Least-cost Envelope Mt. Zirkel Class I WA 98th Percentile Reduction

Appendices

- A Economic Analysis
- B 2006 Wyoming BART Protocol

Acronyms and Abbreviations

°F	Degrees Fahrenheit
°C	Degrees Celsius
BACT	Best Available Control Technology
BART	Best Available Retrofit Technology
CALDESK	Program to Display Data and Results
CALMET	Meteorological Data Preprocessing Program for CALPUFF
CALPOST	Post-processing Program for Calculating Visibility Impacts
CALPUFF	Gaussian Puff Dispersion Model
CFR	Code of Federal Regulations
CO	Carbon Monoxide
COHPAC	Compact Hybrid Particulate Collector
dV	Deciview
ΔdV	Delta Deciview, Change in Deciview
EIA	Energy Information Administration
ESP	Electrostatic Precipitator
EPA	United States Environmental Protection Agency
Fuel NO _x	Oxidation of Fuel-bound Nitrogen
FGC	Flue Gas Conditioning
FGD	Flue Gas Desulfurization
f(RH)	Relative Humidity Factors
kW	Kilowatt
LAER	Lowest Achievable Emission Rate
lb	Pound(s)
LNB	Low-NO _x Burner
LOI	Loss on Ignition
MMBtu	Million British Thermal Units
MM5	Mesoscale Meteorological Model, Version 5
MW	Megawatt
N ₂	Nitrogen
NO _x	Nitrogen Oxide
NSR Manual	<i>New Source Review Workshop Manual</i> (EPA, 1990)
OFA	Over-fire Air

PM	Particulate Matter
PM ₁₀	Particulate Matter less than 10 Micrometers in Aerodynamic Diameter
PM _{2.5}	Particulate Matter less than 2.5 Micrometers in Aerodynamic Diameter
PRB	Powder River Basin
ROFA	Rotating Opposed Fire Air
S&L	Sargent & Lundy
SCR	Selective Catalytic Reduction
SIP	State Implementation Plan
SNCR	Selective Non-catalytic Reduction
SO ₂	Sulfur Dioxide
SO ₃	Sulfur Trioxide
Thermal NO _x	High Temperature Fixation of Atmospheric Nitrogen in Combustion Air
TRC	TRC Company, Inc.
USGS	U.S. Geological Survey
WA	Wilderness Area
WDEQ-AQD	Wyoming Department of Environmental Quality – Air Quality Division

1.0 Introduction

Best Available Retrofit Technology (BART) guidelines were established as a result of U.S. Environmental Protection Agency (EPA) regulations intended to reduce the occurrence of regional haze in national parks and other Class I protected air quality areas in the United States (40 Code of Federal Regulations [CFR] Part 51). These guidelines provide guidance for states when determining which facilities must install additional controls, and the type of controls that must be used. Facilities eligible for BART installation were built between 1962 and 1977, and have the potential to emit more than 250 tons per year of visibility-impairing pollutants.

The Wyoming Department of Environmental Quality (WDEQ) BART regulations state that each source subject to BART must submit a BART application for a construction permit by December 15, 2006. PacifiCorp received an extension from the WDEQ to submit the BART report for Jim Bridger Unit 1 (hereafter referred to as Jim Bridger 1) by January 12, 2007. The BART report that was submitted to WDEQ in January 2007 included a BART analysis, and a proposal and justification for BART at the source. This revised report—submitted in October 2007—incorporates editorial revisions and new model runs since the January 2007 version.

The State of Wyoming has identified those eligible, in-state facilities that are required to reduce emissions under BART, and will set BART emissions limits for those facilities. This information will be included in the State of Wyoming State Implementation Plan (SIP), which the State has estimated will be formally submitted to the EPA by early 2008. The EPA BART guidelines also state that the BART emission limits must be fully implemented within 5 years of EPA's approval of the SIP.

Five elements related to BART address the issue of emissions for the identified facilities:

- Any existing pollution control technology in use at the source
- The cost of the controls
- The remaining useful life of the source
- The energy and non-air quality environmental impacts of compliance
- The degree of improvement in visibility that may reasonably be anticipated from the use of such technology

This report documents the BART analysis that was performed on Jim Bridger 1 by CH2M HILL for PacifiCorp. The analysis was performed for the pollutants nitrogen oxide (NO_x), sulfur dioxide (SO₂), and particulate matter less than 10 micrometers in aerodynamic diameter (PM₁₀), because they are the primary criteria pollutants that affect visibility.

Section 2 of this report provides a description of the present unit operation, including a discussion of coal sources and characteristics. The BART Engineering Analysis is provided in Section 3, by pollutant type. Section 4 provides the methodology and results of the BART Modeling Analysis, followed by recommendations in Section 5 and references in Section 6. Appendices provide more detail on the economic analysis and the 2006 Wyoming BART Protocol.

2.0 Present Unit Operation

The Jim Bridger Station consists of four units with a total generating capacity of 2,120 megawatts (MW). Jim Bridger 1 is a nominal 530 net MW unit located approximately 35 miles northeast of Rock Springs, Wyoming. Unit 1 is equipped with a tangentially fired, pulverized-coal boiler with low-NO_x burners (LNBs) manufactured by Combustion Engineering. The unit was constructed with a Flakt wire frame electrostatic precipitator (ESP). The unit contains a Babcock & Wilcox wet sodium flue gas desulfurization (FGD) system with three absorber towers installed in 1990. An Emerson Ovation distributed control system was installed in 2006.

Jim Bridger 1 was placed in service in 1974. Its current economic depreciation life is through 2040; however, this analysis is based on a 20-year life for BART control technologies. Assuming a BART implementation date of 2014, this will result in an approximate remaining useful life for Jim Bridger 1 of 20 years from the installation date of any new or modified BART-related equipment. This report does not attempt to quantify any additional life extension costs needed to allow the unit and these control devices at Jim Bridger 1 to operate until 2040.

Table 2-1 lists additional unit information and study assumptions for this analysis.

The BART presumptive NO_x limit for tangential-fired boilers burning sub-bituminous coal is 0.15 pound per million British thermal units (lb per MMBtu) and the BART presumptive NO_x limit for burning bituminous coal is 0.28 lb per MMBtu. The main sources of coal burned at Jim Bridger 1 are the Bridger Mine and secondarily the Black Butte Mine and Leucite Hills Mine. These coals are ranked as sub-bituminous, but are closer in characteristics to bituminous coal in many of the parameters influencing NO_x formation. These coals have higher nitrogen content than coals from the Powder River Basin (PRB), which represent the bulk of sub-bituminous coal used in the U.S. This BART analysis has considered the higher nitrogen content and the different combustion characteristics of PRB coals, as compared to those coals used at Jim Bridger 1, and has evaluated the effect of these qualities on NO_x formation and achievable emission rates. Coal sources and characteristics are summarized in Table 2-2. The primary source of coal will be the Bridger Underground Mine, and data on coal from this source were used in the modeling analysis. For the coal analysis that is presented in Section 3, the data from all the coal sources were used.

TABLE 2-1
Unit Operation and Study Assumptions
Jim Bridger 1

General Plant Data	
Site Elevation (feet above mean sea level)	6669
Stack Height (feet)	500
Stack Exit ID (feet) /Exit Area (square feet)	24 /452.4
Stack Exit Temperature (degrees Fahrenheit)	140
Stack Exit Velocity (feet per second)	84.0
Stack Flow (actual cubic feet per minute)	2,281,182
Latitude (degree: minute: second)	41:44:07 north
Longitude (degree: minute: second)	108:47:12 west
Annual Unit Capacity Factor (percentage)	90
Net Unit Output (megawatts)	530
Net Unit Heat Rate (British thermal units (Btu) per kilowatt-hour)(100% load)	10,400 (as measured by fuel throughput)
Boiler Heat Input (million Btu (MMBtu) per hour)(100% load)	6,000 (as measured by continuous emission monitoring)
Type of Boiler	Tangentially fired
Boiler Fuel	Coal
Coal Sources	Bridger Mine, Black Butte Mine, Leucite Hills Mine
Coal Heating Value (Btu per pound [lb]) ^(a)	9,660
Coal Sulfur Content (percentage by weight [wt. %]) ^(a)	0.58
Coal Ash Content (wt. %) ^(a)	10.3
Coal Moisture Content (wt. %) ^(a)	19.3
Coal Nitrogen Content (wt. %) ^(a)	0.98
Current Nitrogen Oxide (NO _x) Controls	Low-NO _x burners
NO _x Emission Rate (lb/MMBtu)	0.45
Current Sulfur Dioxide (SO ₂) Controls	Sodium-based wet scrubber
SO ₂ Emission Rate (lb/MMBtu)	0.267
Current PM ₁₀ ^(b) Controls	Electrostatic Precipitator
PM ₁₀ Emission Rate (lb/MMBtu) ^(c)	0.045

NOTES:

^(a)Coal characteristics based on Bridger Underground Mine (primary coal source)

^(b)PM₁₀ refers to particulate matter less than 10 micrometers in aerodynamic diameter

^(c)Based on maximum historic emission rate from 1999 to 2001, prior to installation of the sulfur trioxide (SO₃) injection system.

TABLE 2-2
Coal Sources and Characteristics
Jim Bridger 1

Mines	Ultimate Analysis (% dry basis)												
	Moisture (%)	Ash (%)	Volatile Matter (%)	Fixed Carbon (%)	British thermal units per pound (Btu/lb)	Sulfur (%)	Moisture and Ash Free (Btu/lb)	Hydrogen	Carbon	Sulfur	Nitrogen	Oxygen	Ash
Bridger Mine Underground	19.3	10.3	32.2	38.3	9660	0.58	13712	4.66	69.2	0.72	1.22	11.8	12.4
Maximum	Not enough data yet to run statistical analysis for variability												
Minimum	Not enough data yet to run statistical analysis for variability												
Bridger Mine Surface	19.1	10.6	32.3	38.0	9390	0.57	13340	4.38	37.4	0.71	1.26	13.2	13.0
Maximum	20.5	12.5	35.5	41.9	9800	0.72	13500	4.69	4.0	0.90	1.43	14.8	15.8
Minimum	17.5	9.0	31.0	36.0	9000	0.49	13100	4.00	64.3	0.60	1.14	11.7	11.2
Bridger Mine Highwall	18.0	9.5	33.0	39.5	9700	0.58	13500	No samples of separate highwall coal					
Maximum	Not enough data yet to run statistical analysis for variability												
Minimum	Not enough data yet to run statistical analysis for variability												
Black Butte Mine	20.0	9.2	33.3	35.6	9450	0.45	13330	4.43	68.7	0.56	1.47	13.4	11.5
Maximum	21.1	10.8	35.4	41.9	10275	0.62	13500	4.66	70.5	0.78	1.69	14.8	13.6
Minimum	18.0	7.6	29.9	36.8	9180	0.33	13140	4.21	66.1	0.41	1.25	11.6	9.7
Leucite Hills Mine (through 2009)	19.4	11.5	30.7	38.3	9080	0.64	13140	4.20	66.0	0.81	1.48	13.2	14.4
Maximum	23.0	15.0	33.0	43.0	10250	0.90	13800	4.70	70.0	1.20	1.64	17.1	19.0
Minimum	17.0	8.0	28.3	33.6	8000	0.40	12300	3.70	61.0	0.50	1.32	10.5	10.0

3.0 BART Engineering Analysis

This section presents the required BART engineering analysis.

3.1 Applicability

In compliance with regional haze requirements, the State of Wyoming must prepare and submit visibility SIPs to the EPA for Class I areas. The State has estimated that the formal submittal of the SIPs will occur by early 2008. The first phase of the regional haze program is the implementation of BART emission controls on all BART eligible units, within 5 years after EPA approval of the SIP.

3.2 BART Process

The specific steps in a BART engineering analysis are identified in 40 CFR 51, Appendix Y, Section IV. The evaluation must include:

- The identification of available, technically feasible, retrofit control options
- Consideration of any pollution control equipment in use at the source (which affects the availability of options and their impacts)
- The costs of compliance with the control options
- The remaining useful life of the facility
- The energy and non-air quality environmental impacts of compliance
- The degree of visibility improvement that may reasonably be anticipated from the use of BART

The following steps are incorporated into the BART analysis:

- Step 1 – Identify All Available Retrofit Control Technologies
- Step 2 – Eliminate Technically Infeasible Options
 - The identification of available, technically feasible, retrofit control options
 - Consideration of any pollution control equipment in use at the source (which affects the applicability of options and their impacts)
- Step 3 – Evaluate Control Effectiveness of Remaining Control Technologies

- Step 4 – Evaluate Impacts and Document the Results
 - The costs of compliance with the control options
 - The remaining useful life of the facility
 - The energy and non-air quality environmental impacts of compliance
- Step 5 – Evaluate Visibility Impacts
 - The degree of visibility improvement that may reasonably be anticipated from BART use

In order to minimize costs in the BART analysis, consideration was made of any pollution control equipment in use at the source, the costs of compliance associated with the control options, and the energy and non-air quality environmental impacts of compliance using these existing control devices. In some cases, enhancing the performance of the existing control equipment was considered. Other scenarios with new control equipment were also developed.

Separate analyses have been conducted for NO_x, SO₂, and PM₁₀ emissions. All costs included in the BART analysis are in 2006 dollars, and costs have not been escalated to the assumed 2014 BART implementation date.

3.2.1 BART NO_x Analysis

Nitrogen oxide formation in coal-fired boilers is a complex process that is dependent on a number of variables, including operating conditions, equipment design, and coal characteristics.

Formation of NO_x

During coal combustion, NO_x is formed in three different ways. The dominant source of NO_x formation is the oxidation of fuel-bound nitrogen (fuel NO_x). During combustion, part of the fuel-bound nitrogen is released from the coal with the volatile matter, and part is retained in the solid portion (char). The nitrogen chemically bound in the coal is partially oxidized to nitrogen oxides (nitric oxide and nitrogen dioxide) and partially reduced to molecular nitrogen (N₂). A smaller part of NO_x formation is due to high temperature fixation of atmospheric nitrogen in the combustion air (thermal NO_x). A very small amount of NO_x is called prompt NO_x. Prompt NO_x results from an interaction of hydrocarbon radicals, nitrogen, and oxygen.

In a conventional pulverized coal burner, air is introduced with turbulence to promote good mixing of fuel and air, which provides stable combustion. However, not all of the oxygen in the air is used for combustion. Some of the oxygen combines with the fuel nitrogen to form NO_x.

Coal characteristics directly and significantly affect NO_x emissions from coal combustion. Coal ranking is a means of classifying coals according to their degree of metamorphism in the natural series, from lignite to sub-bituminous to bituminous and on to anthracite. Lower rank coals, such as the sub-bituminous coals from the PRB, produce lower NO_x emissions than higher rank bituminous coals, due to their higher reactivity and lower nitrogen content. The fixed carbon to volatile matter ratio (fuel ratio), coal oxygen content, and rank are good relative indices of the reactivity of a coal. Lower rank coals release more organically bound nitrogen earlier in the combustion process than do higher rank bituminous coals. When used with LNBs, sub-bituminous coals create a longer time for the kinetics to promote more stable molecular nitrogen, and hence result in lower NO_x emissions.

Coals from the PRB are classified as sub-bituminous C and demonstrate the high reactivity and low NO_x production characteristics described above. Based on data from the Energy Information Administration (EIA), PRB coals currently represent 88 percent of total U.S. sub-bituminous production and 73 percent of western coal production (Energy Information Administration, 2006). Most references to western coal and sub-bituminous coal infer PRB origin and characteristics. Emissions standards differentiating between bituminous and sub-bituminous coals are presumed to use PRB coal as the basis for the sub-bituminous standards, due to its dominant market presence and unique characteristics.

There are a number of western coals that are classified as sub-bituminous, however, they border on being ranked as bituminous and do not display many of the qualities of PRB coals, including most of the low NO_x forming characteristics. Coals from the Bridger, Black Butte, and Leucite Hills mines fall into this category.

As defined by the American Society for Testing and Materials, the only distinguishing characteristic that classifies the coals used at Jim Bridger 1 as sub-bituminous rather than bituminous – is that they are “agglomerating” as compared to “non-agglomerating.” Agglomerating as applied to coal is “the property of softening when it is heated to above about 400 degrees Celsius (°C) in a non-oxidizing atmosphere, and then appearing as a coherent mass after cooling to room temperature.” Because the agglomerating property of coals is the result of particles transforming into a plastic or semi-liquid state when heated, it reflects a change in surface area of the particle. Thus, with the application of heat, agglomerating coals would tend to develop a non-porous surface, while the surface of non-agglomerating coals would become even more porous with combustion. As shown in Figure 3-1, the increased porosity provides more particle surface area, resulting in more favorable combustion conditions. This non-agglomerating property assists in making sub-bituminous coals more amenable to controlling NO_x, by allowing less air to be introduced during the initial ignition portion of the combustion process. The coals from the Bridger, Black Butte and Leucite Hills mines just barely fall into the category of non-agglomerating coals. While each of these coals is considered non-agglomerating, they either do not exhibit those properties of non-agglomerating coals or exhibit them to only a minor degree. The conditions during combustion of typical non-agglomerating coals that make it easier to control NO_x emissions do not exist during combustion of the Bridger blends of coals.

FIGURE 3-1
Illustration of the Effect of Agglomeration on the Speed of Coal Combustion
Jim Bridger 1




Table 3-1 shows key characteristics of a typical PRB coal, compared to coals from the Bridger Mine, Black Butte, and Leucite Hills, as well as coal from Twentymile, which is a representative western bituminous coal.

TABLE 3-1
Coal Characteristics Comparison
Jim Bridger 1

Parameter	Typical Powder River Basin	Bridger Mine	Black Butte	Leucite Hills	Twentymile
Nitrogen (% dry)	1.10	1.26	1.47	1.48	1.85
Oxygen (% dry)	16.2	13.2	13.4	13.2	7.19
Coal-rank	Sub C	Sub B	Sub B	Sub B	Bitum. high volatility B

As shown in Table 3-1, although Bridger, Black Butte, and Leucite Hills are classified as sub-bituminous, they all exhibit higher nitrogen content and lower oxygen content than the PRB coal. The higher nitrogen content is an indication that more nitrogen is available to the combustion process and higher NO_x emissions are likely. Oxygen content can be correlated to the reactivity of the coal, with more reactive coals generally containing higher levels of oxygen. More reactive coals tend to produce lower NO_x emissions, and they are also more conducive to reduction of NO_x emissions through the use of combustion control measures, such as LNBS and over-fire air (OFA). These characteristics indicate that higher NO_x formation is likely with coal from the Bridger, Black Butte, and Leucite Hills mines, rather than with PRB coal. The Bridger, Black Butte, and Leucite Hills coals all contain quality characteristics that fall between a typical PRB coal and Twentymile. Twentymile is a clearly bituminous coal that produces higher NO_x, as has been demonstrated at power plants burning this fuel.

Figures 3-2 and 3-3 graphically illustrate the relationship of nitrogen and oxygen content to the BART presumptive NO_x limits for the coals listed in Table 3-1. Each chart identifies the presumptive BART limit associated with a typical bituminous and sub-bituminous coal, and demonstrates how the Jim Bridger coal falls between these two general coal classifications.

The Bridger blend data point represents a combination of coals from the Bridger Mine, Black Butte, and Leucite Hills that has been used at Jim Bridger 1, and indicates the average NO_x emission rate achieved during the years 2003 to 2005. The Jim Bridger 2 data point consists of the same blend of coals as Jim Bridger 1, and represents the NO_x emission rate achieved after installation of Alstom's current state-of-the-art TFS2000 LNB and OFA system. The long-term sustainable emission rate for this system is expected to be 0.24 lb per MMBtu. All four units at Jim Bridger consist of identical boilers; while there may be some differences in performance among them, installation of the TFS2000 firing system at Jim Bridger 1 would likely result in performance and NO_x emission rates comparable to those at Jim Bridger 2.

Figures 3-2 and 3-3 both demonstrate that for the Jim Bridger units with the TFS2000 low NO_x emission system installed and burning a combination of the Bridger, Black Butte, and Leucite Hill coals, the likely NO_x emission rate will be closer to the bituminous end (0.28) of the BART presumptive NO_x limit range, rather than the BART presumptive NO_x limit of 0.15 lb per MMBtu for sub-bituminous coal. All these factors are consistent with the observed sustainable rate of 0.24 lb per MMBtu.

FIGURE 3-2
 Plot of Typical Nitrogen Content of Various Coals and Applicable Presumptive BART NO_x Limits
 Jim Bridger 1





FIGURE 3-3
 Plot of Typical Oxygen Content of Various Coals and Applicable Presumptive BART NO_x Limits
 Jim Bridger 1



Coal quality characteristics also impact the design and operation of the boiler and associated auxiliary equipment. Minor changes in quality can sometimes be accommodated through operational adjustments or changes to equipment. It is important to note, however, that consistent variations in quality or assumptions of "average" quality for performance projections can be problematic. This is particularly troublesome when dealing with performance issues that are very sensitive to both coal quality and combustion conditions, such as NO_x formation. There is significant variability in the quality of coals burned at Jim Bridger 1. In addition to burning coal from Black Butte and Leucite Hills, Jim Bridger 1 burns coal supplied from the Bridger Mine consisting of three sources: underground, surface, and highwall operations. Each of these coal sources has different quality characteristics, as well as inherent variability in composition of the coal within the mine.

Several of the coal quality characteristics and their effect on NO_x formation have been previously discussed. There are some additional considerations that illustrate the complexity of achieving and maintaining consistent low NO_x emissions with pulverized coal on a shorter term, such as a 30-day rolling average basis.

Good combustion is based on the "three Ts": time, temperature, and turbulence. These parameters along with a "design" coal are taken into consideration when designing a boiler and associated firing equipment such as fans, burners, and pulverizers. If a performance requirement, such as NO_x emission limits, is subsequently changed, conflicts with other performance issues can result.

Jim Bridger 1 is located at an altitude of 6,669 feet above sea level. At this elevation, atmospheric pressure is lower (11.5 pounds per square inch) as compared with sea level pressure of 14.7 pounds per square inch. This lower pressure means that less oxygen is available for combustion for each volume of air. In order to provide adequate oxygen to meet the requirements for efficient combustion, larger volumes of air are required. When adjusting air flows and distribution to lower NO_x using LNBS and OFA, original boiler design restrictions again limit the modifications that can be made and still achieve satisfactory combustion performance.

Another significant factor in controlling NO_x emissions is the fineness of the coal entering the burners. Fineness is influenced by the grindability index (Hardgrove) of the coal. Finer coal particles promote release of volatiles and assist char burnout due to more surface area exposed to air. Nitrogen oxide reduction with high volatile coals is improved with greater fineness and with proper air staging. The lower rank sub-bituminous coals such as PRB coals are quite friable and easy to grind. Coals with lower Hardgrove Grindability Index values, such as those used at Jim Bridger 1, are more difficult to grind and can contribute to higher NO_x levels. In addition, coal fineness can deteriorate over time periods between pulverizer maintenance and service as pulverizer grinding surfaces wear.

In summary, when all the factors of agglomeration versus non-agglomeration, nitrogen and oxygen content of the coals, and the grindability index are taken into account, this analysis demonstrates that, for the coal used at Jim Bridger 1, the more applicable presumptive BART limit is 0.28 lb per MMBtu. The BART analysis for NO_x emissions from Jim Bridger 1 is further described below.

Step 1: Identify All Available Retrofit Control Technologies

The first step of the BART process is to evaluate NO_x control technologies with practical potential for application to Jim Bridger 1, including those control technologies identified as Best Available Control Technology (BACT) or lowest achievable emission rate (LAER) by permitting agencies across the United States. A broad range of information sources have been reviewed in an effort to identify potentially applicable emission control technologies. Jim Bridger 1 NO_x emissions are currently controlled through the use of good combustion practices and OFA.

The following potential NO_x control technology options were considered:

- New/modified LNBS with advanced OFA
- Rotating Opposed Fire Air (ROFA)
- Conventional selective non-catalytic reduction (SNCR) system
- Selective catalytic reduction (SCR) system

Step 2: Eliminate Technically Infeasible Options

~~For Jim Bridger 1, a tangential-fired configuration burning sub-bituminous coal, technical feasibility will primarily be determined by physical constraints, boiler configuration, and on the ability to achieve the regulatory presumptive limit (used as a guide) of 0.28 lb per MMBtu of NO_x. Jim Bridger 1 has an uncontrolled NO_x emission rate of 0.45 lb per MMBtu.~~

For this BART analysis, information pertaining to LNBS, OFA, SNCR, and SCR were based on the *Multi-Pollutant Control Report* (Sargent and Lundy, 2002, hereafter referred to as the S&L Study). Updated cost estimates for SCR and SNCR were used (Sargent and Lundy, 2006). PacifiCorp provided additional emissions data and costs developed by boiler vendors for LNBS and OFA. Also, CH2M HILL solicited a proposal from Mobotec for their ROFA technology.

With SNCR, an amine-based reagent such as ammonia, or more commonly urea, is injected into the furnace within a temperature range of 1,600 degrees Fahrenheit (°F) to 2,100°F, where it reduces NO_x to nitrogen and water. Nitrogen oxide reductions of up to 60 percent have been achieved, although 15 to 30 percent is more realistic for most applications. Selective non-catalytic reduction is typically applied on smaller units. Adequate reagent distribution in the furnaces of large units can be problematic.

Table 3-2 summarizes the control technology options evaluated in this BART analysis, along with projected NO_x emission rates. All technologies can meet the applicable presumptive BART limit of 0.28 lb per MMBTU.

TABLE 3-2
 NO_x Control Technology Emission Rate Ranking
 Jim Bridger 1

Technology	Projected Emission Rate (pounds per million British thermal units)
Presumptive Best Available Retrofit Technology (BART) Limit	0.28
Low-NO _x Burners (LNBs) with Over-fire Air (OFA)	0.24
Rotating Opposed Fire Air (ROFA)	0.22
LNB with OFA and Selective Non-catalytic Reduction (SNCR)	0.20
LNB with OFA and Selective Catalytic Reduction (SCR)	0.07

Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

Preliminary vendor proposals, such as those used to support portions of this BART analysis, may be technically feasible and provide expected or guaranteed emission rates; however, the proposals include inherent uncertainties. These proposals are usually prepared in a limited time frame, may be based on incomplete information, may contain over-optimistic conclusions, and are non-binding. Therefore, emission rate values obtained in such preliminary proposals must be qualified, and it must be recognized that contractual guarantees are established only after more detailed analysis has been completed. The following subsections describe the control technologies and the control effectiveness evaluated in this BART analysis.

New LNBs with OFA System. The mechanism used to lower NO_x with LNBs is to stage the combustion process and provide a fuel-rich condition initially; this is so oxygen needed for combustion is not diverted to combine with nitrogen and form NO_x. Fuel-rich conditions favor the conversion of fuel nitrogen to N₂ instead of NO_x. Additional air (or OFA) is then introduced downstream in a lower temperature zone to burn out the char.

Both LNBs and OFA are considered to be a capital cost, combustion technology retrofit. For LNB retrofits to units configured with tangential-firing such as Jim Bridger 1, it is generally necessary to increase the burner spacing; this prevents interaction of the flames from adjacent burners and reduces burner zone heat flux. These modifications usually require boiler waterwall tube replacement.

Information provided to CH2M HILL by PacifiCorp—based on the S&L Study and data from boiler vendors—indicates that new LNB and OFA retrofit at Jim Bridger 1 would result in an expected NO_x emission rate of 0.24 lb per MMBtu. PacifiCorp has indicated that this rate corresponds to a vendor guarantee, not a vendor prediction, and they believe that this emission rate can be sustained as an average between overhauls. This emission rate represents a significant reduction from the current NO_x emission rate, and is below the more applicable presumptive NO_x emission rate of 0.28 lb per MMBtu.

ROFA. Mobotec markets ROFA as an improved second generation OFA system. Mobotec states that “the flue gas volume of the furnace is set in rotation by asymmetrically placed air nozzles. Rotation is reported to prevent laminar flow, so that the entire volume of the furnace can be used

more effectively for the combustion process. In addition, the swirling action reduces the maximum temperature of the flames and increases heat absorption. The combustion air is also mixed more effectively." A typical ROFA installation will have a booster fan(s) to supply the high velocity air to the ROFA boxes, and Mobotec would propose two 4,000 to 4,300 Hp fans for Jim Bridger 1.

Mobotec expects to achieve a NO_x emission rate of 0.18 lb per MMBtu using ROFA technology. An operating margin of 0.04 lb per MMBtu was added to the expected rate due to Mobotec's limited ROFA experience with western sub-bituminous coals. Under the Mobotec proposal, primarily based on ROFA equipment, the operation of existing LNB and OFA ports will be analyzed. While a typical installation does not require modification to the existing LNB system, and the existing OFA ports are not used, results of computational fluid dynamics modeling will determine the quantity and location of new ROFA ports. The Mobotec proposal includes bent tube assemblies for OFA port installation. Mobotec does not provide installation services, because they believe that the Owner can more cost effectively contract for these services. However, they do provide one onsite construction supervisor during installation and startup.

SNCR. Selective non-catalytic reduction is generally utilized to achieve modest NO_x reductions on smaller units. With SNCR, an amine-based reagent such as ammonia—or more commonly urea—is injected into the furnace within a temperature range of 1,600°F to 2,100°F, where it reduces NO_x to nitrogen and water. Nitrogen oxide reductions of up to 60 percent have been achieved, although 20 to 40 percent is more realistic for most applications.

Reagent utilization, which is a measure of the efficiency with which the reagent reduces NO_x, can range from 20 to 60 percent, depending on the amount of reduction, unit size, operating conditions, and allowable ammonia slip. With low reagent utilization, low temperatures, or inadequate mixing, ammonia slip occurs, allowing unreacted ammonia to create problems downstream. The ammonia may render fly ash unsaleable, react with sulfur to foul heat exchange surfaces, and/or create a visible stack plume. Reagent utilization can have a significant impact on economics, with higher levels of NO_x reduction generally resulting in lower reagent utilization and higher operating cost.

Reductions from higher baseline concentrations (inlet NO_x) are lower in cost per ton, but result in higher operating costs, due to greater reagent consumption. To reduce reagent costs, S&L has assumed that combustion modifications including LNBs and advanced OFA are capable of achieving a projected NO_x emission rate of 0.24 lb per MMBtu. A further reduction of 15 percent in NO_x emission rates for SNCR would result in a projected emission rate of 0.20 lb per MMBtu.

SCR. SCR works on the same chemical principle as SNCR but SCR uses a catalyst to promote the chemical reaction. Ammonia is injected into the flue-gas stream, where it reduces NO_x to nitrogen and water. Unlike the high temperatures required for SNCR, in SCR the reaction takes place on the surface of a vanadium/titanium-based catalyst at a temperature range between 580° F to 750° F. Due to the catalyst, the SCR process is more efficient than SNCR and results in lower NO_x emissions. The most common type of SCR is the high-dust configuration, where the catalyst is located downstream from the boiler economizer and upstream of the air heater and any particulate control equipment. In this location, the SCR is exposed to the full concentration of fly ash in the flue gas that is leaving the boiler. The high-dust configuration is assumed for Jim Bridger 1. In a full-scale SCR, the flue ducts are routed to a separate large reactor containing

the catalyst. With in-duct SCR, the catalyst is located in the existing gas duct, which may be expanded in the area of the catalyst to reduce flue gas flow velocity and increase flue gas residence time. Due to the higher removal rate, a full-scale SCR was used as the basis for analysis at Jim Bridger 1.

Sargent and Lundy prepared the design conditions and cost estimates for SCR at Jim Bridger 1. As with SNCR, it is generally more cost effective to reduce NO_x emission levels as much as possible through combustion modifications, in order to minimize the catalyst surface area and ammonia requirements of the SCR. The S&L design basis for LNB with OFA and SCR results in a projected NO_x emission rate of 0.07 lb per MMBtu. Additional catalyst surface was included in the SCR design to accommodate the characteristics of the coal used at Jim Bridger 1.

Level of Confidence for Vendor Post-control Emissions Estimates. In order to determine the level of NO_x emissions needed to consistently achieve compliance with an established goal, a review of typical NO_x emissions from coal-fired generating units was completed. As a result of this review, it was noted that NO_x emissions can vary significantly around an average emissions level. This variance can be attributed to many reasons, including coal characteristics, unit load, boiler operation including excess air, boiler slagging, burner equipment condition, coal mill fineness, and so forth.

The steps utilized for determining a level of confidence for the vendor expected value are as follows:

- Establish expected NO_x emissions value from vendor.
- Evaluate vendor experience and historical basis for meeting expected values.
- Review and evaluate unit physical and operational characteristics and restrictions. The fewer variations there are in operations, coal supply, etc., the more predictable and less variant the NO_x emissions are.
- For each technology expected value, there is a corresponding potential for actual NO_x emissions to vary from this expected value. From the vendor information presented, along with anticipated unit operational data, an adjustment to the expected value can be made.

Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

Energy Impacts. Installation of LNBs and modification to the existing OFA systems are not expected to significantly impact the boiler efficiency or forced draft fan power usage. Therefore, these technologies will not have energy impacts.

The Mobotec ROFA system requires installation and operation of two 4,000 to 4,300 horsepower ROFA fans (6,410 kilowatts [kW] total). The SNCR system would require approximately 530 kW of additional power.

Selective catalytic reduction retrofit impacts the existing flue gas fan systems, due to the additional pressure drop associated with the catalyst, which is typically a 6- to 8-inch water gage

increase. Total additional power requirements for SCR installation at Jim Bridger 1 are estimated at approximately 3,280 kW, based on the S&L Study.

Environmental Impacts. Mobotec has predicted that carbon monoxide (CO) emissions, and unburned carbon in the ash, commonly referred to as LOI (loss on ignition), would be the same or lower than prior levels for the ROFA system.

The installation of SNCR and SCR could impact the saleability and disposal of fly ash due to ammonia levels, and could potentially create a visible stack plume, which may negate other visibility improvements. Other environmental impacts involve the storage of ammonia, especially if anhydrous ammonia is used, and the transportation of the ammonia to the power plant site.


Economic Impacts. Costs and schedules for the LNBs and OFA, SNCR, and SCR were furnished to CH2M HILL by PacifiCorp, developed using S&L's internal proprietary database, and supplemented (as needed) by vendor-obtained price quotes. The relative accuracy of these cost estimates is stated by S&L to be in the range of plus or minus 20 percent. Cost for the ROFA system was obtained from Mobotec.

A comparison of the technologies on the basis of costs, design control efficiencies, and tons of NO_x removed is summarized in Table 3-3, and the first year control costs are shown in Figure 3-4. The complete economic analysis is contained in Appendix A.

TABLE 3-3
NO_x Control Cost Comparison
Jim Bridger 1

Factor	Low-NO _x Burners (LNBs) with Over-fire Air (OFA)	Rotating Opposed Fire Air (ROFA)	LNB with OFA and Selective Non-catalytic Reduction (SNCR)	LNB with OFA and Selective Catalytic Reduction (SCR)
Total Installed Capital Costs	\$8.7 million	\$20.5 million	22.1 million	\$129.6 million
Total First Year Fixed and Variable Operation and Maintenance Costs	\$0.1 million	\$2.6 million	\$1.5 million	\$3.3 million
Total First Year Annualized Cost	\$0.9 million	\$4.6 million	\$3.6 million	\$15.6 million
Power Consumption (megawatts)	0	6.4	0.5	3.3
Annual Power Usage (1,000 megawatt-hours per year)	0	50.6	4.2	25.8
Nitrogen Oxide (NO _x) Design Control Efficiency	46.7%	51.1%	55.6%	84.4%
NO _x Removed per Year (Tons)	4,967	5,440	5,913	8,987
First Year Average Control Cost (dollars per ton [\$ /Ton] of NO _x Removed)	\$181/ton	\$843/ton	\$613/ton	\$1,736/ton
Incremental Control Cost (\$ /Ton of NO _x Removed)	\$181/ton	\$7,797/ton	\$2,885/ton	\$3,894/ton

FIGURE 3-4
 First Year Control Cost for NO_x Air Pollution Control Options
Jim Bridger 1



Preliminary BART Selection. PacifiCorp selects LNBs with OFA as BART for Jim Bridger 1 based on its significant reduction in NO_x emissions, reasonable control cost, and no additional power requirements or environmental impacts. This scenario does not meet the EPA presumptive limit of 0.15 lb per MMBtu for sub-bituminous coal, but it does meet an emission rate that falls between the bituminous coal presumptive limit of 0.28 lb per MMBtu and the 0.15 lb per MMBtu limit for sub-bituminous coal, which, as discussed in the section on coal quality, is appropriate for this unit.

Step 5: Evaluate Visibility Impacts

Please see Section 4, BART Modeling Analysis.

3.2.2 BART SO₂ Analysis

Sulfur dioxide forms in the boiler during the combustion process, and is primarily dependent on coal sulfur content. The BART analysis for SO₂ emissions on Jim Bridger 1 is described below.

Step 1: Identify All Available Retrofit Control Technologies

A broad range of information sources were reviewed, in an effort to identify potentially applicable emission control technologies for SO₂ at Jim Bridger 1; this included control technologies identified as BACT or LAER by permitting agencies across the United States.

The following potential SO₂ control technology options were considered:

- Optimize current operation of existing wet sodium FGD system
- Upgrade wet sodium FGD system to meet SO₂ emission rate of 0.10 lb per MMBtu
- New dry FGD system

Step 2: Eliminate Technically Infeasible Options

Technical feasibility will primarily be based on the regulatory presumptive limit (used as a guideline) of 95 percent reduction in SO₂ emissions, or 0.15 lb per MMBtu. Based on the coal that Jim Bridger 1 currently burns, the unit would be required to achieve an 87.5 percent SO₂ removal efficiency to meet the presumptive limit of 0.15 lb per MMBtu.

Table 3-4 summarizes the control technology options evaluated in this BART analysis, along with projected SO₂ emission rates. Only one technology option can meet the applicable presumptive BART limit of 0.15 lb per MMBtu.

TABLE 3-4
SO₂ Control Technology Emission Rates
Jim Bridger 1

Technology	Projected Emission Rate (pounds per million British thermal units)
Presumptive Best Available Retrofit Technology (BART) Limit	0.15
Upgrade Existing Wet Sodium System	0.10
Optimize Existing Wet Sodium System	0.20
New Dry Flue Gas Desulfurization System	0.21

Wet Sodium FGD System. Wet sodium FGD systems operate by treating the flue gas in large scrubber vessels with a soda ash solution. The scrubber mixes the flue gas and alkaline reagent using a series of spray nozzles to distribute the reagent across the scrubber vessel. The sodium in the reagent reacts with the SO₂ in the flue gas to form sodium sulfite and sodium bisulfite, which are removed from the scrubber and disposed.

The wet sodium FGD system at Jim Bridger 1 currently achieves approximately 78 percent SO₂ removal to achieve an SO₂ outlet emission rate of 0.27 lb per MMBtu. Optimizing the existing wet FGD system is projected to achieve an SO₂ outlet emission rate of 0.20 lb per MMBtu (83.3 percent SO₂ removal). Optimization would be accomplished by partially closing the bypass damper to reduce the routine bypass flue gas flow used to reheat the treated flue gas from the scrubber, relocating the opacity monitor, and modifying the system to minimize scaling problems.

Upgrading the wet FGD system would achieve an SO₂ outlet emission rate of 0.10 lb per MMBtu (91.7 percent SO₂ removal). Upgrading the system would involve closing the bypass damper to eliminate the routine bypass flue gas flow used to reheat the treated flue gas from the scrubber, relocating the opacity monitor, adding new fans, adding a stack liner and drains for wet operation, and using a refined soda ash reagent. It is considered to be technically infeasible for the present wet FGD system to achieve a 95 percent SO₂ removal (0.06 lb per MMBtu) on a continuous basis since this high level of removal must be incorporated into the original design of the scrubber.

Optimizing the existing wet sodium scrubbing FGD system is projected to achieve an outlet emission rate of 0.20 lb per MMBtu, which would not meet the presumptive limit of 0.15 lb per MMBtu of SO₂. Therefore, this option is eliminated as technically infeasible for this analysis. An upgraded wet sodium scrubbing FGD system is projected to achieve an outlet emission rate of 0.10 lb per MMBtu (91.7 percent SO₂ removal), which would meet the presumptive limit of 0.15 lb per MMBtu of SO₂ for Jim Bridger 1.

New Dry FGD System. The lime spray dryer typically injects lime slurry in the top of the absorber vessel with a rapidly rotating atomizer wheel. The rapid speed of the atomizer wheel causes the lime slurry to separate into very fine droplets that intermix with the flue gas. The SO₂ in the flue gas reacts with the calcium in the lime slurry to form dry calcium sulfate particles. At Jim Bridger 1 this dry particulate matter would be captured downstream in the

existing ESP, along with the fly ash. A lime spray dryer system typically produces a dry waste product suitable for landfill disposal.

The dry FGD system with the existing ESP is projected to achieve 82.5 percent SO₂ removal at Jim Bridger 1. This would result in a controlled SO₂ emission rate of 0.21 lb per MMBtu, based on an uncontrolled SO₂ emission rate of 1.20 lb per MMBtu. Therefore, this option cannot meet the presumptive limit of 0.15 lb per MMBtu of SO₂, and is eliminated from further analysis.

Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

When evaluating the control effectiveness of SO₂ reduction technologies, each option can be compared against benchmarks of performance. One such benchmark is the presumptive BART emission limit because Jim Bridger 1 is required to meet this limit. As indicated previously, the presumptive limit for SO₂ on a BART-eligible coal burning unit is 95 percent removal, or 0.15 lb per MMBtu.

The projected emission rate for an upgraded wet sodium FGD system for Jim Bridger 1 would be 0.10 lb per MMBtu. This option would meet the presumptive SO₂ limit of 0.15 lb per MMBtu.

Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

Energy Impacts. Upgrading the existing wet sodium FGD system would require an additional 530 kW of power.

Environmental Impacts. There will be incremental additions to scrubber waste disposal and makeup water requirements, and a reduction of the stack gas temperature from 140°F to 120°F due to elimination of reheating by the bypassed flue gas.

Economic Impacts. A summary of the costs and amount of SO₂ removed for the upgraded wet sodium FGD system is provided in Table 3-5. The complete economic analysis is contained in Appendix A.

Preliminary BART Selection. CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 1, based on significant reduction in SO₂ emissions (meeting presumptive limit of 0.15 lb per MMBtu), reasonable control costs, and the advantages of minimal additional power requirements and environmental impacts.

Step 5: Evaluate Visibility Impacts

Please see Section 4, BART Modeling Analysis.

TABLE 3-5
SO₂ Control Cost Comparison (Incremental to Existing FGD System)
Jim Bridger 1

Factor	Upgraded Wet FGD
Total Installed Capital Costs	\$13.0 million
Total First Year Fixed and Variable Operation and Maintenance Costs	\$1.3 million
Total First Year Annualized Cost	\$2.5 million
Additional Power Consumption (megawatts)	0.5
Additional Annual Power Usage (1,000 megawatt-hours per year)	4.2
Incremental Sulfur Dioxide (SO ₂) Design Control Efficiency	62.5% (91.7% based on Uncontrolled SO ₂)
Incremental Tons SO ₂ Removed per Year	3,950
First Year Average Control Cost (dollars per ton [\$/Ton] of SO ₂ Removed)	632
Incremental Control Cost (\$/Ton of SO ₂ Removed)	632

3.2.3 BART PM₁₀ Analysis

Jim Bridger 1 is currently equipped with an ESP. Electrostatic precipitators remove particulate matter (PM) from the flue gas stream by charging fly ash particles with a very high direct current voltage, and attracting these charged particles to grounded collection plates. A layer of collected PM forms on the collecting plates and is removed by periodically rapping the plates. The collected ash particles drop into hoppers below the precipitator and are removed periodically by the fly ash-handling system. Historically, the ESP at Jim Bridger 1 has controlled PM₁₀ emissions to levels below 0.045 lb per MMBtu.

The BART analysis for PM₁₀ emissions at Jim Bridger 1 is described below. For the modeling analysis in Section 4, PM₁₀ was used as an indicator for PM, and PM₁₀ includes particulate matter less than 2.5 micrometers in aerodynamic diameter (PM_{2.5}) as a subset.

Step 1: Identify All Available Retrofit Control Technologies

Two retrofit control technologies have been identified for additional PM control:

- Flue gas conditioning
- Polishing fabric filter (baghouse) downstream of existing ESP

Another available control technology is replacing the existing ESP with a new fabric filter. However, because the environmental benefits that would be achieved by a replacement fabric filter are also achieved by installing a polishing fabric filter downstream of the existing ESP at lower costs, installation of a full-size fabric filter was not considered in the analysis.

Step 2: Eliminate Technically Infeasible Options

Flue Gas Conditioning. If the fly ash from coal has high resistivity, such as fly ash from sub-bituminous coal, the ash is not collected effectively in an ESP. This is because the high resistivity makes the particles less willing to accept an electrical charge. Adding flue gas conditioning (FGC), which is typically accomplished by injection of sulfur trioxide (SO₃), will lower the resistivity of the particles so that they will accept more charge and allow the ESP to collect the ash more effectively. Flue gas conditioning systems can account for large improvements in collection efficiency for small ESPs. Therefore, the technology is retained as technically feasible.

Polishing Fabric Filter. A polishing fabric filter could be added downstream of the existing ESP at Jim Bridger 1. One such technology is licensed by the Electric Power Research Institute, and referred to as a COHPAC (Compact Hybrid Particulate Collector). The COHPAC collects the ash that is not collected by the ESP, thus acting as a polishing device. The ESP needs to be kept in service for the COHPAC fabric filter to operate effectively.

The COHPAC fabric filter is about one-half to two-thirds the size of a full-size fabric filter, because the COHPAC has a higher air-to-cloth ratio (7 to 9:1), compared to a full-size pulse jet fabric filter (3.5 to 4:1). This technology is retained as technically feasible.

Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

The existing ESP at Jim Bridger 1 is achieving a controlled PM emission rate of 0.045 lb per MMBtu. Utilizing flue conditioning upstream of the existing ESP is projected to reduce PM emissions to approximately 0.030 lb per MMBtu. Adding a COHPAC fabric filter downstream of the existing ESP is projected to reduce PM emissions to approximately 0.015 lb per MMBtu.

The PM₁₀ control technology emission rates are summarized in Table 3-6.

TABLE 3-6
PM₁₀ Control Technology Emission Rates
Jim Bridger 1

Control Technology	Short-Term Expected PM ₁₀ ^(a) Emission Rate (pounds per million British thermal units)
Flue Gas Conditioning	0.030
Polishing Fabric Filter	0.015

NOTES:

^(a)PM₁₀ refers to particulate matter less than 10 micrometers in aerodynamic diameter

Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

Energy Impacts. Energy is required to overcome the additional pressure drop from the COHPAC fabric filter and associated ductwork. Therefore, a COHPAC retrofit will require an internal diameter fan upgrade and upgrade of the auxiliary power supply system.

A COHPAC fabric filter at Jim Bridger 1 would require approximately 3.4 MW of power, equating to an annual power usage of approximately 26.7 million kW hours.

There is only a small power requirement of approximately 50 kW associated with flue gas conditioning.

Environmental Impacts. There are no negative environmental impacts from the addition of either a COHPAC polishing fabric filter or FGC system.

Economic Impacts. A summary of the costs and PM removed for COHPAC and FGC is recorded in Table 3-7, and the first-year control costs for FGC and fabric filters are shown in Figure 3-5. The complete economic analysis is contained in Appendix A.

TABLE 3-7
PM₁₀ Control Cost Comparison (Incremental to Existing ESP)
Jim Bridger 1


Factor	Flue Gas Conditioning	Polishing Fabric Filter
Total Installed Capital Costs	\$0	\$48.4 million
Total First Year Fixed and Variable Operation and Maintenance Costs	\$0.2 million	\$1.8 million
Total First Year Annualized Cost	\$0.2 million	\$6.4 million
Additional Power Consumption (megawatts)	0.05	3.4
Additional Annual Power Usage (1,000 megawatt-hours per year)	0.4	26.7
Incremental Particulate Matter (PM) Design Control Efficiency	33.3%	66.7%
Incremental Tons PM Removed per Year	355	710
First Year Average Control Cost (dollars per ton [\$ /Ton] of PM Removed)	495	8,973
Incremental Control Cost (\$ /Ton of PM Removed)	495	17,452

Preliminary BART Selection. PacifiCorp selects FGC as BART for Jim Bridger 1 based on its significant reduction in PM emissions, reasonable control cost, minimum additional power requirements, and no environmental impacts.

Step 5: Evaluate Visibility Impacts

Please see Section 4, BART Modeling Analysis.

FIGURE 3-5
First Year Control Cost for PM Air Pollution Control Options
Jim Bridger 1



4.0 BART Modeling Analysis

4.1 Model Selection

CH2M HILL used the CALPUFF modeling system to assess the visibility impacts of emissions from Jim Bridger 1 at nearby Class I areas. The Class I areas potentially affected are located more than 50 kilometers, but less than 300 kilometers, from the Jim Bridger 1 facility. The Class I areas include the following wilderness areas (WA):

- Bridger WA
- Fitzpatrick WA
- Mt. Zirkel WA

The CALPUFF modeling system includes the CALMET meteorological model, a Gaussian puff dispersion model (CALPUFF) with algorithms for chemical transformation and deposition, and a post processor capable of calculating concentrations, visibility impacts, and deposition (CALPOST). The CALPUFF modeling system was applied in a full, refined mode. Version numbers of the various programs in the CALPUFF system used by CH2M HILL were as follows:

- CALMET Version 5.53a, Level 040716
- CALPUFF Version 5.711a, Level 040716
- CALPOST Version 5.51, Level 030709

4.2 CALMET Methodology

4.2.1 Dimensions of the Modeling Domain

CH2M HILL used the CALMET model to generate a three-dimensional wind field and other meteorological parameters suitable for use by the CALPUFF model. A modeling domain was established to encompass the Jim Bridger 1 facility and allow for a 50-kilometer buffer around the Class I areas that were within 300 kilometers of the facility. Grid resolution was 4 kilometer. Figure 4-1 shows the extent of the modeling domain. Except when specifically instructed otherwise by the Wyoming Department of Environmental Quality-Air Quality Division (WDEQ-AQD), CH2M HILL followed the methodology spelled out in the WDEQ-AQD BART Modeling Protocol, a copy of which is included in this report as Appendix B.

CH2M HILL used the Lambert Conformal Conic map projection for the analysis due to the large extent of the domain. The latitude of the projection origin and the longitude of the central meridian were chosen at the approximate center of the domain. Standard parallels were drawn to represent one-sixth and five-sixths of the north-south extent of the domain to minimize distortion in the north-south direction.




Figure 4-1
Jim Bridger Source-Specific
Class I Areas to be Addressed



CH2MHILL

S:\C\B\GIS\PROJECTS\HUNTER\MAPFILES\JIM_BRIDGER_CLASS1.MXD 11/9/2006 MSLAYDEN

The default technical options listed in TRC Companies, Inc.'s (TRC) current example CALMET.inp file were used for CALMET. Vertical resolution of the wind field included ten layers, with vertical face heights as follows (in meters):

- 0, 20, 40, 100, 140, 320, 580, 1020, 1480, 2220, 3500

Other user-specified model options were set to values established by WDEQ-AQD, which appear in Table 3 of Appendix B. Table 4-1 lists the key user-specified options used for this analysis.

TABLE 4-1
User-specified CALMET Options
Jim Bridger 1

CALMET Input Parameter	Value
CALMET Input Group 2	
Map projection (PMAP)	Lambert Conformal
Grid spacing (DGRIDKM)	4
Number vertical layers (NZ)	10
Top of lowest layer (m)	20
Top of highest layer (m)	3500
CALMET Input Group 4	
Observation mode (NOOBS)	0
CALMET Input Group 5	
Prog. Wind data (IPROG)	14
(RMAX1)	30
(RMAX2)	50
Terrain influence (TERRAD)	15
(R1)	5
(R2)	25
CALMET Input Group 6	
Max mixing ht (ZIMAX)	3500

4.2.2 CALMET Input Data

CH2M HILL ran the CALMET model to produce 3 years of analysis: 2001, 2002, and 2003. WDEQ-AQD provided 12-kilometer resolution Mesoscale Meteorological Model, Version 5 (MM5) meteorological data fields that covered the entire modeling domain for each study year.

These three data sets were chosen because they are current and have been evaluated for quality. The MM5 data were used as input to CALMET as the "initial guess" wind field. The initial guess wind field was adjusted by CALMET for local terrain and land use effects to generate a

Step 1 wind field, and further refined using local surface observations to create a final Step 2 wind field.

Surface data for 2001 through 2003 were obtained from the National Climatic Data Center. CH2M HILL processed the data from the National Weather Service's Automated Surface Observing System network for all stations that are in the domain. The surface data were obtained in abbreviated DATSAV3 format. A conversion routine available from the TRC Web site was used to convert the DATSAV3 files to CD-144 format for input into the SMERGE preprocessor and CALMET.

Land use and terrain data were obtained from the U.S. Geological Survey (USGS). Land use data were obtained in Composite Theme Grid format from the USGS, and the Level I USGS land use categories were mapped into the 14 primary CALMET land use categories. Surface properties such as albedo, Bowen ratio, roughness length, and leaf area index were computed from the land use values. Terrain data were taken from USGS 1-degree Digital Elevation Model data, which primarily derive from USGS 1:250,000 scale topographic maps. Missing land use data were filled with values that were assumed appropriate for the missing area.

Precipitation data were obtained from the National Climatic Data Center. All available data in fixed-length, TD-3240 format were obtained for the modeling domain. The list of available stations that have collected complete data varies by year, but CH2M HILL processed all available stations/data within the domain for each year. Precipitation data were prepared with the PEXTRACT/PMERGE processors in preparation for use within CALMET.

Upper-air data were prepared for the CALMET model with the READ62 preprocessor for the following stations:

- Denver, Colorado
- Salt Lake City, Utah
- Riverton, Wyoming
- Rapid City, South Dakota

Figure 4-2 shows the locations of surface and upper air stations within the MM5 modeling domain.

4.2.3 Validation of CALMET Wind Field

CH2M HILL used the CALDESK data display and analysis system (v2.97, Enviromodeling Ltd.) to view plots of wind vectors and other meteorological parameters to evaluate the CALMET wind fields. The CALDESK displays were compared to observed weather conditions, as depicted in surface and upper-air weather maps (National Oceanic and Atmospheric Administration, 2006).





Figure 4-2
Surface and Upper Air Stations Used in the
Jim Bridger BART Analysis



CH2MHILL

SLC \SLCDB\GIS\PROJECTS\HUNTERMAPFILES\JIM_BRIDGER_ASOS.MXD 11/9/2006 MSLAYDEN

4.3 CALPUFF Modeling Approach

For the BART control technology visibility improvement modeling, CH2M HILL followed WDEQ-AQD guidance provided (WDEQ-AQD, 2006).

CH2M HILL drove the CALPUFF model with the meteorological output from CALMET over the modeling domain described earlier. The CALPUFF model was used to predict visibility impacts for the pre-control (baseline) scenario for comparison to the predicted impacts for post-control scenarios for Jim Bridger 1.

4.3.1 Background Ozone and Ammonia

Hourly values of background ozone concentrations were used by CALPUFF for the calculation of SO₂ and NO_x transformation with the MESOPUFF II chemical transformation scheme. CH2M HILL obtained hourly ozone data from the following stations located within the modeling domain for 2001, 2002, and 2003:

- Rocky Mountain National Park, Colorado
- Craters of the Moon National Park, Idaho
- Highland, Utah
- Thunder Basin National Grasslands, Wyoming
- Yellowstone National Park, Wyoming
- Centennial, Wyoming
- Pinedale, Wyoming

For periods of missing hourly ozone data, the chemical transformation relied on a monthly default value of 44 parts per billion. Background ammonia was set to 2 parts per billion. Both of these background values were taken from the guidance document (WDEQ-AQD, 2006).

4.3.2 Stack Parameters

The stack parameters used for the baseline modeling reflect those that are in place under the current permit for Jim Bridger 1. Post-control stack parameters reflect the anticipated changes associated with installation of the control technology alternatives that are being evaluated. The maximum heat input rate of 6,000 MMBtu per hour was used to calculate a maximum emission rate. Measured velocities and stack flow rates were used in the modeling to represent a worst-case situation.

4.3.3 Emission Rates

Pre-control emission rates for Jim Bridger 1 reflect peak 24-hour average emissions that may occur under the source's current permit. The emission rates reflect actual emissions under normal operating conditions, as described by the EPA in the *Regional Haze Regulations and Guidelines for Best Available Retrofit Technology Determinations; Final Rule* (40 CFR Part 51).

CH2M HILL used available continuous emission monitoring data to determine peak 24-hour emission rates. Data reflected operations from the most recent 3- to 5-year period, unless a more recent period was more representative. Allowable short-term (24-hour or shorter period)

emissions or short-term emission limits were used if continuous emission monitoring data were not available.

Emissions were modeled for the following pollutants:

- SO₂
- NO_x
- Coarse particulate (PM_{2.5}<diameter<PM₁₀)
- Fine particulate (diameter<PM_{2.5})
- Sulfates

Post-control emission rates reflect the effects of the emissions control scenario under consideration. Modeled pollutants were the same as those listed for the pre-control scenario.

4.3.4 Post-control Scenarios

Four post-control modeling scenarios were developed to cover the range of effectiveness for the combination of the individual NO_x, SO₂, and PM control technologies being evaluated. The selection of each control device was made based on the engineering analyses described in Section 3 for reasonable technologies that would meet or exceed the presumptive BART levels for each pollutant.

- **Scenario 1:** New LNB with OFA modifications, upgraded wet FGD system, and flue gas conditioning for enhanced ESP performance. As indicated previously, this scenario represents CH2M HILL's preliminary BART recommendation.
- **Scenario 2:** New LNB with OFA modifications, upgraded wet FGD system, and new polishing fabric filter
- **Scenario 3:** New LNB with OFA modifications and SCR, upgraded wet FGD system, and flue gas conditioning for enhanced ESP performance.
- **Scenario 4:** New LNB with OFA modifications and SCR, upgraded wet FGD system, and new polishing fabric filter.

The ROFA option and LNB with OFA and SCR option for NO_x control were not included in the modeling scenarios because their control effectiveness is between the LNB with OFA option and the SCR option. Modeling of NO_x, SO₂, and PM controls alone was not performed because any final BART solution will include a combination of control technologies for NO_x, SO₂, and PM.

Table 4-2 presents the stack parameters and emission rates used for the Jim Bridger 1 analysis for baseline and post-control modeling. In accordance with the WDEQ BART modeling protocol, elemental carbon stack emissions and organic aerosol emissions were not modeled.

4.3.5 Modeling Process

The CALPUFF modeling for the control technology options for Jim Bridger 1 followed this sequence:

- Model pre-control (baseline) emissions
- Model preferred post-control scenario (if applicable)
- Determine degree of visibility improvement
- Model other control scenarios
- Determine degree of visibility improvement
- Factor visibility results into the BART five-step evaluation

4.3.6 Receptor Grids

Discrete receptors for the CALPUFF modeling were placed at uniform receptor spacing along the boundary and in the interior of each area of concern. Class I area receptors were taken from the National Park Service database for Class I area modeling receptors. The TRC COORDS program was used to convert all latitude/longitude coordinates to Lambert Conformal Conic coordinates, including receptors, meteorological stations, and source locations.

4.4 CALPOST

The CALPOST processor was used to determine 24-hour average visibility results with output specified in deciview (dV) units. Calculations of light extinction were made for each pollutant modeled. The sum of all extinction values were used to calculate the delta-dV (Δ dV) change relative to natural background. The following default light extinction coefficients for each pollutant, as shown below, were used:

- Ammonium sulfate 3.0
- Ammonium nitrate 3.0
- PM coarse (PM₁₀) 0.6
- PM fine (PM_{2.5}) 1.0
- Organic carbon 4.0
- Elemental carbon 10.0

CALPOST visibility Method 6 was used to determine the visibility impacts. Monthly relative humidity factors [f (RH)] were used in the light extinction calculations to account for the hygroscopic characteristics of nitrate and sulfate particles. Table 5 of the Wyoming BART Air Modeling Protocol (Appendix B) lists the monthly f (RH) factors for the Class I areas. These values were used for the particular Class I area being modeled.

The natural background conditions as a reference for determining the Δ dV change represented the 20 percent best natural visibility days. The EPA BART guidance document provided dV values for the 10 percent best days for each Class I area, but did not provide individual species concentration data for the 20 percent best background conditions. Species concentrations corresponding to the 20 percent best days were calculated for each Class I area by scaling back the annual average species concentrations given in Table 2-1 of *Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule* (EPA, 2003). A

separate scaling factor was derived for each Class I area such that, when multiplied by the Guidance table annual concentrations, the 20 percent best days dV value for that area would be calculated. This procedure was taken from *Protocol for BART-Related Visibility Improvement Modeling Analysis in North Dakota* (North Dakota Department of Health, 2005). However, the Wyoming BART Air Modeling Protocol (see Appendix B) provided natural background concentrations of aerosol components to use in the BART analysis. Table 4-3 lists the annual average species concentrations from the BART protocol.

TABLE 4-3
Average Natural Levels of Aerosol Components
Jim Bridger 1

Aerosol Component	Average Natural Concentration (micrograms per cubic meter) for Mt. Zirkel Class I Wilderness Area	Average Natural Concentration (micrograms per cubic meter) for Fitzpatrick and Bridger Class I Wilderness Areas
Ammonium Sulfate	0.046	0.045
Ammonium Nitrate	0.038	0.038
Organic Carbon	0.179	0.178
Elemental Carbon	0.008	0.008
Soil	0.190	0.189
Coarse Mass	1.141	1.136

NOTES:

Data in this table was taken from Table 6 of the Wyoming BART Air Modeling Protocol

4.5 Presentation of Modeling Results

This section presents the results of the CALPUFF visibility improvement modeling analysis for Jim Bridger 1.

4.5.1 Visibility Changes for Baseline vs. Preferred Scenario

CH2M HILL modeled Jim Bridger 1 for the baseline and the post-control scenarios. The post-control scenario included emission rates for SO₂, NO_x, and PM₁₀ that would be achieved if BART state-of-the-art technology were installed on Unit 1.

Baseline (and post-control) 98th percentile results were greater than 0.5 ΔdV for the Bridger, WA, Fitzpatrick, WA, and Mt. Zirkel, WA. The 98th percentile results for each Class I area are presented in Table 4-4.

TABLE 4.4
Costs and Visibility Modeling Results for Baseline vs. Post-control Scenarios at Class I Areas
Jim Bridger 1

Scenario	Total First Year Annualized Cost	Class I Area	Highest Delta Declivity (AdV)	95th Percentile (AdV)	Number (No.) of Days Above 0.5 dV	Cost per Reduction in No. of Days Above 0.5 dV	Incremental Cost per dV Reduction	Incremental Cost per Reduction in No. of Days Above 0.5 dV
2001								
Baseline: Current Operation with Wet Flue Gas Desulfurization (FGD), Electrostatic Precipitator (ESP)		Bridger WA Fitzpatrick WA Mt. Zirkel WA	2.504 2.177 1.956	0.746 0.418 1.236	14 7 27	- - -	- - -	- - -
Scenario 1: Low-NO _x Burners (LNBs) with Over-fire Air (OFA), upgrade wet FGD, Flue Gas Conditioning (FGC) for enhanced ESP performance	\$3,392,440 \$3,392,440 \$3,392,440	Bridger WA Fitzpatrick WA Mt. Zirkel WA	1.364 1.369 1.167	0.384 0.221 0.736	7 3 16	\$9,371,381 \$17,220,508 \$6,784,880	\$484,634 \$848,110 \$305,404	\$5,366,619 n/a n/a
Scenario 2: LNB with OFA, upgrade wet FGD, polishing fabric filter	\$9,759,059 \$9,759,059	Bridger WA Fitzpatrick WA Mt. Zirkel WA	1.383 1.171 1.099	0.372 0.211 0.676	6 3 15	\$26,083,741 \$47,145,212 \$17,425,891	\$1,219,882 \$2,439,785 \$913,255	\$530,551,575 \$936,661,890 \$106,110,315
Scenario 3: LNB with OFA and Selective Catalytic Reduction (SCR), upgrade wet FGD, FGC for enhanced ESP performance	\$18,093,916 \$18,093,916 \$18,093,916	Bridger WA Fitzpatrick WA Mt. Zirkel WA	0.876 0.675 0.758	0.279 0.127 0.453	3 1 5	\$38,745,002 \$92,178,405 \$23,108,449	\$1,644,901 \$3,015,693 \$522,451	\$89,622,116 \$99,224,485 \$37,376,039
Scenario 4: LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	\$24,460,535 \$24,460,535 \$24,460,535	Bridger WA Fitzpatrick WA Mt. Zirkel WA	0.838 0.654 0.729	0.268 0.125 0.438	3 1 2	\$51,172,667 n/a \$30,575,668	\$2,223,685 n/a \$978,421	\$578,783,537 n/a \$374,506,994
2002								
Baseline: Current Operation with Wet FGD, ESP		Bridger WA Fitzpatrick WA Mt. Zirkel WA	4.104 1.694 2.801	1.448 0.704 1.496	26 11 34	- - -	- - -	- - -
Scenario 1: LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	\$3,392,440 \$3,392,440	Bridger WA Fitzpatrick WA Mt. Zirkel WA	2.454 1.078 1.544	0.845 0.378 0.816	14 5 13	\$5,625,837 \$10,406,258 \$4,988,882	\$282,703 \$585,407 \$161,545	\$5,366,619 n/a n/a
Scenario 2: LNB with OFA, upgrade wet FGD, polishing fabric filter	\$9,759,059 \$9,759,059	Bridger WA Fitzpatrick WA Mt. Zirkel WA	2.326 1.002 1.496	0.760 0.347 0.777	13 6 13	\$14,603,370 \$27,336,300 \$19,573,100	\$750,697 \$1,551,812 \$464,717	\$97,947,983 \$205,374,803 \$163,246,639
Scenario 3: LNB with OFA and SCR, upgrade wet FGD, FGC for enhanced ESP performance	\$18,093,916 \$18,093,916 \$18,093,916	Bridger WA Fitzpatrick WA Mt. Zirkel WA	1.321 0.649 0.887	0.518 0.226 0.473	9 1 4	\$19,064,348 \$37,853,380 \$17,687,112	\$1,064,348 \$1,809,382 \$603,131	\$51,934,317 \$68,883,114 \$27,417,282
Scenario 4: LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	\$24,460,535 \$24,460,535 \$24,460,535	Bridger WA Fitzpatrick WA Mt. Zirkel WA	1.295 0.659 0.889	0.500 0.223 0.465	8 1 4	\$26,802,252 \$50,853,502 \$23,725,058	\$1,358,919 \$2,446,053 \$815,351	\$335,085,205 \$2,122,206,301 \$795,827,863

TABLE 4.4
Costs and Visibility Modeling Results for Baseline vs. Post-control Scenarios at Class I Areas
Jim Bridger 1

Scenario	Class I Area	Highest Delta Declivity (ΔdV)	9 th Percentile (ΔdV)	Number (No.) of Days Above 0.5 ΔV	Cost per ΔV Reduction	Cost per Reduction in No. of Days Above 0.5 ΔV	Incremental Cost per ΔV Reduction	Incremental Cost per Reduction in No. of Days Above 0.5 ΔV
2003								
Baseline: Current Operation with wet FGD, ESP	Brüger WA Fitzpatrick WA Mt. Zirkel WA	1.708 1.933 1.958	0.761 0.373 1.232	16 7 35	- - -	- - -	- - -	- - -
Scenario 1: LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	Brüger WA Fitzpatrick WA Mt. Zirkel WA	0.987 1.112 1.042	0.411 0.199 0.796	5 2 16	\$9,692,686 \$19,496,782 \$17,854,948	\$309,404 \$878,488 \$178,549	\$2,122,206,301 \$489,739,916 \$127,332,378	n/a n/a \$6,366,619
Scenario 2: LNB with OFA, upgrade wet FGD, polishing fabric filter	Brüger WA Fitzpatrick WA Mt. Zirkel WA	0.985 1.087 1.057	0.408 0.186 0.686	5 2 15	\$8,759,059 \$9,759,059 \$9,759,059	\$887,187 \$1,951,812 \$487,953	\$2,122,206,301 \$489,739,916 \$127,332,378	n/a n/a \$6,366,619
Scenario 3: LNB with OFA and SCR, upgrade wet FGD, FGC for enhanced ESP performance	Brüger WA Fitzpatrick WA Mt. Zirkel WA	0.653 0.691 0.659	0.258 0.118 0.493	3 2 5	\$35,971,999 \$70,956,532 \$22,845,702	\$1,381,840 \$3,615,783 \$603,131	\$55,565,712 \$122,571,423 \$32,844,068	\$4,167,428 n/a \$633,486
Scenario 4: LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	Brüger WA Fitzpatrick WA Mt. Zirkel WA	0.610 0.652 0.636	0.248 0.114 0.422	3 2 5	\$47,681,354 \$94,442,219 \$30,180,181	\$1,881,580 \$4,892,107 \$815,851	\$636,661,890 \$1,591,654,726 \$578,783,537	n/a n/a n/a
3-year Averages								
Baseline: Current Operation with wet FGD, ESP	Brüger WA Fitzpatrick WA Mt. Zirkel WA		0.985 0.488 1.321	18.7 8.3 32.0				
Scenario 1: LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	Brüger WA Fitzpatrick WA Mt. Zirkel WA		0.547 0.266 0.763	8.7 3.3 15.0	\$7,739,407 \$14,601,607 \$6,072,387	\$389,244 \$673,488 \$159,555	\$238,748,209 \$353,701,050 \$128,186,959	\$9,549,928 n/a \$9,549,928
Scenario 2: LNB with OFA, upgrade wet FGD, polishing fabric filter	Brüger WA Fitzpatrick WA Mt. Zirkel WA		0.520 0.248 0.713	8.0 3.7 14.3	\$20,387,224 \$38,984,257 \$16,042,289	\$914,912 \$2,091,227 \$552,400	\$238,748,209 \$353,701,050 \$128,186,959	\$9,549,928 n/a \$9,549,928
Scenario 3: LNB with OFA and SCR, upgrade wet FGD, FGC for enhanced ESP performance	Brüger WA Fitzpatrick WA Mt. Zirkel WA		0.352 0.157 0.453	5.0 1.3 4.7	\$26,584,385 \$53,009,518 \$20,837,523	\$1,323,945 \$2,584,845 \$661,973	\$49,612,243 \$91,591,833 \$32,057,141	\$2,779,286 \$3,572,081 \$862,227
Scenario 4: LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	Brüger WA Fitzpatrick WA Mt. Zirkel WA		0.339 0.154 0.441	4.7 1.3 3.7	\$37,845,077 \$71,037,371 \$27,785,537	\$1,747,161 \$3,494,362 \$883,313	\$47,496,418 \$2,122,206,301 \$530,551,575	\$18,099,957 n/a \$6,366,619

NOTES:
Sample Calculations: Cost per ΔV Reduction for Scenario 1 for 2001: = \$3,392,440 / (0.7964 - 0.427) = \$9,193,905
Sample Calculations: Cost per Reduction in No. of Days Exceeding 0.5 ΔV for 2001: = \$3,392,440 / (20 - 7) = \$260,567

5.0 Preliminary Assessment and Recommendations

As a result of the completed technical and economic evaluations, and consideration of the modeling analysis for Jim Bridger 1, the preliminary recommended BART controls for NO_x, SO₂, and PM are as follows:

- New LNBS and modifications to the OFA system for NO_x control
- Upgrade wet sodium FGD for SO₂ control
- Add flue gas conditioning upstream of existing ESPs for PM control

The above recommendations were identified as Scenario 1 for the modeling analysis described in Section 4. Visibility improvements for all emission control scenarios were analyzed, and the results are compared below, utilizing a least-cost envelope, as outlined in the *New Source Review Workshop Manual* (EPA, 1990, hereafter referred to as the NSR Manual).

5.1 Least-cost Envelope Analysis

The total annualized cost, cost per dV reduction, and cost per reduction in number of days above 0.5 dV for the scenarios modeled in Section 4 to determine the impact on the three Class I areas are listed in Tables 5-1 through 5-3. A comparison of the incremental costs between relevant scenarios is shown in Tables 5-4 through 5-6. The total annualized cost versus number of days above 0.5 dV, and the total annualized cost versus 98th percentile ΔdV reduction are shown in Figures 5-1 to 5-6 for the three Class I areas.

5.1.1 Analysis Methodology

On page B-41 of the NSR Manual, EPA states that “Incremental cost-effectiveness comparisons should focus on annualized cost and emission reduction differences between dominant alternatives. Dominant set of control alternatives are determined by generating what is called the envelope of least-cost alternatives. This is a graphical plot of total annualized costs for a total emissions reductions for all control alternatives identified in the BACT analysis...”

An analysis of incremental cost effectiveness has been conducted. This analysis was performed in the following way. First, the control option scenarios are ranked in ascending order of annualized total costs as shown in Tables 5-1 through 5-3. The incremental cost-effectiveness data, expressed per day and per dV, represents a comparison of the different scenarios, and is summarized in Tables 5-4 through 5-6 for each of the three wilderness areas. Then the most reasonable smooth curve of least-cost control option scenarios is plotted for each analysis. Figures 5-1 through 5-6 present the two analyses (cost per dV reduction and cost per reduction in number of days above 0.5 dV) for each of the three Class I areas impacted by the operation of Jim Bridger 1.

In Figure 5-1, the four scenarios are compared as a graph of total annualized cost versus number of days above 0.5 dV. EPA states that "In calculating incremental costs, the analysis should only be conducted for control options that are dominant among all possible options." In Figure 5-1, the dominant set of control options, Scenarios 1, 3, and 4, represent the least-cost envelope depicted by the curvilinear line connecting them. Scenario 2 is an inferior option and should not be considered in the derivation of incremental cost effectiveness. Scenario 2 represents an inferior control, because Scenario 1 provides approximately the same amount of visibility impact reduction for less cost than Scenario 2. The incremental cost effectiveness is determined by the difference in total annual costs between two contiguous scenarios divided by the difference in emissions reduction.

TABLE 5-1
Control Scenario Results for the Bridger Class I Wilderness Area
Jim Bridger 1

Scenario	Controls	98 th Percentile deciview (dV) Reduction	Average Number of Days Above 0.5 dV (Days)	Total Annualized Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet Flue Gas Desulfurization (FGD), and Electrostatic Precipitator (ESP)	0.00	0.0	\$0.0	\$0.0	\$0.0
1	Low-NO _x Burners (LNBs) with Over-fire Air (OFA), Upgrade Wet FGD, and Flue Gas Conditioning (FGC) for Enhanced ESP Performance	0.44	10.0	\$3.4	\$7.7	\$0.3
2	LNB with OFA, Upgrade Wet FGD, New Fabric Filter	0.47	10.7	\$9.8	\$21.0	\$0.9
3	LNB with OFA and Selective Catalytic Reduction (SCR), Upgrade Wet FGD, and FGC for Enhanced ESP Performance	0.63	13.7	\$18.1	\$28.6	\$1.3
4	LNB with OFA and SCR, Upgrade Wet FGD, New Fabric Filter	0.65	14.0	\$24.5	\$37.8	\$1.7

TABLE 5-2
Control Scenario Results for the Fitzpatrick Class I Wilderness Area
Jim Bridger 1

Scenario	Controls	98 th Percentile deciview (dV) Reduction	Average Number of Days Above 0.5 dV (Days)	Total Annualized Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet Flue Gas Desulfurization (FGD) and Electrostatic Precipitator (ESP)	0.00	0.0	\$0.0	\$0.0	\$0.0
1	Low-NO _x Burner (LNB) with Over-fire Air (OFA), Upgrade Wet FGD, and Flue Gas Conditioning (FGC) for Enhanced ESP Performance	0.23	5.0	\$3.4	\$14.6	\$0.7
2	LNB with OFA, Upgrade Wet FGD, New Fabric Filter	0.25	4.7	\$9.8	\$39.0	\$2.1
3	LNB with OFA and Selective Catalytic Reduction (SCR), Upgrade Wet FGD, and FGC for Enhanced ESP Performance	0.34	7.0	\$18.1	\$53.0	\$2.6
4	LNB with OFA and SCR, Wet FGD, Fabric Filter	0.34	7.0	\$24.5	\$71.0	\$3.5

TABLE 5-3
Control Scenario Results for the Mt. Zirkel Class I Wilderness Area
Jim Bridger 1

Scenario	Controls	98 th Percentile deciview (dV) Reduction	Average Number of Days Above 0.5 dV (Days)	Total Annualized Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet Flue Gas Desulfurization (FGD) and Electrostatic Precipitator (ESP)	0.00	0.0	\$0.0	\$0.0	\$0.0
1	Low-NO _x Burner (LNB) with Over-fire Air (OFA), Upgrade Wet FGD, and Flue Gas Conditioning (FGC) for Enhanced ESP Performance	0.56	17.0	\$3.4	\$6.1	\$0.2
2	LNB with OFA, Upgrade Wet FGD, New Fabric Filter	0.61	17.7	\$9.8	\$16.0	\$0.6
3	LNB with OFA and Selective Catalytic Reduction (SCR), Upgrade Wet FGD, and FGC for Enhanced ESP Performance	0.87	27.3	\$18.1	\$20.8	\$0.7
4	LNB with OFA and SCR, Upgrade Wet FGD, New Fabric Filter	0.88	28.3	\$24.5	\$27.8	\$0.9

TABLE 5-4
Bridger Class I Wilderness Area Incremental Analysis Data
Jim Bridger 1

Options Compared	Incremental Reduction in Days Above 0.5 deciview (dV) (Days)	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	10.0	0.44	\$0.3	\$7.7
Scenario 1 and Scenario 2	0.7	0.03	\$9.5	\$238.7
Scenario 1 and Scenario 3	3.7	0.19	\$4.0	\$75.5
Scenario 1 and Scenario 4	4.0	0.21	\$5.3	\$101.3

TABLE 5-5
Fitzpatrick Class I Wilderness Area Incremental Analysis Data
Jim Bridger 1

Options Compared	Incremental Reduction in Days Above 0.5 deciview (dV) (Days)	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	5.0	0.23	\$0.7	\$14.6
Scenario 1 and Scenario 2	n/a	0.02	n/a	\$353.7
Scenario 1 and Scenario 3	2.0	0.11	\$7.4	\$134.9
Scenario 1 and Scenario 4	2.0	0.11	\$10.5	\$188.1

TABLE 5-6
Mt. Zirkel Class I Wilderness Area Incremental Analysis Data
Jim Bridger 1

Options Compared	Incremental Reduction in Days Above 0.5 deciview (dV) (Days)	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	17.0	0.56	\$0.2	\$6.1
Scenario 1 and Scenario 2	0.7	0.05	\$9.5	\$128.2
Scenario 1 and Scenario 3	10.3	0.31	\$1.4	\$47.5
Scenario 1 and Scenario 4	11.3	0.32	\$1.9	\$65.5

FIGURE 5-1
 Least-cost Envelope Bridger Class I WA Days Reduction
 Jim Bridger 1




FIGURE 5-2
 Least-cost Envelope Bridger Class I WA 98th Percentile Reduction
 Jim Bridger 1




FIGURE 5-3
Least-cost Envelope Fitzpatrick Class I WA Days Reduction
Jim Bridger 1




FIGURE 5-4
Least-cost Envelope Fitzpatrick Class I WA 98th Percentile Reduction
Jim Bridger 1




FIGURE 5-5
Least-cost Envelope Mt. Zirkel Class I WA Days Reduction
Jim Bridger 1





FIGURE 5-6
Least-cost Envelope Mt. Zirkel Class I WA 98th Percentile Reduction
Jim Bridger 1



5.1.2 Analysis Results

Results of the least-cost analysis, shown in Tables 5-1 through 5-6 and Figures 5-1 through 5-6 on the preceding pages, confirm the selection of Scenario 1, based on incremental cost and visibility improvements. Scenario 2 is eliminated because it is to the left of the curve formed by the dominant control alternative scenarios, which indicates a scenario with lower improvement and/or higher costs. Scenario 3 is not selected due to very high incremental costs on the basis of both a cost per day of improvement and a cost per dV reduction. While Scenario 4 provides some potential visibility advantage over Scenario 1, the projected improvement is less than half a dV, and the projected costs are excessive.

Analysis of the results for the Jim Bridger WA Class I Area in Tables 5-1 and 5-4 and Figures 5-1 and 5-2 illustrates the conclusions stated above. The greatest reduction in 98th percentile dV and number of days exceeding 0.5 dV is between the Baseline and Scenario 1. The average incremental cost effectiveness for Scenario 1 compared to the Baseline for the Bridger Wilderness area (Table 5-4) is reasonable at \$300,000 per day and \$7.7 million per dV. However, the incremental cost effectiveness for Scenario 3 compared to Scenario 1 is excessive at \$4 million per day and \$75.5 million per dV. Therefore, Scenario 1 represents BART for Jim Bridger 1.

5.2 Recommendations

5.2.1 NO_x Emission Control

The BART presumptive NO_x limit assigned by EPA for tangentially-fired boilers burning sub-bituminous coal is 0.15 lb per MMBtu. However, as documented in Section 3.2.1, the characteristics of the Jim Bridger coals are more closely aligned with bituminous coals, with a presumptive BART NO_x limit of 0.28 lb per MMBtu.

CH2M HILL recommends the existing low-NO_x burners with over-fire air (LNB with OFA) as BART for Jim Bridger 1, based on the projected significant reduction in NO_x emissions, reasonable control costs, and the advantages of no additional power requirements or non-air quality environmental impacts. Nitrogen oxide reductions are expected to be similar to those realized at Jim Bridger 2. CH2M HILL recommends that the unit be permitted at a rate of 0.26 lb per MMBtu.

5.2.2 SO₂ Emission Control

CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 1, based on the significant reduction in SO₂ emissions, reasonable control costs, and the advantages of minimal additional power requirements and minimal non-air quality environmental impacts. This upgrade approach will meet the BART presumptive SO₂ limit of 0.15 lb per MMBtu.

5.2.3 PM₁₀ Emission Control

CH2M HILL recommends finalizing the permitting of the FGC system to enhance the performance of the existing ESP as BART for Jim Bridger 1, based on the significant reduction

in PM₁₀ emissions, reasonable control costs, and the advantages of minimal additional power requirements and no non-air quality environmental impacts.

5.3 Just-Noticeable Differences in Atmospheric Haze

Conclusions reached in the reference document "Just-Noticeable Differences in Atmospheric Haze" by Dr. Ronald Henry of the University of Southern California (Henry, 2002), state that only dV differences of approximately 1.5 to 2.0 dV, or more are perceivable by the human eye. Deciview changes of less than 1.5 cannot be distinguished by the average person. Therefore, the modeling analysis results indicate that only minimal, if any, observable visibility improvements at the Class I areas studied would be expected under any of the scenarios. Thus the results indicate that even though many millions of dollars will be spent, only minimal if any noticeable visibility improvements may result.

Finally, it should be noted that none of the data were corrected for natural obscuration where water in various forms (fog, clouds, snow or rain) or other naturally caused aerosols obscure the atmosphere. During the period of 2001 through 2003, there were several mega-wildfires that lasted for many days and could have had a significant impact on background visibility in these Class I areas. If natural obscuration were to reduce the reduction in visibility impacts modeled for the Jim Bridger 1 facility, the effect would be to increase the costs per dV reduction that are presented in this report.

6.0 References

- 40 CFR Part 51. *Regional Haze Regulations and Guidelines for Best Available Retrofit Technology Determinations; Final Rule*. July 6, 2005.
- Energy Information Administration, 2006. *Official Energy Statistics from the U.S. Government: Coal*. <http://www.eia.doe.gov/fuelcoal.html>. Accessed October 2006.
- EPA, 1990. *New Source Review Workshop Manual—Prevention of Significant Deterioration and Nonattainment Area Permitting*. Draft. October 1990.
- EPA, 2003. *Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule*. Environmental Protection Agency. EPA-454/8-03-005. September 2003.
- Henry, Ronald, 2002. "Just-Noticeable Differences in Atmospheric Haze," *Journal of the Air & Waste Management Association*. Volume 52, p. 1238.
- National Oceanic and Atmospheric Administration, 2006. U.S. Daily Weather Maps Project. http://docs.lib.noaa.gov/rescue/dwm/data_rescue_daily_weather_maps.html. Accessed October 2006.
- North Dakota Department of Health, 2005. *Protocol for BART-Related Visibility Improvement Modeling Analysis in North Dakota*. North Dakota Department of Health. October 26, 2005.
- Sargent & Lundy, 2002. *Multi-Pollutant Control Report*. October 2002.
- Sargent & Lundy, 2006. *Multi-Pollutant Control Report*. Revised. October 2006.
- WDEQ-AQD, 2006. *BART Air Modeling Protocol—Individual Source Visibility Assessments for BART Control Analyses*. Wyoming Department of Environmental Quality – Air Quality Division. September 2006.

APPENDIX A
Economic Analysis

ECONOMIC ANALYSIS SUMMARY									
Boiler Design: Tangential-Fired PC									
Jim Bridger Unit 1									
Parameter	Current Operation	NOx Control				SO2 Control		PM Control	
		LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	Upgraded Wet FGD	Flue Gas Conditioning	Flue Gas Conditioning	Fabric Filter
Case	1	2	3	4	5	8	9	10	
	LNCFS-1 & Windbox Meds, Wet FGD ESP	LNB w/OFA Wet FGD ESP	ROFA Wet FGD ESP	LNB w/OFA & SNCR Wet FGD ESP	LNB w/OFA & SCR Wet FGD ESP	LNCFS-1 & Windbox Meds, Upgraded Wet FGD ESP	LNCFS-1 & Windbox Meds, Flue Gas Conditioning	LNCFS-1 & Windbox Meds, Wet FGD Fabric Filter	
TOTAL INSTALLED CAPITAL COST (\$)	0	8,700,001	20,528,122	22,127,239	123,575,495	12,999,900	0	48,365,333	
FIRST YEAR O&M COST (\$)									
Operating Labor (\$)	0	0	0	0	0	0	0	0	
Maintenance Material (\$)	0	28,000	42,000	123,000	190,000	25,550	0	51,089	
Maintenance Labor (\$)	0	42,000	63,000	184,500	285,000	17,033	10,000	76,649	
Administrative Labor (\$)	0	0	0	0	0	0	0	0	
TOTAL FIXED O&M COST	0	70,000	105,000	307,500	475,000	42,583	10,000	127,749	
Makeup Water Cost	0	0	0	0	0	30,503	0	0	
Reagent Cost	0	0	0	1,005,811	912,848	533,206	145,854	0	
SCR Catalyst / FF Bag Cost	0	0	0	0	594,000	0	0	300,040	
Waste Disposal Cost	0	0	0	0	0	442,958	0	0	
Electric Power Cost	0	0	2,528,012	208,926	1,291,005	208,926	19,710	1,335,944	
TOTAL VARIABLE O&M COST	0	0	2,528,012	1,214,737	2,797,953	1,215,533	165,564	1,635,944	
TOTAL FIRST YEAR O&M COST	0	70,000	2,633,012	1,822,237	3,272,953	1,258,176	175,564	1,763,732	
FIRST YEAR DEBT SERVICE (\$)	0	827,612	1,952,795	2,104,916	12,326,235	1,236,652	0	4,602,887	
TOTAL FIRST YEAR COST (\$)	0	897,612	4,585,808	3,827,153	15,599,088	2,494,828	175,564	6,366,619	
Power Consumption (MW)	0.0	0.0	5.4	0.5	3.3	0.5	0.1	3.4	
Annual Power Usage (Million kW-Hr/Yr)	0.0	0.0	50.5	4.2	25.8	4.2	0.4	26.7	
CONTROL COST (\$/Ton Removed)									
NOx Removal Rate (%)	0.0%	45.7%	51.1%	55.6%	84.4%	0.0%	0.0%	0.0%	
NOx Removed (Tons/Yr)	0	4,857	5,440	5,913	9,397	0	0	0	
First Year Average Control Cost (\$/Ton NOx Rem.)	0	181	843	913	1,736	0	0	0	
Incremental Control Cost (\$/Ton NOx Removed)	0	2-1	3-2	4-2	5-4	0	0	0	
SO2 Removal Rate (%)	77.8%	0.0%	0.0%	0.0%	0.0%	62.5%	0.0%	0.0%	
SO2 Removed (Tons/Yr)	0	0	0	0	0	3,950	0	0	
First Year Average Control Cost (\$/Ton SO2 Rem.)	0	0	0	0	0	632	0	0	
Incremental Control Cost (\$/Ton SO2 Removed)	Base	0	0	0	0	632	0	0	
PM Removal Rate (%)	99.47%	0.00%	0.00%	0.00%	0.00%	0.00%	33.33%	66.67%	
PM Removed (Tons/Yr)	0	0	0	0	0	0	355	710	
First Year Average Control Cost (\$/Ton PM Rem.)	0	0	0	0	0	0	495	3,973	
Incremental Control Cost (\$/Ton PM Removed)	Base	0	0	0	0	0	495	17,452	
PRESENT WORTH COST (\$)	0	9,555,250	52,697,883	40,725,706	169,562,733	28,372,107	2,145,015	69,935,356	

INPUT CALCULATIONS

Boiler Design: Tangential-Fired PC

Jim Bridger Unit 1

Parameter	NOX Control				SO2 Control		PM Control		Comments
	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter	
Case	1	2	3	4	5	6	7	8	
NCx Emission Control System	LNCFS-1 & Wet FGD	LNB w/OFA Wet FGD	ROFA Wet FGD	LNB w/OFA & SNCR Wet FGD	LNB w/OFA & SCR Wet FGD	LNCFS-1 & Wet FGD	Wet FGD	LNCFS-1 & Wet FGD	10
SO2 Emission Control System	Wet FGD	Wet FGD	Wet FGD	Wet FGD	Wet FGD	Wet FGD	Wet FGD	Wet FGD	
PM Emission Control System	ESP	ESP	ESP	ESP	ESP	ESP	ESP	ESP	
Unit Design and Coal Characteristics									
Type of Unit	PC	PC	PC	PC	PC	PC	PC	PC	PC
Net Power Output (kW)	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000
Net Power Heat Rate (Btu/kWhr)	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320
Boiler Fuel	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground
Coal Heating Value (Btu/Lb)	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660
Coal Sulfur Content (wt.%)	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%
Coal Ash Content (wt.%)	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%
Boiler Heat Input, each (MMBtu/hr)	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000
Coal Flow Rate (Lb/hr)	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077
(Ton/Yr)	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284
(MMBtu/Yr)	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846
Emissions									
Uncontrolled SO2 (Lb/hr)	7,210	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602
(Lb/MMBtu)	1.20	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27
(Lb Moles/hr)	112,54	25,00	25,00	25,00	25,00	25,00	25,00	25,00	25,00
(Ton/Yr)	28,421	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315
SO2 Removal Rate (%)	77.8%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
(Lb/hr)	5,908	0	0	0	0	0	0	0	0
(Ton/Yr)	22,106	0	0	0	0	0	0	0	0
SO2 Emission Rate (Lb/hr)	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602
(Lb/MMBtu)	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27
(Ton/Yr)	5,315	5,315	5,315	5,315	5,315	5,315	5,315	5,315	5,315
Uncontrolled NOx (Lb/hr)	2,700	2,700	2,700	2,700	2,700	2,700	2,700	2,700	2,700
(Lb/MMBtu)	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45
(Lb Moles/hr)	89.96	89.96	89.96	89.96	89.96	89.96	89.96	89.96	89.96
(Ton/Yr)	10,543	10,543	10,543	10,543	10,543	10,543	10,543	10,543	10,543
NOx Removal Rate (%)	0.0%	46.7%	51.1%	55.6%	84.4%	0%	0%	0%	0%
(Lb/hr)	0	1,260	1,380	1,500	2,280	0	0	0	0
(Lb Moles/hr)	0	41.58	45.98	49.98	75.97	0	0	0	0
(Ton/Yr)	0	4,967	5,440	5,913	8,987	0	0	0	0
NOx Emission Rate (Lb/hr)	2,700	1,440	1,320	1,200	420	2,700	2,700	2,700	2,700
(Lb/MMBtu)	0.45	0.24	0.22	0.20	0.07	0.45	0.45	0.45	0.45
(Ton/Yr)	10,543	5,676	5,203	4,730	1,656	10,543	10,543	10,543	10,543
Uncontrolled Fly Ash (Lb/hr)	51,177	270	270	270	270	270	270	270	270
(Lb/MMBtu)	8.530	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045
(Lb Moles/hr)	1,705.3	9.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0
(Ton/Yr)	201,739	1,064	1,064	1,064	1,064	1,064	1,064	1,064	1,064
Fly Ash Removal Rate (%)	99.47%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
(Lb/hr)	50,507	0	0	0	0	0	0	0	0
(Ton/Yr)	200,674	0	0	0	0	0	0	0	0
Fly Ash Emission Rate (Lb/hr)	270	270	270	270	270	270	270	270	270
(Lb/MMBtu)	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045
(Ton/Yr)	1,064	1,064	1,064	1,064	1,064	1,064	1,064	1,064	1,064

Parameter	Current Operation		NOx Control				SO2 Control		PM Control			Comments
	1	2	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	5	8	9	Flue Gas Conditioning	Fabric Filter	
Case												
General Plant Data												
Annual Operation (Hours/Year)	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	
Annual On-Site Power Plant Capacity Factor	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	
Economic Factors												
Interest Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	
Discount Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	
Plant Economic Life (Years)	20	20	20	20	20	20	20	20	20	20	20	
Installed Capital Costs												
NOx Emission Control System (\$2006)	0	8,700,001	20,528,122	39	22,127,239	129,575,495	0	0	0	0	0	
SO2 Emission Control System (\$2006)	0	0	0	0	0	0	12,999,900	0	0	0	0	
PM Emission Control System (\$2006)	0	0	0	0	0	0	12,999,900	0	0	0	0	
Total Emission Control Systems (\$2006)	0	8,700,001	20,528,122	39	22,127,239	129,575,495	12,999,900	0	0	0	0	48,999,333
NOx Emission Control System (\$1000)	0	16	0	0	42	244	0	0	0	0	0	0
SO2 Emission Control System (\$1000)	0	0	0	0	0	0	25	0	0	0	0	0
PM Emission Control System (\$1000)	0	0	0	0	0	0	23	0	0	0	0	0
Total Emission Control Systems (\$1000)	0	16	0	39	42	244	23	0	0	0	0	0
Total Fixed Operating & Maintenance Costs												
Operating Labor (\$)	0	0	0	0	0	0	0	0	0	0	0	0
Maintenance Material (\$)	0	28,000	42,000	0	123,000	190,000	25,550	0	0	0	51,099	0
Maintenance Labor (\$)	0	42,000	63,000	0	194,500	285,000	17,033	0	10,000	0	76,649	0
Administrative Labor (\$)	0	0	0	0	0	0	0	0	0	0	0	0
Total Fixed O&M Cost (\$)	0	70,000	105,000	0	307,500	475,000	42,583	0	10,000	0	127,749	0
Annual Fixed O&M Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%
Water Costs												
Makeup Water Usage (Gpm)	0	0	0	0	0	0	53	0	0	0	0	0
Unit Price (\$/1000 Gallons)	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22
First Year Water Cost (\$)	0	0	0	0	0	0	30,503	0	0	0	0	0
Annual Water Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%
Reagent Costs												
Unit Cost (\$/Ton)	None	None	None	None	Urea	Anhydrous NH3	Soda Ash	Elemental Sulfur	None	None	None	None
(\$/Lb)	0.00	0.00	0.00	0.00	370	400	80.00	370	0.00	0.00	0.00	0.00
Molar Stoichiometry	0.000	0.000	0.000	0.000	0.185	0.200	0.040	0.185	0.000	0.000	0.000	0.000
Reagent Purity (M%)	0.00	0.00	0.00	0.00	0.45	1.00	1.02	0.00	0.00	0.00	0.00	0.00
Reagent Usage (Lb/Hr)	100%	100%	100%	100%	680	579	1,691	100%	100%	100%	90%	90%
First Year Reagent Cost (\$)	0	0	0	0	1,005,841	912,848	633,205	100	148,854	0	0	0
Annual Reagent Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%
SCR Catalyst Life Bag Replacement Cost												
Annual SCR Catalyst (mg) / No. FF Bags	0	0	0	0	0	198	Bags	0	0	0	0	Bags
SCR Catalyst (\$/mg) / Bag Cost (\$/ea.)	3,000	3,000	3,000	3,000	3,000	3,000	184	3,000	3,000	3,000	3,000	2,895
First Year SCR Catalyst / Bag Replacement Cost (\$)	0	0	0	0	0	594,000	2,000	0	0	0	0	404
Annual SCR Catalyst / Bag Cost Esc. Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%
FGD Waste Disposal Costs												
FGD Solid Waste Disposal Rate, Dry (Lb/Hr)	0	0	0	0	0	0	4,618	0	0	0	0	0
FGD Waste Disposal Unit Cost (\$/Dry Ton)	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33
First Year FGD Waste Disposal Cost (\$)	0	0	0	0	0	0	442,959	0	0	0	0	0
Annual Waste Disposal Cost Esc. Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%
Auxiliary Power Costs												
Auxiliary Power Requirement (% of Plant Output) (MW)	0.00%	0.00%	1.21%	0.10%	0.62%	0.62%	0.10%	0.62%	0.01%	0.64%	0.64%	0.64%
Unit Cost (\$2006/MW-Hr)	0.00	0.00	6.41	0.53	3.28	3.28	0.53	0.05	0.05	3.39	3.39	3.39
First Year Auxiliary Power Cost (\$)	0	0	50,000	50,000	50,000	50,000	50,000	50,000	50,000	50,000	50,000	50,000
Annual Power Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%
Total Annual Power Cost (\$)	0	0	2,629,012	208,926	1,291,005	208,926	19,710	1,335,944	19,710	1,335,944	1,335,944	1,335,944
Annual Power Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%

Input Tables

Table 1 - Cases

Index No.	Name of Unit Case →	Existing		NOx Control		SO2 Control		PM Control		
		1	2	3	4	6	7	8	9	10
1	Dave Johnston Unit 3	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	Dry FGD w/ESP	Wet FGD w/ESP	N/A	Fabric Filter
2	Dave Johnston Unit 4	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	Dry FGD w/Fabric Filter	Wet FGD w/Fabric Filter	N/A	Fabric Filter
3	Jim Bridger Unit 1	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	N/A	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
4	Jim Bridger Unit 2	Current Operation	Exist LNB w/OFA	ROFA	SNCR	SCR	N/A	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
5	Jim Bridger Unit 3	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	N/A	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
6	Jim Bridger Unit 4	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	N/A	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
7	Naughton Unit 1	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	Dry FGD w/ESP	Wet FGD w/ESP	Flue Gas Conditioning	Fabric Filter
8	Naughton Unit 2	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	Dry FGD w/Fabric Filter	Wet FGD w/ESP	Flue Gas Conditioning	Fabric Filter
9	Naughton Unit 3	Current Operation	Exist LNB w/OFA	ROFA	SNCR	SCR	N/A	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
10	Wyodak Unit 1	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	Upgraded Dry FGD	Wet FGD	Flue Gas Conditioning	Fabric Filter

Table 2 - Unit Design and Coal Characteristics

Index No.	Name of Unit	Current Emission Control Systems				Unit Design			Coal Quality			
		NOx	SO2	PM	None	Boiler Design	Net Power Output (MW)	Net Plant Heat Rate (Btu/kWh-Hr)	Coal	Heating Value, HHV (Btu/Lb)	Sulfur Content (Wt.%)	Ash Content (Wt.%)
1	Dave Johnston Unit 3	None	None	ESP	Lime Added to Venturi Scrubber	3-Coal Burner, Opposed Wall-Fired PC	250,000	11,200	Dry Fork PRB	7,784	0.47%	5.01%
2	Dave Johnston Unit 4	Winbox Mod., LNCFS-1 & Winbox Mod.	None	ESP	Venturi Scrubber	Tangential-Fired PC	360,000	11,350	Dry Fork PRB	7,784	0.47%	5.01%
3	Jim Bridger Unit 1	LNB - TFS 2000	Wet FGD	ESP	None	Tangential-Fired PC	530,000	11,320	Underground	9,660	0.58%	10.30%
4	Jim Bridger Unit 2	LNCFS-1 & Winbox Mod.	Wet FGD	ESP	None	Tangential-Fired PC	530,000	11,320	Underground	9,660	0.58%	10.30%
5	Jim Bridger Unit 3	LNCFS-1 & Winbox Mod.	Wet FGD	ESP	None	Tangential-Fired PC	530,000	11,320	Underground	9,660	0.58%	10.30%
6	Jim Bridger Unit 4	LNCFS-1 & Winbox Mod.	Wet FGD	ESP	None	Tangential-Fired PC	530,000	11,320	Underground	9,660	0.58%	10.30%
7	Naughton Unit 1	None	None	ESP	None	Tangential-Fired PC	173,000	10,684	Kemmerer Mine	9,970	0.60%	4.64%
8	Naughton Unit 2	None	None	ESP	None	Tangential-Fired PC	226,000	10,574	Kemmerer Mine	9,970	0.60%	4.64%
9	Naughton Unit 3	LNCFS II LNB	Wet FGD	ESP	None	Tangential-Fired PC	356,000	10,336	Kemmerer Mine	9,970	0.60%	4.64%
10	Wyodak Unit 1	LNB	Dry FGD	ESP	None	Opposed Wall-Fired PC	335,000	12,087	Clover Point Mine	7,977	0.65%	7.46%

Table 3 - Emissions

Index No.	Name of Unit	Current Emission Rates (Lb/MMBtu)		NOx Control Emission Rates (Lb/MMBtu)					SO2 Control Emission Rates (Lb/MMBtu)					PM Emission Rates (Lb/MMBtu)				
		Controlled	Controlled NOx	Case 2	Case 3	Case 4	Case 5	Case 6	Case 7	Case 8	Case 9	Case 10	Case 6	Case 7	Case 8	Case 9	Case 10	
1	Dave Johnston Unit 3	1.20	0.70	0.200	0.27	0.21	0.20	0.07	0.21	0.15	0.10	0.07	N/A	0.15	0.10	N/A	0.075	
2	Dave Johnston Unit 4	0.33	0.48	0.061	0.16	0.19	0.12	0.07	N/A	N/A	0.10	0.07	N/A	0.15	0.10	N/A	0.075	
3	Jim Bridger Unit 1	0.27	0.45	0.045	0.24	0.22	0.20	0.07	N/A	N/A	0.10	0.07	N/A	N/A	0.10	0.030	0.075	
4	Jim Bridger Unit 2	0.27	0.24	0.074	0.24	0.22	0.20	0.07	N/A	N/A	0.10	0.07	N/A	N/A	0.10	0.030	0.075	
5	Jim Bridger Unit 3	0.27	0.45	0.057	0.24	0.22	0.20	0.07	N/A	N/A	0.10	0.07	N/A	N/A	0.10	0.030	0.075	
6	Jim Bridger Unit 4	0.17	0.45	0.030	0.24	0.22	0.20	0.07	N/A	N/A	0.10	0.07	N/A	N/A	0.10	0.030	0.075	
7	Naughton Unit 1	1.20	0.56	0.066	0.24	0.28	0.18	0.07	0.18	0.15	0.10	0.07	0.18	0.15	0.10	0.040	0.075	
8	Naughton Unit 2	1.20	0.54	0.064	0.24	0.28	0.18	0.07	0.18	0.15	0.10	0.07	0.18	0.15	0.10	0.040	0.075	
9	Naughton Unit 3	0.50	0.45	0.094	0.35	0.30	0.25	0.07	N/A	N/A	0.10	0.07	N/A	N/A	0.10	0.040	0.075	
10	Wyodak Unit 1	0.50	0.50	0.030	0.23	0.22	0.18	0.07	0.25	N/A	0.10	0.07	0.25	N/A	0.10	0.025	0.075	

Table 4 - Case 1 O&M Costs (Current Operation)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Reagent	Reagent Molar Stoich.	Aux. Power Usage (MW)	Stoich.
1	Dave Johnston Unit 3	\$ -	\$ -	\$ -	\$ -	None	-	-	-
2	Dave Johnston Unit 4	\$ -	\$ -	\$ -	\$ -	None	-	-	-
3	Jim Bridger Unit 1	\$ -	\$ -	\$ -	\$ -	None	-	-	-
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	None	-	-	-
5	Jim Bridger Unit 3	\$ -	\$ -	\$ -	\$ -	None	-	-	-
6	Jim Bridger Unit 4	\$ -	\$ -	\$ -	\$ -	None	-	-	-
7	Naughton Unit 1	\$ -	\$ -	\$ -	\$ -	None	-	-	-
8	Naughton Unit 2	\$ -	\$ -	\$ -	\$ -	None	-	-	-
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	None	-	-	-
10	Wyodak Unit 1	\$ -	\$ -	\$ -	\$ -	None	-	-	-

Table 5 - Case 2 O&M Costs (LNB w/OFA)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Reagent	Reagent Molar Stoich.	Aux. Power Usage (MW)	Stoich.
1	Dave Johnston Unit 3	\$ -	\$ 40,000	\$ 60,000	\$ -	None	-	-	-
2	Dave Johnston Unit 4	\$ -	\$ 36,000	\$ 64,000	\$ -	None	-	-	-
3	Jim Bridger Unit 1	\$ -	\$ 28,000	\$ 42,000	\$ -	None	-	-	-
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	None	-	-	-
5	Jim Bridger Unit 3	\$ -	\$ 28,000	\$ 42,000	\$ -	None	-	-	-
6	Jim Bridger Unit 4	\$ -	\$ 28,000	\$ 42,000	\$ -	None	-	-	-
7	Naughton Unit 1	\$ -	\$ 32,000	\$ 48,000	\$ -	None	-	-	-
8	Naughton Unit 2	\$ -	\$ -	\$ -	\$ -	None	-	-	-
9	Naughton Unit 3	\$ -	\$ 24,000	\$ 36,000	\$ -	None	-	-	-
10	Wyodak Unit 1	\$ -	\$ -	\$ -	\$ -	None	-	-	-

Table 6 - Case 3 O&M Costs (Mobotec ROFA)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ 60,000	\$ 90,000	\$ -	-	None	-	2.76
2	Dave Johnston Unit 4	\$ -	\$ 54,000	\$ 81,000	\$ -	-	None	-	4.33
3	Jim Bridger Unit 1	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41
4	Jim Bridger Unit 2	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41
5	Jim Bridger Unit 3	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41
6	Jim Bridger Unit 4	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41
7	Naughton Unit 1	\$ -	\$ 48,000	\$ 72,000	\$ -	-	None	-	1.42
8	Naughton Unit 2	\$ -	\$ 48,000	\$ 72,000	\$ -	-	None	-	2.51
9	Naughton Unit 3	\$ -	\$ 48,000	\$ 72,000	\$ -	-	None	-	4.47
10	Wyodak Unit 1	\$ -	\$ 38,000	\$ 54,000	\$ -	-	None	-	5.22

Table 7 - Case 4 O&M Costs (LNB w/OFA & SNCR)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ 98,000	\$ 147,000	\$ -	-	Urea	0.41	0.23
2	Dave Johnston Unit 4	\$ -	\$ 105,000	\$ 157,500	\$ -	-	Urea	0.45	0.33
3	Jim Bridger Unit 1	\$ -	\$ 123,000	\$ 184,500	\$ -	-	Urea	0.45	0.53
4	Jim Bridger Unit 2	\$ -	\$ 95,000	\$ 142,500	\$ -	-	Urea	0.45	0.63
5	Jim Bridger Unit 3	\$ -	\$ 122,000	\$ 183,000	\$ -	-	Urea	0.45	0.52
6	Jim Bridger Unit 4	\$ -	\$ 123,000	\$ 184,500	\$ -	-	Urea	0.45	0.53
7	Naughton Unit 1	\$ -	\$ 83,000	\$ 124,500	\$ -	-	Urea	0.45	0.16
8	Naughton Unit 2	\$ -	\$ 93,000	\$ 139,500	\$ -	-	Urea	0.51	0.22
9	Naughton Unit 3	\$ -	\$ 76,000	\$ 112,500	\$ -	-	Urea	0.45	0.33
10	Wyodak Unit 1	\$ -	\$ 83,000	\$ 139,500	\$ -	-	Urea	0.45	0.34

Table 8 - Case 5 O&M Costs (LNB w/OFA & SCR)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Annual SCR Catalyst Replace. (mt)	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ 155,000	\$ 232,500	\$ -	-	Anhydrous NH3	1.00	128	1.57
2	Dave Johnston Unit 4	\$ -	\$ 165,000	\$ 249,000	\$ -	-	Anhydrous NH3	1.00	123	2.29
3	Jim Bridger Unit 1	\$ -	\$ 190,000	\$ 285,000	\$ -	-	Anhydrous NH3	1.00	198	3.28
4	Jim Bridger Unit 2	\$ -	\$ 162,000	\$ 243,000	\$ -	-	Anhydrous NH3	1.00	198	3.25
5	Jim Bridger Unit 3	\$ -	\$ 190,000	\$ 285,000	\$ -	-	Anhydrous NH3	1.00	200	3.22
6	Jim Bridger Unit 4	\$ -	\$ 190,000	\$ 285,000	\$ -	-	Anhydrous NH3	1.00	214	3.36
7	Naughton Unit 1	\$ -	\$ 132,000	\$ 198,000	\$ -	-	Anhydrous NH3	1.00	67	0.96
8	Naughton Unit 2	\$ -	\$ 160,000	\$ 240,000	\$ -	-	Anhydrous NH3	1.00	101	1.34
9	Naughton Unit 3	\$ -	\$ 156,000	\$ 234,000	\$ -	-	Anhydrous NH3	1.00	167	1.99
10	Wyodak Unit 1	\$ -	\$ 181,000	\$ 271,500	\$ -	-	Anhydrous NH3	1.00	160	2.42

Table 9 - Case 6 O&M Costs (Dry FGD)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Annual FF Bag Replace.	Aux. Power Usage (MMW)
1	Dave Johnston Unit 3	\$ 806,128	\$ 714,175	\$ 476,928		173	Lime	1.15	-	2.49
2	Dave Johnston Unit 4						Lime			
3	Jim Bridger Unit 1						Lime			
4	Jim Bridger Unit 2						Lime			
5	Jim Bridger Unit 3						Lime			
6	Jim Bridger Unit 4						Lime			
7	Naughton Unit 1	\$ 506,128	\$ 687,643	\$ 391,762		120	Lime	1.40	-	1.64
8	Naughton Unit 2	\$ 506,128	\$ 860,174	\$ 573,044		165	Lime	1.40	-	2.25
9	Naughton Unit 3						Lime			
10	Wyodak Unit 1		\$ 21,900	\$ 14,600		25	Lime	1.10	-	0.11

Table 10 - Case 7 O&M Costs (Dry FGD w/Fabric Filter)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Annual FF Bag Replace.	Aux. Power Usage (MMW)
1	Dave Johnston Unit 3	\$ 806,128	\$ 714,175	\$ 476,928		173	Lime	1.15	-	3.86
2	Dave Johnston Unit 4	\$ 806,128	\$ 1,102,286	\$ 734,668		248	Lime	1.10	1,457	4.54
3	Jim Bridger Unit 1						Lime			
4	Jim Bridger Unit 2						Lime			
5	Jim Bridger Unit 3						Lime			
6	Jim Bridger Unit 4						Lime			
7	Naughton Unit 1	\$ 506,128	\$ 632,650	\$ 459,286		120	Lime	1.15	865	2.66
8	Naughton Unit 2	\$ 506,128	\$ 905,190	\$ 640,568		165	Lime	1.15	1,193	3.63
9	Naughton Unit 3						Lime			
10	Wyodak Unit 1						Lime			

Table 11 - Case 8 O&M Costs (Wet FGD)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Annual FF Bag Replace.	Aux. Power Usage (MMW)
1	Dave Johnston Unit 3	\$ 809,804	\$ 1,182,587	\$ 788,391		230	Lime	1.02	-	3.45
2	Dave Johnston Unit 4	\$ 809,804	\$ 1,430,784	\$ 953,856		330	Lime	1.02	1,798	6.29
3	Jim Bridger Unit 1		\$ 25,550	\$ 17,033		53	Soda Ash	1.02	-	0.53
4	Jim Bridger Unit 2		\$ 25,550	\$ 17,033		53	Soda Ash	1.02	-	0.53
5	Jim Bridger Unit 3		\$ 25,550	\$ 17,033		52	Soda Ash	1.02	-	0.52
6	Jim Bridger Unit 4		\$ 25,550	\$ 17,033		27	Soda Ash	1.02	-	0.53
7	Naughton Unit 1	\$ 809,804	\$ 963,589	\$ 642,393		160	Lime	1.05	-	2.40
8	Naughton Unit 2	\$ 809,804	\$ 1,226,386	\$ 817,591		220	Lime	1.05	-	3.30
9	Naughton Unit 3		\$ 21,900	\$ 14,600		66	Soda Ash	1.02	-	0.33
10	Wyodak Unit 1	\$ 303,977	\$ 328,496	\$ 218,598		82	Lime	1.02	-	1.78

Table 12 - Case 9 O&M Costs (Flue Gas Conditioning)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements					
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent Usage (Lb/Hr)	Reagent Stoich.	Annual FF Bag Replace.	Aux. Power Usage (MW)	
1	Dave Johnston Unit 3	\$ -	\$ -	\$ -	\$ -	-	None	-	-	-	
2	Dave Johnston Unit 4	\$ -	\$ -	\$ -	\$ -	-	None	-	-	-	
3	Jim Bridger Unit 1	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	100	-	0.05	
4	Jim Bridger Unit 2	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	100	-	0.05	
5	Jim Bridger Unit 3	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	100	-	0.05	
6	Jim Bridger Unit 4	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	33	-	0.05	
7	Naughton Unit 1	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	49	-	0.05	
8	Naughton Unit 2	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	57	-	0.05	
9	Naughton Unit 3	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	53	-	0.05	
10	Wyotak Unit 1	\$ -	\$ -	\$ -	\$ -	-	Elemental Sulfur	-	-	-	

Table 13 - Case 10 O&M Costs (Fabric Filter)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements					
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent Usage (Lb/Hr)	Reagent Stoich.	Annual FF Bag Replace.	Aux. Power Usage (MW)	
1	Dave Johnston Unit 3	\$ -	\$ 45,016	\$ 57,524	\$ -	-	None	-	1,457	1.38	
2	Dave Johnston Unit 4	\$ -	\$ 65,133	\$ 102,199	\$ -	-	None	-	1,798	2.35	
3	Jim Bridger Unit 1	\$ -	\$ 51,099	\$ 76,649	\$ -	-	None	-	2,885	3.39	
4	Jim Bridger Unit 2	\$ -	\$ 51,099	\$ 76,649	\$ -	-	None	-	2,885	3.37	
5	Jim Bridger Unit 3	\$ -	\$ 51,099	\$ 76,649	\$ -	-	None	-	2,827	3.33	
6	Jim Bridger Unit 4	\$ -	\$ 51,099	\$ 76,649	\$ -	-	None	-	2,886	3.39	
7	Naughton Unit 1	\$ -	\$ 45,016	\$ 57,524	\$ -	-	None	-	865	1.01	
8	Naughton Unit 2	\$ -	\$ 45,016	\$ 57,524	\$ -	-	None	-	1,193	1.38	
9	Naughton Unit 3	\$ -	\$ 48,666	\$ 72,959	\$ -	-	None	-	1,759	2.05	
10	Wyotak Unit 1	\$ -	\$ 48,666	\$ 72,959	\$ -	-	None	-	1,798	2.05	

Table 14 - Major Materials Design and Supply Costs

Index No.	Name of Unit Case →	NOx Control						SO2 Control				PM Control	
		2	3	4	5	6	7	8	9	10			
1	Dave Johnston Unit 3	\$ 3,221,912	\$ 3,555,617	\$ 5,173,000	\$ 49,355,000	\$ 83,871,000	\$ 142,077,000	\$ 108,865,669	\$ -	\$ -	\$ 18,359,000		
2	Dave Johnston Unit 4	\$ 2,673,501	\$ 4,345,192	\$ 7,171,085	\$ 66,200,000	\$ -	\$ 137,267,000	\$ 178,174,384	\$ -	\$ -	\$ 30,853,530		
3	Jim Bridger Unit 1	\$ 2,981,982	\$ 6,055,955	\$ 9,528,000	\$ 80,923,000	\$ -	\$ -	\$ 8,010,093	\$ -	\$ -	\$ 29,814,000		
4	Jim Bridger Unit 2	\$ -	\$ 6,055,955	\$ 9,528,000	\$ 80,923,000	\$ -	\$ -	\$ 8,010,093	\$ -	\$ -	\$ 29,814,000		
5	Jim Bridger Unit 3	\$ 2,981,982	\$ 6,055,955	\$ 9,419,000	\$ 80,923,000	\$ -	\$ -	\$ 8,010,093	\$ -	\$ -	\$ 29,814,000		
6	Jim Bridger Unit 4	\$ -	\$ 6,055,955	\$ 9,528,000	\$ 83,009,000	\$ -	\$ -	\$ 3,549,000	\$ -	\$ -	\$ 29,814,000		
7	Naughton Unit 1	\$ 2,502,423	\$ 2,573,792	\$ 7,257,000	\$ 37,292,000	\$ 26,819,000	\$ 42,301,000	\$ 44,000,000	\$ 800,000	\$ 800,000	\$ 15,482,000		
8	Naughton Unit 2	\$ 2,570,874	\$ 3,123,533	\$ 6,784,000	\$ 47,634,000	\$ 39,262,000	\$ 57,621,000	\$ 55,000,000	\$ 800,000	\$ 800,000	\$ 18,359,000		
9	Naughton Unit 3	\$ -	\$ 4,351,377	\$ 11,203,578	\$ 67,373,000	\$ -	\$ -	\$ 2,653,000	\$ -	\$ -	\$ 20,105,000		
10	Wyotak Unit 1	\$ -	\$ 4,500,248	\$ 7,234,860	\$ 72,475,000	\$ 995,100	\$ -	\$ 178,174,384	\$ 1,247,061	\$ -	\$ 20,105,000		

Jim Bridger Unit 1											
LNB w/OFA											
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton NOx Removed)
0	2013										
1	2014	70,000							827,612	827,612	181
2	2015	71,400							827,612	827,612	181
3	2016	72,828							827,612	827,612	181
4	2017	74,285							827,612	827,612	182
5	2018	75,770							827,612	827,612	182
6	2019	77,286							827,612	827,612	182
7	2020	78,831							827,612	827,612	183
8	2021	80,408							827,612	827,612	183
9	2022	82,016							827,612	827,612	183
10	2023	83,655							827,612	827,612	183
11	2024	85,330							827,612	827,612	184
12	2025	87,098							827,612	827,612	185
13	2026	88,777							827,612	827,612	185
14	2027	90,582							827,612	827,612	185
15	2028	92,384							827,612	827,612	186
16	2029	94,211							827,612	827,612	186
17	2030	96,085							827,612	827,612	186
18	2031	98,017							827,612	827,612	187
19	2032	99,977							827,612	827,612	187
20	2033	101,977							827,612	827,612	187
Present Worth (% of PW)		855,250	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	8,700,001	9,555,250	100.0%

Jim Bridger Unit 1											
ROFA											
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton NOx Removed)
0	2013										
1	2014	105,000					2,528,012	2,528,012	1,952,796	4,585,808	843
2	2015	107,100					2,578,573	2,578,573	1,952,796	4,638,468	853
3	2016	109,242					2,630,144	2,630,144	1,952,796	4,692,182	863
4	2017	111,427					2,682,747	2,682,747	1,952,796	4,746,970	873
5	2018	113,655					2,736,402	2,736,402	1,952,796	4,802,853	883
6	2019	115,928					2,791,130	2,791,130	1,952,796	4,859,854	893
7	2020	118,247					2,846,953	2,846,953	1,952,796	4,917,985	904
8	2021	120,612					2,903,892	2,903,892	1,952,796	4,977,289	915
9	2022	123,024					2,961,970	2,961,970	1,952,796	5,037,769	926
10	2023	125,485					3,021,209	3,021,209	1,952,796	5,099,489	937
11	2024	127,994					3,081,633	3,081,633	1,952,796	5,162,423	949
12	2025	130,554					3,143,266	3,143,266	1,952,796	5,226,616	961
13	2026	133,165					3,206,131	3,206,131	1,952,796	5,292,092	973
14	2027	135,829					3,270,254	3,270,254	1,952,796	5,358,878	985
15	2028	138,545					3,335,659	3,335,659	1,952,796	5,427,000	998
16	2029	141,316					3,402,372	3,402,372	1,952,796	5,496,484	1,010
17	2030	144,142					3,470,419	3,470,419	1,952,796	5,567,358	1,023
18	2031	147,025					3,539,828	3,539,828	1,952,796	5,639,649	1,037
19	2032	149,966					3,610,624	3,610,624	1,952,796	5,713,396	1,050
20	2033	152,965					3,682,837	3,682,837	1,952,796	5,788,598	1,064
Present Worth (% of PW)		1,282,875	2.4%	0.0%	0.0%	0.0%	30,886,856	30,886,856	20,528,122	52,637,853	100.0%

Jim Bridger Unit 1												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton NOx Removed)	
0	2013											
1	2014	307,500	-	1,005,811	594,000	-	208,926	1,214,737	2,104,916	3,627,153	613	
2	2015	313,650	-	1,025,927	605,860	-	213,105	1,239,032	2,104,916	3,657,598	619	
3	2016	319,923	-	1,046,446	617,998	-	217,387	1,263,812	2,104,916	3,688,651	624	
4	2017	326,321	-	1,067,375	630,358	-	221,714	1,289,088	2,104,916	3,720,326	629	
5	2018	332,848	-	1,088,722	642,965	-	226,148	1,314,870	2,104,916	3,752,634	635	
6	2019	339,505	-	1,110,496	655,824	-	230,671	1,341,168	2,104,916	3,785,589	640	
7	2020	346,295	-	1,132,706	669,940	-	235,295	1,367,991	2,104,916	3,819,202	646	
8	2021	353,221	-	1,155,381	685,266	-	239,980	1,395,351	2,104,916	3,853,488	652	
9	2022	360,285	-	1,178,468	700,899	-	244,700	1,423,258	2,104,916	3,888,459	658	
10	2023	367,491	-	1,202,037	716,844	-	249,686	1,451,723	2,104,916	3,924,130	664	
11	2024	374,841	-	1,226,078	733,083	-	254,980	1,480,757	2,104,916	3,960,514	670	
12	2025	382,338	-	1,250,598	750,720	-	260,593	1,510,373	2,104,916	3,997,626	676	
13	2026	389,984	-	1,275,614	768,770	-	266,428	1,540,580	2,104,916	4,035,481	683	
14	2027	397,784	-	1,301,124	787,140	-	272,573	1,571,392	2,104,916	4,074,092	689	
15	2028	405,740	-	1,327,146	805,940	-	278,917	1,602,819	2,104,916	4,113,475	696	
16	2029	413,955	-	1,353,689	825,187	-	285,461	1,634,876	2,104,916	4,153,646	703	
17	2030	422,132	-	1,380,763	844,980	-	292,207	1,667,657	2,104,916	4,194,621	709	
18	2031	430,374	-	1,408,378	865,326	-	299,154	1,701,172	2,104,916	4,236,415	717	
19	2032	439,186	-	1,436,946	886,346	-	306,388	1,735,560	2,104,916	4,279,049	724	
20	2033	447,959	-	1,465,276	908,065	-	314,009	1,770,569	2,104,916	4,322,528	731	
Present Worth		3,755,390	0.0%	12,288,849	7,257,405	0.0%	2,532,627	14,891,477	22,127,239	40,725,705	344	
[% of PW]		9.2%	0.0%	30.2%	4.3%	0.0%	6.3%	35.4%	54.3%	100.0%		


Jim Bridger Unit 1												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton NOx Removed)	
0	2013											
1	2014	473,000	-	912,848	594,000	-	1,281,005	2,797,853	12,326,235	15,899,088	1,736	
2	2015	484,500	-	931,105	605,860	-	1,316,825	2,853,810	12,326,235	15,664,545	1,743	
3	2016	494,180	-	949,727	617,998	-	1,343,162	2,910,886	12,326,235	15,731,311	1,750	
4	2017	504,074	-	968,722	630,358	-	1,370,025	2,969,104	12,326,235	15,795,413	1,758	
5	2018	514,155	-	988,096	642,965	-	1,397,425	3,028,488	12,326,235	15,868,876	1,766	
6	2019	524,438	-	1,007,858	655,824	-	1,425,374	3,089,056	12,326,235	15,939,728	1,774	
7	2020	534,927	-	1,028,015	669,940	-	1,453,881	3,150,837	12,326,235	16,011,989	1,782	
8	2021	545,626	-	1,048,575	685,266	-	1,482,959	3,219,654	12,326,235	16,085,714	1,790	
9	2022	556,538	-	1,069,547	700,899	-	1,512,618	3,278,131	12,326,235	16,160,904	1,798	
10	2023	567,669	-	1,090,938	716,844	-	1,542,870	3,343,693	12,326,235	16,237,597	1,807	
11	2024	579,022	-	1,112,757	733,083	-	1,573,728	3,410,587	12,326,235	16,315,824	1,815	
12	2025	590,603	-	1,135,012	750,720	-	1,605,202	3,478,779	12,326,235	16,395,616	1,824	
13	2026	602,415	-	1,157,712	768,770	-	1,637,306	3,546,354	12,326,235	16,477,004	1,833	
14	2027	614,463	-	1,180,865	787,140	-	1,670,053	3,619,321	12,326,235	16,560,019	1,843	
15	2028	626,752	-	1,204,484	805,940	-	1,703,454	3,691,708	12,326,235	16,644,695	1,852	
16	2029	639,287	-	1,228,573	825,187	-	1,737,523	3,765,542	12,326,235	16,731,054	1,862	
17	2030	652,073	-	1,253,145	844,980	-	1,772,273	3,840,853	12,326,235	16,819,161	1,871	
18	2031	665,115	-	1,278,208	865,326	-	1,807,719	3,917,670	12,326,235	16,909,019	1,881	
19	2032	678,417	-	1,303,772	886,346	-	1,843,873	3,995,023	12,326,235	17,000,675	1,892	
20	2033	691,985	-	1,329,847	908,065	-	1,880,751	4,075,944	12,326,235	17,094,164	1,902	
Present Worth		5,803,480	0.0%	11,153,043	7,257,405	0.0%	15,773,310	34,183,758	128,575,485	169,562,733	943	
[% of PW]		3.4%	0.0%	6.6%	4.3%	0.0%	9.3%	20.2%	76.4%	100.0%		

Jim Bridger Unit 1												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton SO2 Removed)	
0	2013											
1	2014	42,583	30,503	533,206		442,958	208,928	1,215,593	1,238,652	2,484,828	632	
2	2015	43,435	31,113	543,670		451,618	197,105	1,289,905	1,236,652	2,516,557	636	
3	2016	44,303	31,735	554,147		460,654	217,357	1,286,703	1,236,652	2,518,355	645	
4	2017	45,188	32,370	565,942		470,071	228,174	1,288,987	1,236,652	2,520,639	651	
5	2018	46,083	33,017	577,159		479,472	228,148	1,315,197	1,236,652	2,551,849	658	
6	2019	47,015	33,678	588,702		489,062	230,671	1,342,113	1,236,652	2,625,760	655	
7	2020	47,965	34,351	600,476		498,943	235,285	1,368,565	1,236,652	2,605,217	672	
8	2021	48,914	35,038	612,486		508,820	239,980	1,395,384	1,236,652	2,631,036	679	
9	2022	49,883	35,739	624,735		518,996	244,780	1,424,261	1,236,652	2,660,913	685	
10	2023	50,880	36,454	637,230		529,376	249,688	1,452,748	1,236,652	2,710,400	694	
11	2024	51,908	37,183	649,975		539,964	254,660	1,481,001	1,236,652	2,770,361	701	
12	2025	52,946	37,928	662,874		550,763	259,773	1,511,166	1,236,652	2,801,036	709	
13	2026	54,005	38,685	676,234		561,778	264,968	1,541,666	1,236,652	2,832,323	717	
14	2027	55,085	39,459	689,758		573,014	270,268	1,572,489	1,236,652	2,864,237	725	
15	2028	56,187	40,248	703,554		584,474	275,673	1,603,949	1,236,652	2,929,961	733	
16	2029	57,311	41,053	717,625		596,164	281,167	1,635,028	1,236,652	2,963,688	750	
17	2030	58,457	41,874	731,977		608,087	286,811	1,665,749	1,236,652	2,999,402	758	
18	2031	59,626	42,711	746,617		620,248	292,547	1,702,123	1,236,652	3,033,657	768	
19	2032	60,819	43,566	761,549		632,654	298,388	1,735,166	1,236,652	3,069,577	777	
20	2033	62,035	44,437	776,780		645,307	304,366	1,770,869	1,236,652	3,109,521	787	
Present Worth (% of FW)		520,271	372,679	6,514,628		5,412,000	2,592,627	14,851,955	12,999,900	28,372,107	359	
		1.8%	1.3%	23.0%	0.0%	19.1%	9.0%	52.3%	45.3%	100.0%		


Flue Gas Conditioning												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton PM Removed)	
0	2013											
1	2014	10,000		145,854			19,710	165,564		175,564	495	
2	2015	10,200		148,771			20,104	168,875		179,075	505	
3	2016	10,404		151,747			20,506	172,253		182,657	515	
4	2017	10,612		154,781			20,916	175,698		186,310	525	
5	2018	10,824		157,877			21,335	179,212		190,036	536	
6	2019	11,041		161,035			21,761	182,795		193,837	546	
7	2020	11,262		164,255			22,197	186,452		197,714	557	
8	2021	11,487		167,540			22,641	190,191		201,668	568	
9	2022	11,717		170,891			23,093	193,985		205,701	580	
10	2023	11,951		174,308			23,555	197,864		209,815	591	
11	2024	12,190		177,795			24,028	201,822		214,012	603	
12	2025	12,434		181,351			24,507	205,858		218,292	615	
13	2026	12,682		184,978			24,997	209,975		222,658	628	
14	2027	12,936		188,678			25,497	214,175		227,111	640	
15	2028	13,195		192,451			26,007	218,458		231,653	653	
16	2029	13,459		196,300			26,527	222,827		236,286	666	
17	2030	13,728		200,226			27,058	227,284		241,012	679	
18	2031	14,002		204,231			27,599	231,830		245,832	693	
19	2032	14,282		208,315			28,151	236,488		250,749	707	
20	2033	14,568		212,482			28,714	241,196		255,764	721	
Present Worth (% of FW)		122,176		1,762,023			240,814	2,022,837		2,145,015	302	
		5.7%	0.0%	63.1%	0.0%	0.0%	11.2%	64.3%	0.0%	100.0%		

Jim Bridger Unit 1		Fabric Filter									
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst/FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton PM Removed)
0	2013										
1	2014	127,749	-	-	300,040	-	1,395,944	1,635,984	4,602,887	6,365,619	8,973
2	2015	130,304	-	-	306,041	-	1,392,663	1,668,703	4,602,887	6,401,894	9,023
3	2016	132,910	-	-	312,162	-	1,399,916	1,702,078	4,602,887	6,437,874	9,074
4	2017	135,568	-	-	318,405	-	1,417,714	1,738,119	4,602,887	6,474,573	9,125
5	2018	138,279	-	-	324,773	-	1,446,089	1,770,841	4,602,887	6,512,007	9,178
6	2019	141,045	-	-	331,268	-	1,474,990	1,806,259	4,602,887	6,550,190	9,232
7	2020	143,866	-	-	337,894	-	1,504,490	1,842,383	4,602,887	6,588,196	9,287
8	2021	146,743	-	-	344,652	-	1,534,579	1,879,231	4,602,887	6,628,361	9,343
9	2022	149,678	-	-	351,545	-	1,565,271	1,916,916	4,602,887	6,669,390	9,400
10	2023	152,671	-	-	358,576	-	1,596,577	1,955,152	4,602,887	6,710,710	9,458
11	2024	155,725	-	-	365,747	-	1,628,508	1,994,255	4,602,887	6,752,368	9,518
12	2025	158,839	-	-	373,062	-	1,661,078	2,034,140	4,602,887	6,795,368	9,578
13	2026	162,016	-	-	380,523	-	1,694,300	2,074,823	4,602,887	6,838,726	9,640
14	2027	165,256	-	-	388,134	-	1,728,186	2,116,319	4,602,887	6,884,462	9,703
15	2028	168,562	-	-	395,898	-	1,762,749	2,158,648	4,602,887	6,930,094	9,767
16	2029	171,933	-	-	403,814	-	1,798,004	2,201,819	4,602,887	6,976,698	9,833
17	2030	175,371	-	-	411,881	-	1,833,865	2,245,855	4,602,887	7,024,113	9,900
18	2031	178,879	-	-	420,128	-	1,870,644	2,290,772	4,602,887	7,072,538	9,968
19	2032	182,456	-	-	428,531	-	1,908,057	2,336,588	4,602,887	7,121,931	10,038
20	2033	186,106	-	-	437,102	-	1,946,218	2,383,319	4,602,887	7,172,312	10,109
Present Worth (% of PW)		1,560,813	-	-	3,665,845	-	16,322,365	19,992,210	48,386,333	69,535,356	4,928
		2.2%	0.0%	0.0%	5.2%	0.0%	23.3%	28.6%	69.2%	100.0%	

First Year Cost for Air Pollution Control Options



Present Worth Cost for Air Pollution Control Options



APPENDIX B

2006 Wyoming BART Protocol

BART Air Modeling Protocol
Individual Source Visibility Assessments
for BART Control Analyses

September, 2006

State of Wyoming
Department of Environmental Quality
Air Quality Division
Cheyenne, WY 82002

Table of Contents

1.0 INTRODUCTION 3
2.0 OVERVIEW 4
3.0 EMISSIONS DATA FOR MODELING 7
 3.1 Baseline Modeling 7
 3.2 Post-Control Modeling..... 8
4.0 METEOROLOGICAL DATA..... 9
5.0 CALPUFF MODEL APPLICATION..... 12
6.0 POST PROCESSING 15
7.0 REPORTING..... 19

1.0 INTRODUCTION

The U.S. EPA has issued final amendments to the Regional Haze Regulations, along with Guidelines for Best Available Retrofit Technology (BART) Determinations.⁽¹⁾ The guidelines address the methodology for determining which facilities must apply BART (sources subject-to-BART) and the evaluation of control options.

The State of Wyoming used air quality modeling in accordance with the EPA Guidelines to determine the Wyoming sources which are subject-to-BART. This Protocol defines the specific methodology to be used by those sources for determining the improvement in visibility to be achieved by BART controls.

The methodology presented in this Protocol is consistent with EPA guidance and the Air Quality Division (AQD) determination of subject-to-BART sources. It is intended that all Wyoming sources that must conduct BART analyses will use this Protocol for their evaluation of control technology visibility improvement. Any deviations from the procedures described herein must be approved by the Division prior to implementation.

⁽¹⁾ 40 CFR Part 51: Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations; Final Rule. 70 Federal Register, 39103-39172, July 6, 2005.

2.0 OVERVIEW

Wyoming AQD determined that eight facilities (sources) in the state are subject-to-BART. The sources are listed in Table 1. Division modeling indicated that each of these sources causes or contributes to visibility impairment in one or more Class I areas. Each source must conduct a BART analysis to define Best Available Retrofit Technology (BART) applicable to that source, and quantify the improvement in Class I visibility associated with BART controls. This Protocol sets out the procedures for quantifying visibility improvement. Other aspects of the full BART analysis are not addressed here.

There are many Class I areas within and surrounding Wyoming (See Figure 1). On the basis of distance from subject-to-BART sources, topography, meteorology, and prior modeling, the AQD has determined that only five Class I areas need be addressed in BART individual source analyses. These are Badlands and Wind Cave National Parks in South Dakota, Mt. Zirkel Wilderness Area in Colorado, and Bridger and Fitzpatrick Wilderness Areas in Wyoming. Sources in eastern Wyoming have been shown to have greatest visibility impacts at the two South Dakota Class I areas, and western Wyoming sources have maximum impacts at Bridger and Fitzpatrick Wilderness Areas, and Mt. Zirkel. Visibility improvement at these highest impact areas will provide the best measure of the effectiveness of BART controls.

Each facility should carry out modeling with the CALPUFF modeling system for the Class I areas specified in Table 2. The AQD will provide meteorological input for CALMET for the years 2001, 2002, and 2003. The model domain covered by the AQD meteorological data is centered in southwest Wyoming, and extends roughly from Twin Falls, ID in the west to the Missouri River in the east, and from Denver in the south to Helena, MT in the north. The domain is shown, along with Class I areas, in Figure 1.

Sources may wish to utilize a smaller domain for CALPUFF modeling. Smaller domains are acceptable if they provide adequate additional area beyond the specific source and Class I areas being addressed. Figure 1 includes a "southwest Wyoming" domain which represents the minimum acceptable area for sources impacting the Bridger and Fitzpatrick Wilderness Areas, and the Mt. Zirkel Wilderness Area, and a "northeast Wyoming" domain as a minimum area for Badlands and Wind Cave National Parks modeling.

The CALPUFF model should be used with each of the three years of meteorological data to calculate visibility impacts for a baseline (existing emissions) case, and for cases reflecting BART controls. The control scenarios are to include individual scenarios for proposed BART controls for each pollutant (SO₂, NO_x, and particulate matter), and a combined scenario representing application of all proposed BART controls. If desired, additional modeling may be performed for controls that are not selected as BART. This might be done, for example, to provide data useful in identifying the control technologies that represent BART. However, visibility modeling is required only for the proposed BART controls.

Table 1. Wyoming Sources Subject-to-BART

Basin Electric	Laramie River Power Plant	Boilers #1,2,3
FMC Corporation	Granger Soda Ash Plant	Boilers #1,2
FMC Corporation	Green River Sodium Plant	Three boilers
General Chemical Co.	Green River Soda Ash	Two boilers
PacifiCorp	Dave Johnson Power Plant	Boilers #3,4
PacifiCorp	Jim Bridger Power Plant	Boilers #1-4
PacifiCorp	Naughton Power Plant	Boilers #1,2,3
PacifiCorp	Wyodak Power Plant	Boiler

Results of visibility modeling will be presented as a comparison between baseline impacts and those calculated for the BART control scenarios. Quantitative measures of impact will be the 98th percentile deciview change (Δdv) relative to the 20% best days natural background, and the number of days with deciview change exceeding 0.5 (EPA ~~Regional Haze Regulations and Guidelines for Best Available Retrofit Technology~~ (BART) Determinations, 70 FR 39103). Results should be presented for each year.

Table 2. Source-Specific Class I Areas to be Addressed

Source	Class I Areas to be Evaluated
Basin Electric Laramie River	Wind Cave NP, Badlands NP
FMC Corporation Granger Soda Ash	Bridger WA, Fitzpatrick WA
FMC Corporation Sodium Products	Bridger WA, Fitzpatrick WA
General Chemical Green River Soda Ash	Bridger WA, Fitzpatrick WA
Pacificorp Dave Johnston	Wind Cave NP, Badlands NP
Pacificorp Jim Bridger	Bridger WA, Fitzpatrick WA, Mt. Zirkel WA
Pacificorp Naughton Plant	Bridger WA, Fitzpatrick WA
Pacificorp Wyodak	Wind Cave NP, Badlands NP

3.0 EMISSIONS DATA FOR MODELING

CALPUFF model input requires source (stack) – specific emission rates for each pollutant, and stack parameters (height, diameter, exit gas temperature, and exit gas velocity). Per EPA BART guidance, these parameters must be representative of maximum actual 24-hour average emitting conditions for baseline (existing) operation, and maximum proposed 24-hour average emissions for future (BART) operations.

3.1 Baseline Modeling

Sources are required to utilize representative baseline emission conditions if data are available; baseline emissions must be documented. Possible sources of emission data are stack tests, CEM data, fuel consumption data, etc. Remember that emissions should represent maximum 24-hour rates. EPA BART guidance states that you should “Use the 24-hour average actual emission rate from the highest emitting day of the meteorological period modeled (for the pre-control scenario).” Thus, baseline conditions should reference data from 2001 through 2003 (or 2004).

As a minimum, modeled emissions must include:

SO ₂	sulfur dioxide
NO _x	oxides of nitrogen
PM _{2.5}	particles with diameter less than 2.5µm
PM _{10-2.5}	particles with diameters greater than 2.5µm but less than or equal to 10 µm

If the fraction of PM₁₀ in the PM_{2.5} (fine) and PM_{10-2.5} (coarse) categories cannot be determined all particulate matter should be assumed to be PM_{2.5}.

In addition, direct emissions of sulfate (SO₄) should be included where possible. Sulfate can be emitted as sulfuric acid (H₂SO₄), sulfur trioxide (SO₃), or as sulfate compounds; emissions should be quantified as the equivalent mass of SO₄.

When test or engineering data are not available to specify SO₄ emissions or the relative fractions of fine and coarse particles, use can be made of speciation profiles available from Federal Land Managers at the website <http://ww2.nature.nps.gov/air/permits/ect/index.cfm>. Profiles are available for a number of source type and control technology combinations. The FLM speciation factors are acceptable if data are available for the appropriate source type.

Emissions of VOC (volatile organic compounds), condensable organics measured in stack tests, and elemental carbon components of PM₁₀ do not need to be included for BART modeling. The only other pollutant noted in EPA BART guidance is ammonia (NH₃). Though ammonia is not believed to be a significant contributor to visibility

impairment in most cases in Wyoming, it could be important for sources with significant ammonia emissions – for example from some NO_x control systems. Sources that are expected to emit ammonia (in pre-or post-control configurations) should include ammonia emissions in their model input.

If quantitative baseline emissions data are unavailable and sources believe that the maximum 24-hour emission rates estimated by the Division (presented in the Subject-to-BART final report) are representative of baseline conditions for their facility, they may be used for baseline modeling. However, emissions of sulfate and ammonia (if applicable) should be included based on the best available test information or speciation factors from current literature.

3.2 Post-Control Modeling

All pollutants described above should be included for each post-control scenario. Post-control emissions (maximum 24-hour average) will generally be the baseline emissions multiplied by a control factor appropriate to the BART control. However, some proposed controls may simply increase the efficiency of existing controls; others may result in an increase in emissions of one pollutant while controlling another. These factors must all be considered in defining emission rates for post-control modeling. Any changes in stack parameters resulting from control application must also be included.

The required visibility assessment will include the effect of each proposed BART control. For example, if a source proposes to add a scrubber for SO₂ control, low NO_x burners for NO_x control, and a baghouse for particulate control, four sets of visibility results should be developed:

- Use of SO₂ control alone
- Use of NO_x control alone
- Use of particulate control alone
- Use of proposed combination of all three controls

All pollutants should be modeled in each CALPUFF model run, but the modeled emissions should reflect only the specific controls or combination of controls addressed in that run.

Additional modeling could be necessary in situations where a facility is comprised of more than one subject-to-BART source, and different BART controls are applicable to different sources. Excessive modeling to address multiple control combinations is not necessary; however, visibility modeling should quantify the effect of BART controls on all affected sources for each pollutant, and of all facility BART controls combined.

4.0 METEOROLOGICAL DATA

Wyoming AQD will provide MM5 meteorological data fields for years 2001, 2002, and 2003 that can be utilized as input to CALMET. The MM5 output will have 12 kilometer resolution and cover the full domain shown in Figure 1.

Mesoscale meteorological data (MM5) were developed and evaluated as part of the AQD's southwest Wyoming NO₂ increment analysis. Three years of MM5 data at 36 km resolution were used to initialize 12 km MM5 simulations. The 12km MM5 modeling used identical physics options to the original 36 km runs. CALMM5 was then used as a preprocessor to produce CALMET - ready MM5 data input files. Quality assurance was performed by comparing the original MM5 output on the 36km national RPO grid to the 12 km MM5 output and observations.

The CALMET model (version 5.53a, level 040716) should be used to prepare meteorological input for CALPUFF. The user may select a domain smaller than the MM5 domain for CALMET and CALPUFF modeling if desired. Figure 1 shows minimum domain areas for modeling of western and eastern Wyoming BART sources. Four kilometer resolution should be specified for CALMET output.

CALMET processing should use the AQD MM5 data, and appropriate surface, upper air, and precipitation data. Figure 2 shows the locations of surface and upper air stations within the MM5 model domain. The MM5 data are used as the initial guess wind field; this wind field is then adjusted by CALMET for terrain and land use to generate a step 1 wind field, and refined using surface and upper air data to create the final step 2 wind field.

Surface, upper air, and precipitation data can be obtained from the National Climatic Data Center. Land use and terrain data are available from the U.S. Geological Survey. Data can be formatted for use in CALMET with standard conversion and processing programs available with the CALMET/CALPUFF software.

Table 3 provides a listing of applicable CALMET input variables for BART meteorological processing. The table includes inputs that are specific to Wyoming BART modeling. Inputs not shown in Table 3 are not relevant to the present application, are dependent on the specific model domain of the user, use model default values, or are obvious from the context.

Table 3. CALMET Control File Inputs

Variable	Description	Value
Input Group 1		
IBYR	Year	2001
		2002
		2003
IBTZ	Base time zone	7
IRTYPE	Run type	1
LCALGRD	Compute data fields for CALGRID	T
Input Group 2		
PMAP	Map projection	LCC
DGRIDKM	Grid spacing (km)	4
NZ	Number of layers	10
ZFACE	Cell face heights (m)	0
		20
		40
		100
		140
		320
		580
		1020
		1480
		2220
		3500
Input Group 4		
NOOBS	No observation Mode	0
Input Group 5		
IWFCOD	Model selection variable	1
IFRADJ	Froude number adjustment	1
IKINE	Kinematic effects	0
IOBR	Use O'Brien procedure	0
ISLOPE	Slope flow effects	1
IEXTRP	Extrapolate surface wind observations	-4
ICALM	Extrapolate calm surface winds	0
BIAS	Biases for weights of surface and upper air stations	All 0
RMIN2	Minimum distance for extrapolation	-1
I PROG	Use gridded prognostic model output	14
ISTEPPG	Time Step (hours)	1
LVARY	Use varying radius of influence	F

Table 3. CALMET Control File Inputs (continued)

Variable	Description	Value
RMAX 1	Maximum radius of influence (km)	30
RMAX 2	Maximum radius of influence (km)	50
RMIN	Minimum radius of influence (km)	0.1
TERRAD	Radius of influence for terrain (km)	15
R1	Relative weighting of first guess wind field and observations (km)	5
R2	Relative weighting aloft (km)	25
IDIOPT 1	Surface temperature	0
IDIOPT 2	Upper air lapse rate	0
ZUPT	Lapse rate depth (m)	200
IDIOPT 3	Average wind components	0
IUPWND	Upper air station	-1
ZUPWND (1)	Bottom and top of layer for domain	1,1000
ZUPWND (2)	scale winds (m)	1,1000
IDIOPT4	Surface wind components	0
IDIOPT5	Upper air wind components	0
Input Group 6		
IAVEZI	Spatial averaging	1
MNMDAV	Max search radius	1
HAFANG	Half angle for averaging (deg)	30
ILEVZI	Layer of winds in averaging	1
ZIMAX	Maximum overland mixing height (m)	3500
ITPROG	3D temperature source	1
IRAD	Interpolation type	1
TRADKM	Radius of influence -- temperature (km)	500
NUMTS	Maximum number of Stations	5
IAVET	Spatial averaging of temperatures	1
NFLAGP	Precipitation interpolation	2

5.0 CALPUFF MODEL APPLICATION

The CALPUFF model (version 5.711a, level 040716) will be used to calculate pollutant concentrations at receptors in each Class I area. Application of CALPUFF should, in general, follow the guidance presented in the Interagency Workgroup on Air Quality Modeling (IWAQM) Phase 2 report (EPA - 454/R98-019) and the EPA Regional Haze Regulations and Guidelines for BART Determinations (70 FR 39103).

Appropriate CALPUFF control file inputs are in Table 4. Note should be taken of the basis for several of the recommended CALPUFF inputs.

- Building downwash effects need not be included. Because of the transport distances involved and the fact that most sources have tall stacks, building downwash is unlikely to have a significant effect on model-predicted concentrations
- Puff splitting is not required. The additional computation time necessary for puff splitting is not justified for purposes of BART analyses.
- Hourly ozone files should be used to define background ozone concentration. Data are available from the following sites within the model domain.
 - Rocky Mountain NP, CO
 - Craters of the Moon NP, ID
 - AIRS - Highland UT
 - Mountain Thunder, WY
 - Yellowstone NP, WY
 - Centennial, WY
 - Pinedale, WY

The background ozone concentration shown in Table 4 is used only when hourly data are missing.

- A constant background ammonia concentration of 2.0 ppb is specified. This value is based upon monitoring data from nearby states and IWAQM guidance. Experience suggests that 2.0 ppb is conservative in that it is unlikely to significantly limit nitrate formation in the model computations.
- MBSOPUFF II chemical transformation rates should be used.
- The species to be modeled should be the seven identified in CALPUFF: SO₂, SO₄, NO_x, HNO₃, NO₃, PM_{2.5}, and PM_{10-2.5}. If ammonia (NH₃) is emitted it should be added to the species list. In most cases, all pollutants modeled will also be emitted, except for HNO₃ and NO₃.

Concentration calculations should be made for receptors covering the areas of the Class I areas being addressed. Receptors in each Class I area will be those designated by the Federal Land Managers and available from the National Park Service website.

Table 4. CALPUFF Control File Inputs

Variable	Description	Value
	Input Group 1	
METRUN	Control parameter for running all periods in met file	1
IBYR	Starting year	2001 2002 2003
XBTZ	Base time zone	7
NSPEC	Number of chemical species modeled	7 (or 8)
NSE	Number of species emitted	5 (or 6)
METFM	Meteorological data format	1
	Input Group 2	
MGAUSS	Vertical distribution in near field	1
MCTADJ	Terrain adjustment method	3
MCTSG	Subgrid scale complex terrain	0
MSLUG	Elongated puffs	0
MTRANS	Transitional plume rise	1
MTIP	Stack tip downwash	1
MSHEAR	Vertical wind shear	0
MSPLIT	Puff splitting allowed?	0
MCHEM	Chemical mechanism	1
MAQCHEM	Aqueous phase transformation	0
MWET	Wet removal	1
MDRY	Dry deposition	1
MDISP	Dispersion Coefficients	3
MROUGH	Adjust sigma for roughness	0
MPARTL	Partial plume penetration of inversions	1
MPDF	PDF for convective conditions	0
	Input Group 4	
PMAP	Map projection	LCC
DGRIDKM	Grid spacing	4

Table 4. CALPUFF Control File Inputs (continued)

ZFACE	Cell face heights (m)	0
		20
		40
		100
		140
		320
		580
		1020
		1480
		2220
		3500
	Input Group 6	
NHILL	Number of terrain features	0
	Input Group 7	
Dry Gas Depo	Chemical parameters for dry gas deposition	Defaults
	Input Group 8	
Dry Part. Depo	Size parameters for dry particle deposition SO ₄ , NO ₃ , PM25 PM10	Defaults 6.5, 1.0
	Input Group 11	
MOZ	Ozone Input option	1
BCKO3	Background ozone – all months (ppb)	44.0
BCKNH3	Background ammonia – all months (ppb)	2.0
	Input Group 12	
XMAXZI	Maximum mixing height (m)	3500
XMINZI	Minimum mixing height (m)	50

6.0 POST PROCESSING

Visibility impacts are calculated from the CALPUFF concentration results using CALPOST. CALPOST version 5.51, level 030709 should be used; the output from CALPOST will provide the highest deciview impact on each day from all receptors within each Class I area modeled.

For some CALPUFF applications such as deposition calculations, the POSTUTIL program is used prior to CALPOST. POSTUTIL is also used to repartition total nitrate by accounting for ammonia limiting. The ammonia limiting calculation in POSTUTIL should not be applied for Wyoming BART modeling. If you believe that ammonia limiting is appropriate for a specific BART analysis, justification should be discussed with the Division prior to its used.

Visibility calculations by CALPOST for BART purposes use Method 6. This method requires input of monthly relative humidity factors, $f(RH)$, for each Class I area. The EPA guidance document provides appropriate data for each area. Table 5 lists monthly $f(RH)$ factors to use for the Wyoming, Colorado, and South Dakota areas to be addressed in BART modeling. The factors shown in Table 5 include averages for the adjacent Class I areas, and are within 0.2 units of the Guideline table values for the individual Class I areas.

Natural background conditions as a reference for determination of the delta-dv change due to a source should be representative of the 20% best natural visibility days. EPA BART guidance provides the 20% best days deciview values for each Class I area on an annual basis, but does not provide species concentration data for the 20% best background conditions. These concentrations are needed for input to CALPOST.

Annual species concentrations corresponding to the 20% best days were calculated for each Class I area to be addressed, by scaling back the annual average concentrations given in Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule (Table 2-1). A separate scaling factor was derived for each Class I area such that, when multiplied by the Guidance table annual concentrations, the 20% best days deciview value for that area would be calculated. The scaled aerosol concentrations were averaged for the Bridger and Fitzpatrick WAs, and for Wind Cave and Badlands NPs, because of their geographical proximity and similar annual background visibility. The 20% best days aerosol concentrations to be used for each month for Wyoming BART evaluations are listed in Table 6.

Table 7 is a list of inputs for CALPOST. These inputs should be used for all BART visibility calculations. Output from CALPOST should be configured to provide a ranked list of the highest delta-deciview values in each Class I area. The 98th percentile delta-deciview value and the number of values exceeding 0.5 can then be determined directly from the CALPOST output.

Table 5. Monthly $f(RH)$ Factors for Class I Areas

Month	Wind Cave NP Badlands NP	Bridger WA Fitzpatrick WA	Mt. Zirkel WA
January	2.65	2.50	2.20
February	2.65	2.30	2.20
March	2.65	2.30	2.00
April	2.55	2.10	2.10
May	2.70	2.10	2.20
June	2.60	1.80	1.80
July	2.30	1.50	1.70
August	2.30	1.50	1.80
September	2.20	1.80	2.00
October	2.25	2.00	1.90
November	2.75	2.50	2.10
December	2.65	2.40	2.10

Table 6. Natural Background Concentrations of Aerosol Components for 20% Best Days for BART Analyses ($\mu\text{g}/\text{m}^3$)

Aerosol Component	Wind Cave NP Badlands NP	Fitzpatrick WA Bridger WA	Mt. Zirkel WA
Ammonium Sulfate	.047	.045	.046
Ammonium Nitrate	.040	.038	.038
Organic Carbon	.186	.178	.179
Elemental Carbon	.008	.008	.008
Soil	.198	.189	.190
Coarse Mass	1.191	1.136	1.141

Table 7. CALPOST Control File Inputs

Variable	Description	Value
	Input Group 1	
ASPEC	Species to Process	VISIB
ILAYER	Layer/deposition code	1
A,B	Scaling factors	0,0
LBACK	Add background concentrations?	F
BTZONE	Base time zone	7
LVSO4	Species to be included in extinction	T
LVNO3		T
LVOC		F
LVPMC		T
LVPMF		T
LVEC		F
LVBK	Include background?	T
SPECPMC	Species name for particulates	PM10
SPECPMF		PM25
EEPMC	Extinction efficiencies	0.6
EEPMF		1.0
EEPMCBK		0.6
EESO4		3.0
EENO3		3.0
EEOC		4.0
EESOIL		1.0
EEEC		10.0
MVISBK	Visibility calculation method	6
RHFAC	Monthly RH adjustment factors	Table 5
BKSO4	Background concentrations	Table 6
BKNO3		Table 6
BKPMC		Table 6
BK OC		Table 6
BKSOIL		Table 6
BKEC		Table 6
BEXTRAY	Extinction due to Rayleigh scattering	10.0

7.0 REPORTING

A report on the BART visibility analysis should be submitted that clearly compares impacts for post-control emissions to those for baseline emissions. Data for baseline and BART scenarios should include both the 98th percentile values and the number of days with delta-deciview values exceeding 0.5. Results should be given for each model year.

Table 8 is an example of a recommended format for presentation of model input and model results. The example is for baseline conditions; similar tables should be provided for each control scenario (SO₂, NO_x, and PM₁₀) and for the combination of all BART controls. Your report tables need not follow the exact format shown in Table 8; but the same information should be provided in a concise and clear form. If additional scenarios were modeled or you wish to present supplemental information, they should be provided in an appendix or separate from the specified final results.

Table 8. Example Format for Presentation of Model Input and Results

Baseline Conditions Model Input Data												
Source (Unit) Description And ID	SO ₂ Emission Rate (lb/day)	NO _x Emission Rate (lb/day)	PM _{2.5} Emission Rate (lb/day)	PM _{10-2.5} Emission Rate (lb/day)	SO ₄ Emission Rate (lb/day)	NH ₃ Emission Rate (lb/day)	Location Easting (m)	Location Northing (m)	Stack Height (m)	Stack Diameter (m)	Exit Velocity (m/s)	Exit Gas Temp (deg K)
							UTM (m)	UTM (m)				

Baseline Visibility Modeling Results

Name of Facility	Class I Area	2001		2002		2003	
		98 th Percentile Value (dv)	No. of days exceeding 0.5 dv	98 th Percentile Value (dv)	No. of days exceeding 0.5 dv	98 th Percentile Value (dv)	No. of days exceeding 0.5 dv

Final Report

BART Analysis for Jim Bridger Unit 2



Prepared For:

PacifiCorp

1407 West North Temple
Salt Lake City, Utah 84116

October 2007

Prepared By:

CH2MHILL

215 South State Street, Suite 1000
Salt Lake City, Utah 84111

Final Report

BART Analysis for Jim Bridger Unit 2

Submitted to
PacifiCorp

October 2007

CH2MHILL

Executive Summary

Background

In response to the Regional Haze Rule and Best Available Retrofit Technology (BART) regulations and guidelines, CH2M HILL was requested to perform a BART analysis for PacifiCorp's Jim Bridger Unit 2 (hereafter referred to as Jim Bridger 2). A Best Available Retrofit Technology analysis has been conducted for the following criteria pollutants: oxides of nitrogen oxide (NO_x), sulfur dioxide (SO₂), and particulate matter less than 10 micrometers in aerodynamic diameter (PM₁₀). The Jim Bridger Station consists of four 530-megawatt (MW) units with a total generating capacity of 2,120 MW. Because the total generating capacity of the Jim Bridger Station exceeds 750 MW, presumptive BART limits apply to Jim Bridger 2, based on the United States Environmental Protection Agency's (EPA) guidelines. BART emissions limits must be achieved within 5 years after the State Implementation Plan (SIP) is approved by the EPA. A compliance date of 2014 was assumed for this analysis.

In completing the BART analysis, technology alternatives were investigated and potential reductions in NO_x, SO₂, and PM₁₀ emissions rates were identified. The following technology alternatives were investigated, listed below by pollutant:

- NO_x emission controls:
 - Low-NO_x burners (LNBS) with over-fire air (OFA)
 - LNBS with rotating opposed fire air (ROFA)
 - LNBS with selective non-catalytic reduction (SNCR) system
 - LNBS with selective catalytic reduction (SCR) system
- SO₂ emission controls:
 - Optimize current operation of existing wet sodium flue gas desulfurization (FGD) system
 - Upgrade wet sodium FGD system to achieve an SO₂ emission rate of 0.10 pound per million British thermal unit (pounds [lbs] per MMBtu)
 - New dry FGD system
- PM₁₀ emission controls:
 - Sulfur trioxide (SO₃) injection flue gas conditioning system on existing electrostatic precipitator (ESP)
 - Polishing fabric filter

BART Engineering Analysis

The specific steps in a BART engineering analysis are identified in the Code of Federal Regulations (CFR) at 40 CFR 51 Appendix Y, Section IV. The evaluation must include:

- The identification of available, technically feasible, retrofit control options
- Consideration of any pollution control equipment in use at the source (which affects the availability of options and their impacts)
- The costs of compliance with the control options
- The remaining useful life of the facility
- The energy and non-air quality environmental impacts of compliance
- The degree of visibility improvement that may reasonably be anticipated from the use of BART

The following steps are incorporated into the BART analysis:

- Step 1 – Identify All Available Retrofit Control Technologies
- Step 2 – Eliminate Technically Infeasible Options
 - The identification of available, technically feasible, retrofit control options
 - Consideration of any pollution control equipment in use at the source (which affects the applicability of options and their impacts)
- Step 3 – Evaluate Control Effectiveness of Remaining Control Technologies
- Step 4 – Evaluate Impacts and Document the Results
 - The costs of compliance with the control options
 - The remaining useful life of the facility
 - The energy and non-air quality environmental impacts of compliance
- Step 5 – Evaluate Visibility Impacts
 - The degree of visibility improvement that may reasonably be anticipated from the use of BART

Separate analyses have been conducted for NO_x, SO₂, and PM₁₀ emissions. All costs included in the BART analyses are in 2006 dollars, and costs have not been escalated to the assumed 2014 BART implementation date.

Coal Characteristics

The main source of coal burned at Jim Bridger 2 will be the Bridger Underground Mine. Secondary sources are the Bridger Surface Mine, the Bridger Highwall Mine, the Black Butte Mine, and the Leucite Hills Mine. These coals are ranked as sub-bituminous, but are closer in

characteristics to bituminous coal in many of the parameters influencing NO_x formation. These coals have higher nitrogen content than coals from the Powder River Basin (PRB), which represent the bulk of sub-bituminous coal use in the United States. This BART analysis has considered the higher nitrogen content and different combustion characteristics of PRB coals, as compared with those coals used at Jim Bridger 2, and has evaluated the effect of these qualities on NO_x formation and achievable emission rates.

Recommendations

CH2M HILL recommends installing the following control devices, which include LNBs with OFA, dry FGD system, and the existing ESP. This combination of control devices is identified as Scenario 1 throughout this report.

NO_x Emission Control

The BART presumptive NO_x limit assigned by EPA for tangentially fired boilers burning sub-bituminous coal is 0.15 lb per MMBtu. However, as documented in this analysis, the characteristics of the Jim Bridger 2 coals are more closely aligned with bituminous coals, with a presumptive BART NO_x limit of 0.28 lb per MMBtu.

CH2M HILL recommends the existing LNBs with OFA (LNB with an OFA) as BART for Jim Bridger 2, based on the projected significant reduction in NO_x emissions, reasonable control costs, and the advantages of no additional power requirements or non-air quality environmental impacts. NO_x reductions have been realized at Jim Bridger 2. CH2M HILL recommends that the unit be permitted at a rate of 0.26 lb per MMBtu.

SO₂ Emission Control

CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 2, based on the significant reduction in SO₂ emissions, reasonable control costs, and the advantages of minimal additional power requirements and minimal non-air quality environmental impacts. This upgrade approach will meet the BART presumptive SO₂ limit of 0.15 lb per MMBtu.

PM₁₀ Emission Control

CH2M HILL recommends finalizing the permitting of the flue gas conditioning (FGC) system to enhance the performance of the existing ESP as BART for Jim Bridger 2, based on the significant reduction in PM₁₀ emissions, reasonable control costs, and the advantages of minimal additional power requirements and no non-air quality environmental impacts.

Control Scenario 1

These BART selections, which include maintaining the existing low NO_x burners with OFA, upgrading the existing FGD system, and operating the existing electrostatic precipitator with an SO₂ FGC system, are identified as Scenario 1 throughout this report.

BART Modeling Analysis

CH2M HILL used the CALPUFF modeling system (Gaussian puff dispersion model) to assess the visibility impacts of emissions from Jim Bridger 2 at Class I areas. The Class I areas potentially affected are located more than 50 kilometers (km), but less than 300 km, from the Jim Bridger Plant.

The Class I areas include the following wilderness areas (WAs):

- Bridger WA
- Fitzpatrick WA
- Mt. Zirkel WA

Because Jim Bridger 2 will simultaneously control NO_x, SO₂, and PM₁₀ emissions, four post-control atmospheric dispersion modeling scenarios were developed to cover the range of effectiveness for combining the individual NO_x, SO₂ and PM₁₀ control technologies under evaluation. These modeling scenarios, and the controls assumed, are as follows:

- **Scenario 1:** Existing LNB with OFA, upgraded wet FGD system, and FGC for enhanced ESP performance. As indicated previously, this scenario represents CH2M HILL's preliminary BART recommendation.
- **Scenario 2:** Existing LNB with OFA, upgraded wet FGD system, and new polishing fabric filter.
- **Scenario 3:** Existing LNB with OFA and SCR, upgraded wet FGD system, and FGC for enhanced ESP performance.
- **Scenario 4:** Existing LNB with OFA and SCR, upgraded wet FGD system, and new polishing fabric filter.

Visibility improvements for all emission control scenarios were analyzed, and the results were compared utilizing a least-cost envelope, as outlined in the draft EPA 1990 *New Source Review Workshop Manual* (NSR Manual).

Least-cost Envelope Analysis

EPA has adopted the least-cost envelope analysis methodology as an accepted methodology for selecting the most reasonable, cost-effective controls. Incremental cost-effectiveness comparisons focus on annualized cost and emission reduction differences between dominant alternatives. The dominant set of control alternatives is determined by generating what is called the envelope of least-cost alternatives. This is a graphical plot of total annualized costs for a total emissions reductions for all control alternatives identified in the BART analysis.

To evaluate the impacts of the modeled control scenarios on the three Class I areas, the total annualized cost, cost per deciview (dV) reduction, and cost per reduction in number of days above 0.5 dV were analyzed. This report provides a comparison of the average incremental costs between relevant scenarios for the three Class I areas; the total annualized cost versus number of

days above 0.5 dV, and the total annualized cost versus 98th percentile delta-deciview (ΔdV) reduction.

Results of the least-cost envelope analysis validate the selection of Scenario 1, based on incremental cost and visibility improvements. Scenario 2 (LNB with OFA, upgraded wet FGD, and polishing fabric filter) is eliminated, because it is to the left of the curve formed by the dominant control alternative scenario, which indicates a scenario with lower improvement and/or higher costs. Scenario 3 (LNB with OFA and SCR, upgraded wet FGD, and FGC for enhanced ESP performance) is not selected due to very high incremental costs, based on cost per day of improvement and cost per dV reduction. While Scenario 4 (LNB with OFA and SCR, upgraded wet FGD, and polishing fabric filter) provides some potential visibility advantage over Scenario 1, the projected improvement is less than half a dV, and the projected costs are excessive. Therefore, Scenario 1 represents BART for Jim Bridger 2.

Just-Noticeable Differences in Atmospheric Haze

Studies have been conducted that demonstrate only dV differences of approximately 1.5 to 2.0 dV or more are perceptible by the human eye. Deciview changes of less than 1.5 cannot be distinguished by the average person. Therefore, the modeling analysis results indicate that only minimal, if any, observable visibility improvements at the Class I areas studied would be expected under any of the control scenarios. Thus, the results indicate that only minimal discernable visibility improvements may result, even though PacifiCorp will be spending many millions of dollars at this single unit, and over a billion dollars when considering its entire fleet of coal-fired power plants.

Contents

1.0	Introduction	1-1
2.0	Present Unit Operation.....	2-1
3.0	BART Engineering Analysis	3-1
3.1	Applicability.....	3-1
3.2	BART Process.....	3-1
3.2.1	BART NO _x Analysis.....	3-2
3.2.2	BART SO ₂ Analysis.....	3-14
3.2.3	BART PM ₁₀ Analysis.....	3-16
4.0	BART Modeling Analysis.....	4-1
4.1	Model Selection	4-1
4.2	CALMET Methodology.....	4-1
4.2.1	Dimensions of the Modeling Domain.....	4-1
4.2.2	CALMET Input Data	4-3
4.2.3	Validation of CALMET Wind Field.....	4-6
4.3	CALPUFF Modeling Approach.....	4-6
4.3.1	Background Ozone and Ammonia.....	4-6
4.3.2	Stack Parameters.....	4-6
4.3.3	Emission Rates.....	4-7
4.3.4	Post-control Scenarios.....	4-7
4.3.5	Modeling Process.....	4-8
4.3.6	Receptor Grids	4-8
4.4	CALPOST.....	4-10
4.5	Presentation of Modeling Results	4-11
4.5.1	Visibility Changes for Baseline vs. Preferred Scenario.....	4-11
5.0	Preliminary Assessment and Recommendations	5-1
5.1	Least-cost Envelope Analysis	5-1
5.1.1	Analysis Methodology	5-1
5.1.2	Analysis Results	5-8
5.2	Recommendations.....	5-8
5.2.1	NO _x Emission Control	5-8
5.2.2	SO ₂ Emission Control	5-8
5.2.3	PM ₁₀ Emission Control	5-8
5.3	Just-Noticeable Differences in Atmospheric Haze	5-9
6.0	References.....	6-1

Tables

2-1	Unit Operation and Study Assumptions
2-2	Coal Sources and Characteristics
3-1	Coal Characteristics Comparison
3-2	NO _x Control Technology Projected Emission Rates
3-3	NO _x Control Cost Comparison
3-4	SO ₂ Control Technology Emission Rates
3-5	SO ₂ Control Cost Comparison (Incremental to Existing Wet FGD System)
3-6	PM ₁₀ Control Technology Emission Rates
3-7	PM ₁₀ Control Cost Comparison
4-1	User-Specified CALMET Options
4-2	BART Model Input Data
4-3	Average Natural Levels of Aerosol Components
4-4	Costs and Visibility Modeling Results for Baseline vs. Post-control Scenarios at Class I Areas
5-1	Control Scenario Results for the Bridger Class I Wilderness Area
5-2	Control Scenario Results for the Fitzpatrick Class I Wilderness Area
5-3	Control Scenario Results for the Mt. Zirkel Class I Wilderness Area
5-4	Bridger Class I Wilderness Area Incremental Analysis Data
5-5	Fitzpatrick Class I Wilderness Area Incremental Analysis Data
5-6	Mt. Zirkel Class I Wilderness Area Incremental Analysis Data

Figures

3-1	Illustration of the Effect of Agglomeration on the Speed of Coal Combustion
3-2	Plot of Typical Nitrogen Content of Various Coals and Applicable Presumptive BART NO _x Limits
3-3	Plot of Typical Oxygen Content of Various Coals and Applicable Presumptive BART NO _x Limits
3-4	First Year Control Cost for NO _x Air Pollution Control Options
3-5	First Year Control Cost for PM Air Pollution Control Options
4-1	Jim Bridger Source-specific Class I Areas to be Addressed
4-2	Surface and Upper Air Station Used in the Jim Bridger BART Analysis
5-1	Least-cost Envelope Bridger Class I Wilderness Area Days Reduction
5-2	Least-cost Envelope Bridger Wilderness Area Class I Area 98 th Percentile Reduction
5-3	Least-cost Envelope Fitzpatrick Class I Wilderness Area Days Reduction
5-4	Least-cost Envelope Fitzpatrick Class I Wilderness Area 98 th Percentile Reduction
5-5	Least-cost Envelope Mt. Zirkel Class I Wilderness Area Days Reduction
5-6	Least-cost Envelope Mt. Zirkel Class I Wilderness Area 98 th Percentile Reduction

Appendices

A	Economic Analysis
B	2006 Wyoming BART Protocol

Acronyms and Abbreviations

°C	Degrees Celsius
°F	Degrees Fahrenheit
ASOS	Automated Surface Observing System
BACT	Best Available Control Technology
BART	Best Available Retrofit Technology
CALMET	Meteorological Data Preprocessing Program for CALPUFF
CALPOST	Post-processing Program for Calculating Visibility Impacts
CALPUFF	Gaussian Puff Dispersion Model
CFR	Code of Federal Regulations
CO	Carbon Monoxide
COHPAC	Compact Hybrid Particulate Collector
Δv	Delta Deciview, Change in Deciview
DCS	Distributed Control System
dV	Deciview
EIA	Energy Information Administration
EPA	United States Environmental Protection Agency
ESP	Electrostatic Precipitator
$f(RH)$	Relative Humidity Factors
FGC	Flue Gas Conditioning
FGD	Flue Gas Desulfurization
Fuel NO _x	Oxidation of Fuel-bound Nitrogen
hp	Horsepower
ID	Internal Diameter
km	Kilometer
kW	Kilowatts
kW-Hr	Kilowatt-hour
LAER	Lowest Achievable Emission Rate
lb	Pound(s)
LNB	Low-NO _x Burner
LOI	Loss on Ignition
MM5	Mesoscale Meteorological Model, Version 5
MMBtu	Million British Thermal Units

MW	Megawatt(s)
N ₂	Nitrogen
NO	Nitric Oxide
NO _x	Nitrogen Oxide
NP	National Park(s)
NSR Manual	<i>New Service Review Workshop Manual</i> (EPA, 1990)
NWS	National Weather Service
OFA	Over-fire Air
PM	Particulate Matter
PM ₁₀	Particulate Matter less than 10 Micrometers in Aerodynamic Diameter
PM _{2.5}	Particulate Matter less than 2.5 Micrometers in Aerodynamic Diameter
PRB	Powder River Basin
ROFA	Rotating Opposed Fire Air
S&L Study	Multi-pollutant Control Report dated October 2002
S&L	Sargent & Lundy
SCR	Selective Catalytic Reduction
SIP	State Implementation Plan
SNCR	Selective Non-catalytic Reduction System
SO ₂	Sulfur Dioxide
SO ₃	Sulfur Trioxide
TRC	TRC Companies, Inc.
USGS	U.S. Geological Survey
WA	Wilderness Area
WDEQ	Wyoming Department of Environmental Quality
WDEQ-AQD	Wyoming Department of Environmental Quality – Air Quality Division

1.0 Introduction

Best Available Retrofit Technology (BART) guidelines were established as a result of United States Environmental Protection Agency (EPA) regulations intended to reduce the occurrence of regional haze in national parks (NPs) and other Class I protected air quality areas in the United States (40 CFR Part 51). These guidelines provide guidance for states when determining which facilities must install additional controls, and the type of controls that must be used. Facilities eligible for BART installation were built between 1962 and 1977, and have the potential to emit more than 250 tons per year of visibility-impairing pollutants.

The Wyoming Department of Environmental Quality (WDEQ) BART regulations state that each source subject to BART must submit a BART application for a construction permit by December 15, 2006. PacifiCorp received an extension from the WDEQ to submit the BART report for Jim Bridger Unit 2 (hereafter referred to as Jim Bridger 2) by January 12, 2007. The BART report that was submitted to the WDEQ in January 2007 included a BART analysis, and a proposal and justification for BART at the source. This revised report, submitted in October 2007, incorporates editorial revisions and new model runs since the January 2007 version.

The State of Wyoming has identified those eligible in-state facilities that are required to reduce emissions under BART, and will set BART emissions limits for those facilities. This information will be included in the State of Wyoming State Implementation Plan (SIP), which the State has estimated will be formally submitted to the EPA by early 2008. The EPA BART guidelines also state that the BART emission limits must be fully implemented within 5 years of EPA's approval of the SIP.

Five elements related to BART address the issue of emissions for the identified facilities:

- Any existing pollution control technology in use at the source
- The cost of the controls
- The remaining useful life of the source
- The energy and non-air quality environmental impacts of compliance
- The degree of improvement in visibility that may reasonably be anticipated from the use of such technology

This report documents the BART analysis that was performed on Jim Bridger 2 by CH2M HILL for PacifiCorp. The analysis was performed for the pollutants nitrogen oxide (NO_x), sulfur dioxide (SO₂), and particulate matter less than 10 micrometers in aerodynamic diameter (PM₁₀), because they are the primary criteria pollutants that affect visibility.

Section 2 of this report provides a description of the present unit operation, including a discussion of coal sources and characteristics. The BART Engineering Analysis is provided in Section 3, by pollutant type. Section 4 provides the methodology and results of the BART Modeling Analysis, followed by recommendations in Section 5 and references in Section 6. Appendices provide more detail on the economic analysis and the 2006 Wyoming BART Protocol.

2.0 Present Unit Operation

The Jim Bridger Station consists of four units with a total generating capacity of 2,120 megawatts (MW). Jim Bridger 2 is a nominal 530-net-MW unit located approximately 35 miles northeast of Rock Springs, Wyoming. Unit 2 is equipped with a tangentially fired pulverized coal boiler. Low-NO_x burner (LNB) TFS 2000 LNBs with over-fire air (OFA) were installed in 2005. The unit was constructed with a Flakt wire frame electrostatic precipitator (ESP). The unit contains a Babcock & Wilcox wet sodium flue gas desulfurization (FGD) system with three absorber towers installed in 1986. An Emerson Ovation distributed control system (DCS) was installed in 2005.

Jim Bridger 2 was placed in service in 1975. Its current economic depreciation life is through 2040; however, this analysis is based on a 20-year life for BART control technologies. Assuming a BART implementation date of 2014, this will result in an approximate remaining useful life for Jim Bridger 2 of 20 years from the installation date of any new or modified BART-related equipment. This report does not attempt to quantify any additional life extension costs needed to allow the unit and these control devices at Jim Bridger 2 to operate until 2040.

Table 2-1 lists additional unit information and study assumptions for this analysis.

The BART presumptive NO_x limit for tangentially fired boilers burning sub-bituminous coal is 0.15 pound per British thermal unit (lb per MMBtu) and the BART presumptive NO_x limit for burning bituminous coal is 0.28 lb per MMBtu. The main sources of coal burned at Jim Bridger 2 are the Bridger Mine, and secondarily, the Black Butte Mine and Leucite Hills Mine. These coals are ranked as sub-bituminous, but are closer in characteristics to bituminous coal in many of the parameters influencing NO_x formation. These coals have higher nitrogen content than coals from the Powder River Basin (PRB), which represent the bulk of sub-bituminous coal used in the United States. This BART analysis has considered the higher nitrogen content and different combustion characteristics of PRB coals, as compared with those coals used at Jim Bridger 2, and has evaluated the effect of these qualities on NO_x formation and achievable emission rates. Coal sources and characteristics are summarized in Table 2-2. The primary source of coal will be the Bridger Underground Mine, and data on coal from this source were used in the modeling analysis. For the coal analysis that is presented in Section 3.2.1, the data from all the coal sources were used.

TABLE 2-1
Unit Operation and Study Assumptions
Jim Bridger 2

General Plant Data	
Site Elevation (feet above mean sea level)	6669
Stack Height (feet)	500
Stack Exit Internal Diameter (feet) /Exit Area (square feet)	24 /452.4
Stack Exit Temperature °F (degrees Fahrenheit)	140
Stack Exit Velocity (feet per second)	84.0
Stack Flow (actual cubic feet per minute)	2,281,182
Latitude (degree: minute : second)	41:44:16.42 north
Longitude (degree: minute : second)	108:47:10.59 west
Annual Unit Capacity Factor (percentage)	90
Net Unit Output (megawatts)	530
Net Unit Heat Rate (British thermal unit [Btu]/kilowatt-hour [kW-Hr])(100% load)	10,400 (as measured by fuel throughput)
Boiler Heat Input (million British thermal units [MMBtu] per hour)(100% load)	6,000 (as measured by continuous emission monitoring)
Type of Boiler	Tangentially fired
Boiler Fuel	Coal
Coal Sources	Bridger Mine, Black Butte Mine, Leucite Hills Mine
Coal Heating Value (Btu per pound [lb]) ^a	9,660
Coal Sulfur Content (percentage by weight [wt. %]) ^a	0.58
Coal Ash Content (wt. %) ^a	10.3
Coal Moisture Content (wt. %) ^a	19.3
Coal Nitrogen Content (wt. %) ^a	0.98
Current Nitrogen Oxide (NO _x) Controls	Low NO _x burners
NO _x Emission Rate (lb/MMBtu)	0.24
Current Sulfur Oxide (SO ₂) Controls	Sodium based wet scrubber
SO ₂ Emission Rate (lb/MMBtu)	0.267
Current PM ₁₀ Controls	Electrostatic Precipitator
PM ₁₀ Emission Rate (lb/MMBtu) ^b	0.074

NOTES:

^a Coal characteristics based on Bridger Underground Mine (primary coal source)

^b Based on maximum historic emission rate from 1999 – 2001, before installation of the sulfur trioxide (SO₃) injection system.

TABLE 2-2
Coal Sources and Characteristics
Jim Bridger 2

Mines	Ultimate Analysis (% dry basis)												
	Moist. (%)	Ash (%)	Volatile Matter (%)	Fixed Carbon (%)	Btu/lb	Sulfur (%)	Moisture and Ash Free (Btu/lb)	Hydrogen	Carbon	Sulfur	Nitrogen	Oxygen	Ash
Bridger Mine Underground	19.3	10.3	32.2	38.3	9660	0.58	13712	4.66	69.2	0.72	1.22	11.8	12.4
Maximum	Not enough data yet to run statistical analysis for variability												
Minimum	Not enough data yet to run statistical analysis for variability												
Bridger Mine Surface	19.1	10.6	32.3	38.0	9390	0.57	13340	4.38	37.4	0.71	1.26	13.2	13.0
Maximum	20.5	12.5	35.5	41.9	9800	0.72	13500	4.69	4.0	0.90	1.43	14.8	15.8
Minimum	17.5	9.0	31.0	36.0	9000	0.49	13100	4.00	64.3	0.60	1.14	11.7	11.2
Bridger Mine Highwall	18.0	9.5	33.0	39.5	9700	0.58	13500	No samples of separate highwall coal					
Maximum	Not enough data yet to run statistical analysis for variability												
Minimum	Not enough data yet to run statistical analysis for variability												
Black Butte Mine	20.0	9.2	33.3	35.6	9450	0.45	13330	4.43	68.7	0.56	1.47	13.4	11.5
Max	21.1	10.8	35.4	41.9	10275	0.62	13500	4.66	70.5	0.78	1.69	14.8	13.6
Min	18.0	7.6	29.9	36.8	9180	0.33	13140	4.21	66.1	0.41	1.25	11.6	9.7
Leucite Hills Mine (through 2009)	19.4	11.5	30.7	38.3	9080	0.64	13140	4.20	66.0	0.81	1.48	13.2	14.4
Maximum	23.0	15.0	33.0	43.0	10250	0.90	13800	4.70	70.0	1.20	1.64	17.1	19.0
Minimum	17.0	8.0	28.3	33.6	8000	0.40	12300	3.70	61.0	0.50	1.32	10.5	10.0

3.0 BART Engineering Analysis

This section presents the required BART engineering analysis.

3.1 Applicability

In compliance with regional haze requirements, the State of Wyoming must prepare and submit visibility SIPs to the EPA for Class I areas. The State has estimated that the formal submittal of the SIPs will occur by early 2008. The first phase of the regional haze program is the implementation of BART emission controls on all BART eligible units, within 5 years after EPA approval of the SIP.

3.2 BART Process

The specific steps in a BART engineering analysis are identified in the Code of Federal Regulations (CFR) at 40 CFR 51 Appendix Y, Section IV. The evaluation must include:

- The identification of available, technically feasible, retrofit control options
- Consideration of any pollution control equipment in use at the source (which affects the availability of options and their impacts)
- The costs of compliance with the control options
- The remaining useful life of the facility
- The energy and non-air quality environmental impacts of compliance
- The degree of visibility improvement that may reasonably be anticipated from the use of BART.

The following steps are incorporated into the BART analysis:

- Step 1 – Identify All Available Retrofit Control Technologies
- Step 2 – Eliminate Technically Infeasible Options
 - The identification of available, technically feasible, retrofit control options
 - Consideration of any pollution control equipment in use at the source (which affects the applicability of options and their impacts)
- Step 3 – Evaluate Control Effectiveness of Remaining Control Technologies
- Step 4 – Evaluate Impacts and Document the Results
 - The costs of compliance with the control options
 - The remaining useful life of the facility
 - The energy and non-air quality environmental impacts of compliance

- Step 5 – Evaluate Visibility Impacts
 - The degree of visibility improvement that may reasonably be anticipated from the use of BART

In order to minimize costs in the BART analysis, consideration was made of any pollution control equipment in use at the source, the costs of compliance associated with the control options, and the energy and non-air quality environmental impacts of compliance using these existing control devices. In some cases, enhancing the performance of the existing control equipment was considered. Other scenarios with new control equipment were also developed.

Separate analyses have been conducted for NO_x, SO₂, and PM₁₀ emissions. All costs included in the BART analyses are in 2006 dollars, and costs have not been escalated to the assumed 2014 BART implementation date.

3.2.1 BART NO_x Analysis

Nitrogen oxide formation in coal-fired boilers is a complex process that is dependent on a number of variables, including operating conditions, equipment design, and coal characteristics.

Formation of NO_x

During coal combustion, NO_x is formed in three different ways. The dominant source of NO_x formation is the oxidation of fuel-bound nitrogen (fuel NO_x). During combustion, part of the fuel NO_x is released from the coal with the volatile matter, and part of it is retained in the solid portion (char). The nitrogen chemically bound in the coal is partially oxidized to nitrogen oxide and nitrogen dioxide) and partially reduced to molecular nitrogen (N₂). A smaller part of NO_x formation is due to high temperature fixation of atmospheric nitrogen in the combustion air (thermal NO_x). A very small amount of NO_x is called “prompt” NO_x. Prompt NO_x results from an interaction of hydrocarbon radicals, nitrogen, and oxygen.

In a conventional pulverized coal burner, air is introduced with turbulence to promote good mixing of fuel and air, which provides stable combustion. However, not all of the oxygen in the air is used for combustion. Some of the oxygen combines with the fuel nitrogen to form NO_x.

Coal characteristics directly and significantly affect NO_x emissions from coal combustion. Coal ranking is a means of classifying coals according to their degree of metamorphism in the natural series, from lignite to sub-bituminous to bituminous and on to anthracite. Lower-rank coals, such as the sub-bituminous coals from the PRB, produce lower NO_x emissions than higher rank bituminous coals, due to their higher reactivity and lower nitrogen content. The fixed carbon to volatile matter ratio (fuel ratio), coal oxygen content, and rank are good relative indices of the reactivity of a coal. Lower-rank coals release more organically bound nitrogen earlier in the combustion process than do higher rank bituminous coals. When used with LNBS, sub-bituminous coals create a longer time for the kinetics to promote more stable molecular nitrogen and, hence, result in lower NO_x emissions.

Coals from the PRB are classified as sub-bituminous C and demonstrate the high reactivity and low NO_x production characteristics described above. Based on data from the Energy Information Administration (EIA), PRB coals currently represent 88 percent of total United States sub-bituminous production and 73 percent of western coal production. Most references to western coal and sub-bituminous coal infer PRB origin and characteristics. Emissions

standards differentiating between bituminous and sub-bituminous coals are presumed to use PRB coal as the basis for the sub-bituminous standards, due to their dominant market presence and unique characteristics.

There are a number of western coals that are classified as sub-bituminous; however, they border on being ranked as bituminous and do not display many of the qualities of PRB coals, including most of the low NO_x forming characteristics. Coals from the Bridger, Black Butte, and Leucite Hills Mines fall into this category.

As defined by the American Society for Testing and Materials, the only distinguishing characteristic that classifies the coals used at Jim Bridger 2 as sub-bituminous rather than bituminous – that is, they are “agglomerating” as compared with “non-agglomerating.” Agglomerating as applied to coal is “the property of softening when it is heated to above about 400 degrees Celsius ($^{\circ}\text{C}$) in a non-oxidizing atmosphere, and then appearing as a coherent mass after cooling to room temperature.” Because the agglomerating property of coals is the result of particles transforming into a plastic or semi-liquid state when heated, it reflects a change in surface area of the particle. Thus, with the application of heat, agglomerating coals would tend to develop a non-porous surface, while the surface of non-agglomerating coals would become even more porous with combustion. As shown on Figure 3-1, the increased porosity provides more particle surface area, resulting in more favorable combustion conditions. This non-agglomerating property assists in making sub-bituminous coals more amenable to controlling NO_x by allowing less air to be introduced during the initial ignition portion of the combustion process. The coals from the Bridger, Black Butte and Leucite Hills Mines just barely fall into the category of non-agglomerating coals. While each of these coals is considered non-agglomerating, they either do not exhibit those properties of non-agglomerating coals or exhibit them to only a minor degree. The conditions during combustion of typical non-agglomerating coals that make it easier to control NO_x emissions do not exist during combustion of the Bridger blends of coals.

FIGURE 3-1
Illustration of the Effect of Agglomeration on the Speed of Coal Combustion
Jim Bridger 2




Table 3-1 shows key characteristics of a typical PRB coal, compared with coals from the Bridger, Black Butte, and Leucite Hills Mines, as well as coal from Twentymile, which is a representative western bituminous coal.

TABLE 3-1
Coal Characteristics Comparison
Jim Bridger 2

Parameter	Typical PRB	Bridger Mine	Black Butte	Leucite Hills	Twentymile
Nitrogen (% dry)	1.10	1.26	1.47	1.48	1.85
Oxygen (% dry)	16.2	13.2	13.4	13.2	7.19
Coal rank	Sub C	Sub B	Sub B	Sub B	Bituminous high-volatility B

As shown in Table 3-1, although Bridger, Black Butte, and Leucite Hills coals are classified as sub-bituminous, they all exhibit higher nitrogen content and lower oxygen content than the PRB coal. The higher nitrogen content is an indication that more nitrogen is available to the combustion process and higher NO_x emissions are likely. Oxygen content can be correlated to the reactivity of the coal, with more reactive coals generally containing higher levels of oxygen. More reactive coals tend to produce lower NO_x emissions, and are more conducive to reduction of NO_x emissions through the use of combustion control measures, such as LNBs and OFA. These characteristics indicate that higher NO_x formation is likely with coal from the Bridger, Black Butte, and Leucite Hills Mines, rather than with PRB coal. The Bridger, Black Butte, and Leucite Hills coals all contain quality characteristics that fall between a typical PRB coal and Twentymile. Twentymile is a clearly bituminous coal that produces higher NO_x, as has been demonstrated at power plants that burn this fuel.

Figures 3-2 and 3-3 show the relationship of nitrogen and oxygen content to the BART presumptive NO_x limits for the coals listed in Table 3-1. Each chart identifies the presumptive BART limit associated with a typical bituminous and sub-bituminous coal, and demonstrates how the Jim Bridger 2 coal falls between these two general coal classifications.

The Bridger blend data point represents a combination of coals from the Bridger, Black Butte, and Leucite Hills Mines that has been used at Jim Bridger 2, and indicates the average NO_x emission rate achieved during the years 2003 through 2005. The Jim Bridger 2 data point represents the NO_x emission rate achieved after installation of Alstom's current state of the art TFS2000 LNB and OFA System. The long-term sustainable emission rate for this system is expected to be 0.24 lb per MMBtu.

Figures 3-2 and 3-3 both demonstrate that for the Jim Bridger 2 units with the TFS2000 low-NO_x emission system installed and burning a combination of the Bridger, Black Butte, and Leucite Hill coals, the likely NO_x emission rate (0.28) will be closer to the bituminous end of the BART presumptive NO_x limit range, rather than the BART presumptive NO_x limit of 0.15 lb per MMBtu for sub-bituminous coal. All these factors are consistent with the observed sustainable rate of 0.24 lb per MMBtu.

FIGURE 3-2
 Plot of Typical Nitrogen Content of Various Coals and Applicable Presumptive BART NO_x Limits
Jim Bridger 2





FIGURE 3-3
 Plot of Typical Oxygen Content of Various Coals and Applicable Presumptive BART NO_x Limits
Jim Bridger 2



Coal quality characteristics also affect the design and operation of the boiler and associated auxiliary equipment. Minor changes in quality can sometimes be accommodated through operational adjustments or changes to equipment. However, consistent variations in quality or assumptions of "average" quality for performance projections can be problematic. This is particularly troublesome when dealing with performance issues that are very sensitive to both coal quality and combustion conditions, such as NO_x formation. There is significant variability in the quality of coals burned at Jim Bridger 2. In addition to burning coal from Black Butte and Leucite Hills Mines, Jim Bridger 2 burns coal supplied from the Bridger Mine consisting of three sources: underground, surface, and highwall operations. Each of these coal sources has different quality characteristics, as well as inherent variability in the composition of coal within the mine.

Several of the coal quality characteristics and their effect on NO_x formation have been previously discussed. There are some additional considerations that illustrate the complexity of achieving and maintaining consistent low NO_x emissions with pulverized coal on a shorter term, such as a 30-day rolling average basis.

Good combustion is based on the "three Ts": time, temperature, and turbulence. These parameters, along with a "design" coal, are taken into consideration when designing a boiler and associated firing equipment such as fans, burners, and pulverizers. If a performance requirement such as NO_x emission limits is subsequently changed, conflicts with and between other performance issues can result.

Jim Bridger 2 is located at an altitude of 6,669 feet above mean sea level. At this elevation, atmospheric pressure is lower (11.5 pounds per square inch) as compared with sea level pressure of 14.7 pounds per square inch. This lower pressure means that less oxygen is available for combustion for each volume of air. In order to provide adequate oxygen to meet the requirements for efficient combustion, larger volumes of air are required. When adjusting air flows and distribution to reduce NO_x emissions, using low NO_x burners and OFA, original boiler design restrictions again limit the modifications that can be made and still achieve satisfactory combustion performance.

Another significant factor in controlling NO_x emissions is the fineness of the coal entering the burners. Fineness is influenced by the grindability index (Hardgrove) of the coal. Finer coal particles promote release of volatiles and assist char burnout due to more surface area exposed to air. Nitrogen oxide reduction with high-volatile coals is improved with greater fineness and with proper air staging. The lower rank sub-bituminous coals such as PRB coals are quite friable and easy to grind. Coals with lower Hardgrove Grindability Index values, such as those used at Jim Bridger 2, are more difficult to grind and can contribute to higher NO_x levels. In addition, coal fineness can deteriorate over time periods between pulverizer maintenance and service, as pulverizer grinding surfaces undergo wear.

In summary, when all the factors of agglomeration versus non-agglomeration, nitrogen and oxygen content of the coals, and the grindability index are taken into account, this analysis demonstrates that for the coal used at Jim Bridger 2, the more applicable presumptive BART limit for NO_x emissions is 0.28 lb per MMBtu. The BART analysis for NO_x emissions from Jim Bridger 2 is further described below.

Step 1: Identify All Available Retrofit Control Technologies

The first step of the BART process is to evaluate NO_x control technologies with practical potential for application to Jim Bridger 2, including those control technologies identified as Best Available Control Technology (BACT) or lowest achievable emission rate (LAER) by permitting agencies across the United States. A broad range of information sources have been reviewed in an effort to identify potentially applicable emission control technologies. NO_x emissions at Jim Bridger 2 are currently controlled through the use of good combustion practices and OFA.

The following potential NO_x control technology options were considered:

- New/modified LNB with advanced OFA
- Mobotec rotating opposed fire air (ROFA)
- LNB with OFA and conventional selective non-catalytic reduction (SNCR) system
- LNB with OFA and selective catalytic reduction (SCR) system

Step 2: Eliminate Technically Infeasible Options

For Jim Bridger 2, a tangentially fired configuration burning sub-bituminous coal, technical feasibility will primarily be determined by physical constraints, boiler configuration, and the ability to achieve the regulatory presumptive limit (used as a guide) of 0.28 lb of NO_x per MMBtu. Jim Bridger 2 has a current NO_x emission rate of 0.24 lb per MMBtu.

For this BART analysis, information pertaining to LNBs, OFA, SNCR, and SCR were based on the Multi-pollutant Control Report dated October 2002 (Sargent & Lundy [S&L], 2002, hereafter referred to as S&L Study). Updated cost estimates for SCR and SNCR were used. PacifiCorp provided additional emissions data and costs developed by boiler vendors for LNBs and OFA. Also, CH2M HILL solicited a proposal from Mobotec for its ROFA technology.

With SNCR, an amine-based reagent such as ammonia, or more commonly urea, is injected into the furnace within a temperature range of 1,600 to 2,100°F, where it reduces NO_x to nitrogen and water. NO_x reductions of up to 40 to 60 percent have been achieved, although 15 to 30 percent is more realistic for most applications. SNCR is typically applied on smaller units.

Table 3-2 summarizes the control technology options evaluated in this BART analysis, along with projected NO_x emission rates. All of the evaluated technologies are projected to meet the applicable presumptive BART limit of 0.28 lb per MMBtu.

TABLE 3-2
NO_x Control Technology Projected Emission Rates
Jim Bridger 2

Technology	Projected Emission Rate (lb per MMBtu)
Presumptive BART Limit	0.28
LNB with OFA	0.24
ROFA	0.22
LNB with OFA and SNCR	0.20
LNB with OFA and SCR	0.07

Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

Preliminary vendor proposals, such as those used to support portions of this BART analysis, may be technically feasible and provide expected or guaranteed emission rates; however, the proposals include inherent uncertainties. These proposals are usually prepared in a limited timeframe, may be based on incomplete information, may contain over-optimistic conclusions, and are non-binding. Therefore, emission rate values obtained in such preliminary proposals must be qualified, and it must be recognized that contractual guarantees are established only after more detailed analysis has been completed. The following subsections describe the control technologies and the control effectiveness evaluated in this BART analysis.

LNBs with OFA System. The mechanism used to lower NO_x with LNBs is to stage the combustion process and provide a fuel rich condition initially; this is so oxygen needed for combustion is not diverted to combine with nitrogen and form NO_x. Fuel-rich conditions favor the conversion of fuel nitrogen to N₂ instead of NO_x. Additional air (or OFA) is then introduced downstream in a lower temperature zone to burn out the char.

Both LNBs and OFA are considered to be a capital cost, combustion technology retrofit. For LNB retrofits to units configured with tangential-firing such as Jim Bridger 2, it is generally necessary to increase the burner spacing; this prevents interaction of the flames from adjacent burners and reduces burner zone heat flux. These modifications usually require boiler waterwall tube replacement. However, Jim Bridger 2 has already been modified with the installation of a TFS-2000 LNB with OFA system.

Information provided to CH2M HILL by PacifiCorp, based on the S&L Study and data from boiler vendors, indicates that the existing TFS-2000 LNB with and OFA system at Jim Bridger 2 could be more finely tuned to result in an expected NO_x emission rate of 0.24 lb per MMBtu. PacifiCorp has indicated that this rate corresponds to a vendor guarantee, not a vendor prediction, and they believe that this emission rate can be sustained as an average between overhauls. This emission rate represents a significant reduction from the current NO_x emission rate, and is below the more applicable presumptive NO_x emission rate of 0.28 lb per MMBtu.

ROFA. Mobotec markets ROFA as an improved second generation OFA system. Mobotec states that "the flue gas volume of the furnace is set in rotation by asymmetrically placed air nozzles. Rotation is reported to prevent laminar flow, so that the entire volume of the furnace can be

used more effectively for the combustion process. In addition, the swirling action reduces the maximum temperature of the flames and increases heat absorption. The combustion air is also mixed more effectively." A typical ROFA installation would have a booster fan(s) to supply the high velocity air to the ROFA boxes, and Mobotec would propose two 4,000- to 4,300-horsepower (hp) fans for Jim Bridger 2.

Mobotec proposes to achieve a NO_x emission rate of 0.18 lb per MMBtu using ROFA technology. An operating margin of 0.04 lb per MMBtu was added to the expected rate due to Mobotec's limited ROFA experience with western sub-bituminous coals. Under the Mobotec proposal, which is primarily based on ROFA equipment, the operation of existing LNB and OFA ports would be analyzed. While a typical installation does not require modification to the existing LNB system and the existing OFA ports are not used, results of computational fluid dynamics modeling would determine the quantity and location of new ROFA ports. The Mobotec proposal includes bent tube assemblies for OFA port installation.

Mobotec would not provide installation services because the Owner could more cost effectively contract for these services. However, it would provide one onsite construction supervisor during installation and startup.

SNCR. Selective non-catalytic reduction is generally utilized to achieve modest NO_x reductions on smaller units. With SNCR, an amine-based reagent such as ammonia, or more commonly urea, is injected into the furnace within a temperature range of 1,600 to 2,100°F, where it reduces NO_x to nitrogen and water. NO_x reductions of up to 60 percent have been achieved, although 20 to 40 percent is more realistic for most applications.

Reagent utilization, which is a measure of the efficiency with which the reagent reduces NO_x , can range from 20 to 60 percent, depending on the amount of reduction, unit size, operating conditions, and allowable ammonia slip. With low reagent utilization, low temperatures, or inadequate mixing, ammonia slip occurs, allowing unreacted ammonia to create problems downstream. The ammonia may render fly ash unsaleable, react with sulfur to foul heat exchange surfaces, and/or create a visible stack plume. Reagent utilization can have a significant impact on economics, with higher levels of NO_x reduction generally resulting in lower reagent utilization and higher operating cost.

Reductions from higher baseline concentrations (inlet NO_x) are lower in cost per ton, but result in higher operating costs, due to greater reagent consumption. Unit 2 has already had combustion modifications including LNBs and advanced OFA, capable of achieving a projected NO_x emission rate of 0.24 lb per MMBtu. At a further reduction of 15 percent in NO_x emission rates for SNCR would result in a projected emission rate of 0.20 lb per MMBtu.

SCR. Selective catalytic reduction works on the same chemical principle as SNCR, but SCR uses a catalyst to promote the chemical reaction. Ammonia is injected into the flue gas stream, where it reduces NO_x to nitrogen and water. Unlike the high temperatures required for SNCR, in SCR, the reaction takes place on the surface of a vanadium/titanium-based catalyst at a temperature range between 580 to 750°F. Due to the catalyst, the SCR process is more efficient than SNCR and results in lower NO_x emissions. The most common type of SCR is the high-dust configuration, where the catalyst is located downstream from the boiler economizer, and upstream of the air heater and any particulate control equipment. In this location, the SCR is

exposed to the full concentration of fly ash in the flue gas that is leaving the boiler. The high-dust configuration is assumed for Jim Bridger 2.

In a full-scale SCR, the flue ducts are routed to a separate large reactor containing the catalyst. With in-duct SCR, the catalyst is located in the existing gas duct, which may be expanded in the area of the catalyst to reduce flue gas flow velocity and increase flue gas residence time. Due to the higher removal rate, a full-scale SCR was used as the basis for analysis at Jim Bridger 2.

Sargent and Lundy prepared the design conditions and cost estimates for SCR at Jim Bridger 2. Unit 2 has already had combustion modifications including LNBS and advanced OFA, capable of achieving a projected NO_x emission rate of 0.24 lb per MMBtu. The S&L design basis for LNB with OFA and SCR results in a projected NO_x emission rate of 0.07 lb per MMBtu. Additional catalyst surface was included in the SCR design to accommodate the characteristics of the coal used at Jim Bridger 2.

Level of Confidence for Vendor Post-control Emissions Estimates. In order to determine the level of NO_x emissions needed to consistently achieve compliance with an established goal, a review of typical NO_x emissions from coal-fired generating units was completed. As a result of this review, it was noted that NO_x emissions can vary significantly around an average emissions level. Variations may result for many reasons, including coal characteristics, unit load, boiler operation including excess air, boiler slagging, burner equipment condition, and coal mill fineness.

The steps utilized for determining a level of confidence for the vendor expected values are as follows:

1. Establish expected NO_x emissions value from vendor.
2. Evaluate vendor experience and historical basis for meeting expected values.
3. Review and evaluate unit physical and operational characteristics and restrictions. The fewer variations there are in operations, coal supply, etc., the more predictable and less variant the NO_x emissions.
4. For each technology expected value, there is a corresponding potential for actual NO_x emissions to vary from this expected value. From the vendor information presented, along with anticipated unit operational data, an adjustment to the expected value can be made.

Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

Energy Impacts. Installation of LNBS and modification to the existing OFA systems are not expected to significantly affect the boiler efficiency or forced draft fan power usage. Therefore, these technologies will not have energy impacts.

The Mobotec ROFA system would require installation and operation of two 4,000- to 4,300-hp ROFA fans (6,410 kilowatts [kW] total). The SNCR system would require approximately 530 kW of additional power.

SCR retrofit impacts the existing flue gas fan systems, due to the additional pressure drop associated with the catalyst, which is typically a 6- to 8-inch water gage increase. Total additional power requirements for SCR installation at Jim Bridger 2 are estimated at approximately 3,250 kW, based on the S&L Study.

Environmental Impacts. Mobotec has predicted that carbon monoxide (CO) emissions, and unburned carbon in the ash, commonly referred to as LOI (loss on ignition), would be the same or lower than prior levels for the ROFA system.

The installation of SNCR and SCR could affect the saleability and disposal of fly ash due to ammonia levels, and could potentially create a visible stack plume, which may negate other visibility improvements. Other environmental impacts involve the storage of ammonia, especially if anhydrous ammonia is used, and the transportation of the ammonia to the power plant site.

Economic Impacts. Costs and schedules for the LNBs and OFA, SNCR, and SCR were furnished to CH2M HILL by PacifiCorp, developed using S&L's internal proprietary database, and supplemented (as needed) by vendor-obtained price quotes. The relative accuracy of these cost estimates is stated by S&L to be in the range of plus or minus 20 percent. Cost for the ROFA system was obtained from Mobotec.

A comparison of the technologies on the basis of costs, design control efficiencies, and tons of NO_x removed is summarized in Table 3-3, and the first-year control costs are presented in Figure 3-4. The complete economic analysis is contained in Appendix A.

TABLE 3-3
NO_x Control Cost Comparison
Jim Bridger 2


Factor	Low-NO _x Burners (LNBs) with Over-fire Air (OFA) (Existing)	Mobotec Rotating Opposed Fire Air (ROFA)	Selective Non-Catalytic Reduction (SNCR)	Selective Catalytic Reduction (SCR)
Total Installed Capital Costs	\$0	\$20.5 million	13.4 million	\$120.9 million
Total First Year Fixed and Variable Operation and Maintenance Costs	\$0	\$2.6 million	\$1.0 million	\$3.2 million
Total First Year Annualized Cost	\$0	\$4.6 million	\$2.3 million	\$14.7 million
Power Consumption (megawatts)	0	6.4	0.5	3.3
Annual Power Usage (1,000 million kilowatt-hours per year)	0	50.6	4.2	25.6
NO _x Design Control Efficiency	0.0%	8.3%	16.7%	70.8%
NO _x Removed per Year (Tons)	0	473	946	4,021
First Year Average Control Cost (\$/Ton of NO _x Removed)	\$0/ton	\$9,695/ton	\$2,389/ton	\$3,654/ton
Incremental Control Cost (\$/Ton of NO _x Removed)	\$0/ton	\$9,695/ton	\$2,389/ton	\$4,044/ton

Preliminary BART Selection. CH2M HILL recommends selection of the existing LNBs with OFA as BART for Jim Bridger 2, based on the projected significant reduction in NO_x emissions, reasonable control costs, and the advantages of no additional power requirements or non-air quality environmental impacts. Low-NO_x burner with OFA does not meet the EPA presumptive limit of 0.15 lb per MMBtu for sub-bituminous coal; however, it meets an emission rate that falls between the presumptive limit of 0.28 lb per MMBtu for bituminous coal and the limit of 0.15 lb per MMBtu for sub-bituminous coal. As discussed in the section on coal quality, the recommended technology and the achieved emission rate are deemed appropriate as BART for NO_x emissions from the coals combusted at Jim Bridger 2.

Step 5: Evaluate Visibility Impacts

See Section 4, BART Modeling Analysis.

FIGURE 3-4
First Year Control Cost for NOx Air Pollution Control Options
Jim Bridger 2



3.2.2 BART SO₂ Analysis

Sulfur dioxide forms in the boiler during the combustion process, and is primarily dependent on coal sulfur content. The BART analysis for SO₂ emissions on Jim Bridger 2 is described below.

Step 1: Identify All Available Retrofit Control Technologies

A broad range of information sources were reviewed, in an effort to identify potentially applicable emission control technologies for SO₂ at Jim Bridger 2. This included control technologies identified as BACT or LAER by permitting agencies across the United States.

The following potential SO₂ control technology options were considered:

- Optimize current operation of existing wet sodium FGD system
- Upgrade wet sodium FGD system to meet SO₂ emission rate of 0.10 lb per MMBtu
- New dry FGD system

Step 2: Eliminate Technically Infeasible Options

Technical feasibility will primarily be based on the regulatory presumptive limit (used as a guideline) of 95 percent reduction in SO₂ emissions, or 0.15 lb per MMBtu. Based on the coal that Jim Bridger 2 currently burns, the unit would be required to achieve an 87.5 percent SO₂ removal efficiency to meet the presumptive limit of 0.15 lb per MMBtu.

Table 3-4 summarizes the control technology options evaluated in this BART analysis, along with projected SO₂ emission rates. Only one technology option can meet the applicable presumptive BART limit of 0.15 lb per MMBtu.

TABLE 3-4
SO₂ Control Technology Emission Rates
Jim Bridger 2

Technology	Projected Emission Rate (lb per MMBtu)
Presumptive BART Limit	0.15
Upgrade Existing Wet Sodium System	0.10
Optimize Existing Wet Sodium System	0.20
New Dry FGD System	0.21

Wet Sodium FGD System. Wet sodium FGD systems operate by treating the flue gas in large scrubber vessels with a soda ash solution. The scrubber mixes the flue gas and alkaline reagent using a series of spray nozzles to distribute the reagent across the scrubber vessel. The sodium in the reagent reacts with the SO₂ in the flue gas to form sodium sulfite and sodium bisulfite, which are removed from the scrubber and disposed.

The wet sodium FGD system at Jim Bridger 2 currently achieves approximately 78 percent SO₂ removal to achieve an SO₂ outlet emission rate of 0.27 lb per MMBtu. Optimizing the existing wet FGD system is projected to achieve an SO₂ outlet emission rate of 0.20 lb per MMBtu (83.3 percent SO₂ removal). Optimization would be accomplished by partially closing

the bypass damper to reduce the routine bypass flue gas flow used to reheat the treated flue gas from the scrubber, relocating the opacity monitor, and modifying the system to minimize scaling problems.

Upgrading the wet FGD system is projected to achieve an SO₂ outlet emission rate of 0.10 lb per MMBtu (91.7 percent SO₂ removal). Upgrading the system would involve closing the bypass damper to eliminate the routine bypass flue gas flow used to reheat the treated flue gas from the scrubber, relocating the opacity monitor, adding new fans, adding a stack liner and drains for wet operation, and using a refined soda ash reagent. It is considered to be technically infeasible for the present wet FGD system to achieve a 95 percent SO₂ removal rate (0.06 lb per MMBtu) on a continuous basis because this high level of removal must be incorporated into the original design of the scrubber.

Optimizing the existing wet sodium scrubbing FGD system is projected to achieve an outlet emission rate of 0.20 lb per MMBtu, which would not meet the presumptive limit of 0.15 lb of SO₂ per MMBtu. Therefore, this option is eliminated as technically infeasible for this analysis. An upgraded wet sodium scrubbing FGD system is projected to achieve an outlet emission rate of 0.10 lb per MMBtu (91.7 percent SO₂ removal), which would meet the presumptive limit of 0.15 lb of SO₂ per MMBtu for Jim Bridger 2.

New Dry FGD System. The lime spray dryer typically injects lime slurry in the top of the absorber vessel with a rapidly rotating atomizer wheel. The rapid speed of the atomizer wheel causes the lime slurry to separate into very fine droplets that intermix with the flue gas. The SO₂ in the flue gas reacts with the calcium in the lime slurry to form dry calcium sulfate particles. At Jim Bridger 2, this dry particulate matter (PM) would be captured downstream in the existing ESP, along with the fly ash. A lime spray dryer system typically produces a dry waste product suitable for landfill disposal.

The dry FGD system with the existing ESP is projected to achieve 82.5 percent SO₂ removal at Jim Bridger 2. This would result in a controlled SO₂ emission rate of 0.21 lb per MMBtu, based on an uncontrolled SO₂ emission rate of 1.20 lb per MMBtu. Therefore, this option cannot meet the presumptive limit of 0.15 lb SO₂ per MMBtu, and is eliminated from further analysis as technically infeasible.

Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

When evaluating the control effectiveness of SO₂ reduction technologies, each option can be compared against benchmarks of performance. One such benchmark is the presumptive BART emission limit because Jim Bridger 2 is required to meet this limit. As indicated previously, the presumptive limit for SO₂ on a BART-eligible coal burning unit is 95 percent removal, or 0.15 lb per MMBtu.

The projected emission rate for an upgraded wet sodium FGD system for Jim Bridger 2 would be 0.10 lb per MMBtu. This option would meet the presumptive SO₂ limit of 0.15 lb per MMBtu.

Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

Energy Impacts. Upgrading the existing wet sodium FGD system would require an additional 530 kW of power.

Environmental Impacts. There will be incremental additions to scrubber waste disposal and makeup water requirements, and a reduction of the stack gas temperature from 140 to 120°F, due to elimination of reheating by the bypassed flue gas.

Economic Impacts. A summary of the costs and amount of SO₂ removed for the upgraded wet sodium FGD system is provided in Table 3-5. The complete economic analysis is contained in Appendix A.

TABLE 3-5
SO₂ Control Cost Comparison (Incremental to Existing Wet FGD System)
Jim Bridger 2

Factor	Upgraded Wet Flue Gas Desulfurization
Total Installed Capital Costs	\$13.0 million
Total First Year Fixed & Variable Operation and Maintenance Costs	\$1.3 million
Total First Year Annualized Cost	\$2.5 million
Additional Power Consumption (megawatt)	0.5
Additional Annual Power Usage (1000 megawatt-hour per year)	4.2
Incremental SO ₂ Design Control Efficiency	62.5% (91.7% based on Uncontrolled SO ₂)
Incremental Tons SO ₂ Removed per Year	3,950
First Year Average Control Cost (dollars per ton [\$/Ton] of SO ₂ Removed)	632
Incremental Control Cost (\$/Ton of SO ₂ Removed)	632

Preliminary BART Selection. CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 2, based on significant reduction in SO₂ emissions (meeting presumptive limit of 0.15 lb per MMBtu), reasonable control costs, and the advantages of minimal additional power requirements and environmental impacts.

Step 5: Evaluate Visibility Impacts

See Section 4, BART Modeling Analysis.

3.2.3 BART PM₁₀ Analysis

Jim Bridger 2 is currently equipped with an ESP. Electrostatic precipitators remove PM from the flue gas stream by charging fly ash particles with a very high direct current voltage, and

attracting these charged particles to grounded collection plates. A layer of collected PM forms on the collecting plates and is removed by periodically rapping the plates. The collected ash particles drop into hoppers below the precipitator and are removed periodically by the fly ash-handling system. Historically, the ESP at Jim Bridger 2 has controlled PM₁₀ emissions to levels below 0.074 lb per MMBtu.

The BART analysis for PM₁₀ emissions at Jim Bridger 2 is described below. For the modeling analysis in Section 4, PM₁₀ was used as an indicator for PM, and PM₁₀ includes particulate matter less than 2.5 micrometers in aerodynamic diameter (PM_{2.5}) as a subset.

Step 1: Identify All Available Retrofit Control Technologies

The following two retrofit control technologies have been identified for additional PM control:

- Flue gas conditioning
- Polishing fabric filter (baghouse) downstream of existing ESP

Another available control technology is replacing the existing ESP with a new fabric filter. However, because the environmental benefits that would be achieved by a replacement fabric filter are also achieved by installing a polishing fabric filter downstream of the existing ESP at lower costs, installation of a full fabric filter was not considered in the analysis.

Step 2: Eliminate Technically Infeasible Options

Flue Gas Conditioning. If the fly ash from coal has high resistivity, such as fly ash from sub-bituminous coal, the ash is not collected effectively in an ESP. This is because the high resistivity makes the particles less willing to accept an electrical charge. Adding flue gas conditioning (FGC), which is typically accomplished by injection of sulfur trioxide (SO₃), will lower the resistivity of the particles so that they will accept more charge and allow the ESP to collect the ash more effectively. Flue gas conditioning systems can account for large improvements in collection efficiency for small ESPs.

Polishing Fabric Filter. A polishing fabric filter could be added downstream of the existing ESP at Jim Bridger 2. One such technology is licensed by the Electric Power Research Institute, and referred to as a COHPAC (Compact Hybrid Particulate Collector). The COHPAC collects the ash that is not collected by the ESP, thus acting as a polishing device. The ESP needs to be kept in service for the COHPAC fabric filter to operate effectively.

The COHPAC fabric filter is about one-half to two-thirds the size of a full size fabric filter, because the COHPAC has a higher air-to-cloth ratio (7 to 9:1), compared with a full-size pulse jet fabric filter (3.5 to 4:1).

Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

The existing ESP at Jim Bridger 2 is achieving a controlled PM emission rate of 0.074 lb per MMBtu. Utilizing FGC upstream of the existing ESP is projected to reduce PM emissions to approximately 0.030 lb per MMBtu. Adding a COHPAC fabric filter downstream of the existing ESP is projected to reduce PM emissions to approximately 0.015 lb per MMBtu.

The PM₁₀ control technology emission rates are summarized in Table 3-6.

TABLE 3-6
 PM₁₀ Control Technology Emission Rates
 Jim Bridger 2

Control Technology	Short-term Expected PM ₁₀ Emission Rate (lb per MMBtu)
Flue Gas Conditioning	0.030
Polishing Fabric Filter	0.015

Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

Energy Impacts. Energy is required to overcome the additional pressure drop from the COHPAC fabric filter and associated ductwork. Therefore, a COHPAC retrofit will require an internal diameter (ID) fan upgrade and upgrade of the auxiliary power supply system.

A COHPAC fabric filter at Jim Bridger 2 would require approximately 3.4 MW of power, equating to an annual power usage of approximately 26.5 million kilowatt-hour (kW-Hr).

There is only a small power requirement of approximately 50 kW associated with FGC.

Environmental Impacts. There are no negative environmental impacts from the addition of a COHPAC polishing fabric filter or FGC system.

Economic Impacts. A summary of the costs and PM removed for COHPAC and FGC is recorded in Table 3-7, and the first-year control costs for FGC and fabric filters are shown on Figure 3-5. The complete economic analysis is contained in Appendix A.

TABLE 3-7
 PM₁₀ Control Cost Comparison
 Jim Bridger 2


Factor	Flue Gas Conditioning	Polishing Fabric Filter
Total Installed Capital Costs	\$0	\$48.4 million
Total First Year Fixed and Variable Operations and Maintenance Costs	\$0.2 million	\$1.8 million
Total First Year Annualized Cost	\$0.2 million	\$ 6.4 million
Additional Power Consumption (megawatts)	0.05	3.4
Additional Annual Power Usage (million kilowatt-hours per year)	0.4	26.5
Incremental Particulate Matter (PM) Design Control Efficiency	59.5%	79.7%
Incremental Tons PM Removed per Year	1,041	1,395
First Year Average Control Cost (dollars per ton [\$ /Ton] of PM Removed)	169	4,556
Incremental Control Cost (\$ /Ton of SO ₂ PM Removed)	169	17,426

Preliminary BART Selection. CH2M HILL recommends selection of flue gas conditioning upstream of the existing ESP as BART for Jim Bridger 2, based on the significant reduction in PM emissions, reasonable control costs, and advantages of minimal additional power requirements and no environmental impacts.

Step 5: Evaluate Visibility Impacts.

See Section 4, BART Modeling Analysis.

FIGURE 3-5
First Year Control Cost for PM Air Pollution Control Options
Jim Bridger 2



4.0 BART Modeling Analysis

4.1 Model Selection

CH2M HILL used the CALPUFF modeling system (Gaussian puff dispersion model) to assess the visibility impacts of emissions from Jim Bridger 2 at nearby Class I areas. The Class I areas potentially affected are located more than 50 kilometers (km) but less than 300 km from the Jim Bridger 2 facility. The Class I areas include the following wilderness areas (WAs):

- Bridger WA
- Fitzpatrick WA
- Mt. Zirkel WA

The CALPUFF modeling system includes the CALMET meteorological model, CALPUFF modeling system with algorithms for chemical transformation and deposition, and a post processor capable of calculating concentrations, visibility impacts, and deposition (CALPOST). The CALPUFF modeling system was applied in a full, refined mode. Version numbers of the various programs in the CALPUFF modeling system used by CH2M HILL were as follows:

- CALMET Version 5.53a, Level 040716
- CALPUFF Version 5.711a, Level 040716
- CALPOST Version 5.51, Level 030709

4.2 CALMET Methodology

4.2.1 Dimensions of the Modeling Domain

CH2M HILL used the CALMET model to generate a three-dimensional wind field and other meteorological parameters suitable for use by the CALPUFF modeling system. A modeling domain was established to encompass the Jim Bridger 2 facility and allow for a 50-km buffer around the Class I areas that were within 300 km of the facility. Grid resolution was 4 km. Figure 4-1 shows the extent of the modeling domain. Except when specifically instructed otherwise by the Wyoming Department of Environmental Quality-Air Quality Division (WDEQ-AQD), CH2M HILL followed the methodology spelled out in the WDEQ-AQD BART Modeling Protocol, a copy of which is included in this report as Appendix B.

CH2M HILL used the Lambert Conformal Conic map projection for the analysis because of the large extent of the domain. The latitude of the projection origin and the longitude of the central meridian were chosen at the approximate center of the domain. Standard parallels were drawn to represent one-sixth and five-sixths of the north-south extent of the domain to minimize distortion in the north-south direction.




Figure 4-1
Jim Bridger Source-Specific
Class I Areas to be Addressed



CH2MHILL

S:\C\Bridger\PROJECTS\HUNTERMAPFILES\JIM_BRIDGER_CLASS1.MXD 11/9/2006 MSLAYDEN

The default technical options listed in TRC Companies, Inc.'s (TRC) current example CALMET.inp file were used for CALMET. Vertical resolution of the wind field included ten layers, with vertical face heights as follows (in meters):

- 0, 20, 40, 100, 140, 320, 580, 1020, 1480, 2220, 3500

Other user-specified model options were set to values established by WDEQ-AQD, which appear in Table 3 of Appendix B. Table 4-1 lists the key user-specified options used for this analysis.

TABLE 4-1
User-Specified CALMET Options
Jim Bridger 2

CALMET Input Parameter	Value
CALMET Input Group 2	
Map projection (PMAP)	Lambert Conformal
Grid spacing (DGRIDKM)	4
Number vertical layers (NZ)	10
Top of lowest layer (m)	20
Top of highest layer (m)	3500
CALMET Input Group 4	
Observation mode (NOOBS)	0
CALMET Input Group 5	
Prog. Wind data (IPROG)	14
(RMAX1)	30
(RMAX2)	50
Terrain influence (TERRAD)	15
(R1)	5
(R2)	25
CALMET Input Group 6	
Max mixing ht (ZIMAX)	3500

4.2.2 CALMET Input Data

CH2M HILL ran the CALMET model to produce 3 years of analysis: 2001, 2002, and 2003. WDEQ-AQD provided 12-km resolution Mesoscale Meteorological Model, Version 5 (MM5) meteorological data fields that covered the entire modeling domain for each study year.

These three data sets were chosen because they are current and have been evaluated for quality. The MM5 data were used as input to CALMET as the "initial guess" wind field. The initial guess wind field was adjusted by CALMET for local terrain and land use effects to generate a

Step 1 wind field, and further refined using local surface observations to create a final Step 2 wind field.

Surface data for 2001 through 2003 were obtained from the National Climatic Data Center. CH2M HILL processed the data from the National Weather Service's Automated Surface Observing System (ASOS) network for all stations that are in the domain. The surface data were obtained in abbreviated DATSAV3 format. A conversion routine available from the TRC website was used to convert the DATSAV3 files to CD-144 format for input into the SMERGE preprocessor and CALMET.

Land use and terrain data were obtained from the U.S. Geological Survey (USGS). Land use data were obtained in Composite Theme Grid format from the USGS, and the Level I USGS land use categories were mapped into the 14 primary CALMET land use categories. Surface properties such as albedo, Bowen ratio, roughness length, and leaf area index were computed from the land use values. Terrain data were taken from USGS 1-degree Digital Elevation Model data, which primarily derive from USGS 1:250,000 scale topographic maps. Missing land use data were filled with values that were assumed appropriate for the missing area.

Precipitation data were obtained from the National Climatic Data Center. All available data in fixed-length, TD-3240 format were obtained for the modeling domain. The list of available stations that have collected complete data varies by year, but CH2M HILL processed all available stations/data within the domain for each year. Precipitation data were prepared with the PEXTRACT/PMERGE processors in preparation for use within CALMET.

Upper-air data were prepared for the CALMET model with the READ62 preprocessor for the following stations:

- Denver, Colorado
- Salt Lake City, Utah
- Riverton, Wyoming
- Rapid City, South Dakota

Figure 4-2 shows the locations of surface and upper air stations within the MM5 modeling domain.




Figure 4-2
Surface and Upper Air Stations Used in the
Jim Bridger BART Analysis



CH2MHILL

SLC \ISLDB\GIS\PROJECTS\HUNTER\MAPPFILES\JIM_BRIDGER_LASOS.MXD 11/9/2006 MSL:YDEN

4.2.3 Validation of CALMET Wind Field

CH2M HILL used the CALDESK data display and analysis system (v2.97, Enviromodeling Ltd.) to view plots of wind vectors and other meteorological parameters to evaluate the CALMET wind fields. The CALDESK displays were compared with observed weather conditions, as depicted in surface and upper-air weather maps from the National Oceanic and Atmospheric Administration Central Library U.S. Daily Weather Maps Project (National Oceanic Atmospheric Administration, 2006).

4.3 CALPUFF Modeling Approach

For the BART control technology visibility improvement modeling, CH2M HILL followed WDEQ-AQD guidance provided in the document titled *BART Air Modeling Protocol-Individual Source Visibility Assessments for BART Control Analyses* (WDEQ-AQD, 2006).

CH2M HILL drove the CALPUFF model with the meteorological output from CALMET over the modeling domain described in this report. The CALPUFF modeling system was used to predict visibility impacts for the pre-control (baseline) scenario for comparison to the predicted impacts for post-control scenarios for Jim Bridger 2.

4.3.1 Background Ozone and Ammonia

Hourly values of background ozone concentrations were used by CALPUFF for the calculation of SO₂ and NO_x transformation with the MESOPUFF II chemical transformation scheme. CH2M HILL obtained hourly ozone data from the following stations located within the modeling domain for 2001, 2002, and 2003:

- Rocky Mountain National Park, Colorado
- Craters of the Moon National Park, Idaho
- Highland, Utah
- Thunder Basin National Grasslands, Wyoming
- Yellowstone National Park, Wyoming
- Centennial, Wyoming
- Pinedale, Wyoming

For periods of missing hourly ozone data, the chemical transformation relied on a monthly default value of 44 parts per billion. Background ammonia was set to 2 parts per billion. Both of these background values were taken from the guidance document (WDEQ-AQD, 2006).

4.3.2 Stack Parameters

The stack parameters used for the baseline modeling reflect those that are in place under the current permit for Jim Bridger 2, except for the NO_x emission rate where 0.24 lb per MMBtu (achieved with the new LNB with OFA system) was used in lieu of the permit limit of 0.45 lb per MMBtu. Post-control stack parameters reflect the anticipated changes associated with installation of the control technology alternatives that are being evaluated. The maximum heat input rate of 6,000 MMBtu per hour was used to calculate a maximum emission rate. Measured velocities and stack flow rates were used in the modeling to represent a worst-case situation.

4.3.3 Emission Rates

Pre-control emission rates for Jim Bridger 2 reflect peak 24-hour average emissions that could occur under the source's current permit. The emission rates reflect actual emissions under normal operating conditions, as described by the EPA in the *Regional Haze Regulations and Guidelines for Best Available Retrofit Technology Determinations; Final Rule* (40 CFR Part 51).

CH2M HILL used available continuous emission monitoring data to determine peak 24-hour emission rates. Data reflected operations from the most recent 3- to 5-year period, unless a more recent period was more representative. Allowable short-term (24-hour or shorter period) emissions or short-term emission limits were used if continuous emission monitoring data were not available.

Emissions were modeled for the following pollutants:

- SO₂
- NO_x
- Coarse particulate (PM_{2.5}<diameter<PM₁₀)
- Fine particulate (diameter<PM_{2.5})
- Sulfates

Post-control emission rates reflect the effects of the emissions control scenario under consideration. Modeled pollutants were the same as those listed for the pre-control scenario.

4.3.4 Post-control Scenarios

Four post-control modeling scenarios were developed to cover the range of effectiveness for the combination of the individual NO_x, SO₂, and PM control technologies being evaluated. The selection of each control device was made based on the engineering analyses described in Section 3 for reasonable technologies that would meet or exceed the presumptive BART levels for each pollutant.

- **Scenario 1:** Existing LNB with OFA, upgraded wet FGD system, and FGC for enhanced ESP performance. As indicated previously, this scenario represents CH2M HILL's preliminary BART recommendation.
- **Scenario 2:** Existing LNB with OFA, upgraded wet FGD system, and new polishing fabric filter.
- **Scenario 3:** Existing LNB with OFA and SCR, upgraded wet FGD system, and flue gas conditioning for enhanced ESP performance.
- **Scenario 4:** Existing LNB with OFA and SCR, upgraded wet FGD system, and new polishing fabric filter.

The ROFA and SNCR options for NO_x control were not included in the modeling scenarios because their control effectiveness is between the existing LNB with OFA option and the SCR option. Modeling of NO_x, SO₂, and PM controls alone was not performed because any final BART solution will include a combination of control technologies for NO_x, SO₂, and PM.

Table 4-2 presents the stack parameters and emission rates used for the Jim Bridger 2 analysis for baseline and post-control modeling. In accordance with the WDEQ BART modeling protocol, elemental carbon stack emissions and organic aerosol emissions were not modeled.

4.3.5 Modeling Process

The CALPUFF modeling system for the control technology options for Jim Bridger 2 followed this sequence:

- Model pre-control (baseline) emissions
- Model preferred post-control scenario (if applicable)
- Determine degree of visibility improvement
- Model other control scenarios
- Determine degree of visibility improvement
- Factor visibility results into BART five-step evaluation

4.3.6 Receptor Grids

Discrete receptors for the CALPUFF modeling system were placed at uniform receptor spacing along the boundary and in the interior of each area of concern. Class I area receptors were taken from the National Park Service database for Class I area modeling receptors. The TRC COORDS program was used to convert all latitude/longitude coordinates to Lambert Conformal Conic coordinates, including receptors, meteorological stations, and source locations.

TABLE 4-2
BART Model Input Data
Jim Bridger 2

	Baseline			
	Post-control Scenario 1	Post-control Scenario 2	Post-control Scenario 3	Post-control Scenario 4
	Current Operations with Existing Low-NOx Burners (LNBs), wet Flue Gas Desulfurization (FGD) and Electrostatic Precipitator (ESP)			
Sulfur dioxide (SO ₂) Stack Emissions (pounds per hour (lb/hr))	600	600	600	600
Nitrogen Oxide (NO _x) Stack Emissions (pound per million British thermal units (lb/MMBtu)) ^a	0.24	0.24	0.07	0.07
NO _x Stack Emissions (lb/hr)	1,440	1,440	420	420
PM ₁₀ Stack Emissions (lb/MMBtu)	0.074	0.015	0.030	0.015
PM ₁₀ Stack Emissions (lb/hr)	444	90.0	180	90.0
Coarse Particulate (PM _{2.5-10} diameter-PM ₁₀) Stack Emissions (lb/hr) ^b	191	51.3	77.4	51.3
Fine Particulate (diameter<PM _{2.5}) Stack Emissions (lb/hr) ^b	253	38.7	103	38.7
HF Stack Emissions (lb/MMBtu)	0.00055	0.00055	0.00055	0.00055
HF Stack Emissions (lb/hr)	3.3	3.3	3.3	3.3
Sulfuric Acid (H ₂ SO ₄) as SO _x Stack Emissions (lb/hr)	54.1	54.1	92.987	92.987
Ammonium Sulfate ((NH ₄) ₂ SO ₄) Stack Emissions (lb/MMBtu)			0.00117	0.00117
(NH ₄) ₂ SO ₄ Stack Emissions (lb/hr)			7.02	7.02
(NH ₄) ₂ SO ₄ as SO _x Stack Emissions (lb/hr)			5.10	5.10
(NH ₄)HSO ₄ Stack Emissions (lb/MMBtu)			0.00204	0.00204
(NH ₄)HSO ₄ as SO _x Stack Emissions (lb/hr)			12.2	12.2
Total Filterable PM ₁₀ (lb/hr) (including PM _{2.5})	452	188	187.8	97.8
Total Sulfate (as SO _x) (lb/hr)	54.1	54.1	54.1	54.1
Stack Conditions				
Stack Height (feet)	500	500	500	500
Stack Height (meters)	152	152	152	152
Stack Exit Diameter (feet)	24.00	24.00	24.00	24.00
Stack Exit Diameter (meters)	7.32	7.32	7.32	7.32
Stack Exit Temperature (°F)	140	140	140	140
Stack Exit Temperature (Kelvin)	333.2	333.2	333.2	333.2
Stack Exit Flow (actual cubic feet per minute)	2,281,182	2,208,010	2,437,627	2,437,627
Stack Exit Area (square feet)	452	452	452	452
Stack Exit Velocity (feet per second) ^c	84.04	89.81	89.81	89.81
Stack Exit Velocity (meters per second) ^d	25.62274	24.78	27.437	27.437

NOTES:
 Scenario 2, 3, and 4 were not modeled at this lower, correct velocity of 81.24 feet per second due to lack of time and the fact that the conclusions to select Scenario 1 would not have changed.
^a Based on AP-42, Table 1.1-5, the coarse particulates are counted as a percentage of PM₁₀. This equates to 43 percent ESP and 57 percent baghouses.
^b Based on AP-42, Table 1.1-5, the fine particulates are counted as a percentage of PM₁₀. This equates to 57 percent ESP and 43 percent baghouses.

4.4 CALPOST

The CALPOST processor was used to determine 24-hour average visibility results with output specified in deciview (dV) units. Calculations of light extinction were made for each pollutant modeled. The sum of all extinction values were used to calculate the delta-dV (Δ dV) change relative to natural background. The following default light extinction coefficients for each pollutant were used:

- Ammonium sulfate 3.0
- Ammonium nitrate 3.0
- PM coarse (PM₁₀) 0.6
- PM fine (PM_{2.5}) 1.0
- Organic carbon 4.0
- Elemental carbon 10.0

CALPOST visibility Method 6 was used to determine the visibility impacts. Monthly relative humidity factors [f (RH)] were used in the light extinction calculations to account for the hygroscopic characteristics of nitrate and sulfate particles. Table 5 of the Wyoming BART Air Modeling Protocol (Appendix B) lists the monthly f (RH) factors for the Class I areas. These values were used for the particular Class I area being modeled.

The natural background conditions as a reference for determining the Δ dV change represented the 20 percent best natural visibility days. The EPA BART guidance document provided dV values for the 10 percent best days for each Class I area, but did not provide individual species concentration data for the 20 percent best days. Species concentrations corresponding to the 20 percent best days were calculated for each Class I area by scaling back the annual average species concentrations given in Table 2-1 of *Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule* (EPA, 2003). A separate scaling factor was derived for each Class I area such that, when multiplied by the guidance table annual concentrations, the 20 percent best days dV value for that area would be calculated. This procedure was taken from *Protocol for BART-Related Visibility Improvement Modeling Analysis in North Dakota* (North Dakota Department of Health, 2005). The Wyoming BART Air Modeling Protocol (see Appendix B) provided natural background concentrations of aerosol components to use in the BART analysis. Table 4-3 lists the annual average species concentrations from the BART protocol.

TABLE 4-3
Average Natural Levels of Aerosol Components
Jim Bridger 2

Aerosol Component	Average Natural Concentration (micrograms per cubic meter) for Mt. Zirkel Class I Wilderness Area	Average Natural Concentration (micrograms per cubic meter) for Fitzpatrick and Bridger Class I Wilderness Areas
Ammonium Sulfate	0.046	0.045
Ammonium Nitrate	0.038	0.038
Organic Carbon	0.179	0.178
Elemental Carbon	0.008	0.008
Soil	0.190	0.189
Coarse Mass	1.141	1.136

NOTES:

Data in this table was taken from Table 6 of the Wyoming BART Air Modeling Protocol.

4.5 Presentation of Modeling Results

This section presents the results of the CALPUFF visibility improvement modeling analysis for Jim Bridger 2.

4.5.1 Visibility Changes for Baseline vs. Preferred Scenario

CH2M HILL modeled Jim Bridger 2 for the baseline conditions and post-control scenarios. The post-control scenarios included emission rates for NO_x, SO₂, and PM₁₀ that would be achieved if BART technology were installed on Unit 2.

Baseline (and post-control) 98th percentile results were greater than 0.5 ΔdV for the Bridger, Fitzpatrick, and Mt. Zirkel WAs. The 98th percentile results for each Class I area are presented in Table 4-4.

TABLE 4.4
Costs and Visibility Modeling Results for Baseline vs. Post-control Scenarios at Class / Areas
Jim Bridger 2

Scenario	Total First Year Annualized Cost	Class / Area	Modeling Results			Number (No.) of Days Above 0.5 dV	Cost per Reduction in No. of Days Above 0.5 dV	Incremental Cost per dV Reduction	Incremental Cost per Reduction in No. of Days Above 0.5 dV
			Highest Delta- (dV)	95th Percentile Delta- (dV)	95th Percentile Delta- (dV)				
2001									
Baseline: current operation with wet FGD, ESP		Bridger WA	1,730	0.530		10			
		Fitzpatrick WA	1,358	0.298		4			
		ML Zirkel WA	1,394	0.842		23			
Scenario 1: Existing LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	\$2,494,828	Bridger WA	1,370	0.585		7	\$17,205,710	\$831,609	\$2,484,828
	\$2,494,828	Fitzpatrick WA	1,368	0.223		3	\$22,888,330	\$358,404	\$2,484,828
	\$2,494,828	ML Zirkel WA	1,163	0.733		18	\$77,112,131	\$2,213,085	\$2,484,828
Scenario 2: Existing LNB with OFA, upgrade wet FGD, polishing fabric filter	\$8,852,380	Bridger WA	1,366	0.375		6	\$100,595,230	\$488,042,485	\$8,852,380
	\$8,852,380	Fitzpatrick WA	1,177	0.210		3	\$54,983,728	\$1,106,548	\$8,852,380
	\$8,852,380	ML Zirkel WA	1,103	0.881		15	\$8,476,618	\$86,825,531	\$8,852,380
Scenario 3: Existing LNB with OFA and SCR, upgrade wet FGD, FGC for enhanced ESP performance	\$17,187,631	Bridger WA	0.876	0.279		3	\$100,512,463	\$6,729,210	\$17,187,631
	\$17,187,631	Fitzpatrick WA	0.678	0.127		1	\$44,412,484	\$954,868	\$17,187,631
	\$17,187,631	ML Zirkel WA	0.758	0.455		5	\$89,867,113	\$3,383,588	\$17,187,631
Scenario 4: Existing LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	\$23,545,184	Bridger WA	0.838	0.268		3	\$136,099,327	\$7,848,395	\$23,545,184
	\$23,545,184	Fitzpatrick WA	0.657	0.125		1	\$58,424,773	\$1,121,199	\$23,545,184
	\$23,545,184	ML Zirkel WA	0.731	0.439		2			\$23,545,184
2002									
Baseline: current operation with wet FGD, ESP		Bridger WA	2,838	0.880		20			
		Fitzpatrick WA	1,273	0.534		8			
		ML Zirkel WA	1,975	1.008		18			
Scenario 1: Existing LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	\$2,494,828	Bridger WA	2,442	0.847		14	\$17,448,349	\$415,805	\$2,494,828
	\$2,494,828	Fitzpatrick WA	1,073	0.377		5	\$15,890,624	\$831,609	\$2,494,828
	\$2,494,828	ML Zirkel WA	1,545	0.815		13	\$12,926,570	\$488,666	\$2,494,828
Scenario 2: Existing LNB with OFA, upgrade wet FGD, polishing fabric filter	\$8,852,380	Bridger WA	-2,317	0.784		13	\$42,972,720	\$1,264,626	\$8,852,380
	\$8,852,380	Fitzpatrick WA	0.937	0.348		6	\$47,593,442	\$4,426,180	\$8,852,380
	\$8,852,380	ML Zirkel WA	1,487	0.777		13	\$98,321,982	\$1,770,478	\$8,852,380
Scenario 3: Existing LNB with OFA and SCR, upgrade wet FGD, FGC for enhanced ESP performance	\$17,187,631	Bridger WA	1,316	0.516		9	\$36,260,825	\$91,101,683	\$17,187,631
	\$17,187,631	Fitzpatrick WA	0.846	0.228		1	\$85,803,997	\$2,455,376	\$17,187,631
	\$17,187,631	ML Zirkel WA	0.884	0.474		5	\$32,186,575	\$1,322,125	\$17,187,631
Scenario 4: Existing LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	\$23,545,184	Bridger WA	1,280	0.489		7	\$47,953,531	\$1,811,168	\$23,545,184
	\$23,545,184	Fitzpatrick WA	0.936	0.222		1	\$75,465,332	\$3,383,588	\$23,545,184
	\$23,545,184	ML Zirkel WA	0.865	0.465		4	\$43,361,296	\$1,681,799	\$23,545,184

TABLE 4.4
Oasis and Visibility Modeling Results for Baseline vs. Post-control Scenarios at Class I Areas
Jim Bridger 2

Scenario	Class I Area	Highest Delta- (dV)	Modeling Results		Number (No.) of Days Above 0.5 dV	Incremental Cost per dV Reduction	Incremental Cost Reduction in No. of Days Above 0.5 dV
			98th Percentile Delta- (dV)	Cost per Reduction in No. of Days Above 0.5 dV			
2003							
Baseline: current operation with wet FGD, ESP	Bridger WA	1,208	0.533	-	-	-	-
	Fitzpatrick WA	1,348	0.283	-	-	-	-
	Mt. Zirkel WA	1,304	0.803	-	-	-	-
Scenario 1: Existing LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	Bridger WA	0.985	0.416	\$21,323,318	\$623,707	\$2,494,828	NA
	Fitzpatrick WA	1,118	0.200	\$38,600,444	\$2,494,828	\$2,494,828	NA
	Mt. Zirkel WA	1,043	0.735	-\$10,985,116	\$623,707	\$135,287,070	\$6,957,552
Scenario 2: Existing LNB with OFA, upgrade wet FGD, polishing fabric filter	Bridger WA	0.983	0.409	\$71,390,163	\$2,213,095	\$808,221,758	NA
	Fitzpatrick WA	1,090	0.188	\$118,031,737	\$9,852,380	\$528,796,025	NA
	Mt. Zirkel WA	1,054	0.688	\$76,977,220	\$1,770,476	\$135,287,070	\$6,957,552
Scenario 3: Existing LNB with OFA and SCR, upgrade wet FGD, FGC for enhanced ESP performance	Bridger WA	0.852	0.258	\$62,500,477	\$2,864,605	\$5,200,338	NA
	Fitzpatrick WA	0.683	0.118	\$118,535,388	\$17,187,631	\$119,075,014	NA
	Mt. Zirkel WA	0.687	0.438	\$46,705,520	\$1,145,842	\$2,945,656	\$833,525
Scenario 4: Existing LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	Bridger WA	0.808	0.248	\$82,614,878	\$3,924,197	\$635,755,230	NA
	Fitzpatrick WA	0.665	0.115	\$159,089,078	\$23,545,184	\$2,118,184,101	NA
	Mt. Zirkel WA	0.635	0.423	\$81,981,009	\$1,569,679	\$23,796,025	NA
3-year Averages							
Baseline: current operation with wet FGD, ESP	Bridger WA	0.684	0.684	-	-	-	-
	Fitzpatrick WA	0.365	0.365	-	-	-	-
	Mt. Zirkel WA	0.684	0.684	-	-	-	-
Scenario 1: Existing LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	Bridger WA	0.549	0.549	\$18,480,207	\$75,730	\$9,536,328	NA
	Fitzpatrick WA	0.267	0.267	\$25,371,132	\$1,496,897	\$3,572,250	NA
	Mt. Zirkel WA	0.761	0.761	\$20,226,335	\$467,780	\$9,536,328	NA
Scenario 2: Existing LNB with OFA, upgrade wet FGD, polishing fabric filter	Bridger WA	0.523	0.523	\$54,756,931	\$1,770,476	\$238,408,211	NA
	Fitzpatrick WA	0.249	0.249	\$76,094,959	\$6,639,285	\$35,197,350	NA
	Mt. Zirkel WA	0.715	0.715	\$52,980,948	\$1,475,397	\$138,216,474	\$9,536,328
Scenario 3: Existing LNB with OFA and SCR, upgrade wet FGD, FGC for enhanced ESP performance	Bridger WA	0.351	0.351	\$51,562,894	\$2,148,454	\$48,554,860	\$2,776,417
	Fitzpatrick WA	0.157	0.157	\$82,632,842	\$4,687,596	\$90,930,011	\$3,572,250
	Mt. Zirkel WA	0.455	0.455	\$40,002,245	\$1,120,932	\$31,976,666	\$893,063
Scenario 4: Existing LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	Bridger WA	0.338	0.338	\$68,049,663	\$2,716,752	\$501,912,024	\$9,536,328
	Fitzpatrick WA	0.154	0.154	\$111,588,548	\$6,421,414	\$2,118,184,101	NA
	Mt. Zirkel WA	0.442	0.442	\$53,288,646	\$1,412,711	\$915,477,214	\$4,768,164

NOTES:
Sample Calculations: Cost per dV Reduction for Scenario 1 for 2001: = \$2,494,828 / (0.814 - 0.424) = \$5,936,995
Sample Calculations: Cost per Reduction in No. of Days Exceeding 0.5 dV for 2001: = \$2,494,828 / (20 - 7) = \$181,910.

5.0 Preliminary Assessment and Recommendations

As a result of the completed technical and economic evaluations, and consideration of the modeling analysis for Jim Bridger 2, the preliminary recommended BART controls for NO_x, SO₂, and PM are as follows:

- Existing LNBs and OFA system for NO_x control
- Upgrade the existing wet sodium FGD for SO₂ control
- Add flue gas conditioning upstream of the existing ESP for PM control

The above recommendations were identified as Scenario 1 for the modeling analysis described in Section 4. Visibility improvements for all emission control scenarios were analyzed, and the results are compared below, utilizing a least-cost envelope, as outlined in the draft EPA 1990 *New Source Review Workshop Manual* (EPA, 1990, hereafter referred to as NSR Manual). The purpose of this analysis is to use an objective, EPA-approved methodology to evaluate and make the final recommendation of BART control technology.

5.1 Least-cost Envelope Analysis

For the control scenarios modeled in Section 4, Tables 5-1 through 5-3 list the total annualized cost, cost per dV reduction, and cost per reduction in number of days above 0.5 dV for each of the three Class I areas. A comparison of the incremental results between selected scenarios is provided in Tables 5-4 through 5-6. Figures 5-1 to 5-6 show the total annualized cost versus number of days above 0.5 dV, and the total annualized cost versus 98th percentile ΔdV reduction, for the three Class I areas.

5.1.1 Analysis Methodology

On page B-41 of the New Source Manual, EPA states that "incremental cost-effectiveness comparisons should focus on annualized cost and emission reduction differences between dominant alternatives. Dominant set of control alternatives are determined by generating what is called the envelope of least-cost alternatives. This is a graphical plot of total annualized costs for a total emissions reductions for all control alternatives identified in the BACT analysis..."

An analysis of incremental cost effectiveness has been conducted. This analysis was performed in the following way. First, the control option scenarios are ranked in ascending order of annualized total costs, as shown in Tables 5-1 through 5-3. The incremental cost effectiveness data, expressed per day and per dV, represents a comparison of the different scenarios, and is summarized in Tables 5-4 through 5-6 for each of the three wilderness areas. Then the most reasonable smooth curve of least-cost control option scenarios is plotted for each analysis. Figures 5-1 through 5-6 present the two analyses (cost per dV reduction and cost per reduction in number of days above 0.5 dV) for each of the three Class I areas affected by the operation of Jim Bridger 2.

In Figure 5-1, the four scenarios are compared as a graph of total annualized cost versus number of days above 0.5 dV. EPA states that "in calculating incremental costs, the analysis should only be conducted for control options that are dominant among all possible options." In Figure 5-1, the dominant set of control options, Scenarios 1, 3 and 4, represent the least-cost envelope depicted by the curvilinear line connecting them. Scenario 2 is an inferior option and should not be considered in the derivation of incremental cost effectiveness. Scenario 2 represents inferior controls, because Scenario 1 provides approximately the same amount of visibility impact reduction for less cost than Scenario 2. The incremental cost effectiveness is determined by the difference in total annual costs between two contiguous scenarios divided by the difference in emissions reduction.

TABLE 5-1
Control Scenario Results for the Bridger Class 1 Wilderness Area
Jim Bridger 2

Scenario	Controls	98 th Percentile deciview (dV) Reduction	Average Number of Days Above 0.5 dV (Days)	Total Annualize d Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet Flue Gas Desulfurization (FGD), Electrostatic Precipitator (ESP)	0.00	0.0	\$0.0	\$0.0	\$0.0
1	Existing Low-NO _x burner (LNB) with OFA, upgraded wet FGD system, and Flue Gas Conditioning (FGC) for enhanced ESP performance	0.14	4.3	\$2.5	\$18.5	\$0.6
2	LNB with OFA, upgraded wet FGD system, and new polishing fabric filter	0.16	5.0	\$8.9	\$54.8	\$1.8
3	LNB with OFA and SCR, upgraded wet FGD system, FGC for enhanced ESP performance	0.33	8.0	\$17.2	\$51.6	\$2.1
4	LNB with OFA and SCR, upgraded wet FGD system, new polishing fabric filter	0.35	8.7	\$23.5	\$68.0	\$2.7

TABLE 5-2
Control Scenario Results for the Fitzpatrick Class I Wilderness Area
Jim Bridger 2

Scenario	Controls	98 th Percentile dV Reduction	Average Number of Days Above 0.5 dV (Days)	Total Annualized Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet FGD and ESP	0.00	0.0	\$0.0	\$0.0	\$0.0
1	Existing LNB with OFA, upgraded wet FGD system, and FGC for enhanced ESP performance	0.10	1.7	\$2.5	\$25.4	\$1.5
2	LNB with OFA, upgraded wet FGD system, and new polishing fabric filter	0.12	1.3	\$8.9	\$76.1	\$6.6
3	LNB with OFA and SCR, upgraded wet FGD system, FGC for enhanced ESP performance	0.21	3.7	\$17.2	\$82.6	\$4.7
4	LNB with OFA and SCR, upgraded wet FGD system, new polishing fabric filter	0.21	3.7	\$23.5	\$111.6	\$6.4

TABLE 5-3
Control Scenario Results for the Mt. Zirkel Class I Wilderness Area
Jim Bridger 2

Scenario	Controls	98 th Percentile dV Reduction	Average Number of Days Above 0.5 dV (Days)	Total Annualized Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet FGD and ESP	0.00	0.0	\$0.0	\$0.0	\$0.0
1	Existing LNB with OFA, upgraded wet FGD system, and FGC for enhanced ESP performance	0.12	5.3	\$2.5	\$20.2	\$0.5
2	LNB with OFA, upgraded wet FGD system, and new polishing fabric filter.	0.17	6.0	\$8.9	\$52.4	\$1.5
3	LNB with OFA and SCR, upgraded wet FGD system, FGC for enhanced ESP performance	0.43	15.3	\$17.2	\$40.0	\$1.1
4	LNB with OFA and SCR, upgraded wet FGD system, new polishing fabric filter.	0.44	16.7	\$23.5	\$53.3	\$1.4

TABLE 5-4
Bridger Class I Wilderness Area Incremental Analysis Data
Jim Bridger 2

Options Compared	Incremental Reduction in Days Above 0.5 deciview (dV) (Days)	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	4.3	0.14	\$0.58	\$18.5
Scenario 1 and Scenario 2	0.7	0.03	\$9.5	\$238.4
Scenario 1 and Scenario 3	3.7	0.20	\$4.0	\$74.1
Scenario 1 and Scenario 4	4.3	0.21	\$4.9	\$99.8

TABLE 5-5
Fitzpatrick Class I Wilderness Area Incremental Analysis Data
Jim Bridger 2

Options Compared	Incremental Reduction in Days Above 0.5 deciview (dV) (Days)	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	1.7	0.10	\$1.50	\$25.4
Scenario 1 and Scenario 2	NA	0.02	NA	\$353.2
Scenario 1 and Scenario 3	2.0	0.11	\$7.3	\$134.0
Scenario 1 and Scenario 4	2.0	0.11	\$10.5	\$186.8

TABLE 5-6
Mt. Zirkel Class I Wilderness Area Incremental Analysis Data
Jim Bridger 2

Options Compared	Incremental Reduction in Days Above 0.5 dV (Days)	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	5.3	0.12	\$0.47	\$20.23
Scenario 1 and Scenario 2	0.7	0.05	\$9.5	\$139.2
Scenario 1 and Scenario 3	10.0	0.31	\$1.5	\$48.0
Scenario 1 and Scenario 4	11.3	0.32	\$1.9	\$66.1

FIGURE 5-1
Least-cost Envelope Bridger Class I Wilderness Area Days Reduction
Jim Bridger 2




FIGURE 5-2
Least-cost Envelope Bridger Wilderness Area Class I Area 98th Percentile Reduction
Jim Bridger 2




FIGURE 5-3
 Least-cost Envelope Fitzpatrick Class I Wilderness Area Days Reduction
Jim Bridger 2




FIGURE 5-4
 Least-cost Envelope Fitzpatrick Class I Wilderness Area 98th Percentile Reduction
Jim Bridger 2




FIGURE 5-5
Least-cost Envelope Mt. Zirkel Class I Wilderness Area Days Reduction
Jim Bridger 2





FIGURE 5-6
Least-cost Envelope Mt. Zirkel Class I Wilderness Area 98th Percentile Reduction
Jim Bridger 2



5.1.2 Analysis Results

Results of the least-cost analysis, shown in Tables 5-1 through 5-6 and Figures 5-1 through 5-6 on the preceding pages, confirm the selection of Scenario 1, based on incremental cost and visibility improvements. Scenario 2 is eliminated because it is to the left of the curve formed by the dominant control alternative scenarios, which indicates a scenario with lower improvement and/or higher costs. Scenario 3 is not selected due to very high incremental costs for both a cost per day of improvement and a cost per dV reduction. While Scenario 4 provides some potential visibility advantage over Scenario 1, the projected improvement is less than half a dV, and the projected costs are excessive.

Analysis of the results for the Jim Bridger Class 1WA in Tables 5-1 and 5-4 and Figures 5-1 and 5-2 illustrates the conclusions stated above. The greatest reduction in 98th percentile dV and number of days above 0.5 dV is between the baseline and Scenario 1. The incremental cost effectiveness for Scenario 1 compared with the baseline for the Bridger WA, for example, is reasonable at \$580,000 per day and \$18.5 million per deciview. However, the incremental cost effectiveness for Scenario 3 compared with Scenario 1 is excessive at \$4.0 million per day and \$71.1 million per deciview. The same conclusions are reached for each of the three WAs studied. Therefore, Scenario 1 represents BART for Jim Bridger 2.

5.2 Recommendations

5.2.1 NO_x Emission Control

The BART presumptive NO_x limit assigned by EPA for tangentially fired boilers burning sub-bituminous coal is 0.15 lb per MMBtu. However, as documented in Section 3.2.1, the characteristics of the Jim Bridger coals are more closely aligned with bituminous coals, with a presumptive BART NO_x limit of 0.28 lb per MMBtu.

CH2M HILL recommends the existing LNBS with OFA (LNB with OFA) as BART for Jim Bridger 2, based on the projected significant reduction in NO_x emissions, reasonable control costs, and the advantages of no additional power requirements or non-air quality environmental impacts. NO_x reductions have been realized at Jim Bridger 2. CH2M HILL recommends that the unit be permitted at a rate of 0.26 lb per MMBtu.

5.2.2 SO₂ Emission Control

CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 2, based on the significant reduction in SO₂ emissions, reasonable control costs, and the advantages of minimal additional power requirements and minimal non-air quality environmental impacts. This upgrade approach will meet the BART presumptive SO₂ limit of 0.15 lb per MMBtu.

5.2.3 PM₁₀ Emission Control

CH2M HILL recommends finalizing the permitting of the FGC system to enhance the performance of the existing ESP as BART for Jim Bridger 2, based on the significant reduction in PM₁₀ emissions, reasonable control costs, and the advantages of minimal additional power requirements and no non-air quality environmental impacts.

5.3 Just-Noticeable Differences in Atmospheric Haze

Conclusions reached in the reference document "Just-Noticeable Differences in Atmospheric Haze" by Dr. Ronald Henry (2002), state that only dV differences of approximately 1.5 to 2.0 dV, or more are perceptible by the human eye. Deciview changes of less than 1.5 cannot be distinguished by the average person. Therefore, the modeling analysis results indicate that only minimal, if any, observable visibility improvements at the Class I areas studied would be expected under any of the scenarios. Thus the results indicate that even though many millions of dollars will be spent, only minimal, if any, visibility improvements could result.

None of the data were corrected for natural obscuration. Water in various forms (fog, clouds, snow, or rain) or other naturally caused aerosols can obscure the atmosphere and reduce visibility. During the period of 2001 through 2003, there were several mega-wildfires that lasted for many days, with a significant impact on background visibility in these Class I areas. If natural obscuration lessens the achievable reduction in visibility impacts modeled for BART controls at the Jim Bridger 2 facility, the overall effect would be to increase the costs per dV reduction that are presented in this report.

6.0 References

- 40 CFR Part 51. *Regional Haze Regulations and Guidelines for Best Available Retrofit Technology Determinations; Final Rule*. July 6, 2005.
- Energy Information Administration, 2006. *Official Energy Statistics from the U.S. Government: Coal*. <http://www.eia.doe.gov/fuelcoal.html>. Accessed October 2006.
- EPA, 1990. *New Source Review Workshop Manual—Prevention of Significant Deterioration and Nonattainment Area Permitting*. Draft. October 1990.
- EPA, 2003. *Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule*. Environmental Protection Agency. EPA-454/8-03-005. September 2003.
- Henry, Ronald, 2002. "Just-Noticeable Differences in Atmospheric Haze," *Journal of the Air & Waste Management Association*. Volume 52, p. 1238.
- National Oceanic and Atmospheric Administration, 2006. U.S. Daily Weather Maps Project. http://docs.lib.noaa.gov/rescue/dwm/data_rescue_daily_weather_maps.html. Accessed October 2006.
- North Dakota Department of Health, 2005. *Protocol for BART-Related Visibility Improvement Modeling Analysis in North Dakota*. North Dakota Department of Health. October 26, 2005.
- Sargent & Lundy, 2002. *Multi-Pollutant Control Report*. October 2002.
- Sargent & Lundy, 2006. *Multi-Pollutant Control Report*. Revised. October 2006.
- WDEQ-AQD, 2006. *BART Air Modeling Protocol—Individual Source Visibility Assessments for BART Control Analyses*. Wyoming Department of Environmental Quality – Air Quality Division. September 2006.

APPENDIX A
Economic Analysis

PacifiCorp BART Analysis Scenarios

Select Unit: **4** Jim Bridger Unit 2

Index No.	Name of Unit
1	Dave Johnston Unit 3
2	Dave Johnston Unit 4
3	Jim Bridger Unit 1
4	Jim Bridger Unit 2
5	Jim Bridger Unit 3
6	Jim Bridger Unit 4
7	Naughton Unit 1
8	Naughton Unit 2
9	Naughton Unit 3
10	Wyodak Unit 1

Index No.	Dave Johnston				Naughton				Wyodak						
	D.J Unit 3		D.J Unit 4		NTN Unit 1		NTN Unit 2		NTN Unit 3		JB Unit 1		JB Unit 2		
Scenario	First Year Cost	Scenario	First Year Cost	Scenario	First Year Cost	Scenario	First Year Cost	Scenario	First Year Cost	Scenario	First Year Cost	Scenario	First Year Cost	Scenario	First Year Cost
Baseline - Current Operation with ESP	N/A	Baseline - Current Operation with Venturi Scrubber	N/A	Baseline - Current Operation with ESP	N/A	Baseline - Current Operation with Wet FGD and ESP	N/A	Baseline - Current Operation with Wet FGD and ESP	N/A	Baseline - Current Operation with Wet FGD and ESP	N/A	Baseline - Current Operation with Dry FGD, Fabric Filter	N/A	Baseline - Current Operation with Dry FGD, Fabric Filter	N/A
Scenario 1 - LNB with OFA, Dry FGD, Existing ESP	N/A	Scenario 1 - LNB with OFA, Dry FGD, Fabric Filter	N/A	Scenario 1 - LNB with OFA, Dry FGD, ESP	N/A	Scenario 1 - LNB with OFA, Wet FGD, ESP	N/A	Scenario 1 - LNB with OFA, Dry FGD, New Fabric Filter	N/A	Scenario 1 - LNB with OFA, Wet FGD, New Fabric Filter	N/A	Scenario 1 - LNB with OFA, Dry FGD, Fabric Filter	N/A	Scenario 1 - LNB with OFA, Dry FGD, Fabric Filter	N/A
Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	N/A
Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	N/A	Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	N/A	Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	N/A	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	N/A	Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	N/A	Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	N/A	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	N/A	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	N/A
Scenario 4 - LNB with OFA and SCR, Wet FGD, Existing ESP, New Stack	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, ESP, New Stack	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, ESP, New Stack	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, ESP, New Stack	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, ESP, New Stack	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A

ECONOMIC ANALYSIS SUMMARY

Jim Bridger Unit 2

Boiler Design: Tangential-Fired PC

Parameter	NOx Control				SO2 Control			PM Control	
	Current Operation	Exist. LNB WFOFA	ROFA	SNCR	SCR	Upgraded Wet FGD	Flue Gas Conditioning	Flue Gas Conditioning	Fabric Filter
Case	1	2	3	4	5	8	8	8	10
NOx Emission Control System	LNB - TFS 2000	Exdrt. LNB w/WOFA	ROFA	SNCR	SCR	LNB - TFS 2000	LNB - TFS 2000	LNB - TFS 2000	LNB - TFS 2000
SO2 Emission Control System	Wet FGD	Wet FGD	Wet FGD	Wet FGD	Wet FGD	Upgraded Wet FGD	Wet FGD	Wet FGD	Wet FGD
PM Emission Control System	ESP	ESP	ESP	ESP	ESP	ESP	Flue Gas Conditioning	Flue Gas Conditioning	Fabric Filter
TOTAL INSTALLED CAPITAL COST (\$)	0	0	20,528,122	13,427,239	120,875,494	12,898,900	0	0	48,386,333
FIRST YEAR O&M COST (\$)									
Operating Labor (\$)	0	0	0	0	0	0	0	0	0
Maintenance Material (\$)	0	0	42,000	85,000	162,000	25,550	0	0	51,099
Maintenance Labor (\$)	0	0	63,000	142,500	243,000	17,033	10,000	0	76,649
Administrative Labor (\$)	0	0	0	0	0	0	0	0	0
TOTAL FIXED O&M COST	0	0	105,000	237,500	405,000	42,583	10,000	0	127,749
Makeup Water Cost	0	0	0	0	0	30,503	0	0	0
Reagent Cost	0	0	0	536,432	912,848	533,206	145,854	0	0
SCR Catalyst / FF Bag Cost	0	0	0	0	894,000	0	0	0	300,040
Waste Disposal Cost	0	0	0	0	0	442,958	0	0	0
Electric Power Cost	0	0	2,528,012	208,926	1,282,333	208,926	19,710	0	1,326,877
TOTAL VARIABLE O&M COST	0	0	2,528,012	245,358	2,769,181	1,215,593	165,564	0	1,626,917
TOTAL FIRST YEAR O&M COST	0	0	2,533,012	982,858	3,194,181	1,258,176	175,564	0	1,754,666
FIRST YEAR DEBT SERVICE (\$)	0	0	1,952,796	1,277,304	11,488,823	1,238,852	0	0	4,602,887
TOTAL FIRST YEAR COST (\$)	0	0	4,585,808	2,260,162	14,692,303	2,494,828	175,564	0	6,357,552
Power Consumption (MM)	0.0	0.0	6.4	0.5	3.3	0.5	0.1	0.1	3.4
Annual Power Usage (Million kWh/Yr)	0.0	0.0	50.6	4.2	25.6	4.2	0.4	0.4	26.5
CONTROL COST (\$/Ton Removed)									
NOx Removal Rate (%)	0.0%	0.0%	8.3%	16.7%	70.8%	0.0%	0.0%	0.0%	0.0%
NOx Removed (Tons/Yr)	0	0	473	946	4,021	0	0	0	0
First Year Average Control Cost (\$/Ton NOx Rem.)	0	0	9,695	2,389	3,654	0	0	0	0
Incremental Control Cost (\$/Ton NOx Removed)	0	0	9,695	2,389	4,044	0	0	0	0
SO2 Removal Rate (%)	77.3%	0.0%	0.0%	0.0%	0.0%	62.5%	0.0%	0.0%	0.0%
SO2 Removed (Tons/Yr)	0	0	0	0	0	3,950	0	0	0
First Year Average Control Cost (\$/Ton SO2 Rem.)	0	0	0	0	0	632	0	0	0
Incremental Control Cost (\$/Ton SO2 Removed)	Base	0	0	0	0	632	0	0	0
PM Removal Rate (%)	99.13%	0.00%	0.00%	0.00%	0.00%	0.00%	59.46%	1,041	79.73%
PM Removed (Tons/Yr)	0	0	0	0	0	0	1,041	1,395	1,041
First Year Average Control Cost (\$/Ton PM Rem.)	0	0	0	0	0	0	169	4,556	169
Incremental Control Cost (\$/Ton PM Removed)	Base	0	0	0	0	0	169	17,426	17,426
PRESENT WORTH COST (\$)	0	0	52,687,883	25,435,659	159,901,524	28,372,107	2,145,015	0	69,824,582

INPUT CALCULATIONS

Jim Bridger Unit 2

Parameter	Boiler Design:										Comments		
	Tangential-Fired PC					NOx Control						PM Control	
	Current Operation	Exist. LNB w/OFA	ROFA	SNCR	SCR	SO2 Control	Flue Gas Conditioning	Fabric Filter					
Case	1	2	3	4	5	6	7	8	9	10			
NOx Emission Control System	LNB - TFS 2000 Wet FGD	Exist. LNB w/OFA Wet FGD	ROFA Wet FGD	SNCR Wet FGD	SCR Wet FGD	LNB - TFS 2000 Upgraded Wet FGD	LNB - TFS 2000 Wet FGD	LNB - TFS 2000 Wet FGD	LNB - TFS 2000 Wet FGD	LNB - TFS 2000 Wet FGD	LNB - TFS 2000 Wet FGD		
SO2 Emission Control System	ESP	ESP	ESP	ESP	ESP	ESP	ESP	ESP	Flue Gas Conditioning	Fabric Filter			
Unit Design and Coal Characteristics													
Type of Unit	PC	PC	PC	PC	PC	PC	PC	PC	PC	PC	PC		
Net Power Output (KW)	630,000	630,000	630,000	630,000	630,000	630,000	630,000	630,000	630,000	630,000	630,000		
Net Plant Heat Rate (Btu/KWh)	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320		
Boiler Fuel	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground		
Coal Heating Value (Btu/Lb)	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660		
Coal Sulfur Content (wt.%)	0.68%	0.68%	0.68%	0.68%	0.68%	0.68%	0.68%	0.68%	0.68%	0.68%	0.68%		
Coal Ash Content (wt.%)	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%		
Boiler Heat Input, each (MMBtu/Hr)	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000		
Coal Flow Rate (Lb/Hr)	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077		
(Ton/Yr)	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284		
(MMBtu/Yr)	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846		
Emissions													
Uncontrolled SO2 (Lb/Hr)	7,210	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602		
(Lb/MMBtu)	1.20	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27		
(Lb Moles/Hr)	112,84	25,00	25,00	25,00	25,00	25,00	25,00	25,00	25,00	25,00	25,00		
(Tons/Yr)	29,421	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315		
SO2 Removal Rate (%)	77.8%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%		
(Lb/Hr)	5,608	0	0	0	0	0	0	0	0	0	0		
(Ton/Yr)	22,106	0	0	0	0	0	0	0	0	0	0		
SO2 Emission Rate (Lb/Hr)	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602		
(Lb/MMBtu)	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27		
(Ton/Yr)	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315		
Uncontrolled NOx (Lb/Hr)	1,440	1,440	1,440	1,440	1,440	1,440	1,440	1,440	1,440	1,440	1,440		
(Lb/MMBtu)	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24		
(Lb Moles/Hr)	47,98	47,98	47,98	47,98	47,98	47,98	47,98	47,98	47,98	47,98	47,98		
(Tons/Yr)	5,676	5,676	5,676	5,676	5,676	5,676	5,676	5,676	5,676	5,676	5,676		
NOx Removal Rate (%)	0.0%	0.0%	8.3%	15.7%	70.3%	0%	0%	0%	0%	0%	0%		
(Lb/Hr)	0	0	120	240	1,020	0	0	0	0	0	0		
(Lb Moles/Hr)	0.00	0.00	4.00	8.00	33.99	0.00	0.00	0.00	0.00	0.00	0.00		
(Ton/Yr)	0	0	473	846	4,021	0	0	0	0	0	0		
NOx Emission Rate (Lb/Hr)	1,440	1,440	1,320	1,200	420	1,440	1,440	1,440	1,440	1,440	1,440		
(Lb/MMBtu)	0.24	0.24	0.22	0.20	0.07	0.24	0.24	0.24	0.24	0.24	0.24		
(Ton/Yr)	5,676	5,676	5,203	4,730	1,566	5,676	5,676	5,676	5,676	5,676	5,676		
Uncontrolled Fly Ash (Lb/Hr)	51,177	444	444	444	444	444	444	444	444	444	444		
(Lb/MMBtu)	8.50	0.074	0.074	0.074	0.074	0.074	0.074	0.074	0.074	0.074	0.074		
(Lb Moles/Hr)	1,705.3	14.8	14.8	14.8	14.8	14.8	14.8	14.8	14.8	14.8	14.8		
(Tons/Yr)	20,173.9	1,750	1,750	1,750	1,750	1,750	1,750	1,750	1,750	1,750	1,750		
Fly Ash Removal Rate (%)	89.13%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	59.46%	79.73%	35.4		
(Lb/Hr)	50,733	0	0	0	0	0	0	0	264	354	1,395		
(Ton/Yr)	199,988	0	0	0	0	0	0	0	1,041	1,395	5,015		
Fly Ash Emission Rate (Lb/Hr)	444	444	444	444	444	444	444	444	180	90	365		
(Lb/MMBtu)	0.074	0.074	0.074	0.074	0.074	0.074	0.074	0.074	0.030	0.015	0.015		
(Ton/Yr)	1,750	1,750	1,750	1,750	1,750	1,750	1,750	1,750	710	365	365		

Parameter	Current Operation		NOX Control				SO2 Control		PM Control		Comments
	Exist. LNB w/OFA	ROFA	SNCR	SCR	Flue Gas Conditioning	Fabric Filter	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter		
Case	1	2	3	4	5	6	7	8	9	10	
General Plant Data											
Annual Operation (Hours/Year)	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	
Annual On-Site Power Plant Capacity Factor	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	
Economic Factors											
Interest Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	
Discount Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	
Plant Economic Life (Years)	20	20	20	20	20	20	20	20	20	20	
Installed Capital Costs											
NOx Emission Control System (\$2006)	0	0	20,528,122	13,427,239	120,875,494	120,875,494	12,999,900	0	0	0	
SO2 Emission Control System (\$2006)	0	0	0	0	0	0	0	0	0	0	
PM Emission Control System (\$2006)	0	0	0	0	0	0	0	0	0	48,386,333	
Total Emission Control Systems (\$2006)	0	0	20,528,122	13,427,239	120,875,494	120,875,494	12,999,900	0	0	48,386,333	
NOx Emission Control System (\$/kW)	0	0	39	25	228	228	0	0	0	0	
SO2 Emission Control System (\$/kW)	0	0	0	0	0	0	25	0	0	0	
PM Emission Control System (\$/kW)	0	0	0	0	0	0	0	0	0	0	
Total Emission Control Systems (\$/kW)	0	0	39	25	228	228	25	0	0	0	
Total Fixed Operating & Maintenance Costs											
Operating Labor (\$)	0	0	0	0	0	0	0	0	0	0	
Maintenance Material (\$)	0	0	42,000	95,000	162,000	162,000	25,550	0	0	51,099	
Maintenance Labor (\$)	0	0	63,000	142,500	243,000	243,000	17,033	10,000	10,000	76,549	
Administrative Labor (\$)	0	0	0	0	0	0	0	0	0	0	
Total Fixed O&M Cost (\$)	0	0	105,000	237,500	405,000	405,000	42,583	10,000	10,000	127,649	
Annual Fixed O&M Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
Water Cost											
Makeup Water Usage (Gpm)	0	0	0	0	0	0	53	0	0	0	
Unit Price (\$/1000 Gallons)	1.22	1.22	1.22	0.00	1.22	1.22	1.22	1.22	1.22	1.22	
First Year Water Cost (\$)	0	0	0	0	0	0	65	0	0	0	
Annual Water Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
Reagent Cost											
Unit Cost (\$/Ton)	None	None	None	Urea	Anhydrous NH3	Soda Ash	Elemental Sulfur	Elemental Sulfur	None	None	
Unit Cost (\$/LB)	0.00	0.00	0.00	370	400	80.00	370	370	0.00	0.00	
Molar Stoichiometry	0.00	0.00	0.00	0.185	0.200	0.040	0.185	0.185	0.00	0.00	
Reagent Purity (Wt-%)	0.00	0.00	0.00	0.45	1.00	1.02	1.02	1.00	0.00	0.00	
Reagent Usage (Lb/Hr)	0	0	0	368	679	1,691	100	100	90	90	
First Year Reagent Cost (\$)	0	0	0	536,432	912,848	533,206	145,864	145,864	0	0	
Annual Reagent Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
SCR Catalyst / FF Bag Replacement Cost											
Annual SCR Catalyst (m3) / No. FF Bags	0	0	0	0	198	0	0	0	0	0	
SCR Catalyst (\$/m3) / Bag Cost (\$/Bag)	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	
First Year SCR Catalyst / Bag Replace. Cost (\$)	0	0	0	0	594,000	0	0	0	0	0	
Annual SCR Catalyst / Bag Cost Esc. Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
FGD Waste Disposal Cost											
FGD Solid Waste Disposal Rate, Dry (Lb/Hr)	0	0	0	0	0	4,618	0	0	0	0	
FGD Waste Disposal Unit Cost (\$/Dry Ton)	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	
First Year FGD Waste Disposal Cost (\$)	0	0	0	0	0	442,958	0	0	0	0	
Annual Waste Disposal Cost Esc. Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
Auxiliary Power Cost											
Auxiliary Power Requirement (% of Plant Output) (MW)	0.00%	0.00%	1.21%	0.10%	0.61%	0.10%	0.01%	0.01%	0.64%	0.64%	
Unit Cost (\$2006/MW-Hr)	0.00	0.00	6.41	0.53	3.25	0.53	0.05	0.05	3.37	3.37	
First Year Auxiliary Power Cost (\$)	0	0	50.00	50.00	50.00	50.00	50.00	50.00	50.00	50.00	
Annual Power Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	

Input Tables

Table 1 - Cases

Index No.	Name of Unit Case →	PM Control												
		Existing	1	2	3	4	5	6	7	8	9	10		
1	Dave Johnston Unit 3	Current Operation	LNB w/OFA	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Dry FGD w/ESP	Dry FGD w/ESP	Dry FGD w/ESP	Wet FGD w/ESP	N/A	Fabric Filter
2	Dave Johnston Unit 4	Current Operation	LNB w/OFA	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	LNB w/OFA & SNCR	N/A	N/A	N/A	Wet FGD w/ESP	N/A	Fabric Filter
3	Jim Bridger Unit 1	Current Operation	LNB w/OFA	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	LNB w/OFA & SNCR	N/A	N/A	N/A	Wet FGD w/ESP	Flue Gas Conditioning	Fabric Filter
4	Jim Bridger Unit 2	Current Operation	Exakt LNB w/OFA	LNB w/OFA	ROFA	SNCR	SNCR	SNCR	N/A	N/A	N/A	Wet FGD w/ESP	Flue Gas Conditioning	Fabric Filter
5	Jim Bridger Unit 3	Current Operation	LNB w/OFA	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	LNB w/OFA & SNCR	N/A	N/A	N/A	Wet FGD w/ESP	Flue Gas Conditioning	Fabric Filter
6	Jim Bridger Unit 4	Current Operation	LNB w/OFA	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	LNB w/OFA & SNCR	N/A	N/A	N/A	Wet FGD w/ESP	Flue Gas Conditioning	Fabric Filter
7	Naughton Unit 1	Current Operation	LNB w/OFA	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Dry FGD w/ESP	Dry FGD w/ESP	Dry FGD w/ESP	Wet FGD w/ESP	Flue Gas Conditioning	Fabric Filter
8	Naughton Unit 2	Current Operation	LNB w/OFA	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Dry FGD w/ESP	Dry FGD w/ESP	Dry FGD w/ESP	Wet FGD w/ESP	Flue Gas Conditioning	Fabric Filter
9	Naughton Unit 3	Current Operation	Exakt LNB w/OFA	LNB w/OFA	ROFA	SNCR	SNCR	SNCR	N/A	N/A	N/A	Wet FGD w/ESP	Flue Gas Conditioning	Fabric Filter
10	Wyodak Unit 1	Current Operation	LNB w/OFA	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Upgraded Dry FGD	Upgraded Dry FGD	Upgraded Dry FGD	Wet FGD	Flue Gas Conditioning	Fabric Filter

Table 2 - Unit Design and Coal Characteristics

Index No.	Name of Unit	Current Emission Control Systems			Unit Design			Coal Quality			
		NOx	SO2	PM	Boiler Design	Net Power Output (kW)	Net Plant Heat Rate (Btu/kWh)	Coal	Heating Value, HHV (Btu/Lb)	Sulfur Content (Wt.%)	Ash Content (Wt.%)
1	Dave Johnston Unit 3	None	None	ESP	3-Cell Burner, Opposed Wall-Fired PC	250,000	11,200	Dry Fork PRB	7,784	0.47%	6.01%
2	Dave Johnston Unit 4	Windbox Mods., LINCFS-1 & Windbox Mods.	Lime Added to Venturi Scrubber	Venturi Scrubber	Tangential-Fired PC	360,000	11,350	Dry Fork PRB Underground	7,784	0.47%	6.01%
3	Jim Bridger Unit 1	None	Wet FGD	ESP	Tangential-Fired PC	530,000	11,320	Bridger Mine Underground	9,660	0.58%	10.30%
4	Jim Bridger Unit 2	LNB - TFS 2000	Wet FGD	ESP	Tangential-Fired PC	530,000	11,320	Bridger Mine Underground	9,660	0.58%	10.30%
5	Jim Bridger Unit 3	Windbox Mods., LINCFS-1 & Windbox Mods.	Wet FGD	ESP	Tangential-Fired PC	530,000	11,320	Bridger Mine Underground	9,660	0.58%	10.30%
6	Jim Bridger Unit 4	Windbox Mods., LINCFS-1 & Windbox Mods.	Wet FGD	ESP	Tangential-Fired PC	530,000	11,320	Bridger Mine Underground	9,660	0.58%	10.30%
7	Naughton Unit 1	None	None	ESP	Tangential-Fired PC	173,000	10,694	Kemmerer Mine	9,970	0.60%	4.64%
8	Naughton Unit 2	None	None	ESP	Tangential-Fired PC	225,000	10,574	Kemmerer Mine	9,970	0.60%	4.64%
9	Naughton Unit 3	LINCFS II LNB	Wet FGD	ESP	Tangential-Fired PC	356,000	10,336	Kemmerer Mine	9,970	0.60%	4.84%
10	Wyodak Unit 1	LNB	Dry FGD	ESP	Opposed Wall-Fired PC	335,000	12,087	Clevis Point Mine	7,977	0.65%	7.46%

Index No.	Name of Unit	Current Emission Rates (Lb/MMBtu)		NOx Control Emission Rates (Lb/MMBtu)		SO2 Control Emission Rates (Lb/MMBtu)		PM Emission Rates (Lb/MMBtu)				
		Controlled	Controlled NOx	Case 2	Case 3	Case 4	Case 5	Case 6	Case 7	Case 8	Case 9	Case 10
1	Dave Johnston Unit 3	1.20	0.70	0.20	0.27	0.21	0.20	0.21	0.19	0.10	N/A	0.015
2	Dave Johnston Unit 4	0.33	0.43	0.651	0.45	0.19	0.12	N/A	0.15	0.10	N/A	0.015
3	Jim Bridger Unit 1	0.27	0.45	0.846	0.24	0.22	0.20	N/A	N/A	0.10	0.030	0.015
4	Jim Bridger Unit 2	0.27	0.24	0.074	0.24	0.22	0.20	N/A	N/A	0.10	0.030	0.015
5	Jim Bridger Unit 3	0.27	0.45	0.057	0.24	0.22	0.20	N/A	N/A	0.10	0.030	0.015
6	Jim Bridger Unit 4	0.17	0.45	0.030	0.24	0.22	0.20	N/A	N/A	0.10	0.030	0.015
7	Naughton Unit 1	1.20	0.58	0.956	0.24	0.28	0.18	0.18	0.16	0.10	0.040	0.015
8	Naughton Unit 2	1.20	0.54	0.964	0.24	0.28	0.18	0.18	0.16	0.10	0.040	0.015
9	Naughton Unit 3	0.50	0.45	0.094	0.35	0.30	0.25	N/A	N/A	0.10	0.040	0.015
10	Wyodak Unit 1	0.50	0.50	0.030	0.23	0.22	0.18	0.25	N/A	0.10	0.025	0.015

Table 4 - Case 1 O&M Costs (Current Operation)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ -	\$ -	\$ -	-	None	-	-
2	Dave Johnston Unit 4	\$ -	\$ -	\$ -	\$ -	-	None	-	-
3	Jim Bridger Unit 1	\$ -	\$ -	\$ -	\$ -	-	None	-	-
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	-	None	-	-
5	Jim Bridger Unit 3	\$ -	\$ -	\$ -	\$ -	-	None	-	-
6	Jim Bridger Unit 4	\$ -	\$ -	\$ -	\$ -	-	None	-	-
7	Naughton Unit 1	\$ -	\$ -	\$ -	\$ -	-	None	-	-
8	Naughton Unit 2	\$ -	\$ -	\$ -	\$ -	-	None	-	-
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	-	None	-	-
10	Wyodak Unit 1	\$ -	\$ -	\$ -	\$ -	-	None	-	-

Table 5 - Case 2 O&M Costs (LNB w/OFA)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ 40,000	\$ 60,000	\$ -	-	None	-	-
2	Dave Johnston Unit 4	\$ -	\$ 36,000	\$ 54,000	\$ -	-	None	-	-
3	Jim Bridger Unit 1	\$ -	\$ 28,000	\$ 42,000	\$ -	-	None	-	-
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	-	None	-	-
5	Jim Bridger Unit 3	\$ -	\$ -	\$ -	\$ -	-	None	-	-
6	Jim Bridger Unit 4	\$ -	\$ 28,000	\$ 42,000	\$ -	-	None	-	-
7	Naughton Unit 1	\$ -	\$ 32,000	\$ 48,000	\$ -	-	None	-	-
8	Naughton Unit 2	\$ -	\$ 32,000	\$ 48,000	\$ -	-	None	-	-
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	-	None	-	-
10	Wyodak Unit 1	\$ -	\$ 24,000	\$ 36,000	\$ -	-	None	-	-

Table 6 - Case 3 O&M Costs (Mobotec ROFA)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnson Unit 3	\$ -	\$ 50,000	\$ 90,000	\$ -	-	None	-	2.78
2	Dave Johnson Unit 4	\$ -	\$ 54,000	\$ 81,000	\$ -	-	None	-	4.33
3	Jim Bridger Unit 1	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41
4	Jim Bridger Unit 2	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41
5	Jim Bridger Unit 3	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41
6	Jim Bridger Unit 4	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41
7	Naughton Unit 1	\$ -	\$ 48,000	\$ 72,000	\$ -	-	None	-	1.42
8	Naughton Unit 2	\$ -	\$ 48,000	\$ 72,000	\$ -	-	None	-	2.61
9	Naughton Unit 3	\$ -	\$ 48,000	\$ 72,000	\$ -	-	None	-	4.47
10	Wyodak Unit 1	\$ -	\$ 36,000	\$ 54,000	\$ -	-	None	-	5.22

Table 7 - Case 4 O&M Costs (LNB w/OFA & SNCR)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnson Unit 3	\$ -	\$ 96,000	\$ 147,000	\$ -	-	Urea	0.41	0.23
2	Dave Johnson Unit 4	\$ -	\$ 105,000	\$ 157,500	\$ -	-	Urea	0.45	0.33
3	Jim Bridger Unit 1	\$ -	\$ 123,000	\$ 184,500	\$ -	-	Urea	0.45	0.53
4	Jim Bridger Unit 2	\$ -	\$ 96,000	\$ 142,500	\$ -	-	Urea	0.45	0.53
5	Jim Bridger Unit 3	\$ -	\$ 122,000	\$ 183,000	\$ -	-	Urea	0.45	0.52
6	Jim Bridger Unit 4	\$ -	\$ 123,000	\$ 184,500	\$ -	-	Urea	0.45	0.53
7	Naughton Unit 1	\$ -	\$ 83,000	\$ 124,500	\$ -	-	Urea	0.45	0.16
8	Naughton Unit 2	\$ -	\$ 93,000	\$ 139,500	\$ -	-	Urea	0.51	0.22
9	Naughton Unit 3	\$ -	\$ 75,000	\$ 112,500	\$ -	-	Urea	0.45	0.33
10	Wyodak Unit 1	\$ -	\$ 93,000	\$ 139,500	\$ -	-	Urea	0.45	0.34

Table 8 - Case 5 O&M Costs (LNB w/OFA & SCR)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnson Unit 3	\$ -	\$ 155,000	\$ 232,500	\$ -	-	Anhydrous NHS	1.00	1.57
2	Dave Johnson Unit 4	\$ -	\$ 166,000	\$ 249,000	\$ -	-	Anhydrous NHS	1.00	2.29
3	Jim Bridger Unit 1	\$ -	\$ 190,000	\$ 285,000	\$ -	-	Anhydrous NHS	1.00	3.28
4	Jim Bridger Unit 2	\$ -	\$ 162,000	\$ 243,000	\$ -	-	Anhydrous NHS	1.00	3.25
5	Jim Bridger Unit 3	\$ -	\$ 190,000	\$ 285,000	\$ -	-	Anhydrous NHS	1.00	3.22
6	Jim Bridger Unit 4	\$ -	\$ 190,000	\$ 285,000	\$ -	-	Anhydrous NHS	1.00	3.36
7	Naughton Unit 1	\$ -	\$ 122,000	\$ 183,000	\$ -	-	Anhydrous NHS	1.00	0.98
8	Naughton Unit 2	\$ -	\$ 166,000	\$ 249,000	\$ -	-	Anhydrous NHS	1.00	1.34
9	Naughton Unit 3	\$ -	\$ 166,000	\$ 249,000	\$ -	-	Anhydrous NHS	1.00	1.67
10	Wyodak Unit 1	\$ -	\$ 181,000	\$ 271,500	\$ -	-	Anhydrous NHS	1.00	2.42

Table 9 - Case 6 O&M Costs (Dry FGD)

Index No.	Name of Unit	Annual Fixed O&M Costs					Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor		Reagent	Reagent Stoich.	Annual FF Bag Replace.	Aux. Power Usage (MW)	
1	Dave Johnston Unit 3	\$ 505,128	\$ 714,175	\$ 476,928	\$ -	\$ -	Lime	1.15	-	2.49	
2	Dave Johnston Unit 4	\$ -	\$ -	\$ -	\$ -	\$ -	Lime	-	-	-	
3	Jim Bridger Unit 1	\$ -	\$ -	\$ -	\$ -	\$ -	Lime	-	-	-	
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	\$ -	Lime	-	-	-	
5	Jim Bridger Unit 3	\$ -	\$ -	\$ -	\$ -	\$ -	Lime	-	-	-	
6	Jim Bridger Unit 4	\$ -	\$ -	\$ -	\$ -	\$ -	Lime	-	-	-	
7	Naughton Unit 1	\$ 505,128	\$ 687,643	\$ 391,762	\$ -	\$ 120	Lime	1.40	-	1.64	
8	Naughton Unit 2	\$ 505,128	\$ 869,174	\$ 573,044	\$ -	\$ 165	Lime	1.40	-	2.25	
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	\$ -	Lime	-	-	-	
10	Wyodak Unit 1	\$ -	\$ 21,900	\$ 14,600	\$ -	\$ 25	Lime	1.10	-	0.11	

Table 10 - Case 7 O&M Costs (Dry FGD w/Fabric Filter)

Index No.	Name of Unit	Annual Fixed O&M Costs					Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor		Reagent	Reagent Stoich.	Annual FF Bag Replace.	Aux. Power Usage (MW)	
1	Dave Johnston Unit 3	\$ 505,128	\$ 1,132,687	\$ 476,928	\$ -	\$ 173	Lime	1.15	1,467	3.88	
2	Dave Johnston Unit 4	\$ 505,128	\$ 1,102,288	\$ 734,858	\$ -	\$ 248	Lime	1.10	1,798	4.54	
3	Jim Bridger Unit 1	\$ -	\$ -	\$ -	\$ -	\$ -	Lime	-	-	-	
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	\$ -	Lime	-	-	-	
5	Jim Bridger Unit 3	\$ -	\$ -	\$ -	\$ -	\$ -	Lime	-	-	-	
6	Jim Bridger Unit 4	\$ -	\$ -	\$ -	\$ -	\$ -	Lime	-	-	-	
7	Naughton Unit 1	\$ 505,128	\$ 632,680	\$ 469,286	\$ -	\$ 120	Lime	1.15	865	2.66	
8	Naughton Unit 2	\$ 505,128	\$ 905,190	\$ 640,668	\$ -	\$ 165	Lime	1.15	1,193	3.63	
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	\$ -	Lime	-	-	-	
10	Wyodak Unit 1	\$ -	\$ -	\$ -	\$ -	\$ -	Lime	-	-	-	

Table 11 - Case 8 O&M Costs (Wet FGD)

Index No.	Name of Unit	Annual Fixed O&M Costs					Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor		Reagent	Reagent Stoich.	Annual FF Bag Replace.	Aux. Power Usage (MW)	
1	Dave Johnston Unit 3	\$ 309,804	\$ 1,132,687	\$ 788,391	\$ -	\$ 230	Lime	1.02	-	3.45	
2	Dave Johnston Unit 4	\$ 309,804	\$ 1,430,784	\$ 953,856	\$ -	\$ 330	Lime	1.02	1,798	6.29	
3	Jim Bridger Unit 1	\$ -	\$ 29,650	\$ 17,033	\$ -	\$ 63	Soda Ash	1.02	-	0.63	
4	Jim Bridger Unit 2	\$ -	\$ 29,650	\$ 17,033	\$ -	\$ 63	Soda Ash	1.02	-	0.63	
5	Jim Bridger Unit 3	\$ -	\$ 29,650	\$ 17,033	\$ -	\$ 62	Soda Ash	1.02	-	0.62	
6	Jim Bridger Unit 4	\$ -	\$ 25,550	\$ 17,033	\$ -	\$ 27	Soda Ash	1.02	-	0.53	
7	Naughton Unit 1	\$ 309,804	\$ 963,569	\$ 642,393	\$ -	\$ 160	Lime	1.05	-	2.40	
8	Naughton Unit 2	\$ 309,804	\$ 1,226,386	\$ 877,691	\$ -	\$ 220	Lime	1.05	-	3.30	
9	Naughton Unit 3	\$ -	\$ 21,900	\$ 14,600	\$ -	\$ 66	Soda Ash	1.02	-	0.33	
10	Wyodak Unit 1	\$ 305,677	\$ 328,496	\$ 218,998	\$ -	\$ 82	Lime	1.02	-	1.75	

Table 12 - Case 9 O&M Costs (Flue Gas Conditioning)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent Usage (Lb/Hr)	Annual FF Bag Replace.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ -	\$ -	\$ -	-	None	-	-
2	Dave Johnston Unit 4	\$ -	\$ -	\$ -	\$ -	-	None	-	-
3	Jim Bridger Unit 1	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental sulfur	100	0.05
4	Jim Bridger Unit 2	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental sulfur	100	0.05
5	Jim Bridger Unit 3	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental sulfur	100	0.05
6	Jim Bridger Unit 4	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental sulfur	100	0.05
7	Naughton Unit 1	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental sulfur	43	0.05
8	Naughton Unit 2	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental sulfur	67	0.05
9	Naughton Unit 3	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental sulfur	67	0.05
10	Wyodak Unit 1	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental sulfur	63	0.05

Table 13 - Case 10 O&M Costs (Fabric Filter)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent Stoich.	Annual FF Bag Replace.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ 45,016	\$ 67,524	\$ -	-	None	1,457	1.38
2	Dave Johnston Unit 4	\$ -	\$ 66,183	\$ 102,199	\$ -	-	None	1,798	2.38
3	Jim Bridger Unit 1	\$ -	\$ 51,099	\$ 76,649	\$ -	-	None	2,885	3.39
4	Jim Bridger Unit 2	\$ -	\$ 51,099	\$ 76,649	\$ -	-	None	2,885	3.37
5	Jim Bridger Unit 3	\$ -	\$ 51,099	\$ 76,649	\$ -	-	None	2,827	3.33
6	Jim Bridger Unit 4	\$ -	\$ 51,099	\$ 76,649	\$ -	-	None	2,885	3.39
7	Naughton Unit 1	\$ -	\$ 45,016	\$ 67,524	\$ -	-	None	865	1.01
8	Naughton Unit 2	\$ -	\$ 45,016	\$ 67,524	\$ -	-	None	1,193	1.38
9	Naughton Unit 3	\$ -	\$ 48,666	\$ 72,999	\$ -	-	None	1,799	2.06
10	Wyodak Unit 1	\$ -	\$ 48,666	\$ 72,999	\$ -	-	None	1,798	2.06

Table 14 - Major Materials Design and Supply Costs

Index No.	Name of Unit Case ->	NOX Control		SO2 Control		PM Control		
		3	4	6	7	8	9	10
1	Dave Johnston Unit 3	\$ 3,221,912	\$ 5,556,617	\$ 5,773,000	\$ 49,355,000	\$ -	\$ -	\$ 18,359,000
2	Dave Johnston Unit 4	\$ 2,673,501	\$ 4,343,192	\$ 7,171,085	\$ 66,200,000	\$ -	\$ -	\$ 30,853,530
3	Jim Bridger Unit 1	\$ 2,981,982	\$ 6,056,955	\$ 9,528,000	\$ 80,923,000	\$ -	\$ -	\$ 29,814,000
4	Jim Bridger Unit 2	\$ 2,981,982	\$ 6,056,955	\$ 9,528,000	\$ 80,923,000	\$ -	\$ -	\$ 29,814,000
5	Jim Bridger Unit 3	\$ 2,981,982	\$ 6,056,955	\$ 9,419,000	\$ 80,923,000	\$ -	\$ -	\$ 29,814,000
6	Jim Bridger Unit 4	\$ 2,981,982	\$ 6,056,955	\$ 9,528,000	\$ 83,009,000	\$ -	\$ -	\$ 29,814,000
7	Naughton Unit 1	\$ 2,570,123	\$ 2,675,792	\$ 7,257,000	\$ 37,292,000	\$ 26,819,000	\$ 42,301,000	\$ 15,482,000
8	Naughton Unit 2	\$ 2,570,674	\$ 3,123,533	\$ 8,784,000	\$ 47,934,000	\$ 39,262,000	\$ 57,621,000	\$ 18,359,000
9	Naughton Unit 3	\$ 3,187,636	\$ 4,351,377	\$ 11,234,576	\$ 67,373,000	\$ -	\$ -	\$ 20,105,000
10	Wyodak Unit 1	\$ -	\$ 4,590,245	\$ 7,234,860	\$ 72,475,000	\$ 996,100	\$ -	\$ 1,247,061

Jim Bridger Unit 2											
Exist. LNB w/OFA											
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton NOx Removed)
0	2013										
1	2014										
2	2015										
3	2016										
4	2017										
5	2018										
6	2019										
7	2020										
8	2021										
9	2022										
10	2023										
11	2024										
12	2025										
13	2026										
14	2027										
15	2028										
16	2029										
17	2030										
18	2031										
19	2032										
20	2033										
Present Worth		0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
(% of PW)											

Jim Bridger Unit 2											
ROFA											
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton NOx Removed)
0	2013										
1	2014	105,000					2,528,012	2,528,012	1,952,796	4,585,808	9,885
2	2015	107,100					2,578,573	2,578,573	1,952,796	4,638,468	9,806
3	2016	109,242					2,630,144	2,630,144	1,952,796	4,692,162	9,920
4	2017	111,427					2,682,747	2,682,747	1,952,796	4,746,970	10,036
5	2018	113,655					2,736,402	2,736,402	1,952,796	4,802,853	10,154
6	2019	115,928					2,791,130	2,791,130	1,952,796	4,859,854	10,274
7	2020	118,247					2,846,953	2,846,953	1,952,796	4,917,995	10,397
8	2021	120,612					2,903,892	2,903,892	1,952,796	4,977,269	10,523
9	2022	123,024					2,961,970	2,961,970	1,952,796	5,037,789	10,651
10	2023	125,485					3,021,209	3,021,209	1,952,796	5,099,489	10,781
11	2024	127,994					3,081,633	3,081,633	1,952,796	5,162,423	10,914
12	2025	130,554					3,143,266	3,143,266	1,952,796	5,226,616	11,050
13	2026	133,165					3,206,131	3,206,131	1,952,796	5,292,092	11,188
14	2027	135,829					3,270,254	3,270,254	1,952,796	5,358,878	11,329
15	2028	138,545					3,335,659	3,335,659	1,952,796	5,427,000	11,473
16	2029	141,316					3,402,372	3,402,372	1,952,796	5,496,484	11,620
17	2030	144,142					3,470,419	3,470,419	1,952,796	5,567,358	11,770
18	2031	147,025					3,539,828	3,539,828	1,952,796	5,639,649	11,923
19	2032	149,966					3,610,624	3,610,624	1,952,796	5,713,386	12,078
20	2033	152,965					3,682,837	3,682,837	1,952,796	5,788,588	12,238
Present Worth		1,282,875	0.0%	0.0%	0.0%	0.0%	30,586,856	30,586,856	20,538,123	52,687,853	100.0%
(% of PW)		2.4%					58.6%	58.6%	38.0%		

Jim Bridger Unit 2											
Year	Date	TOTAL FIXED		Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton NOx Removed)
		O&M COST	Water Cost								
0	2013										
1	2014	237,500		536,432			208,928	745,358	1,277,304	2,260,162	2,388
2	2015	242,250		547,161			213,105	760,268	1,277,304	2,279,820	2,410
3	2016	247,085		558,104			217,367	775,471	1,277,304	2,299,870	2,431
4	2017	252,037		569,266			221,714	790,980	1,277,304	2,320,321	2,453
5	2018	257,078		580,652			226,148	806,800	1,277,304	2,341,182	2,475
6	2019	262,219		592,265			230,671	822,936	1,277,304	2,362,459	2,497
7	2020	267,464		604,110			235,285	839,395	1,277,304	2,384,162	2,520
8	2021	272,813		616,192			239,990	856,183	1,277,304	2,406,289	2,544
9	2022	278,268		628,516			244,790	873,308	1,277,304	2,428,879	2,567
10	2023	283,834		641,086			249,686	890,772	1,277,304	2,451,911	2,592
11	2024	289,511		653,908			254,680	908,588	1,277,304	2,475,403	2,617
12	2025	295,301		666,986			259,773	926,760	1,277,304	2,499,365	2,642
13	2026	301,207		680,326			264,969	945,295	1,277,304	2,523,806	2,668
14	2027	307,232		693,933			270,268	964,201	1,277,304	2,548,736	2,694
15	2028	313,376		707,811			275,673	983,485	1,277,304	2,574,165	2,721
16	2029	319,644		721,967			281,187	1,003,154	1,277,304	2,600,102	2,748
17	2030	326,037		736,407			286,811	1,023,217	1,277,304	2,626,558	2,776
18	2031	332,557		751,135			292,547	1,043,682	1,277,304	2,653,543	2,805
19	2032	339,208		766,158			298,388	1,064,555	1,277,304	2,681,088	2,834
20	2033	345,983		781,481			304,365	1,085,847	1,277,304	2,709,143	2,864
Present Worth		2,301,740		6,554,053			2,552,627	8,108,660	13,427,233	25,435,659	1,344
(% of PW)		11.4%		25.8%			10.0%	35.3%	52.8%	100.0%	


Jim Bridger Unit 2											
Year	Date	TOTAL FIXED		Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton NOx Removed)
		O&M COST	Water Cost								
0	2013										
1	2014	405,000		912,848	584,000		1,282,333	2,765,181	11,498,623	14,682,803	3,654
2	2015	413,100		831,105	605,880		1,307,979	2,844,964	11,498,623	14,756,687	3,670
3	2016	421,362		949,727	617,988		1,334,139	2,901,864	11,498,623	14,821,848	3,687
4	2017	429,789		968,722	630,358		1,360,822	2,958,901	11,498,623	14,888,313	3,703
5	2018	438,385		988,096	642,965		1,388,038	3,018,099	11,498,623	14,956,106	3,720
6	2019	447,153		1,007,858	655,824		1,415,799	3,079,481	11,498,623	15,025,256	3,737
7	2020	456,096		1,028,015	668,940		1,444,115	3,141,070	11,498,623	15,095,789	3,755
8	2021	465,218		1,048,575	682,319		1,472,997	3,203,892	11,498,623	15,167,732	3,774
9	2022	474,522		1,069,547	695,956		1,502,457	3,267,870	11,498,623	15,241,114	3,794
10	2023	484,012		1,090,936	709,885		1,532,506	3,333,328	11,498,623	15,315,964	3,809
11	2024	493,683		1,112,757	724,083		1,563,156	3,399,995	11,498,623	15,392,311	3,828
12	2025	503,567		1,135,012	738,594		1,594,419	3,467,995	11,498,623	15,470,185	3,848
13	2026	513,638		1,157,712	753,336		1,626,308	3,537,355	11,498,623	15,549,615	3,868
14	2027	523,911		1,180,864	768,402		1,658,824	3,608,103	11,498,623	15,630,636	3,888
15	2028	534,389		1,204,484	783,770		1,692,041	3,680,265	11,498,623	15,713,276	3,908
16	2029	545,077		1,228,572	799,446		1,725,951	3,753,870	11,498,623	15,797,659	3,929
17	2030	555,978		1,253,145	815,435		1,760,368	3,828,947	11,498,623	15,883,546	3,951
18	2031	567,088		1,278,208	831,743		1,795,575	3,905,526	11,498,623	15,971,247	3,972
19	2032	578,440		1,303,772	848,378		1,831,467	3,983,657	11,498,623	16,060,689	3,995
20	2033	590,009		1,328,841	865,346		1,868,116	4,063,309	11,498,623	16,151,941	4,017
Present Worth		4,948,231		11,153,043	7,257,405		15,957,352	34,077,800	120,875,494	159,901,924	1,989
(% of PW)		3.1%		7.0%	4.5%		0.0%	21.3%	75.6%	100.0%	

Jim Bridger Unit 2 Upgraded Wet FGD											
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton SO2 Removed)
0	2013										
1	2014	43,583	30,503	533,206		449,958	208,926	1,215,593	1,236,652	2,484,828	632
2	2015	43,465	31,113	543,870		451,818	213,105	1,238,905	1,236,652	2,519,951	632
3	2016	44,368	31,735	554,747		460,854	217,387	1,264,703	1,236,652	2,514,658	645
4	2017	45,189	32,320	565,642		470,971	221,714	1,291,957	1,236,652	2,571,838	651
5	2018	46,083	33,017	577,158		478,472	226,148	1,319,787	1,236,652	2,566,542	658
6	2019	47,015	33,976	588,702		485,082	230,671	1,348,113	1,236,652	2,625,760	665
7	2020	47,955	34,351	600,476		488,843	235,285	1,376,955	1,236,652	2,695,562	672
8	2021	48,914	35,038	612,486		500,820	239,980	1,396,354	1,236,652	2,561,901	679
9	2022	49,883	35,739	624,735		516,998	244,790	1,424,281	1,236,652	2,710,806	686
10	2023	50,880	36,454	637,230		529,976	249,666	1,452,746	1,236,652	2,740,289	694
11	2024	51,908	37,183	649,975		539,964	254,600	1,481,501	1,236,652	2,770,381	701
12	2025	52,946	37,928	662,974		550,763	259,773	1,511,457	1,236,652	2,801,036	709
13	2026	54,005	38,685	676,234		561,776	265,168	1,541,966	1,236,652	2,832,323	717
14	2027	55,085	39,459	689,756		573,074	270,888	1,572,459	1,236,652	2,864,237	725
15	2028	56,187	40,248	703,554		584,474	276,973	1,603,949	1,236,652	2,896,788	733
16	2029	57,311	41,053	717,625		595,164	283,417	1,636,028	1,236,652	2,929,981	742
17	2030	58,457	41,874	731,977		606,087	289,988	1,668,748	1,236,652	2,963,958	750
18	2031	59,626	42,711	746,617		620,249	296,988	1,702,123	1,236,652	2,998,402	759
19	2032	60,819	43,565	761,549		632,654	304,366	1,736,168	1,236,652	3,033,637	768
20	2033	62,035	44,437	776,780		645,307	304,366	1,770,869	1,236,652	3,069,577	777
Present Worth (% of PW)		520,271	372,679	6,514,628	0.0%	5,412,000	2,592,627	14,351,935	12,969,800	28,372,107	359
			1.8%			19.1%	9.0%	52.3%	45.8%	100.0%	


Jim Bridger Unit 2 Flue Gas Conditioning											
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton PM Removed)
0	2013										
1	2014	10,000		145,854			19,710	165,564		175,564	169
2	2015	10,200		148,771			20,104	168,875		179,075	172
3	2016	10,404		151,747			20,506	172,253		182,657	176
4	2017	10,612		154,781			20,916	175,688		186,310	179
5	2018	10,824		157,877			21,335	179,212		190,036	183
6	2019	11,041		161,035			21,761	182,796		193,837	186
7	2020	11,262		164,255			22,197	186,452		197,714	190
8	2021	11,487		167,540			22,641	190,181		201,668	194
9	2022	11,717		170,891			23,093	193,985		205,701	198
10	2023	11,951		174,309			23,555	197,864		209,815	202
11	2024	12,190		177,795			24,026	201,822		214,012	206
12	2025	12,434		181,351			24,507	205,858		218,292	210
13	2026	12,682		184,978			24,997	209,975		222,658	214
14	2027	12,936		188,678			25,497	214,175		227,111	218
15	2028	13,195		192,451			26,007	218,458		231,653	223
16	2029	13,459		196,300			26,527	222,827		236,286	227
17	2030	13,728		200,226			27,058	227,284		241,012	232
18	2031	14,002		204,231			27,599	231,830		245,832	235
19	2032	14,282		208,315			28,151	236,466		250,749	241
20	2033	14,568		212,482			28,714	241,195		255,764	246
Present Worth (% of PW)		122,178	0.0%	1,762,023	0.0%	0.0%	240,814	2,022,837	0.0%	2,145,015	103
		5.7%		83.1%			11.2%	64.3%		100.0%	

Jim Bridger Unit 2		Fabric Filter									
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton PM Removed)
0	2013										
1	2014	127,749	-	-	300,040	-	1,326,877	1,628,917	4,602,887	6,357,562	4,556
2	2015	130,304	-	-	305,041	-	1,353,415	1,653,456	4,602,887	6,392,646	4,561
3	2016	132,910	-	-	312,162	-	1,380,463	1,682,801	4,602,887	6,428,441	4,607
4	2017	135,568	-	-	316,405	-	1,408,063	1,728,488	4,602,887	6,464,952	4,633
5	2018	138,279	-	-	324,773	-	1,436,255	1,781,027	4,602,887	6,502,183	4,660
6	2019	141,045	-	-	331,288	-	1,464,960	1,795,248	4,602,887	6,540,179	4,687
7	2020	143,866	-	-	337,884	-	1,494,279	1,832,173	4,602,887	6,578,925	4,715
8	2021	146,743	-	-	344,652	-	1,524,165	1,868,316	4,602,887	6,618,446	4,743
9	2022	149,678	-	-	351,545	-	1,554,648	1,905,193	4,602,887	6,658,757	4,772
10	2023	152,671	-	-	358,576	-	1,585,741	1,944,317	4,602,887	6,699,875	4,801
11	2024	155,725	-	-	365,747	-	1,617,456	1,985,203	4,602,887	6,741,814	4,832
12	2025	158,839	-	-	373,062	-	1,649,805	2,027,967	4,602,887	6,784,593	4,863
13	2026	162,016	-	-	380,523	-	1,682,801	2,073,324	4,602,887	6,828,227	4,893
14	2027	165,256	-	-	388,194	-	1,716,457	2,104,591	4,602,887	6,872,734	4,925
15	2028	168,562	-	-	395,886	-	1,750,766	2,146,593	4,602,887	6,918,131	4,958
16	2029	171,933	-	-	403,814	-	1,785,802	2,188,516	4,602,887	6,964,436	4,991
17	2030	175,371	-	-	411,981	-	1,821,518	2,233,409	4,602,887	7,011,667	5,025
18	2031	178,879	-	-	420,128	-	1,857,948	2,275,077	4,602,887	7,059,842	5,059
19	2032	182,456	-	-	428,531	-	1,895,107	2,323,638	4,602,887	7,108,981	5,095
20	2033	186,105	-	-	437,102	-	1,933,010	2,370,111	4,602,887	7,159,103	5,131
Present Worth (% of PM)		1,560,813	2.2%	0.0%	3,685,845	5.3%	19,211,591	23.2%	48,386,333	69.3%	2,502
										100.0%	

First Year Cost for Air Pollution Control Options



Present Worth Cost for Air Pollution Control Options



APPENDIX B
2006 Wyoming BART Protocol

APPENDIX B
2006 Wyoming BART Protocol

BART Air Modeling Protocol
Individual Source Visibility Assessments
for BART Control Analyses

September, 2006

State of Wyoming
Department of Environmental Quality
Air Quality Division
Cheyenne, WY 82002

Table of Contents

1.0	INTRODUCTION	3
2.0	OVERVIEW	4
3.0	EMISSIONS DATA FOR MODELING	7
3.1	Baseline Modeling	7
3.2	Post-Control Modeling.....	8
4.0	METEOROLOGICAL DATA.....	9
5.0	CALPUFF MODEL APPLICATION.....	12
6.0	POST PROCESSING	15
7.0	REPORTING	19

1.0 INTRODUCTION

The U.S. EPA has issued final amendments to the Regional Haze Regulations, along with Guidelines for Best Available Retrofit Technology (BART) Determinations.⁽¹⁾ The guidelines address the methodology for determining which facilities must apply BART (sources subject-to-BART) and the evaluation of control options.

The State of Wyoming used air quality modeling in accordance with the EPA Guidelines to determine the Wyoming sources which are subject-to-BART. This Protocol defines the specific methodology to be used by those sources for determining the improvement in visibility to be achieved by BART controls.

The methodology presented in this Protocol is consistent with EPA guidance and the Air Quality Division (AQD) determination of subject-to-BART sources. It is intended that all Wyoming sources that must conduct BART analyses will use this Protocol for their evaluation of control technology visibility improvement. Any deviations from the procedures described herein must be approved by the Division prior to implementation.

⁽¹⁾ 40 CFR Part 51: Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations; Final Rule. 70 Federal Register, 39103-39172, July 6, 2005.

2.0 OVERVIEW

Wyoming AQD determined that eight facilities (sources) in the state are subject-to-BART. The sources are listed in Table 1. Division modeling indicated that each of these sources causes or contributes to visibility impairment in one or more Class I areas. Each source must conduct a BART analysis to define Best Available Retrofit Technology (BART) applicable to that source, and quantify the improvement in Class I visibility associated with BART controls. This Protocol sets out the procedures for quantifying visibility improvement. Other aspects of the full BART analysis are not addressed here.

There are many Class I areas within and surrounding Wyoming (See Figure 1). On the basis of distance from subject-to-BART sources, topography, meteorology, and prior modeling, the AQD has determined that only five Class I areas need be addressed in BART individual source analyses. These are Badlands and Wind Cave National Parks in South Dakota, Mt. Zirkel Wilderness Area in Colorado, and Bridger and Fitzpatrick Wilderness Areas in Wyoming. Sources in eastern Wyoming have been shown to have greatest visibility impacts at the two South Dakota Class I areas, and western Wyoming sources have maximum impacts at Bridger and Fitzpatrick Wilderness Areas, and Mt. Zirkel. Visibility improvement at these highest impact areas will provide the best measure of the effectiveness of BART controls.

Each facility should carry out modeling with the CALPUFF modeling system for the Class I areas specified in Table 2. The AQD will provide meteorological input for CALMET for the years 2001, 2002, and 2003. The model domain covered by the AQD meteorological data is centered in southwest Wyoming, and extends roughly from Twin Falls, ID in the west to the Missouri River in the east, and from Denver in the south to Helena, MT in the north. The domain is shown, along with Class I areas, in Figure 1.

Sources may wish to utilize a smaller domain for CALPUFF modeling. Smaller domains are acceptable if they provide adequate additional area beyond the specific source and Class I areas being addressed. Figure 1 includes a "southwest Wyoming" domain which represents the minimum acceptable area for sources impacting the Bridger and Fitzpatrick Wilderness Areas, and the Mt. Zirkel Wilderness Area, and a "northeast Wyoming" domain as a minimum area for Badlands and Wind Cave National Parks modeling.

The CALPUFF model should be used with each of the three years of meteorological data to calculate visibility impacts for a baseline (existing emissions) case, and for cases reflecting BART controls. The control scenarios are to include individual scenarios for proposed BART controls for each pollutant (SO₂, NO_x, and particulate matter), and a combined scenario representing application of all proposed BART controls. If desired, additional modeling may be performed for controls that are not selected as BART. This might be done, for example, to provide data useful in identifying the control technologies that represent BART. However, visibility modeling is required only for the proposed BART controls.

Table 1. Wyoming Sources Subject-to-BART

Basin Electric	Laramie River Power Plant	Boilers #1,2,3
FMC Corporation	Granger Soda Ash Plant	Boilers #1,2
FMC Corporation	Green River Sodium Plant	Three boilers
General Chemical Co.	Green River Soda Ash	Two boilers
PacifiCorp	Dave Johnson Power Plant	Boilers #3,4
PacifiCorp	Jim Bridger Power Plant	Boilers #1-4
PacifiCorp	Naughton Power Plant	Boilers #1,2,3
PacifiCorp	Wyodak Power Plant	Boiler

Results of visibility modeling will be presented as a comparison between baseline impacts and those calculated for the BART control scenarios. Quantitative measures of impact will be the 98th percentile deciview change (Δv) relative to the 20% best days natural background, and the number of days with deciview change exceeding 0.5 (EPA Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations, 70 FR 39103). Results should be presented for each year.

Table 2. Source-Specific Class I Areas to be Addressed

Source	Class I Areas to be Evaluated
Basin Electric Laramie River	Wind Cave NP, Badlands NP
FMC Corporation Granger Soda Ash	Bridger WA, Fitzpatrick WA
FMC Corporation Sodium Products	Bridger WA, Fitzpatrick WA
General Chemical Green River Soda Ash	Bridger WA, Fitzpatrick WA
Pacificorp Dave Johnston	Wind Cave NP, Badlands NP
Pacificorp Jim Bridger	Bridger WA, Fitzpatrick WA, Mt. Zirkel WA
Pacificorp Naughton Plant	Bridger WA, Fitzpatrick WA
Pacificorp Wyodak	Wind Cave NP, Badlands NP

3.0 EMISSIONS DATA FOR MODELING

CALPUFF model input requires source (stack) – specific emission rates for each pollutant, and stack parameters (height, diameter, exit gas temperature, and exit gas velocity). Per EPA BART guidance, these parameters must be representative of maximum actual 24-hour average emitting conditions for baseline (existing) operation, and maximum proposed 24-hour average emissions for future (BART) operations.

3.1 Baseline Modeling

Sources are required to utilize representative baseline emission conditions if data are available; baseline emissions must be documented. Possible sources of emission data are stack tests, CEM data, fuel consumption data, etc. Remember that emissions should represent maximum 24-hour rates. EPA BART guidance states that you should “Use the 24-hour average actual emission rate from the highest emitting day of the meteorological period modeled (for the pre-control scenario).” Thus, baseline conditions should reference data from 2001 through 2003 (or 2004).

As a minimum, modeled emissions must include:

SO ₂	sulfur dioxide
NO _x	oxides of nitrogen
PM _{2.5}	particles with diameter less than 2.5µm
PM _{10-2.5}	particles with diameters greater than 2.5µm but less than or equal to 10 µm

If the fraction of PM₁₀ in the PM_{2.5} (fine) and PM_{10-2.5} (coarse) categories cannot be determined all particulate matter should be assumed to be PM_{2.5}.

In addition, direct emissions of sulfate (SO₄) should be included where possible. Sulfate can be emitted as sulfuric acid (H₂SO₄), sulfur trioxide (SO₃), or as sulfate compounds; emissions should be quantified as the equivalent mass of SO₄.

When test or engineering data are not available to specify SO₄ emissions or the relative fractions of fine and coarse particles, use can be made of speciation profiles available from Federal Land Managers at the website <http://ww2.nature.nps.gov/air/permits/ect/index.cfm>. Profiles are available for a number of source type and control technology combinations. The FLM speciation factors are acceptable if data are available for the appropriate source type.

Emissions of VOC (volatile organic compounds), condensable organics measured in stack tests, and elemental carbon components of PM₁₀ do not need to be included for BART modeling. The only other pollutant noted in EPA BART guidance is ammonia (NH₃). Though ammonia is not believed to be a significant contributor to visibility

impairment in most cases in Wyoming, it could be important for sources with significant ammonia emissions – for example from some NO_x control systems. Sources that are expected to emit ammonia (in pre-or post-control configurations) should include ammonia emissions in their model input.

If quantitative baseline emissions data are unavailable and sources believe that the maximum 24-hour emission rates estimated by the Division (presented in the Subject-to-BART final report) are representative of baseline conditions for their facility, they may be used for baseline modeling. However, emissions of sulfate and ammonia (if applicable) should be included based on the best available test information or speciation factors from current literature.

3.2 Post-Control Modeling

All pollutants described above should be included for each post-control scenario. ~~Post-control emissions (maximum 24-hour average) will generally be the baseline emissions multiplied by a control factor appropriate to the BART control.~~ However, some proposed controls may simply increase the efficiency of existing controls; others may result in an increase in emissions of one pollutant while controlling another. These factors must all be considered in defining emission rates for post-control modeling. Any changes in stack parameters resulting from control application must also be included.

The required visibility assessment will include the effect of each proposed BART control. For example, if a source proposes to add a scrubber for SO₂ control, low NO_x burners for NO_x control, and a baghouse for particulate control, four sets of visibility results should be developed:

- Use of SO₂ control alone
- Use of NO_x control alone
- Use of particulate control alone
- Use of proposed combination of all three controls

All pollutants should be modeled in each CALPUFF model run, but the modeled emissions should reflect only the specific controls or combination of controls addressed in that run.

Additional modeling could be necessary in situations where a facility is comprised of more than one subject-to-BART source, and different BART controls are applicable to different sources. Excessive modeling to address multiple control combinations is not necessary; however, visibility modeling should quantify the effect of BART controls on all affected sources for each pollutant, and of all facility BART controls combined.

4.0 METEOROLOGICAL DATA

Wyoming AQD will provide MM5 meteorological data fields for years 2001, 2002, and 2003 that can be utilized as input to CALMET. The MM5 output will have 12 kilometer resolution and cover the full domain shown in Figure 1.

Mesoscale meteorological data (MM5) were developed and evaluated as part of the AQD's southwest Wyoming NO₂ increment analysis. Three years of MM5 data at 36 km resolution were used to initialize 12 km MM5 simulations. The 12km MM5 modeling used identical physics options to the original 36 km runs. CALMM5 was then used as a preprocessor to produce CALMET - ready MM5 data input files. Quality assurance was performed by comparing the original MM5 output on the 36km national RPO grid to the 12 km MM5 output and observations.

The CALMET model (version 5.53a, level 040716) should be used to prepare meteorological input for CALPUFF. The user may select a domain smaller than the MM5 domain for CALMET and CALPUFF modeling if desired. Figure 1 shows minimum domain areas for modeling of western and eastern Wyoming BART sources. Four kilometer resolution should be specified for CALMET output.

CALMET processing should use the AQD MM5 data, and appropriate surface, upper air, and precipitation data. Figure 2 shows the locations of surface and upper air stations within the MM5 model domain. The MM5 data are used as the initial guess wind field; this wind field is then adjusted by CALMET for terrain and land use to generate a step 1 wind field, and refined using surface and upper air data to create the final step 2 wind field.

Surface, upper air, and precipitation data can be obtained from the National Climatic Data Center. Land use and terrain data are available from the U.S. Geological Survey. Data can be formatted for use in CALMET with standard conversion and processing programs available with the CALMET/CALPUFF software.

Table 3 provides a listing of applicable CALMET input variables for BART meteorological processing. The table includes inputs that are specific to Wyoming BART modeling. Inputs not shown in Table 3 are not relevant to the present application, are dependent on the specific model domain of the user, use model default values, or are obvious from the context.

Table 3. CALMET Control File Inputs

Variable	Description	Value
Input Group 1		
IBYR	Year	2001
		2002
		2003
IBTZ	Base time zone	7
IRTYPE	Run type	1
LCALGRD	Compute data fields for CALGRID	T
Input Group 2		
PMP	Map projection	LCC
DGRIDKM	Grid spacing (km)	4
NZ	Number of layers	10
ZFACE	Cell face heights (m)	0
		20
		40
		100
		140
		320
		580
		1020
		1480
		2220
		3500
Input Group 4		
NOOBS	No observation Mode	0
Input Group 5		
IWFCOD	Model selection variable	1
IFRADJ	Froude number adjustment	1
IKINE	Kinematic effects	0
IOBR	Use O'Brien procedure	0
ISLOPE	Slope flow effects	1
IEXTRP	Extrapolate surface wind observations	-4
ICALM	Extrapolate calm surface winds	0
BIAS	Biases for weights of surface and upper air stations	All 0
RMIN2	Minimum distance for extrapolation	-1
I PROG	Use gridded prognostic model output	14
ISTEPPG	Time Step (hours)	1
LVARY	Use varying radius of influence	F

Table 3. CALMET Control File Inputs (continued)

Variable	Description	Value
RMAX 1	Maximum radius of influence (km)	30
RMAX 2	Maximum radius of influence (km)	50
RMIN	Minimum radius of influence (km)	0.1
TERRAD	Radius of influence for terrain (km)	15
R1	Relative weighting of first guess wind field and observations (km)	5
R2	Relative weighting aloft (km)	25
IDIOPT 1	Surface temperature	0
IDIOPT 2	Upper air lapse rate	0
ZUPT	Lapse rate depth (m)	200
IDIOPT 3	Average wind components	0
IUPWND	Upper air station	-1
ZUPWND (1)	Bottom and top of layer for domain	1, 1000
ZUPWND (2)	scale winds (m)	1, 1000
IDIOPT4	Surface wind components	0
IDIOPT5	Upper air wind components	0
Input Group 6		
IAVEZI	Spatial averaging	1
MNMDAV	Max search radius	1
HAFANG	Half angle for averaging (deg)	30
ILEVZI	Layer of winds in averaging	1
ZIMAX	Maximum overland mixing height (m)	3500
ITPROG	3D temperature source	1
IRAD	Interpolation type	1
TRADKM	Radius of influence -- temperature (km)	500
NUMTS	Maximum number of Stations	5
IAVET	Spatial averaging of temperatures	1
NFLAGP	Precipitation interpolation	2

5.0 CALPUFF MODEL APPLICATION

The CALPUFF model (version 5.711a, level 040716) will be used to calculate pollutant concentrations at receptors in each Class I area. Application of CALPUFF should, in general, follow the guidance presented in the Interagency Workgroup on Air Quality Modeling (IWAQM) Phase 2 report (EPA - 454/R98-019) and the EPA Regional Haze Regulations and Guidelines for BART Determinations (70 FR 39103).

Appropriate CALPUFF control file inputs are in Table 4. Note should be taken of the basis for several of the recommended CALPUFF inputs.

- Building downwash effects need not be included. Because of the transport distances involved and the fact that most sources have tall stacks, building downwash is unlikely to have a significant effect on model-predicted concentrations
- Puff splitting is not required. The additional computation time necessary for puff splitting is not justified for purposes of BART analyses.
- Hourly ozone files should be used to define background ozone concentration. Data are available from the following sites within the model domain.
 - Rocky Mountain NP, CO
 - Craters of the Moon NP, ID
 - AIRS - Highland UT
 - Mountain Thunder, WY
 - Yellowstone NP, WY
 - Centennial, WY
 - Pinedale, WY

The background ozone concentration shown in Table 4 is used only when hourly data are missing.

- A constant background ammonia concentration of 2.0 ppb is specified. This value is based upon monitoring data from nearby states and IWAQM guidance. Experience suggests that 2.0 ppb is conservative in that it is unlikely to significantly limit nitrate formation in the model computations.
- MESOPUFF II chemical transformation rates should be used.
- The species to be modeled should be the seven identified in CALPUFF: SO₂, SO₄, NO_x, HNO₃, NO₃, PM_{2.5}, and PM_{10-2.5}. If ammonia (NH₃) is emitted it should be added to the species list. In most cases, all pollutants modeled will also be emitted, except for HNO₃ and NO₃.

Concentration calculations should be made for receptors covering the areas of the Class I areas being addressed. Receptors in each Class I area will be those designated by the Federal Land Managers and available from the National Park Service website.

Table 4. CALPUFF Control File Inputs

Variable	Description	Value
	Input Group 1	
METRUN	Control parameter for running all periods in met file	1
IBYR	Starting year	2001 2002 2003
XBTZ	Base time zone	7
NSPEC	Number of chemical species modeled	7 (or 8)
NSE	Number of species emitted	5 (or 6)
METFM	Meteorological data format	1
	Input Group 2	
MGAUSS	Vertical distribution in near field	1
MCTADJ	Terrain adjustment method	3
MCTSG	Subgrid scale complex terrain	0
MSLUG	Elongated puffs	0
MTRANS	Transitional plume rise	1
MTIP	Stack tip downwash	1
MSHEAR	Vertical wind shear	0
MSPLIT	Puff splitting allowed?	0
MCHEM	Chemical mechanism	1
MAQCHEM	Aqueous phase transformation	0
MWET	Wet removal	1
MDRY	Dry deposition	1
MDISP	Dispersion Coefficients	3
MROUGH	Adjust sigma for roughness	0
MPARTL	Partial plume penetration of inversions	1
MPDF	PDF for convective conditions	0
	Input Group 4	
PMAP	Map projection	LCC
DGRIDKM	Grid spacing	4

Table 4. CALPUFF Control File Inputs (continued)

ZFACE	Cell face heights (m)	0
		20
		40
		100
		140
		320
		580
		1020
		1480
		2220
		3500
	Input Group 6	
NHILL	Number of terrain features	0
	Input Group 7	
Dry Gas Depo	Chemical parameters for dry gas deposition	Defaults
	Input Group 8	
Dry Part. Depo	Size parameters for dry particle deposition SO ₄ , NO ₃ , PM _{2.5} PM ₁₀	Defaults 6.5, 1.0
	Input Group 11	
MOZ	Ozone Input option	1
BCKO3	Background ozone – all months (ppb)	44.0
BCKNH3	Background ammonia – all months (ppb)	2.0
	Input Group 12	
XMAXZI	Maximum mixing height (m)	3500
XMINZI	Minimum mixing height (m)	50

6.0 POST PROCESSING

Visibility impacts are calculated from the CALPUFF concentration results using CALPOST. CALPOST version 5.51, level 030709 should be used; the output from CALPOST will provide the highest deciview impact on each day from all receptors within each Class I area modeled.

For some CALPUFF applications such as deposition calculations, the POSTUTIL program is used prior to CALPOST. POSTUTIL is also used to repartition total nitrate by accounting for ammonia limiting. The ammonia limiting calculation in POSTUTIL should not be applied for Wyoming BART modeling. If you believe that ammonia limiting is appropriate for a specific BART analysis, justification should be discussed with the Division prior to its used.

Visibility calculations by CALPOST for BART purposes use Method 6. This method requires input of monthly relative humidity factors, $f(\text{RH})$, for each Class I area. The EPA guidance document provides appropriate data for each area. Table 5 lists monthly $f(\text{RH})$ factors to use for the Wyoming, Colorado, and South Dakota areas to be addressed in BART modeling. The factors shown in Table 5 include averages for the adjacent Class I areas, and are within 0.2 units of the Guideline table values for the individual Class I areas.

Natural background conditions as a reference for determination of the delta-dv change due to a source should be representative of the 20% best natural visibility days. EPA BART guidance provides the 20% best days deciview values for each Class I area on an annual basis, but does not provide species concentration data for the 20% best background conditions. These concentrations are needed for input to CALPOST.

Annual species concentrations corresponding to the 20% best days were calculated for each Class I area to be addressed, by scaling back the annual average concentrations given in Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule (Table 2-1). A separate scaling factor was derived for each Class I area such that, when multiplied by the Guidance table annual concentrations, the 20% best days deciview value for that area would be calculated. The scaled aerosol concentrations were averaged for the Bridger and Fitzpatrick WAs, and for Wind Cave and Badlands NPs, because of their geographical proximity and similar annual background visibility. The 20% best days aerosol concentrations to be used for each month for Wyoming BART evaluations are listed in Table 6.

Table 7 is a list of inputs for CALPOST. These inputs should be used for all BART visibility calculations. Output from CALPOST should be configured to provide a ranked list of the highest delta-deciview values in each Class I area. The 98th percentile delta-deciview value and the number of values exceeding 0.5 can then be determined directly from the CALPOST output.

Table 5. Monthly f(RH) Factors for Class I Areas

Month	Wind Cave NP Badlands NP	Bridger WA Fitzpatrick WA	Mt. Zirkel WA
January	2.65	2.50	2.20
February	2.65	2.30	2.20
March	2.65	2.30	2.00
April	2.55	2.10	2.10
May	2.70	2.10	2.20
June	2.60	1.80	1.80
July	2.30	1.50	1.70
August	2.30	1.50	1.80
September	2.20	1.80	2.00
October	2.25	2.00	1.90
November	2.75	2.50	2.10
December	2.65	2.40	2.10

Table 6. Natural Background Concentrations of Aerosol Components for 20% Best Days for BART Analyses ($\mu\text{g}/\text{m}^3$)

Aerosol Component	Wind Cave NP Badlands NP	Fitzpatrick WA Bridger WA	Mt. Zirkel WA
Ammonium Sulfate	.047	.045	.046
Ammonium Nitrate	.040	.038	.038
Organic Carbon	.186	.178	.179
Elemental Carbon	.008	.008	.008
Soil	.198	.189	.190
Coarse Mass	1.191	1.136	1.141

Table 7. CALPOST Control File Inputs

Variable	Description	Value
	Input Group 1	
ASPEC	Species to Process	VISIB
ILAYER	Layer/deposition code	1
A,B	Scaling factors	0,0
LBACK	Add background concentrations?	F
BTZONE	Base time zone	7
LVS04	Species to be included in extinction	T
LVNO3		T
LVOC		F
LVPMC		T
LVPMF		T
LVEC		F
LVBK	Include background?	T
SPECPMC	Species name for particulates	PM10
SPECPMF		PM25
EETMC	Extinction efficiencies	0.6
EETMF		1.0
EETMCBK		0.6
EES04		3.0
EEN03		3.0
EEOC		4.0
EESOIL		1.0
EEEC		10.0
MVISBK	Visibility calculation method	6
RHFAC	Monthly RH adjustment factors	Table 5
BKSO4	Background concentrations	Table 6
BKNO3		Table 6
BKPMC		Table 6
BK OC		Table 6
BKSOIL		Table 6
BKEC		Table 6
BEXTRAY	Extinction due to Rayleigh scattering	10.0

7.0 REPORTING

A report on the BART visibility analysis should be submitted that clearly compares impacts for post-control emissions to those for baseline emissions. Data for baseline and BART scenarios should include both the 98th percentile values and the number of days with delta-deciview values exceeding 0.5. Results should be given for each model year.

Table 8 is an example of a recommended format for presentation of model input and model results. The example is for baseline conditions; similar tables should be provided for each control scenario (SO₂, NO_x, and PM10) and for the combination of all BART controls. Your report tables need not follow the exact format shown in Table 8; but the same information should be provided in a concise and clear form. If additional scenarios were modeled or you wish to present supplemental information, they should be provided in an appendix or separate from the specified final results.

Table 8. Example Format for Presentation of Model Input and Results

Baseline Conditions Model Input Data												
Source (Unit) Description And ID	SO ₂ Emission Rate (lb/day)	NO _x Emission Rate (lb/day)	PM _{2.5} Emission Rate (lb/day)	PM _{10-2.5} Emission Rate (lb/day)	SO ₄ Emission Rate (lb/day)	NH ₃ Emission Rate (lb/day)	Location Easting UTM (m)	Location Northing UTM (m)	Stack Height (m)	Stack Diameter (m)	Exit Velocity (m/s)	Exit Gas Temp (deg K)

Baseline Visibility Modeling Results

Name of Facility	Class I Area	2001		2002		2003	
		98 th Percentile Value (dv)	No. of days exceeding 0.5 dv	98 th Percentile Value (dv)	No. of days exceeding 0.5 dv	98 th Percentile Value (dv)	No. of days exceeding 0.5 dv

Final Report

BART Analysis for Jim Bridger Unit 3

Prepared For:

PacifiCorp

1407 West North Temple
Salt Lake City, Utah 84116

October 2007

Prepared By:

CH2MHILL

215 South State Street, Suite 1000
Salt Lake City, Utah 84111

AQD Jim Bridger BART
001922

Final Report

BART Analysis for Jim Bridger Unit 3



Prepared For:

PacifiCorp

1407 West North Temple
Salt Lake City, Utah 84116

October 2007

Prepared By:

CH2MHILL

215 South State Street, Suite 1000
Salt Lake City, Utah 84111

Final Report

BART Analysis for Jim Bridger Unit 3

Submitted to
PacifiCorp

October 2007

CH2MHILL

Executive Summary

Background

In response to the Regional Haze Rule and Best Available Retrofit Technology (BART) regulations and guidelines, CH2M HILL was requested to perform a BART analysis for PacifiCorp's Jim Bridger Unit 3 (hereafter referred to as Jim Bridger 3). Best Available Retrofit Technology analysis has been conducted for the following criteria pollutants: nitrogen oxide (NO_x), sulfur dioxide (SO₂), and particulate matter less than 10 micrometers in aerodynamic diameter (PM₁₀). The Jim Bridger Station consists of four 530 megawatt (MW) units with a total generating capacity of 2,120 MW. Because the total generating capacity of the Jim Bridger Station exceeds 750 MW, presumptive BART emission limits apply to Jim Bridger 3, based on the United States Environmental Protection Agency's (EPA) guidelines. BART emissions limits must be achieved within five years after the State Implementation Plan (SIP) is approved by the EPA. A compliance date of 2014 was assumed for this analysis.

In completing the BART analysis, technology alternatives were investigated and potential reductions in NO_x, SO₂, and PM₁₀ emissions rates were identified. The following technology alternatives were investigated, listed below by pollutant:

- NO_x emission controls:
 - Low-NO_x burners (LNB) with over-fire air (OFA)
 - Rotating opposed fire air (ROFA)
 - LNB with selective non-catalytic reduction (SNCR) system
 - LNB with selective catalytic reduction (SCR) system
- SO₂ emission controls:
 - Optimize current operation of existing wet sodium flue gas desulfurization (FGD) system
 - Upgrade wet sodium FGD system to achieve an SO₂ emission rate of 0.10 lb per MMBtu
 - New dry FGD system
- PM₁₀ emission controls:
 - Sulfur trioxide (SO₃) injection flue gas conditioning system on existing electrostatic precipitator (ESP)
 - Polishing fabric filter

BART Engineering Analysis

The specific steps in a BART engineering analysis are identified in the Code of Federal Regulations (CFR) at 40 CFR 51 Appendix Y, Section IV. The evaluation must include:

- The identification of available, technically feasible, retrofit control options
- Consideration of any pollution control equipment in use at the source (which affects the availability of options and their impacts)
- The costs of compliance with the control options
- The remaining useful life of the facility
- The energy and non-air quality environmental impacts of compliance
- The degree of visibility improvement that may reasonably be anticipated from the use of BART

The following steps are incorporated into the BART analysis:

- Step 1 – Identify All Available Retrofit Control Technologies
- Step 2 – Eliminate Technically Infeasible Options
 - The identification of available, technically feasible, retrofit control options
 - Consideration of any pollution control equipment in use at the source (which affects the applicability of options and their impacts)
- Step 3 – Evaluate Control Effectiveness of Remaining Control Technologies
- Step 4 – Evaluate Impacts and Document the Results
 - The costs of compliance with the control options
 - The remaining useful life of the facility
 - The energy and non-air quality environmental impacts of compliance
- Step 5 – Evaluate Visibility Impacts
 - The degree of visibility improvement that may reasonably be anticipated from the use of BART

Separate analyses have been conducted for NO_x, SO₂, and PM₁₀ emissions. All costs included in the BART analyses are in 2006 dollars, and costs have not been escalated to the assumed 2014 BART implementation date.

Coal Characteristics

The main source of coal burned at Jim Bridger 3 will be the Bridger Underground Mine. Secondary sources are the Bridger Surface Mine, the Bridger Highwall Mine, the Black Butte Mine, and the Leucite Hills Mine. These coals are ranked as sub-bituminous, but are closer in characteristics to bituminous coal in many of the parameters influencing NO_x formation. These coals have higher nitrogen content than coals from the Powder River Basin (PRB),

which represent the bulk of sub-bituminous coal use in the U.S. This BART analysis has considered the higher nitrogen content and different combustion characteristics of PRB coals, as compared to those coals used at Jim Bridger 3, and has evaluated the effect of these qualities on NO_x formation and achievable emission rates.

Recommendations

CH2M HILL recommends these BART selections, which include installing low NO_x burners with over-fire air, upgrading the existing FGD system, and operating the existing electrostatic precipitator with an SO₃ flue gas conditioning system. This combination of control devices is identified as Scenario 1 throughout this report.

NO_x Emission Control

The BART presumptive NO_x limit assigned by EPA for tangentially-fired boilers burning sub-bituminous coal is 0.15 lb per MMBtu. However, as documented in this analysis, the characteristics of the Jim Bridger coals are more closely aligned with bituminous coals, with a presumptive BART NO_x limit of 0.28 lb per MMBtu.

CH2M HILL recommends low-NO_x burners with over-fire air (LNB with OFA) as BART for Jim Bridger 3, based on the projected significant reduction in NO_x emissions, reasonable control costs, and the advantages of no additional power requirements or non-air quality environmental impacts. NO_x reductions are expected to be similar to those realized at Jim Bridger 2. CH2M HILL recommends that the unit be permitted at a rate of 0.26 lb per MMBtu.

SO₂ Emission Control

CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 3, based on the significant reduction in SO₂ emissions, reasonable control costs, and the advantages of minimal additional power requirements and minimal non-air quality environmental impacts. This upgrade approach will meet the BART presumptive SO₂ limit of 0.15 lb per MMBtu.

PM₁₀ Emission Control

CH2M HILL recommends finalizing the permitting of the flue gas conditioning system to enhance the performance of the existing ESP as BART for Jim Bridger 3, based on the significant reduction in PM₁₀ emissions, reasonable control costs, and the advantages of minimal additional power requirements and no non-air quality environmental impacts.

BART Modeling Analysis

CH2M HILL used the CALPUFF modeling system to assess the visibility impacts of emissions from Jim Bridger 3 at Class I areas. The Class I areas potentially affected are located more than 50 kilometers, but less than 300 kilometers, from the Jim Bridger Plant.

The Class I areas include the following wilderness areas (WAs):

- Bridger WA
- Fitzpatrick WA
- Mt. Zirkel WA

Because Jim Bridger 3 will simultaneously control NO_x, SO₂, and PM₁₀ emissions, four post-control atmospheric dispersion modeling scenarios were developed to cover the range of effectiveness for combining the individual NO_x, SO₂, and PM₁₀ control technologies under evaluation. These modeling scenarios, and the controls assumed, are as follows:

- **Scenario 1:** New LNB with OFA modifications, upgraded wet FGD system, and flue gas conditioning for enhanced ESP performance. As indicated previously, this scenario represents CH2M HILL HILL's preliminary BART recommendation.
- **Scenario 2:** New LNB with OFA modifications, upgraded wet FGD system, and new polishing fabric filter.
- **Scenario 3:** New LNB with OFA modifications and SCR, upgraded wet FGD system, and flue gas conditioning for enhanced ESP performance.
- **Scenario 4:** New LNB with OFA modifications and SCR, upgraded wet FGD system, and new polishing fabric filter.

Visibility improvements for all emission control scenarios were analyzed, and the results were compared utilizing a least-cost envelope, as outlined in the *New Source Review Workshop Manual*.¹

Least-cost Envelope Analysis

EPA has adopted the least-cost envelope analysis methodology as an accepted methodology for selecting the most reasonable, cost-effective controls. Incremental cost-effectiveness comparisons focus on annualized cost and emission reduction differences between dominant alternatives. The dominant set of control alternatives is determined by generating what is called the envelope of least-cost alternatives. This is a graphical plot of total annualized costs for total emissions reductions for all control alternatives identified in the BART analysis.

To evaluate the impacts of the modeled control scenarios on the three Class I areas, the total annualized cost, cost per deciview (dV) reduction, and cost per reduction in number of days above 0.5 dV were analyzed. This report provides a comparison of the average incremental costs between relevant scenarios for the three Class I areas; the total annualized cost versus number of days above 0.5 dV, and the total annualized cost versus 98th percentile delta-deciview (ΔdV) reduction.

Results of the least-cost envelope analysis validate the selection of Scenario 1, based on incremental cost and visibility improvements. Scenario 2 (LNB with OFA, upgraded wet FGD, and polishing fabric filter) is eliminated, because it is to the left of the curve formed by the dominant control alternative scenario, which indicates a scenario with lower

¹ EPA, 1990. *New Source Review Workshop Manual*. Draft. Environmental Protection Agency. October, 1990.

improvement and/or higher costs. Scenario 3 (LNB with OFA and SCR, upgraded wet FGD, and flue gas conditioning for enhanced ESP performance) is not selected due to very high incremental costs, on the basis of both a cost per day of improvement and cost per dV reduction. While Scenario 4 (LNB with OFA and SCR, upgraded wet FGD, and polishing fabric filter) provides some potential visibility advantage over Scenario 1, the projected improvement is less than half a dV, and the projected costs are excessive. Therefore, Scenario 1 represents BART for Jim Bridger 3.

Just-Noticeable Differences in Atmospheric Haze

Studies have been conducted that demonstrate only dV differences of approximately 1.5 to 2.0 dV or more are perceptible by the human eye. Deciview changes of less than 1.5 cannot be distinguished by the average person. Therefore, the modeling analysis results indicate that only minimal, if any, observable visibility improvements at the Class I areas studied would be expected under any of the control scenarios. Thus, the results indicate that only minimal discernable visibility improvements may result, even though PacifiCorp will be spending many millions of dollars at this single unit, and over a billion dollars when considering its entire fleet of coal-fired power plants.

Contents

1.0	Introduction.....	1-1
2.0	Present Unit Operation.....	2-1
3.0	BART Engineering Analysis	3-1
3.1	Applicability	3-1
3.2	BART Process	3-1
3.2.1	BART NO _x Analysis	3-2
3.2.2	BART SO ₂ Analysis.....	3-14
3.2.3	BART PM ₁₀ Analysis.....	3-17
4.0	BART Modeling Analysis.....	4-1
4.1	Model Selection.....	4-1
4.2	CALMET Methodology	4-1
4.2.1	Dimensions of the Modeling Domain	4-1
4.2.2	CALMET Input Data.....	4-4
4.2.3	Validation of CALMET Wind Field	4-6
4.3	CALPUFF Modeling Approach	4-6
4.3.1	Background Ozone and Ammonia	4-6
4.3.2	Stack Parameters	4-6
4.3.3	Emission Rates	4-7
4.3.4	Post-control Scenarios	4-7
4.3.5	Modeling Process	4-8
4.3.6	Receptor Grids.....	4-8
4.4	CALPOST	4-10
4.5	Presentation of Modeling Results.....	4-11
4.5.1	Visibility Changes for Baseline vs. Preferred Scenario	4-11
5.0	Preliminary Assessment and Recommendations	5-1
5.1	Least-cost Envelope Analysis	5-1
5.1.1	Analysis Methodology	5-1
5.1.2	Analysis Results	5-9
5.2	Recommendations	5-9
5.2.1	NO _x Emission Control.....	5-9
5.2.2	SO ₂ Emission Control	5-9
5.2.3	PM ₁₀ Emission Control	5-9
5.3	Just-Noticeable Differences in Atmospheric Haze	5-10
6.0	References.....	6-1

Tables

- 2-1 Unit Operation and Study Assumptions
- 2-2 Coal Sources and Characteristics
- 3-1 Coal Characteristics Comparison
- 3-2 NO_x Control Technology Projected Emission Rates
- 3-3 NO_x Control Cost Comparison
- 3-4 SO₂ Control Technology Emission Rates
- 3-5 SO₂ Control Cost Comparison (Incremental to Existing FGD System)
- 3-6 PM₁₀ Control Technology Emission Rates
- 3-7 PM₁₀ Control Cost Comparison (Incremental to Existing ESP)
- 4-1 User-specified CALMET Options
- 4-2 BART Model Input Data
- 4-3 Average Natural Levels of Aerosol Components
- 4-4 Costs and Visibility Modeling Results for Baseline vs. Post-Control Scenarios at Class I Areas
- 5-1 Control Scenario Results for the Bridger Class I Wilderness Area
- 5-2 Control Scenario Results for the Fitzpatrick Class I Wilderness Area
- 5-3 Control Scenario Results for the Mt. Zirkel Class I Wilderness Area
- 5-4 Bridger Class I Wilderness Area Incremental Analysis Data
- 5-5 Fitzpatrick Class I Wilderness Area Incremental Analysis Data
- 5-6 Mt. Zirkel Class I Wilderness Area Incremental Analysis Data

Figures

- 3-1 Illustration of the Effect of Agglomeration on the Speed of Coal Combustion
- 3-2 Plot of Typical Nitrogen Content of Various Coals and Applicable Presumptive BART NO_x Limits
- 3-3 Plot of Typical Oxygen Content of Various Coals and Applicable Presumptive BART NO_x Limits
- 3-4 First Year Control Cost for NO_x Air Pollution Control Options
- 3-5 First Year Control Cost for PM Air Pollution Control Options
- 4-1 Jim Bridger Source-Specific Class I Areas to be Addressed
- 4-2 Surface and Upper Air Stations Used in the Jim Bridger BART Analysis
- 5-1 Least-cost Envelope Bridger Class I WA Days Reduction
- 5-2 Least-cost Envelope Bridger Class I WA 98th Percentile Reduction
- 5-3 Least-cost Envelope Fitzpatrick Class I WA Days Reduction
- 5-4 Least-cost Envelope Fitzpatrick Class I WA 98th Percentile Reduction
- 5-5 Least-cost Envelope Mt. Zirkel Class I WA Days Reduction
- 5-6 Least-cost Envelope Mt. Zirkel Class I WA 98th Percentile Reduction

Appendices

- A Economic Analysis
- B 2006 Wyoming BART Protocol

Acronyms and Abbreviations

°F	Degree Fahrenheit
BACT	Best Available Control Technology
BART	Best Available Retrofit Technology
CALDESK	Program to Display Data and Results
CALMET	Meteorological Data Preprocessing Program for CALPUFF
CALPOST	Post-processing Program for Calculating Visibility Impacts
CALPUFF	Gaussian Puff Dispersion Model
COHPAC	Compact Hybrid Particulate Collector
dV	Deciview
ΔV	Delta Deciview, Change in Deciview
DEQ	Department of Environmental Quality
ESP	Electrostatic Precipitator
EPA	United States Environmental Protection Agency
FGC	Flue Gas Conditioning
FGD	Flue Gas Desulfurization
kW	Kilowatt
kW-Hr	Kilowatt-hour
LNB	Low-NO _x Burner
lb	Pound
MMBtu	Million British Thermal Units
MM5	Mesoscale Meteorological Model, Version 5
MW	Megawatts
NO _x	Nitrogen Oxides
OFA	Over Fire Air
PM	Particulate Matter
PM _{2.5}	Particulate Matter less than 2.5 Micrometers in Aerodynamic Diameter
PM ₁₀	Particulate Matter less than 10 Micrometers in Aerodynamic Diameter
PRB	Powder River Basin
ROFA	Rotating Opposed Fire Air
S&L	Sargent & Lundy
SCR	Selective Catalytic Reduction
SIP	State Implementation Plan

SNCR	Selective Non-catalytic Reduction
SO ₂	Sulfur Dioxide
SO ₃	Sulfur Trioxide
USGS	U.S. Geological Survey
WA	Wilderness Area
WDEQ-AQD	Wyoming Department of Environmental Quality -- Air Quality Division

1.0 Introduction

Best Available Retrofit Technology (BART) guidelines were established as a result of United States Environmental Protection Agency (EPA) regulations intended to reduce the occurrence of regional haze in national parks and other Class I protected air quality areas in the United States (40 CFR Part 51). These guidelines provide guidance for states when determining which facilities must install additional controls, and the type of controls that must be used. Facilities eligible for BART installation were built between 1962 and 1977, and have the potential to emit more than 250 tons per year of visibility-impairing pollutants.

The Wyoming Department of Environmental Quality (DEQ) BART regulations state that each source subject to BART must submit a BART application for a construction permit by December 15, 2006. PacifiCorp received an extension from the Wyoming DEQ to submit the BART report for Jim Bridger Unit 3 (hereafter referred to as Jim Bridger 3) by January 12, 2007. The BART Report that was submitted to WDEQ in January 2007 included a BART analysis, and a proposal and justification for BART at the source. This revised report—submitted in October 2007—incorporates editorial revisions and new model runs since the January 2007 version.

The State of Wyoming has identified those eligible, in-state facilities that are required to reduce emissions under BART, and will set BART emissions limits for those facilities. This information will be included in the State of Wyoming State Implementation Plan (SIP), which the State has estimated will be formally submitted to the EPA by early 2008. The EPA BART guidelines also state that the BART emission limits must be fully implemented within 5 years of EPA's approval of the SIP.

Five elements related to BART address the issue of emissions for the identified facilities:

- Any existing pollution control technology in use at the source
- The cost of the controls
- The remaining useful life of the source
- The energy and non-air quality environmental impacts of compliance
- The degree of improvement in visibility that may reasonably be anticipated from the use of such technology

This report documents the BART analysis that was performed on Jim Bridger 3 by CH2M HILL for PacifiCorp. The analysis was performed for the pollutants nitrogen oxide (NO_x), sulfur dioxide (SO₂), and particulate matter less than 10 micrometers in aerodynamic diameter (PM₁₀), because they are the primary criteria pollutants that affect visibility.

Section 2 of this report provides a description of the present unit operation, including a discussion of coal sources and characteristics. The BART Engineering Analysis is provided in Section 3, by pollutant type. Section 4 provides the methodology and results of the BART Modeling Analysis, followed by recommendations in Section 5. References are provided in Section 6. Appendices provide more detail on the economic analysis and the 2006 Wyoming BART Protocol.

2.0 Present Unit Operation

The Jim Bridger Station consists of four units with a total generating capacity of 2,120 megawatts (MW). Jim Bridger 3 is a nominal 530 net MW unit located approximately 35 miles northeast of Rock Springs, Wyoming. It is equipped with a tangentially fired pulverized coal boiler with low NO_x burners manufactured by Combustion Engineering. The unit was constructed with a Flakt wire frame electrostatic precipitator (ESP). The unit contains a Babcock & Wilcox wet sodium flue gas desulfurization (FGD) system with three absorber towers installed in 1988. An Emerson Ovation distributed control system (DCS) was installed in 2003.

Jim Bridger 3 was placed in service in 1976. Its current economic depreciation life is through 2040; however, this analysis is based on a 20-year life for BART control technologies. Assuming a BART implementation date of 2014, this will result in an approximate remaining useful life for Jim Bridger 3 of 20 years from the installation date of any new or modified BART-related equipment. This report does not attempt to quantify any additional life extension costs needed to allow the unit and these control devices at Jim Bridger 3 to operate until 2040.

Table 2-1 lists additional unit information and study assumptions for this analysis.

The BART presumptive NO_x limit for tangential-fired boilers burning sub-bituminous coal is 0.15 lb per MMBtu and the BART presumptive NO_x limit for burning bituminous coal is 0.28 lb per MMBtu. The main sources of coal burned at Jim Bridger 3 are the Bridger Mine and secondarily the Black Butte Mine and Leucite Hills Mine. These coals are ranked as sub-bituminous, but are closer in characteristics to bituminous coal in many of the parameters influencing NO_x formation. These coals have higher nitrogen content than coals from the Powder River Basin (PRB), which represent the bulk of sub-bituminous coal use in the U.S. This BART analysis has considered the higher nitrogen content and the different combustion characteristics of PRB coals, as compared to those coals used at Jim Bridger 3, and has evaluated the effect of these qualities on NO_x formation and achievable emission rates. Coal sources and characteristics are summarized in Table 2-2. The primary source of coal will be the Bridger Underground Mine, and data on coal from this source were used in the modeling analysis. For the coal analysis that is presented in Section 3.2.1, the data from all the coal sources were used.

TABLE 2-1
Unit Operation and Study Assumptions
Jim Bridger 3

General Plant Data	
Site Elevation feet above MSL	6669
Stack Height (feet)	500
Stack Exit Internal Diameter (feet) /Exit Area (square feet)	24 /452.4
Stack Exit Temperature (degrees Fahrenheit)	140
Stack Exit Velocity (feet per second)	84.04
Stack Flow (actual cubic feet per minute)	2,281,182
Latitude (degree: minute: second)	41:44:18.54 north
Longitude (degree: minute: second)	108:47:12.82 west
Annual Unit Capacity Factor (percentage)	90
Net Unit Output (megawatts)	530
Net Unit Heat Rate (British thermal unit [Btu]/kilowatt-hour)(100% load)	10,400 (as measured by fuel throughput)
Boiler Heat Input (million British thermal units [MMBtu] per hour)(100% load)	6,000 (as measured by continuous emission monitoring)
Type of Boiler	Tangentially fired
Boiler Fuel	Coal
Coal Sources	Bridger Mine, Black Butte Mine, Leucite Hills Mine
Coal Heating Value (Btu/ per pound [lb]) ^(a)	9,660
Coal Sulfur Content (percentage by weight [wt. %]) ^(a)	0.58
Coal Ash Content (wt. %) ^(a)	10.3
Coal Moisture Content (wt. %) ^(a)	19.3
Coal Nitrogen Content (wt. %) ^(a)	0.98
Current Nitrogen Oxide (NO _x) Controls	Low NO _x burners
NO _x Emission Rate (lb per MMBtu)	0.45
Current Sulfur Dioxide (SO ₂) Controls	Sodium based wet scrubber
SO ₂ Emission Rate (lb per MMBtu)	0.267
Current PM ₁₀ Controls	Electrostatic Precipitator
PM ₁₀ ^(c) Emission Rate (lb per MMBtu) ^(b)	0.057

NOTES:

^(a) Coal characteristics based on Bridger Underground Mine (primary coal source).

^(b) Based on maximum historic emission rate from 1999-2001, prior to installation of the SO₃ injection system.

^(c) PM₁₀ refers to particulate matter less than 10 micrometers in aerodynamic diameter.

TABLE 2-2
Coal Sources and Characteristics
Jim Bridger 3

Mines	Ultimate Analysis (% dry basis)												
	Moisture (%)	Ash (%)	Volatile Matter (%)	Fixed Carbon (%)	British thermal units per pound (Btu/lb)	Sulfur (%)	Moisture and Ash Free (Btu/lb)	Hydrogen	Carbon	Sulfur	Nitrogen	Oxygen	Ash
Bridger Mine Underground	19.3	10.3	32.2	38.3	9660	0.58	13712	4.66	69.2	0.72	1.22	11.8	12.4
Maximum	Not enough data yet to run statistical analysis for variability												
Minimum	Not enough data yet to run statistical analysis for variability												
Bridger Mine Surface	19.1	10.6	32.3	38.0	9390	0.57	13340	4.38	37.4	0.71	1.26	13.2	13.0
Maximum	20.5	12.5	35.5	41.9	9800	0.72	13500	4.69	4.0	0.90	1.43	14.8	15.8
Minimum	17.5	9.0	31.0	36.0	9000	0.49	13100	4.00	64.3	0.60	1.14	11.7	11.2
Bridger Mine Highwall	18.0	9.5	33.0	39.5	9700	0.58	13500	No samples of separate highwall coal					
Maximum	Not enough data yet to run statistical analysis for variability												
Minimum	Not enough data yet to run statistical analysis for variability												
Black Butte Mine	20.0	9.2	33.3	35.6	9450	0.45	13330	4.43	68.7	0.56	1.47	13.4	11.5
Maximum	21.1	10.8	35.4	41.9	10275	0.62	13500	4.66	70.5	0.78	1.69	14.8	13.6
Minimum	18.0	7.6	29.9	36.8	9180	0.33	13140	4.21	66.1	0.41	1.25	11.6	9.7
Leucite Hills Mine (through 2009)	19.4	11.5	30.7	38.3	9080	0.64	13140	4.20	66.0	0.81	1.48	13.2	14.4
Maximum	23.0	15.0	33.0	43.0	10250	0.90	13800	4.70	70.0	1.20	1.64	17.1	19.0
Minimum	17.0	8.0	28.3	33.6	8000	0.40	12300	3.70	61.0	0.50	1.32	10.5	10.0

3.0 BART Engineering Analysis

This section presents the required BART engineering analysis.

3.1 Applicability

In compliance with regional haze requirements, the State of Wyoming must prepare and submit visibility SIPs to the EPA for Class I areas. The State has estimated that the formal submittal of the SIPs will occur by early 2008. The first phase of the regional haze program is the implementation of BART emission controls on all BART eligible units, within 5 years after EPA approval of the SIP.

3.2 BART Process

The specific steps in a BART engineering analysis are identified in the Code of Federal Regulations (CFR) at 40 CFR 51 Appendix Y, Section IV. The evaluation must include:

- The identification of available, technically feasible, retrofit control options
- Consideration of any pollution control equipment in use at the source (which affects the availability of options and their impacts)
- The costs of compliance with the control options
- The remaining useful life of the facility
- The energy and non-air quality environmental impacts of compliance, and
- The degree of visibility improvement that may reasonably be anticipated from the use of BART

The following steps are incorporated into the BART analysis:

- Step 1 – Identify All Available Retrofit Control Technologies
- Step 2 – Eliminate Technically Infeasible Options
 - The identification of available, technically feasible, retrofit control options
 - Consideration of any pollution control equipment in use at the source (which affects the applicability of options and their impacts)
- Step 3 – Evaluate Control Effectiveness of Remaining Control Technologies
- Step 4 – Evaluate Impacts and Document the Results
 - The costs of compliance with the control options
 - The remaining useful life of the facility
 - The energy and non-air quality environmental impacts of compliance

- Step 5 – Evaluate Visibility Impacts
 - The degree of visibility improvement that may reasonably be anticipated from the use of BART

In order to minimize costs in the BART analysis, consideration was made of any pollution control equipment in use at the source, the costs of compliance associated with the control options, and the energy and non-air quality environmental impacts of compliance using these existing control devices. In some cases, enhancing the performance of the existing control equipment was considered. Other scenarios with new control equipment were also developed.

All costs included in the BART analysis are in 2006 dollars (not escalated to 2014 BART implementation date).

3.2.1 BART NO_x Analysis

Nitrogen oxide formation in coal-fired boilers is a complex process that is dependent on a number of variables, including operating conditions, equipment design, and coal characteristics.

Formation of NO_x

During coal combustion, NO_x is formed in three different ways. The dominant source of NO_x formation is the oxidation of fuel-bound nitrogen. During combustion, part of the fuel-bound nitrogen is released from the coal with the volatile matter, and part is retained in the solid portion (char). The nitrogen chemically bound in the coal is partially oxidized to nitrogen oxides (nitric oxide and nitrogen dioxide) and partially reduced to molecular nitrogen. A smaller part of NO_x formation is due to high temperature fixation of atmospheric nitrogen in the combustion air. A very small amount of NO_x is called “prompt” NO_x. Prompt NO_x results from an interaction of hydrocarbon radicals, nitrogen, and oxygen.

In a conventional pulverized coal burner, air is introduced with turbulence to promote good mixing of fuel and air, which provides stable combustion. However, not all of the oxygen in the air is used for combustion. Some of the oxygen combines with the fuel nitrogen to form NO_x.

Coal characteristics directly and significantly affect NO_x emissions from coal combustion. Coal ranking is a means of classifying coals according to their degree of metamorphism in the natural series, from lignite to sub-bituminous to bituminous and on to anthracite. Lower rank coals, such as the sub-bituminous coals from the PRB, produce lower NO_x emissions than higher rank bituminous coals, due to their higher reactivity and lower nitrogen content. The fixed carbon to volatile matter ratio (fuel ratio), coal oxygen content, and rank are good relative indices of the reactivity of a coal. Lower rank coals release more organically bound nitrogen earlier in the combustion process than do higher rank bituminous coals. When used with low-NO_x burners (LNBs), sub-bituminous coals create a longer time for the kinetics to promote more stable molecular nitrogen, and hence result in lower NO_x emissions.

Coals from the PRB are classified as sub-bituminous C and demonstrate the high reactivity and low NO_x production characteristics described above. Based on data from the Energy Information Administration, PRB coals currently represent 88 percent of total U.S. sub-bituminous production and 73 percent of western coal production (Energy Information Administration, 2006). Most references to “western” coal and sub-bituminous coal infer PRB origin and characteristics. Emissions standards differentiating between bituminous and sub-

bituminous coals are presumed to use PRB coal as the basis for the sub-bituminous standards, due to its dominant market presence and unique characteristics.

There are a number of western coals that are classified as sub-bituminous, however, they border on being ranked as bituminous and do not display many of the qualities of PRB coals, including most of the low NO_x forming characteristics. Coals from the Bridger, Black Butte, and Leucite Hills mines fall into this category.

As defined by the American Society for Testing and Materials, the only distinguishing characteristic that classifies the coals used at Jim Bridger 3 as sub-bituminous rather than bituminous – that is, they are “agglomerating” as compared to “non-agglomerating”. Agglomerating as applied to coal is “the property of softening when it is heated to above about 400°C in a non-oxidizing atmosphere, and then appearing as a coherent mass after cooling to room temperature.” Because the agglomerating property of coals is the result of particles transforming into a plastic or semi-liquid state when heated, it reflects a change in surface area of the particle. Thus, with the application of heat, agglomerating coals would tend to develop a non-porous surface while the surface of non-agglomerating coals would become even more porous with combustion. As shown by Figure 3-1, the increased porosity provides more particle surface area resulting in more favorable combustion conditions. This non-agglomerating property assists in making sub-bituminous coals more amenable to controlling NO_x by allowing less air to be introduced during the initial ignition portion of the combustion process. The coals from the Bridger, Black Butte and Leucite Hills mines just barely fall into the category of non-agglomerating coals. While each of these coals is considered non-agglomerating, they either do not exhibit those properties of non-agglomerating coals or exhibit them to only a minor degree. The conditions during combustion of typical non-agglomerating coals that make it easier to control NO_x emissions do not exist for the Bridger blends of coals.

FIGURE 3-1
Illustration of the Effect of Agglomeration on the Speed of Coal Combustion
Jim Bridger 3




Table 3-1 shows key characteristics of a typical PRB coal compared to coals from the Bridger Mine, Black Butte, and Leucite Hills, as well as Twentymile, which is a representative western bituminous coal.

TABLE 3-1
Coal Characteristics Comparison
Jim Bridger 3

Parameter	Typical Powder River Basin	Bridger Mine	Black Butte	Leucite Hills	Twentymile
Nitrogen (percentage dry)	1.10	1.26	1.47	1.48	1.85
Oxygen (percentage dry)	16.2	13.2	13.4	13.2	7.19
Coal rank	Sub C	Sub B	Sub B	Sub B	Bituminous high volatility B

As shown in Table 3-1, although Bridger, Black Butte, and Leucite Hills are classified as sub-bituminous, they all exhibit higher nitrogen content and lower oxygen content than the PRB coal. The higher nitrogen content is an indication that more nitrogen is available to the combustion process and higher NO_x emissions are likely. Oxygen content can be correlated to the reactivity of the coal, with more reactive coals generally containing higher levels of oxygen. More reactive coals tend to produce lower NO_x emissions, and they are also more conducive to reduction of NO_x emissions through the use of combustion control measures, such as low NO_x burners and over-fire air (OFA). These characteristics indicate that higher NO_x formation is likely with coal from the Bridger, Black Butte, and Leucite Hills mines, rather than with PRB coal. The Bridger, Black Butte, and Leucite Hills coals all contain quality characteristics that fall between a typical PRB coal and Twentymile. Twentymile is a clearly bituminous coal that produces higher NO_x, as has been demonstrated at power plants burning this fuel.

Figures 3-2 and 3-3 graphically illustrate the relationship of nitrogen and oxygen content to the BART presumptive NO_x limits for the coals listed in Table 3-1. Each chart identifies the presumptive BART limit associated with a typical bituminous and sub-bituminous coal, and demonstrates how the Jim Bridger coal falls between these two general coal classifications.

The Bridger blend data point represents a combination of coals from the Bridger Mine, Black Butte, and Leucite Hills that has been used at Jim Bridger 3, and indicates the average NO_x emission rate achieved during the years 2003-2005. The Jim Bridger 2 data point consists of the same blend of coals as Jim Bridger 3, and represents the NO_x emission rate achieved after installation of Alstom's current state-of-the-art TFS2000 LNB and OFA system. The long-term sustainable emission rate for this system is expected to be 0.24 lb per MMBtu. All four units at Jim Bridger consist of identical boilers; while there may be some differences in performance among them, installation of the TFS2000 firing system at Jim Bridger 3 would likely result in performance and NO_x emission rates comparable to those at Jim Bridger 2.

Figures 3-2 and 3-3 both demonstrate that for the Jim Bridger units—with the TFS2000 low NO_x emission system installed, and burning a combination of the Bridger, Black Butte, and

Leucite Hill coals—the likely NO_x emission rate will be closer to the bituminous end (0.28) of the BART presumptive NO_x limit range, rather than the BART presumptive NO_x limit of 0.15 lb per MMBtu for sub-bituminous coal. All of these factors are consistent with the observed sustainable rate of 0.24 lb per MMBtu.

FIGURE 3-2
 Plot of Typical Nitrogen Content of Various Coals and Applicable Presumptive BART NO_x Limits
Jim Bridger 3





FIGURE 3-3
Plot of Typical Oxygen Content of Various Coals and Applicable Presumptive BART NO_x Limits
Jim Bridger 3



Coal quality characteristics also impact the design and operation of the boiler and associated auxiliary equipment. Minor changes in quality can sometimes be accommodated through operational adjustments or equipment changes. It is important to note, however, that consistent variations in quality or assumptions of “average” quality for performance projections can be problematic. This is particularly troublesome when dealing with performance issues that are very sensitive to both coal quality and combustion conditions, such as NO_x formation. There is significant variability in the quality of coals burned at Jim Bridger 3. In addition to burning coal from Black Butte and Leucite Hills, Jim Bridger 3 burns coal supplied from the Bridger Mine consisting of three sources: underground, surface, and highwall operations. Each of these coal sources has different quality characteristics, as well as inherent variability in composition of the coal within the mine.

Several of the coal quality characteristics and their effect on NO_x formation have been previously discussed. There are some additional considerations that illustrate the complexity of achieving and maintaining consistent low NO_x emissions with pulverized coal on a shorter term, such as a 30-day rolling average basis.

Good combustion is based on the “three Ts”: time, temperature, and turbulence. These parameters along with a “design” coal are taken into consideration when designing a boiler and associated firing equipment such as fans, burners, and pulverizers. If a performance requirement such as NO_x emission limits is subsequently changed, conflicts with and between other performance issues can result.

Jim Bridger 3 is located at an altitude of 6,669 feet above sea level. Atmospheric pressure is lower at this elevation, 11.5 pounds per square inch, as compared with sea level pressure of 14.7 pounds per square inch. This lower pressure means that less oxygen is available for combustion for each volume of air. In order to provide adequate oxygen to meet the requirements for efficient combustion, larger volumes of air are required. When adjusting air flows and distribution to reduce NO_x emissions using LNB and OFA, original boiler design restrictions again limit the modifications that can be made while still achieving satisfactory combustion performance.

Another significant factor in controlling NO_x emissions is the fineness of the coal entering the burners. Fineness is influenced by the Hardgrove Grindability Index of the coal. Finer coal particles promote release of volatiles and assist char burnout due to more surface area being exposed to air. NO_x reduction with high volatile coals is improved with greater fineness and with proper air staging. The lower rank sub-bituminous coals such as PRB coals are quite friable and easy to grind. Coals with lower Hardgrove Grindability Index values, such as those used at Jim Bridger 3, are more difficult to grind and can contribute to higher NO_x levels. In addition, coal fineness can deteriorate over time periods between pulverizer maintenance and service as pulverizer grinding surfaces wear.

In summary, when all the factors of agglomeration versus non-agglomeration, nitrogen and oxygen content of the coals, and the grindability index are taken into account, this analysis demonstrates that, for the coal used at Jim Bridger 3, the more applicable presumptive BART limit for NO_x emissions is 0.28 lb per MMBtu. The BART analysis for NO_x emissions from Jim Bridger 3 is further described below.

Step 1: Identify All Available Retrofit Control Technologies

The first step of the BART process is to evaluate NO_x control technologies with practical potential for application to Jim Bridger 3, including those control technologies identified as Best Available Control Technology (BACT) or lowest achievable emission rate (LAER) by permitting agencies across the United States. A broad range of information sources have been reviewed in an effort to identify potentially applicable emission control technologies. NO_x emissions at Jim Bridger 3 are currently controlled through the use of good combustion practices and OFA.

The following potential NO_x control technology options were considered:

- New/modified LNBs with advanced OFA
- Rotating Opposed Fire Air (ROFA)
- Conventional selective non-catalytic reduction (SNCR) system
- Selective catalytic reduction (SCR) system

Step 2: Eliminate Technically Infeasible Options

For Jim Bridger 3, a tangential-fired configuration burning sub-bituminous coal, technical feasibility will primarily be determined by physical constraints, boiler configuration, and on the ability to achieve the regulatory presumptive limit (used as a guide) of 0.28 lb NO_x per MMBtu. Jim Bridger 3 has an uncontrolled NO_x emission rate of 0.45 lb per MMBtu.

For this BART analysis, information pertaining to LNBS, OFA, SNCR, and SCR were based on the *Multi-Pollutant Control Report* (Sargent and Lundy, 2002, hereafter referred to as the S&L Study). Updated cost estimates for SCR and SNCR were used (Sargent & Lundy, 2006). PacifiCorp provided additional emissions data and costs developed by boiler vendors for LNBS and OFA. Also, CH2M HILL solicited a proposal from Mobotec for their ROFA technology.

With SNCR, an amine-based reagent such as ammonia, or more commonly urea, is injected into the furnace within a temperature range of 1,600 degrees Fahrenheit (°F) to 2,100°F, where it reduces NO_x to nitrogen and water. NO_x reductions of up to 40 to 60 percent have been achieved, although 15 to 30 percent is more realistic for most applications. SNCR is typically applied on smaller units. Adequate reagent distribution in the furnaces of large units can be problematic.

Table 3-2 summarizes the control technology options evaluated in this BART analysis, along with projected NO_x emission rates. All technologies can meet the applicable presumptive BART limit of 0.28 lb per MMBtu.

TABLE 3-2
NO_x Control Technology Projected Emission Rates
Jim Bridger 3

Technology	Projected Emission Rate (pounds per million British thermal units)
Presumptive Best Available Retrofit Technology (BART) Limit	0.28
Low-NO _x burners (LNBS) with over-fire air (OFA)	0.24
Rotating Opposed Fire Air	0.22
LNB with OFA and Selective Non-catalytic Reduction (SNCR)	0.20
LNB with OFA and Selective Catalytic Reduction (SCR)	0.07

Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

Preliminary vendor proposals, such as those used to support portions of this BART analysis, may be technically feasible and provide expected or guaranteed emission rates; however, the proposals include inherent uncertainties. These proposals are usually prepared in a limited time frame, may be based on incomplete information, may contain over-optimistic conclusions, and are non-binding. Therefore, emission rate values obtained in such preliminary proposals must be qualified, and it must be recognized that contractual guarantees are established only after more detailed analysis has been completed. The following subsections describe the control technologies and the control effectiveness evaluated in this BART analysis.

New LNBS with OFA System. The mechanism used to lower NO_x with LNBS is to stage the combustion process and provide a fuel rich condition initially; this is so oxygen needed for combustion is not diverted to combine with nitrogen and form NO_x. Fuel-rich conditions favor

the conversion of fuel nitrogen to nitrogen instead of NO_x . Additional air (or OFA) is then introduced downstream in a lower temperature zone to burn out the char.

Both LNBs and OFA are considered to be a capital cost, combustion technology retrofit. For LNB retrofits to units configured with tangential-firing such as Jim Bridger 3, it is generally necessary to increase the burner spacing; this prevents interaction of the flames from adjacent burners and reduces burner zone heat flux. These modifications usually require boiler waterwall tube replacement.

Information provided to CH2M HILL by PacifiCorp—based on the S&L Study and data from boiler vendors—indicates that a new LNB and OFA retrofit at Jim Bridger 3 would result in an expected NO_x emission rate of 0.24 lb per MMBtu. PacifiCorp has indicated that this rate corresponds to a vendor guarantee, not a vendor prediction, and they believe that this emission rate can be sustained as an average between overhauls. This emission rate represents a significant reduction from the current NO_x emission rate, and is below the more applicable presumptive NO_x emission rate of 0.28 lb per MMBtu.

Rotating Opposed Fire Air. Mobotec markets ROFA as an improved second generation OFA system. Mobotec states that “the flue gas volume of the furnace is set in rotation by asymmetrically placed air nozzles. Rotation is reported to prevent laminar flow, so that the entire volume of the furnace can be used more effectively for the combustion process. In addition, the swirling action reduces the maximum temperature of the flames and increases heat absorption. The combustion air is also mixed more effectively.” A typical ROFA installation would have a booster fan(s) to supply the high velocity air to the ROFA boxes, and Mobotec would propose two 4,000 to 4,300 horsepower fans for Jim Bridger 3.

Mobotec proposes to achieve a NO_x emission rate of 0.18 lb per MMBtu using ROFA technology. An operating margin of 0.04 lb per MMBtu was added to the expected rate due to Mobotec’s limited ROFA experience with western sub-bituminous coals. Under the Mobotec proposal, which is primarily based on ROFA equipment, the operation of existing LNB and OFA ports would be analyzed. While a typical installation does not require modification to the existing LNB system and the existing OFA ports are not used, results of computational fluid dynamics modeling would determine the quantity and location of new ROFA ports. The Mobotec proposal includes bent tube assemblies for OFA port installation.

Mobotec would not provide installation services, because they believe that the Owner can more cost effectively contract for these services. However, they would provide one onsite construction supervisor during installation and startup.

Selective Non-catalytic Reduction. With SNCR—a process generally utilized to achieve modest NO_x reductions on smaller units—an amine-based reagent such as ammonia, or more commonly urea, is injected into the furnace within a temperature range of 1,600°F to 2,100°F, where it reduces NO_x to nitrogen and water. NO_x reductions of up to 60 percent have been achieved, although 20 to 40 percent is more realistic for most applications.

Reagent utilization, which is a measure of the efficiency with which the reagent reduces NO_x , can range from 20 to 60 percent, depending on the amount of reduction, unit size, operating conditions, and allowable ammonia slip. With low reagent utilization, low temperatures, or inadequate mixing, ammonia slip occurs, allowing unreacted ammonia to create problems

downstream. The ammonia may render fly ash unsaleable, react with sulfur to foul heat exchange surfaces, and/or create a visible stack plume. Reagent utilization can have a significant impact on economics, with higher levels of NO_x reduction generally resulting in lower reagent utilization and higher operating cost.

Reductions from higher baseline concentrations (inlet NO_x) are lower in cost per ton, but result in higher operating costs, due to greater reagent consumption. To reduce reagent costs, S&L has assumed that combustion modifications including LNBs and advanced OFA, capable of achieving a projected NO_x emission rate of 0.24 lb per MMBtu. At a further reduction of 15 percent in NO_x emission rates for SNCR would result in a projected emission rate of 0.20 lb per MMBtu.

Selective Catalytic Reduction. While working on the same chemical principle as SNCR, SCR uses a catalyst to promote the chemical reaction. Ammonia is injected into the flue-gas stream, where it reduces NO_x to nitrogen and water. Unlike the high temperatures required for SNCR, in SCR the reaction takes place on the surface of a vanadium/titanium-based catalyst at a temperature range between 580°F to 750°F. Due to the catalyst, the SCR process is more efficient than SNCR and results in lower NO_x emissions. The most common type of SCR is the high-dust configuration, where the catalyst is located downstream from the boiler economizer and upstream of the air heater and any particulate control equipment. In this location, the SCR is exposed to the full concentration of fly ash in the flue gas that is leaving the boiler. The high-dust configuration is assumed for Jim Bridger 3. In a full-scale SCR, the flue ducts are routed to a separate large reactor containing the catalyst. With in-duct SCR, the catalyst is located in the existing gas duct, which may be expanded in the area of the catalyst to reduce flue gas flow velocity and increase flue gas residence time. Due to the higher removal rate, a full-scale SCR was used as the basis for analysis at Jim Bridger 3.

S&L prepared the design conditions and cost estimates for SCR at Jim Bridger 3. As with SNCR, it is generally more cost effective to reduce NO_x emission levels as much as possible through combustion modifications, in order to minimize the catalyst surface area and ammonia requirements of the SCR. The S&L design basis for LNB with OFA and SCR results in a projected NO_x emission rate of 0.07 lb per MMBtu. Additional catalyst surface was included in the SCR design to accommodate the characteristics of the coal used at Jim Bridger 3.

Level of Confidence for Vendor Post-control Emissions Estimates. In order to determine the level of NO_x emissions needed to consistently achieve compliance with an established goal, a review of typical NO_x emissions from coal-fired generating units was completed. As a result of this review, it was noted that NO_x emissions can vary significantly around an average emissions level. Variations may result for many reasons, including coal characteristics, unit load, boiler operation including excess air, boiler slagging, burner equipment condition, coal mill fineness, and so forth.

The steps utilized for determining a level of confidence for the vendor expected value are as follows:

- Establish expected NO_x emissions value from vendor.
- Evaluate vendor experience and historical basis for meeting expected values.

- Review and evaluate unit physical and operational characteristics and restrictions. The fewer variations there are in operations, coal supply, etc., the more predictable and less variant the NO_x emissions are.
- For each technology expected value, there is a corresponding potential for actual NO_x emissions to vary from this expected value. From the vendor information presented, along with anticipated unit operational data, an adjustment to the expected value can be made.

Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

Energy Impacts. Installation of LNBs and modification to the existing OFA systems are not expected to significantly impact the boiler efficiency or forced draft fan power usage. Therefore, these technologies will not have energy impacts.

The Mobotec ROFA system would require installation and operation of two 4,000 to 4,300 horsepower ROFA fans (6,410 kW total). The SNCR system would require approximately 520 kW of additional power.

Selective catalytic reduction retrofit impacts the existing flue gas fan systems, due to the additional pressure drop associated with the catalyst, which is typically a 6- to 8-inch water gage increase. Total additional power requirements for SCR installation at Jim Bridger 3 are estimated at approximately 3,220 kW, based on the S&L Study.

Environmental Impacts. Mobotec has predicted that carbon monoxide emissions, and unburned carbon in the ash, commonly referred to as loss on ignition, would be the same or lower than prior levels for the ROFA system.

The installation of SNCR or SCR systems could impact the saleability and disposal of fly ash due to ammonia levels, and could potentially create a visible stack plume, which may negate other visibility improvements. Other environmental impacts involve the storage of ammonia (especially if anhydrous ammonia is used), and the transportation of the ammonia to the power plant site.

Economic Impacts. Costs and schedules for the LNBs and OFA, SNCR, and SCR were furnished to CH2M HILL by PacifiCorp, developed using S&L's internal proprietary database, and supplemented (as needed) by vendor-obtained price quotes. The relative accuracy of these cost estimates is stated by S&L to be in the range of plus or minus 20 percent. Cost for the ROFA system was obtained from Mobotec.

A comparison of the technologies on the basis of costs, design control efficiencies, and tons of NO_x removed is summarized in Table 3-3, and the first year control costs are presented in Figure 3-4. The complete economic analysis is contained in Appendix A.

TABLE 3-3
NO_x Control Cost Comparison
Jim Bridger 3


Factor	Low-NO _x Burners (LNBs) with Over-fire Air (OFA)	Mobotec Rotating Opposed Fire Air (ROFA)	LNB with OFA and Selective Non- Catalytic Reduction (SNCR)	LNB with OFA and Selective Catalytic Reduction (SCR)
Total Installed Capital Costs	\$8.7 million	\$20.5 million	22.0 million	\$129.6 million
Total First Year Fixed and Variable Operation and Maintenance Costs	\$0.1 million	\$2.6 million	\$1.5 million	\$3.3 million
Total First Year Annualized Cost	\$0.9 million	\$4.6 million	\$3.6 million	\$15.6 million
Power Consumption (megawatts [MW])	0	6.4	0.5	3.3
Annual Power Usage (million MW-hours per year)	0	50.6	4.1	25.4
NO _x Design Control Efficiency	46.7%	51.1%	55.6%	84.4%
NO _x Removed per Year (Tons)	4,967	5,440	5,913	8,987
Nitrogen Oxide (NO _x) Design Control Efficiency	\$181/ton	\$843/ton	\$610/ton	\$1,734/ton
Incremental Control Cost (dollars per ton [\$ /ton] of NO _x Removed)	\$181/ton	\$7,797/ton	\$2,863/ton	\$3,896/ton

Preliminary BART Selection. CH2M HILL recommends selection of LNBs with OFA as BART for Jim Bridger 3 based on its significant reduction in NO_x emissions, reasonable control cost, and no additional power requirements or environmental impacts. Low-NO_x burners with OFA does not meet the EPA presumptive limit of 0.15 lb per MMBtu for sub-bituminous coal, but it does meet an emission rate that falls between the presumptive limit of 0.28 lb per MMBtu for bituminous coal and the limit of 0.15 lb per MMBtu for sub-bituminous coal. As discussed in the section on coal quality, the recommended technology and the achieved emission rate are deemed appropriate as BART for NO_x emissions from the coals combusted at Jim Bridger 3.

Step 5: Evaluate Visibility Impacts

Please see Section 4, BART Modeling Analysis.

FIGURE 3-4
First Year Control Cost for NO_x Air Pollution Control Options
Jim Bridger 3



3.2.2 BART SO₂ Analysis

Sulfur dioxide forms in the boiler during the combustion process, and is primarily dependent on coal sulfur content. The BART analysis for SO₂ emissions on Jim Bridger 3 is described below.

Step 1: Identify All Available Retrofit Control Technologies

A broad range of information sources were reviewed, in an effort to identify potentially applicable emission control technologies for SO₂ at Jim Bridger 3. This included control technologies identified as BACT or LAER by permitting agencies across the United States.

The following potential SO₂ control technology options were considered:

- Optimize current operation of existing wet sodium FGD system
- Upgrade wet sodium FGD system to meet SO₂ emission rate of 0.10 lb per MMBtu
- New dry FGD system

Step 2: Eliminate Technically Infeasible Options

Technical feasibility will primarily be based on the regulatory presumptive limit (used as a guideline) of 95 percent reduction in SO₂ emissions, or 0.15 lb per MMBtu. Based on the coal that Jim Bridger 3 currently burns, the unit would be required to achieve an 87.5 percent SO₂ removal efficiency to meet the presumptive limit of 0.15 lb per MMBtu.

Table 3-4 summarizes the control technology options evaluated in this BART analysis, along with projected SO₂ emission rates. Only one technology option can meet the applicable presumptive BART limit of 0.15 lb per MMBtu.

TABLE 3-4
SO₂ Control Technology Emission Rates
Jim Bridger 3

Technology	Projected Sulfur Dioxide (SO ₂) Emission Rate (pound per million British thermal units)
Presumptive Best Available Retrofit Technology Limit	0.15
Upgrade Existing Wet Sodium System	0.10
Optimize Existing Wet Sodium System	0.20
New Dry Flue Gas Desulfurization System	0.21

Wet Sodium FGD System. Wet sodium FGD systems operate by treating the flue gas in large scrubber vessels with a soda ash solution. The scrubber mixes the flue gas and alkaline reagent using a series of spray nozzles to distribute the reagent across the scrubber vessel. The sodium in the reagent reacts with the SO₂ in the flue gas to form sodium sulfite and sodium bisulfite, which are removed from the scrubber and disposed.

The wet sodium FGD system at Jim Bridger 3 currently achieves approximately 78 percent SO₂ removal to achieve an SO₂ outlet emission rate of 0.27 lb per MMBtu. Optimizing the existing wet FGD system would achieve an SO₂ outlet emission rate of 0.20 lb per MMBtu (83.3 percent SO₂ removal) by partially closing the bypass damper to reduce routine bypass flue gas flow used to reheat the treated flue gas from the scrubber, relocating the opacity monitor, and modifying the system to minimize scaling problems.

Upgrading the wet FGD system would achieve an SO₂ outlet emission rate of 0.10 lb per MMBtu (91.7 percent SO₂ removal) by closing the bypass damper to eliminate routine bypass flue gas flow used to reheat the treated flue gas from the scrubber, relocating the opacity monitor, adding new fans, adding a stack liner and drains for wet operation, and using a refined soda ash reagent. It is considered technically infeasible for the present wet FGD system to achieve 95 percent SO₂ removal (0.06 lb per MMBtu) on a continuous basis, since this high level of removal must be incorporated into the original design of the scrubber.

Optimizing the existing wet sodium scrubbing FGD system is projected to achieve an outlet emission rate of 0.20 lb per MMBtu which would not meet the presumptive limit of 0.15 lb SO₂ per MMBtu. Therefore, this option is eliminated as technically infeasible for this analysis. An upgraded wet sodium scrubbing FGD system is projected to achieve an outlet emission rate of 0.10 lb per MMBtu (91.7 percent SO₂ removal) which would meet the presumptive limit of 0.15 lb SO₂ per MMBtu for Jim Bridger 3.

New Dry FGD System. The lime spray dryer typically injects lime slurry in the top of the absorber vessel with a rapidly rotating atomizer wheel. The rapid speed of the atomizer wheel causes the lime slurry to separate into very fine droplets that intermix with the flue gas. The SO₂ in the flue gas reacts with the calcium in the lime slurry to form dry calcium sulfate particles. At Jim Bridger 3, this dry particulate matter would be captured downstream in the existing ESP, along with the fly ash. A lime spray dryer system typically produces a dry waste product suitable for landfill disposal.

The dry FGD system with the existing ESP is projected to achieve 82.5 percent SO₂ removal at Jim Bridger 3. This would result in a controlled SO₂ emission rate of 0.21 lb per MMBtu, based on an uncontrolled SO₂ emission rate of 1.20 lb per MMBtu. Therefore, this option cannot meet the presumptive limit of 0.15 lb SO₂ per MMBtu, and is eliminated from further analysis as technically infeasible.

Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

When evaluating the control effectiveness of SO₂ reduction technologies, each option can be compared against benchmarks of performance. One such benchmark is the presumptive BART emission limit because Jim Bridger 3 is required to meet this limit. As indicated previously, the presumptive limit for SO₂ on a BART-eligible coal burning unit is 95 percent removal, or 0.15 lb per MMBtu.

The projected emission rate for an upgraded wet sodium FGD system for Jim Bridger 3 would be 0.10 lb per MMBtu. This option would meet the presumptive SO₂ limit of 0.15 lb per MMBtu.

Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

Energy Impacts. Upgrading the existing wet sodium FGD system would require an additional 520 kW of power.

Environmental Impacts. There will be incremental additions to scrubber waste disposal and makeup water requirements. Another environmental impact is a reduction of the stack gas temperature from 140°F to 120°F due to elimination of the bypassed flue gas which had provided approximately 20°F of reheat.

Economic Impacts. A summary of the costs and amount of SO₂ removed for the upgraded wet sodium FGD system is provided in Table 3-5. The complete economic analysis is contained in Appendix A.

TABLE 3-5
SO₂ Control Cost Comparison (Incremental to Existing FGD System)
Jim Bridger Unit 3

Factor	Upgraded Wet Flue Gas Desulfurization (FGD)
Total Installed Capital Costs	\$13.0 million
Total First Year Fixed and Variable Operation and Maintenance Costs	\$1.3 million
Total First Year Annualized Cost	\$2.5 million
Additional Power Consumption (megawatts [MW])	0.5
Additional Annual Power Usage (1000 MW-hours per year)	4.1
Incremental Sulfur Dioxide (SO ₂) Design Control Efficiency	62.5% (91.7% based on Uncontrolled SO ₂)
Incremental Tons SO ₂ Removed per Year	3,950
First Year Average Control Cost (dollars per ton [\$/Ton] of SO ₂ Removed)	632
Incremental Control Cost (\$/Ton of SO ₂ Removed)	632

Preliminary BART Selection. CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 3 based on its significant reduction in SO₂ emissions (meeting presumptive limit of 0.15 lb per MMBtu), reasonable control costs, and the advantages of minimal additional power requirements and environmental impacts.

Step 5: Evaluate Visibility Impacts

Please see Section 4, BART Modeling Analysis.

3.2.3 BART PM₁₀ Analysis

Jim Bridger 3 is currently equipped with an ESP. Electrostatic precipitators remove particulate matter (PM) from the flue gas stream by charging fly ash particles with a very high direct current voltage, and attracting these charged particles to grounded collection plates. A layer of collected PM forms on the collecting plates and is removed by periodically rapping the plates. The collected ash particles drop into hoppers below the precipitator and are removed periodically by the fly ash-handling system. Historically, the ESP at Jim Bridger 3 has controlled PM₁₀ emissions to levels below 0.057 lb per MMBtu.

The BART analysis for PM₁₀ emissions at Jim Bridger 3 is described in this section. For the modeling analysis in Section 4, PM₁₀ was used as an indicator for PM, and PM₁₀ includes particulate matter less than 2.5 micrometers in aerodynamic diameter (PM_{2.5}) as a subset.

Step 1: Identify All Available Retrofit Control Technologies

Two retrofit control technologies have been identified for additional PM control:

- Flue gas conditioning
- Polishing fabric filter (baghouse) downstream of existing ESP

Another available control technology is replacing the existing ESP with a new fabric filter. Because the environmental benefits of replacing the fabric filter are also achieved by the lower-cost option of installing a polishing fabric filter downstream of the existing ESP, installation of a full fabric filter was not considered in the analysis.

Step 2: Eliminate Technically Infeasible Options

Flue Gas Conditioning. If the fly ash from coal has high resistivity, such as fly ash from sub-bituminous coal, the ash is not collected effectively in an ESP. This is because the high resistivity makes the particles less willing to accept an electrical charge. Adding flue gas conditioning (FGC), which is typically accomplished by injection of sulfur trioxide (SO₃), will lower the resistivity of the particles so that they will accept more charge and allow the ESP to collect the ash more effectively. Flue gas conditioning systems can account for large improvements in collection efficiency for small ESPs.

Polishing Fabric Filter. A polishing fabric filter could be added downstream of the existing ESP at Jim Bridger 3. One such technology is licensed by the Electric Power Research Institute, and referred to as a COHPAC (Compact Hybrid Particulate Collector). The COHPAC collects the ash that is not collected by the ESP, thus acting as a polishing device. The ESP needs to be kept in service for the COHPAC fabric filter to operate effectively.

The COHPAC fabric filter is about one-half to two-thirds the size of a full-size fabric filter, because the COHPAC has a higher air-to-cloth ratio (7 to 9:1), compared to a full-size pulse jet fabric filter (3.5 to 4:1).

Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

The existing ESP at Jim Bridger 3 is achieving a controlled PM emission rate of 0.057 lb per MMBtu. Utilizing flue conditioning upstream of the existing ESP is projected to reduce PM emissions to approximately 0.030 lb per MMBtu. Adding a COHPAC fabric filter downstream of the existing ESP is projected to reduce PM emissions to approximately 0.015 lb per MMBtu.

The PM₁₀ control technology emission rates are summarized in Table 3-6.

TABLE 3-6
PM₁₀ Control Technology Emission Rates
Jim Bridger 3

Control Technology	Short-term Projected PM ₁₀ ^(a) Emission Rate (pound per million British thermal units)
Flue Gas Conditioning	0.030
Polishing Fabric Filter	0.015

NOTES:

^(a) PM₁₀ refers to particulate matter less than 10 micrometers in aerodynamic diameter

Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

Energy Impacts. Energy is required to overcome the additional pressure drop from the COHPAC fabric filter and associated ductwork. Therefore, a COHPAC retrofit will require an internal diameter fan upgrade and upgrade of the auxiliary power supply system.

The COHPAC fabric filter at Jim Bridger 3 would require approximately 3.3 MW of power, equating to an annual power usage of approximately 26.3 million kW-Hr.

There is only a small power requirement of approximately 50 kW associated with flue gas conditioning.

Environmental Impacts. There are no negative environmental impacts from the addition of a COHPAC polishing fabric filter or flue gas conditioning system.

Economic Impacts. A summary of the costs and PM removed for COHPAC and flue gas conditionings are recorded in Table 3-7, and the first-year control costs for flue gas conditioning and fabric filters are shown in Figure 3-5. The complete economic analysis is contained in Appendix A.

TABLE 3-7
PM₁₀ Control Cost Comparison (Incremental to Existing ESP)
Jim Bridger 3


Factor	Flue Gas Conditioning	Polishing Fabric Filter
Total Installed Capital Costs	\$0	\$48.4 million
Total First Year Fixed and Variable Operations and Maintenance Costs	\$0.2 million	\$1.7 million
Total First Year Annualized Cost	\$0.2 million	\$ 6.3 million
Additional Power Consumption (MW)	0.05	3.43
Annual Power Usage (million kilowatt-hours per year)	0.4	26.3
Incremental Particulate Matter (PM) Design Control Efficiency	47.4%	73.7%
Incremental Tons PM Removed per Year	639	993
First Year Average Control Cost (dollars per ton [\$ /Ton] of PM Removed)	275	6,381
Incremental Control Cost (\$ /Ton of PM Removed)	275	17,371

Preliminary BART Selection. CH2M HILL recommends selection of flue gas conditioning upstream of the existing ESP as BART for Jim Bridger 3 based on the significant reduction in PM emissions, reasonable control costs, and advantages of minimal additional power requirements and no environmental impacts.

Step 5: Evaluate Visibility Impacts

Please see Section 4, BART Modeling Analysis.

FIGURE 3-5
First Year Control Cost for PM Air Pollution Control Options
Jim Bridger 3



4.0 BART Modeling Analysis

4.1 Model Selection

CH2M HILL used the CALPUFF modeling system to assess the visibility impacts of emissions from Jim Bridger 3 at nearby Class I areas. The Class I areas potentially affected are located more than 50 kilometers but less than 300 kilometers from the Jim Bridger 3 facility. The Class I areas include the following wilderness areas (WA):

- Bridger WA
- Fitzpatrick WA
- Mt. Zirkel WA

The CALPUFF modeling system includes the CALMET meteorological model, a Gaussian puff dispersion model (CALPUFF) with algorithms for chemical transformation and deposition, and a post processor capable of calculating concentrations, visibility impacts, and deposition (CALPOST). The CALPUFF modeling system was applied in a full, refined mode. Version numbers of the various programs in the CALPUFF system used by CH2M HILL were as follows:

- CALMET Version 5.53a, Level 040716
- CALPUFF Version 5.711a, Level 040716
- CALPOST Version 5.51, Level 030709

4.2 CALMET Methodology

4.2.1 Dimensions of the Modeling Domain

CH2M HILL used the CALMET model to generate a three-dimensional wind field and other meteorological parameters suitable for use by the CALPUFF model. A modeling domain was established to encompass the Jim Bridger 3 facility and allow for a 50-kilometer buffer around the Class I areas that were within 300 kilometers of the facility; the grid resolution was 4 kilometers. Figure 4-1 shows the extent of the modeling domain. Except when specifically instructed otherwise by the Wyoming Department of Environmental Quality – Air Quality Division (WDEQ-AQD), CH2M HILL followed the methodology spelled out in the WDEQ-AQD BART Modeling Protocol, a copy of which is included as Appendix B.

CH2M HILL used the Lambert Conformal Conic map projection for the analysis due to the large extent of the domain. The latitude of the projection origin and the longitude of the central meridian were chosen at the approximate center of the domain. Standard parallels were drawn to represent one-sixth and five-sixths of the north-south extent of the domain to minimize distortion in the north-south direction.




Figure 4-1
 Jim Bridger Source-Specific
 Class I Areas to be Addressed



CH2MHILL

S:\C\DRG\PROJECTS\HUNTER\MAPPFILES\JIM_BRIDGER_CLASS1.MXD 11/9/2006 MSLAYDEN

The default technical options listed in TRC Companies, Inc.'s (TRC) current example CALMET.inp file were used for CALMET. Vertical resolution of the wind field included ten layers, with vertical face heights as follows (in meters):

- 0, 20, 40, 100, 140, 320, 580, 1020, 1480, 2220, 3500

Other user-specified model options were set to values established by WDEQ-AQD which appear in Table 3 of Appendix B. Table 4-1 lists the key user-specified options used for this analysis.

TABLE 4-1
User-specified CALMET Options
Jim Bridger 3

CALMET Input Parameter	Value
CALMET Input Group 2	
Map projection (PMAP)	Lambert Conformal
Grid spacing (DGRIDKM)	4
Number vertical layers (NZ)	10
Top of lowest layer (m)	20
Top of highest layer (m)	3500
CALMET Input Group 4	
Observation mode (NOOBS)	0
CALMET Input Group 5	
Prog. Wind data (IPROG)	14
(RMAX1)	30
(RMAX2)	50
Terrain influence (TERRAD)	
(R1)	5
(R2)	25
CALMET Input Group 6	
Max mixing ht (ZIMAX)	3500

4.2.2 CALMET Input Data

CH2M HILL ran the CALMET model to produce three years of analysis: 2001, 2002, and 2003. WDEQ-AQD provided 12-km resolution Mesoscale Meteorological Model, Version 5 (MM5) meteorological data fields that covered the entire modeling domain for each study year.

These three data sets were chosen because they are current and have been evaluated for quality. The MM5 data were used as input to CALMET as the "initial guess" wind field. The initial guess wind field was adjusted by CALMET for local terrain and land use effects to generate a Step 1 wind field, and further refined using local surface observations to create a final Step 2 wind field.

Surface data for 2001 through 2003 were obtained from the National Climatic Data Center. CH2M HILL processed the data from the National Weather Service's Automated Surface Observing System network for all stations that are in the domain. The surface data were obtained in abbreviated DATSAV3 format. A conversion routine available from the TRC Web site was used to convert the DATSAV3 files to CD-144 format for input into the SMERGE preprocessor and CALMET.

Land use and terrain data were obtained from the U.S. Geological Survey (USGS). Land use data were obtained in Composite Theme Grid format from the USGS, and the Level 1 USGS land use categories were mapped into the 14 primary CALMET land use categories. Surface properties such as albedo, Bowen ratio, roughness length, and leaf area index were computed from the land use values. Terrain data were taken from USGS 1-degree Digital Elevation Model data, which primarily derive from USGS 1:250,000 scale topographic maps. Missing land use data were filled with values that were assumed appropriate for the missing area.

Precipitation data were obtained from the National Climatic Data Center. All available data in fixed-length, TD-3240 format were obtained for the modeling domain. The list of available stations that have collected complete data varies by year, but CH2M HILL processed all available stations/data within the domain for each year. Precipitation data were prepared with the PXTRACT/PMERGE processors in preparation for use within CALMET.

Upper-air data were prepared for the CALMET model with the READ62 preprocessor for the following stations:

- Denver, Colorado
- Salt Lake City, Utah
- Riverton, Wyoming
- Rapid City, South Dakota

Figure 4-2 shows the locations of surface and upper air stations within the MM5 modeling domain.




Figure 4-2
Surface and Upper Air Stations Used in the
Jim Bridger BART Analysis



CH2MHILL

S:\C\ISL\DRGIS\PROJECTS\HUNTER\MAPFILES\JIM_BRIDGER_ASOS.MXD 11/9/2006 10:51:25 AM

4.2.3 Validation of CALMET Wind Field

CH2M HILL used the CALDESK data display and analysis system (v2.97, Enviromodeling Ltd.) to view plots of wind vectors and other meteorological parameters to evaluate the CALMET wind fields. The CALDESK displays were compared to observed weather conditions, as depicted in surface and upper-air weather maps (National Oceanic and Atmospheric Administration, 2006).

4.3 CALPUFF Modeling Approach

For the BART control technology visibility improvement modeling, CH2M HILL followed WDEQ-AQD guidance provided (WDEQ-AQD, 2006).

CH2M HILL drove the CALPUFF model with the meteorological output from CALMET over the modeling domain described earlier. The CALPUFF model was used to predict visibility impacts for the pre-control (baseline) scenario for comparison to the predicted impacts for post-control scenarios for Jim Bridger 3.

4.3.1 Background Ozone and Ammonia

Hourly values of background ozone concentrations were used by CALPUFF for the calculation of SO₂ and NO_x transformation with the MESOPUFF II chemical transformation scheme. CH2M HILL obtained hourly ozone data from the following stations located within the modeling domain for 2001, 2002, and 2003:

- Rocky Mountain National Park, Colorado
- Craters of the Moon National Park, Idaho
- Highland, Utah
- Thunder Basin National Grasslands, Wyoming
- Yellowstone National Park, Wyoming
- Centennial, Wyoming
- Pinedale, Wyoming

For periods of missing hourly ozone data, the chemical transformation relied on a monthly default value of 44 parts per billion. Background ammonia was set to 2 parts per billion. Both of these background values were taken from the guidance document (WDEQ-AQD, 2006).

4.3.2 Stack Parameters

The stack parameters used for the baseline modeling reflect those that are in place under the current permit for Jim Bridger 3. Post-control stack parameters reflect the anticipated changes associated with installation of the control technology alternatives that are being evaluated. The maximum heat input rate of 6,000 MMBtu per hour was used to calculate a maximum emission rate. Measured velocities and stack flow rates were used in the modeling to represent a worst-case situation.

4.3.3 Emission Rates

Pre-control emission rates for Jim Bridger 3 reflect peak 24-hour average emissions that may occur under the source's current permit. The emission rates reflect actual emissions under normal operating conditions, as described by the EPA in the *Regional Haze Regulations and Guidelines for Best Available Retrofit Technology Determinations; Final Rule* (40 CFR Part 51).

CH2M HILL used available continuous emission monitoring data to determine peak 24-hour emission rates. Data reflected operations from the most recent 3- to 5-year period unless a more recent period was more representative. Allowable short-term (24-hour or shorter period) emissions or short-term emission limits were used if continuous emission monitoring data were not available.

Emissions were modeled for the following pollutants:

- SO₂
- NO_x
- Coarse particulate (PM_{2.5}<diameter<PM₁₀)
- Fine particulate (diameter<PM_{2.5})
- Sulfates

Post-control emission rates reflect the effects of the emissions control scenario under consideration. Modeled pollutants were the same as those listed for the pre-control scenario.

4.3.4 Post-control Scenarios

Four post-control modeling scenarios were developed to cover the range of effectiveness for the combination of the individual NO_x, SO₂, and PM control technologies being evaluated. The selection of each control device was made based on the engineering analyses described in Section 3 for reasonable technologies that would meet or exceed the presumptive BART levels for each pollutant.

- **Scenario 1:** New LNB with OFA modifications, upgraded wet FGD system and flue gas conditioning for enhanced ESP performance. As indicated previously, this scenario represents CH2M HILL's preliminary BART recommendation.
- **Scenario 2:** New LNB with OFA modifications, upgraded wet FGD system and new polishing fabric filter.
- **Scenario 3:** New LNB with OFA modifications and SCR, upgraded wet FGD system and flue gas conditioning for enhanced ESP performance.
- **Scenario 4:** New LNB with OFA modifications and SCR, upgraded wet FGD system and new polishing fabric filter.

The ROFA option and LNB with OFA & SCR option for NO_x control were not included in the modeling scenarios because their control effectiveness is between the LNB with OFA option and the SCR option. Modeling of NO_x, SO₂, and PM controls alone was not performed because any final BART solution will include a combination of control technologies for NO_x, SO₂, and PM.

Table 4-2 presents the stack parameters and emission rates used for the Jim Bridger 3 analysis for baseline and post-control modeling. In accordance with the WDEQ BART modeling protocol, elemental carbon stack emissions and organic aerosol emissions were not modeled.

4.3.5 Modeling Process

The CALPUFF modeling for the control technology options for Jim Bridger 3 followed this sequence:

- Model pre-control (baseline) emissions
- Model preferred post-control scenario (if applicable)
- Determine degree of visibility improvement
- Model other control scenarios
- Determine degree of visibility improvement
- Factor visibility results into the BART "five-step" evaluation

4.3.6 Receptor Grids

Discrete receptors for the CALPUFF modeling were placed at uniform receptor spacing along the boundary and in the interior of each area of concern. Class I area receptors were taken from the National Park Service database for Class I area modeling receptors. The TRC COORDS program was used to convert all latitude/longitude coordinates to Lambert Conformal Conic coordinates, including receptors, meteorological stations, and source locations.

TABLE 4-2
BART Model Input Data
Jim Bridger 3

Model Input Data	Baseline	Post-control Scenario			
		Scenario 1 LNB with Over Fire Air (OFA), Upgrade Wet FGD & Flue Gas Conditioning (FGC) for Enhanced ESP Performance	Scenario 2 LNB with OFA, Upgrade Wet FGD, New Fabric Filter	Scenario 3 LNB with OFA and SCR, Upgrade Wet FGD & FGC for Enhanced ESP Performance	Scenario 4 LNB with OFA and SCR, Upgrade Wet FGD, New Fabric Filter
Sulfur Dioxide (SO ₂) Stack Emissions (pounds per hour (lb/hr))	1,602	800	600	600	600
Nitrogen Oxide (NO _x) Stack Emissions (lb/hr)	2,700	1,440	1,440	420	420
PM ₁₀ Stack Emissions (lb/hr)	342	180	90.0	180	90.0
Coarse Particulates (PM _{2.5} -diameter-PM ₁₀) Stack Emissions (lb/hr) ^(b)	147	77.4	51.3	77.4	51.3
Fine Particulates (diameter-PM _{2.5}) Stack Emissions (lb/hr) ^(b)	195	103	38.7	103	38.7
Sulfuric Acid (H ₂ SO ₄) Stack Emissions (lb/hr)	55.2	55.2	55.2	94.8	94.8
H ₂ SO ₄ as Sulfate (SO ₄) Stack Emissions (lb/hr)	54.1	54.1	54.1	92.9	92.9
Ammonium Sulfate [(NH ₄) ₂ SO ₄] Stack Emissions (lb/hr)				7.02	7.02
(NH ₄) ₂ SO ₄ as SO _x Stack Emissions (lb/hr)				5.10	5.10
(NH ₄)HSO ₄ as SO _x Stack Emissions (lb/hr)				12.2	12.2
(NH ₄)HSO ₄ as SO ₂ Stack Emissions (lb/hr)				10.2	10.2
Total Sulfate (as SO _x) (lb/hr)	54.1	54.1	54.1	108	108
Stack Conditions					
Stack Height (meters)	152	152	152	152	152
Stack Exit Diameter (meters)	7.32	7.32	7.32	7.32	7.32
Stack Exit Temperature (Kelvin)	333	322	333	333	333
Stack Exit Velocity (meters per second)	25.6	24.8	27.4	27.4	27.4

NOTES:
^(b) Based on AP-42, Table 1.1-6, coarse particulates are counted as a percentage of PM₁₀. This equates to 43 percent ESP and 57 percent baghouse. PM₁₀ and PM_{2.5} refer to particulate matter less than 10 and 2.5 micrometers, respectively, in aerodynamic diameter.
^(c) Based on AP-42, Table 1.1-6, fine particulates are counted as a percentage of PM₁₀. This equates to 57 percent ESP and 43 percent baghouse. PM₁₀ and PM_{2.5} refer to particulate matter less than 10 and 2.5 micrometers, respectively, in aerodynamic diameter.

4.4 CALPOST

The CALPOST processor was used to determine 24-hour average visibility results with output specified in deciview (dV) units. Calculations of light extinction were made for each pollutant modeled. The sum of all extinction values were used to calculate the delta-dV (Δ dV) change relative to natural background. The following default light extinction coefficients for each pollutant were used:

- Ammonium sulfate 3.0
- Ammonium nitrate 3.0
- PM coarse (PM₁₀) 0.6
- PM fine (PM_{2.5}) 1.0
- Organic carbon 4.0
- Elemental carbon 10.0

CALPOST visibility Method 6 was used to determine the visibility impacts. Monthly relative humidity factors were used in the light extinction calculations to account for the hygroscopic characteristics of nitrate and sulfate particles. Table 5 of the Wyoming BART Air Modeling Protocol (Appendix B) lists the monthly relative humidity factors for the Class I areas. These values were used for the particular Class I area being modeled.

The natural background conditions as a reference for determining the delta-deciview (Δ dV) change represented the 20 percent best natural visibility days. The EPA BART guidance document provided dV values for the 10 percent best days for each Class I area, but did not provide individual species concentration data for the 20 percent best days. Species concentrations corresponding to the 20 percent best days were calculated for each Class I area by scaling back the annual average species concentrations given in Table 2-1 of *Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule* (EPA, 2003). A separate scaling factor was derived for each Class I area such that, when multiplied by the Guidance table annual concentrations, the 20 percent best days dV value for that area would be calculated. This procedure was taken from *Protocol for BART-Related Visibility Improvement Modeling Analysis in North Dakota* (North Dakota Department of Health, 2005). The Wyoming BART Air Modeling Protocol (see Appendix B) did provide natural background concentrations of aerosol components to use in the BART analysis. Table 4-3 lists the annual average species concentrations from the BART protocol.

TABLE 4-3
Average Natural Levels of Aerosol Components
Jim Bridger 3

Aerosol Component	Average Natural Concentration (micrograms per cubic meter) for Mt. Zirkel Class I Wilderness Area	Average Natural Concentration (micrograms per cubic meter) for Fitzpatrick and Bridger Class I Wilderness Areas
Ammonium Sulfate	0.046	0.045
Ammonium Nitrate	0.038	0.038
Organic Carbon	0.179	0.178
Elemental Carbon	0.008	0.008
Soil	0.190	0.189
Coarse Mass	1.141	1.136

NOTES:

Source: Table 6 of the Wyoming BART Air Modeling Protocol

4.5 Presentation of Modeling Results

This section presents the results of the CALPUFF visibility improvement modeling analysis for Jim Bridger 3.

4.5.1 Visibility Changes for Baseline vs. Preferred Scenario

CH2M HILL modeled Jim Bridger 3 for the baseline conditions and post-control scenarios. The post-control scenarios included emission rates for NO_x, SO₂, and PM₁₀ that would be achieved if BART technology were installed on Jim Bridger 3.

Baseline (and post-control) 98th percentile results were greater than 0.5 ΔV for the Bridger WA, Fitzpatrick WA, and Mt. Zirkel WA. The 98th percentile results for each Class I area are presented in Table 4-4.

TABLE 4-4
Costs and Visibility Modeling Results for Baseline vs. Post-Control Scenarios at Class I Areas
Jim Bridger 3

Scenario	Class I Wilderness Area	Total First Year Annualized Cost	Modeling Results					Incremental Cost per Reduction in No. of Days Above 0.5 dV
			Highest Change in Declivity (dV)	9 th Percentile (dV)	Number (No.) of Days Above 0.5 dV	Cost per dV Reduction	Cost per Reduction in No. of Days Above 0.5 dV	
2001								
Baseline: current operation with wet Flue Gas Desulfurization (FGD), Electrostatic Precipitator (ESP)	Bridger, Fitzpatrick, Mt. Zirkel		2,508, 2,178, 1,945	0.741, 0.416, 1.226	15, 7, 27			
Scenario 1: Low-NO _x Burners (LNBs) with Over Fire Air (OFA), upgrade wet FGD, Flue Gas Conditioning (FGC) for enhanced ESP performance	Bridger, Fitzpatrick, Mt. Zirkel	\$3,387,823	1,366, 1,386, 1,168	0.396, 0.223, 0.733	7, 3, 16	\$9,543,444, \$17,373,862, \$6,872,054	\$423,460, \$946,961, \$307,993	
Scenario 2: LNB with OFA, upgrade wet FGD, polishing fabric filter	Bridger, Fitzpatrick, Mt. Zirkel	\$9,726,040	1,393, 1,182, 1,102	0.376, 0.214, 0.677	6, 3, 15	\$26,646,685, \$47,676,667, \$17,715,920	\$1,080,671, \$2,451,510, \$113,180,670	
Scenario 3: LNB with OFA and Selective Catalytic Reduction (SCR), upgrade wet FGD, FGC for enhanced ESP performance	Bridger, Fitzpatrick, Mt. Zirkel	\$18,074,111	0.875, 0.681, 0.759	0.278, 0.128, 0.451	3, 1, 5	\$39,121,453, \$82,324,522, \$23,321,434	\$1,506,176, \$3,012,352, \$821,551	
Scenario 4: LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	Bridger, Fitzpatrick, Mt. Zirkel	\$24,412,229	0.837, 0.66, 0.731	0.268, 0.126, 0.437	3, 1, 2	\$51,611,478, \$83,603,524, \$30,940,721	\$576,192,500, \$3,169,056,761, \$452,722,679	
2002								
Baseline: current operation with wet FGD, ESP	Bridger, Fitzpatrick, Mt. Zirkel		4,103, 1,906, 2,801	1.447, 0.713, 1.498	27, 11, 94			
Scenario 1: LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	Bridger, Fitzpatrick, Mt. Zirkel	\$3,387,823	2,447, 1,074, 1,541	0.854, 0.377, 0.815	14, 4, 13	\$5,713,191, \$10,083,103, \$4,660,355	\$260,609, \$483,989, \$161,330	
Scenario 2: LNB with OFA, upgrade wet FGD, polishing fabric filter	Bridger, Fitzpatrick, Mt. Zirkel	\$9,726,040	2,318, 1,005, 1,484	0.782, 0.349, 0.778	13, 6, 13	\$14,625,624, \$26,719,890, \$13,508,989	\$694,717, \$1,945,208, \$463,145	
Scenario 3: LNB with OFA and SCR, upgrade wet FGD, FGC for enhanced ESP performance	Bridger, Fitzpatrick, Mt. Zirkel	\$18,074,111	1,316, 0.551, 0.882	0.509, 0.226, 0.473	9, 4, 4	\$19,268,775, \$37,113,165, \$17,633,279	\$1,004,117, \$1,807,411, \$602,470	
Scenario 4: LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	Bridger, Fitzpatrick, Mt. Zirkel	\$24,412,229	1,290, 0.541, 0.650	0.488, 0.222, 0.464	7, 1, 4	\$25,724,161, \$49,719,407, \$23,608,506	\$1,220,611, \$2,441,223, \$813,741	

TABLE 4-4
Costs and Visibility Modeling Results for Baseline vs. Post-Control Scenarios at Class I Areas
Jim Bridger 3

Scenario	Total First Year Annualized Cost	Class I Wilderness Area	Modeling Results					Incremental Cost per Reduction in No. of Days Above 0.5 dV
			Highest Change in Declivity (dV)	9 th Percentile (dV)	Number (No.) of Days Above 0.5 dV	Cost per dV Reduction	Cost per Reduction in No. of Days Above 0.5 dV	
2003								
Baseline: current operation with wet FGD, ESP		Bridger, Fitzpatrick, Mt. Zirkel	1,703	0.759	16	--		
Scenario 1: LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	\$3,387,923	Bridger, Fitzpatrick, Mt. Zirkel	0.983	0.414	5	\$9,820,065	\$307,893	
Scenario 2: LNB with OFA, upgrade wet FGD, polishing fabric filler	\$9,726,040	Bridger, Fitzpatrick, Mt. Zirkel	1,053	0.734	16	\$18,117,233	\$178,312	
Scenario 3: LNB with OFA and SCR, upgrade wet FGD, FGC for enhanced ESP performance	\$19,074,111	Bridger, Fitzpatrick, Mt. Zirkel	0.852	0.258	3	\$36,076,071	\$54,921,522	
Scenario 4: LNB with OFA and SCR, upgrade wet FGD, polishing fabric filler	\$24,412,229	Bridger, Fitzpatrick, Mt. Zirkel	0.663	0.115	2	\$82,822,163	\$2,112,705,834	
3-year Averages								
Baseline: Current Operation with wet FGD, ESP		Bridger, Fitzpatrick, Mt. Zirkel	0.962	0.503	19.3	--		
Scenario 1: LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	\$3,387,923	Bridger, Fitzpatrick, Mt. Zirkel	1.317	0.264	8.3	\$14,175,408	\$635,235	
Scenario 2: LNB with OFA, upgrade wet FGD, polishing fabric filler	\$9,726,040	Bridger, Fitzpatrick, Mt. Zirkel	0.761	0.250	3.7	\$16,111,607	\$4,853,564	
Scenario 3: LNB with OFA and SCR, upgrade wet FGD, FGC for enhanced ESP performance	\$19,074,111	Bridger, Fitzpatrick, Mt. Zirkel	0.349	0.157	1.3	\$28,523,058	\$47,877,422	
Scenario 4: LNB with OFA and SCR, upgrade wet FGD, polishing fabric filler	\$24,412,229	Bridger, Fitzpatrick, Mt. Zirkel	0.452	0.154	1.3	\$70,015,953	\$2,112,705,834	

NOTES:
Sample Calculations: Cost per dV Reduction for Scenario 1 for 2001: = \$3,387,923 / (0.8868 - 0.492) = \$9,845,751
Sample Calculations: Cost per Reduction in No. of Days Exceeding 0.5 dV for 2001: = \$3,387,923 / (20 - 7) = \$260,609

5.0 Preliminary Assessment and Recommendations

As a result of the completed technical and economic evaluations, and consideration of the modeling analysis for Jim Bridger 3, the preliminary recommended BART controls for NO_x, SO₂, and PM are as follows:

- New LNBS and modifications to the OFA system for NO_x control
- Upgrade wet sodium FGD for SO₂ control
- Add flue gas conditioning upstream of existing ESPs for PM control

The above recommendations were identified as Scenario 1 for the modeling analysis described in Section 4. Visibility improvements for all emission control scenarios were analyzed, and the results are compared below, utilizing a least-cost envelope, as outlined in the *New Source Review Workshop Manual* (EPA, 1990). The purpose of this analysis is to use an objective, EPA-approved methodology to evaluate and make the final recommendation of BART control technology.

5.1 Least-cost Envelope Analysis

For the control scenarios modeled in Section 4, Tables 5-1 through 5-3 list the total annualized cost, cost per dV reduction, and cost per reduction in number of days above 0.5 dV for each of the three Class I areas. A comparison of the incremental results between selected scenarios is provided in Tables 5-4 through 5-6. Figures 5-1 to 5-6 show the total annualized cost versus number of days above 0.5 dV, and the total annualized cost versus 98th percentile ΔdV reduction, for the three Class I areas.

5.1.1 Analysis Methodology

On page B-41 of the *New Source Review Workshop Manual*, the EPA states that: "Incremental cost-effectiveness comparisons should focus on annualized cost and emission reduction differences between dominant alternatives. Dominant set of control alternatives are determined by generating what is called the envelope of least-cost alternatives. This is a graphical plot of total annualized costs for a total emissions reductions for all control alternatives identified in the BACT analysis..."

An analysis of incremental cost effectiveness has been conducted. This analysis was performed in the following way. First, the control option scenarios are ranked in ascending order of annualized total costs, as shown in Tables 5-1 through 5-3. The incremental cost effectiveness data, expressed per day and per dV, represents a comparison of the different scenarios, and is summarized in Tables 5-4 through 5-6 for each of the three wilderness areas. Then the most reasonable smooth curve of least-cost control option scenarios is plotted for each analysis. Figures 5-1 through 5-6 present the two analyses (cost per dV reduction and cost per reduction in number of days above 0.5 dV) for each of the three Class I areas impacted by the operation of Jim Bridger 3.

In Figure 5-1, the four scenarios are compared as a graph of total annualized cost versus number of days above 0.5 dV. EPA states that "in calculating incremental costs, the analysis should only be conducted for control options that are dominant among all possible options." In Figure 5-1, the dominant set of control options, Scenarios 1, 3 and 4, represent the least-cost envelope depicted by the curvilinear line connecting them. Scenario 2 is an inferior option and should not be considered in the derivation of incremental cost effectiveness. Scenario 2 represents inferior controls, because Scenario 1 provides approximately the same amount of visibility impact reduction for less cost than Scenario 2. The incremental cost effectiveness is determined by the difference in total annual costs between two contiguous scenarios, divided by the difference in emissions reduction.

TABLE 5-1
Control Scenario Results for the Bridger Class I Wilderness Area
Jim Bridger 3

Scenario	Controls	98 th Percentile Deciview (dV) Reduction	Average Number of Days Above 0.5 dV (Days)	Total Annualized Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet Flue Gas Desulfurization (FGD), Electrostatic Precipitator (ESP)	0.00	0.0	0.0	0.0	0.0
1	Low-NO _x Burners (LNBS) with Over Fire Air (OFA), upgraded wet FGD system, flue Gas Conditioning (FGC) for enhanced ESP performance	0.43	10.7	3.4	7.9	0.3
2	LNB with OFA, upgraded wet FGD system, and new polishing fabric filter	0.46	11.3	9.7	21.2	0.9
3	LNB with OFA and Selective Catalytic Reduction (SCR), upgraded wet FGD system, FGC for enhanced ESP performance	0.63	14.3	18.1	28.5	1.3
4	LNB with OFA and SCR, upgraded wet FGD system, new polishing fabric filter	0.64	15.0	24.4	37.9	1.6

TABLE 5-2
Control Scenario Results for the Fitzpatrick Class I Wilderness Area
Jim Bridger 3

Scenario	Controls	98 th Percentile dV Reduction	Average Number of Days Above 0.5 dV (Days)	Total Annualized Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet Flue Gas Desulfurization (FGD), Electrostatic Precipitator (ESP)	0.00	0.0	0.0	0.0	0.0
1	Low-NO _x Burners (LNBS) with Over Fire Air (OFA), upgraded wet FGD system, flue Gas Conditioning (FGC) for enhanced ESP performance	0.24	5.3	3.4	14.2	0.6
2	LNB with OFA, upgraded wet FGD system, and new polishing fabric filter	0.25	4.7	9.7	38.5	2.1
3	LNB with OFA and Selective Catalytic Reduction (SCR), upgraded wet FGD system, FGC for enhanced ESP performance	0.35	7.0	18.1	52.3	2.6
4	LNB with OFA and SCR, upgraded wet FGD system, new polishing fabric filter	0.35	7.0	24.4	70.0	3.5

TABLE 5-3
Control Scenario Results for the Mt. Zirkel Class I Wilderness Area
Jim Bridger 3

Scenario	Controls	98 th Percentile dV Reduction	Average Number of Days Above 0.5 dV (Days)	Total Annualized Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet Flue Gas Desulfurization (FGD), Electrostatic Precipitator (ESP)	0.00	0.0	\$0.0	\$0.0	\$0.0
1	Low-NO _x Burners (LNBs) with Over Fire Air (OFA), upgraded wet FGD system, flue Gas Conditioning (FGC) for enhanced ESP performance	0.56	17.0	\$3.4	\$6.1	\$0.2
2	LNB with OFA, upgraded wet FGD system, and new polishing fabric filter	0.60	17.7	\$9.7	\$16.1	\$0.6
3	LNB with OFA and Selective Catalytic Reduction (SCR), upgraded wet FGD system, FGC for enhanced ESP performance	0.87	27.3	\$18.1	\$20.9	\$0.7
4	LNB with OFA and SCR, upgraded wet FGD system, new polishing fabric filter	0.88	28.3	\$24.4	\$27.8	\$0.9

TABLE 5-4
Bridger Class I Wilderness Area Incremental Analysis Data
Jim Bridger 3

Options Compared	Incremental Reduction in Days Above 0.5 Deciview (dV) (Days)	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	10.7	0.43	\$0.32	\$7.9
Scenario 1 and Scenario 2	0.7	0.03	\$9.5	\$221.1
Scenario 1 and Scenario 3	3.7	0.20	\$4.0	\$72.5
Scenario 1 and Scenario 4	4.3	0.21	\$4.9	\$98.6

TABLE 5-5
Fitzpatrick Class I Wilderness Area Incremental Analysis Data
Jim Bridger 3

Options Compared	Incremental Reduction in Days Above 0.5 Deciview (dV) (Days)	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	5.3	0.24	\$0.64	\$14.2
Scenario 1 and Scenario 2	NA	0.01	NA	\$463.8
Scenario 1 and Scenario 3	1.7	0.11	\$8.8	\$137.7
Scenario 1 and Scenario 4	1.7	0.11	\$12.6	\$191.7

TABLE 5-6
Mt. Zirkel Class I Wilderness Area Incremental Analysis Data
Jim Bridger 3

Options Compared	Incremental Reduction in Days Above 0.5 Deciview (dV) (Days)	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	17.0	0.56	\$0.20	\$6.09
Scenario 1 and Scenario 2	0.7	0.05	\$9.5	\$134.9
Scenario 1 and Scenario 3	10.3	0.31	\$1.4	\$47.6
Scenario 1 and Scenario 4	11.3	0.32	\$1.9	\$65.6

FIGURE 5-1
Least-cost Envelope Bridger Class I WA Days Reduction
Jim Bridger 3




FIGURE 5-2
Least-cost Envelope Bridger Class I WA 98th Percentile Reduction
Jim Bridger 3




FIGURE 5-3
Least-cost Envelope Fitzpatrick Class I WA Days Reduction
Jim Bridger 3




FIGURE 5-4
Least-cost Envelope Fitzpatrick Class I WA 98th Percentile Reduction
Jim Bridger 3




FIGURE 5-5
 Least-cost Envelope Mt. Zirkel Class I WA Days Reduction
 Jim Bridger 3





FIGURE 5-6
 Least-cost Envelope Mt. Zirkel Class I WA 98th Percentile Reduction
 Jim Bridger 3



5.1.2 Analysis Results

Results of the least-cost Analysis, shown in Tables 5-1 through 5-6 and Figures 5-1 through 5-6 on the preceding pages, confirm the selection of Scenario 1, based on incremental cost and visibility improvements. Scenario 2 is eliminated because it is to the left of the curve formed by the "dominant" control alternative scenarios, which indicates a scenario with lower improvement and/or higher costs. Scenario 3 is not selected due to very high incremental costs for both a cost per day of improvement and a cost per dV reduction. While Scenario 4 provides some potential visibility advantage over Scenario 1, the projected improvement is less than half a dV, and the projected costs are excessive.

Analysis of the results for the Jim Bridger Class I WA in Tables 5-1 and 5-4 and Figures 5-1 and 5-2 illustrates these conclusions. The greatest reduction in 98th percentile dV and number of days above 0.5 dV is between the Baseline and Scenario 1. The incremental cost-effectiveness for Scenario 1—compared to the Baseline for the Bridger WA, for example—is reasonable at \$320,000 per day and \$7.9 million/dV. However, the incremental cost effectiveness for Scenario 3 compared to Scenario 1, again for the Bridger WA, is excessive at \$4.0 million per day and \$72.5 million per dV. The same conclusions are reached for each of the three wilderness areas studied. Therefore, Scenario 1 represents BART for Jim Bridger 3.

5.2 Recommendations

5.2.1 NO_x Emission Control

The BART presumptive NO_x limit assigned by EPA for tangentially-fired boilers burning sub-bituminous coal is 0.15 lb per MMBtu. However, as documented in Section 3.2.1, the characteristics of the Jim Bridger coals are more closely aligned with bituminous coals, and have been assigned a presumptive BART NO_x limit of 0.28 lb per MMBtu.

CH2M HILL recommends LNB with OFA as BART for Jim Bridger 3, based on the projected significant reduction in NO_x emissions, reasonable control costs, and the advantages of no additional power requirements or non-air quality environmental impacts. NO_x reductions are expected to be similar to those realized at Jim Bridger 2. CH2M HILL recommends that the unit be permitted at a rate of 0.26 lb per MMBtu.

5.2.2 SO₂ Emission Control

CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 3, based on the significant reduction in SO₂ emissions, reasonable control costs, and the advantages of both minimal additional power requirements and non-air quality environmental impacts. This upgrade approach will meet the BART presumptive SO₂ limit of 0.15 lb per MMBtu.

5.2.3 PM₁₀ Emission Control

CH2M HILL recommends finalizing the permitting of the FGC system to enhance the performance of the existing ESP as BART for Jim Bridger 3, based on the significant reduction in PM₁₀ emissions, reasonable control costs, and the advantages of minimal additional power requirements and no non-air quality environmental impacts.

5.3 Just-Noticeable Differences in Atmospheric Haze

Conclusions reached in the reference document "Just-Noticeable Differences in Atmospheric Haze" by Dr. Ronald Henry (2002), state that only dV differences of approximately 1.5 to 2.0 dV, or more are perceptible by the human eye. Deciview changes of less than 1.5 cannot be distinguished by the average person. Therefore, the modeling analysis results indicate that only minimal, if any, observable visibility improvements at the Class I areas studied would be expected under any of the scenarios. Thus the results indicate that even though many millions of dollars will be spent, only minimal if any visibility improvements may result.

Finally, it should be noted that none of the data were corrected for natural obscuration. Water in various forms (fog, clouds, snow, or rain) or other naturally caused aerosols may obscure the atmosphere and reduce visibility. During the period of 2001 through 2003, there were several mega-wildfires that lasted for many days, with a significant impact on background visibility in these Class I areas. If natural obscuration lessens the achievable reduction on visibility impacts modeled for BART controls at the Jim Bridger 3 facility, the overall effect would be to increase the costs per dV reduction that are presented in this report.

6.0 References

- 40 CFR Part 51. *Regional Haze Regulations and Guidelines for Best Available Retrofit Technology Determinations; Final Rule*. July 6, 2005.
- Energy Information Administration, 2006. *Official Energy Statistics from the U.S. Government: Coal*. <http://www.eia.doe.gov/fuelcoal.html>. Accessed October 2006.
- EPA, 2003. *Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule*. Environmental Protection Agency. EPA-454/8-03-005. September 2003.
- EPA, 1990. *New Source Review Workshop Manual—Prevention of Significant Deterioration and Nonattainment Area Permitting*. Draft. October 1990.
- Henry, Ronald, 2002. "Just-Noticeable Differences in Atmospheric Haze," *Journal of the Air & Waste Management Association*. Volume 52, p. 1238.
- National Oceanic and Atmospheric Administration, 2006. U.S. Daily Weather Maps Project. http://docs.lib.noaa.gov/rescue/dwm/data_rescue_daily_weather_maps.html. Accessed October 2006.
- North Dakota Department of Health, 2005. *Protocol for BART-Related Visibility Improvement Modeling Analysis in North Dakota*. North Dakota Department of Health. October 26, 2005.
- Sargent & Lundy, 2002. *Multi-Pollutant Control Report*. October 2002.
- Sargent & Lundy, 2006. *Multi-Pollutant Control Report*. Revised. October 2006.
- WDEQ-AQD, 2006. *BART Air Modeling Protocol—Individual Source Visibility Assessments for BART Control Analyses*. Wyoming Department of Environmental Quality – Air Quality Division. September 2006.

APPENDIX A
Economic Analysis

PacifiCorp BART Analysis Scenarios

Select Unit:		5	Jim Bridger Unit 3
Index No.	Name of Unit		
1	Dave Johnston Unit 3		
2	Dave Johnston Unit 4		
3	Jim Bridger Unit 1		
4	Jim Bridger Unit 2		
5	Jim Bridger Unit 3		
6	Jim Bridger Unit 4		
7	Naughton Unit 1		
8	Naughton Unit 2		
9	Naughton Unit 3		
10	Wyodak Unit 1		

Scenario	Dave Johnston		Naughton		Wyodak	
	DJ Unit 3	DJ Unit 4	NTN Unit 1	NTN Unit 2	NTN Unit 3	WYD Unit 1
Baseline - Current Operation with Venturi Scrubber	Scenario - Current Operation with Venturi Scrubber	Scenario - Current Operation with Wet FGD and ESP	Scenario - Current Operation with Wet FGD and ESP	Scenario - Current Operation with Wet FGD and ESP	Scenario - Current Operation with Wet FGD and ESP	Scenario - Current Operation with Dry FGD, Fabric Filter
Scenario 1 - LNB with OFA, Dry FGD, Existing ESP	Scenario 1 - LNB with OFA, Dry FGD, Fabric Filter	Scenario 1 - LNB with OFA, Dry FGD, ESP	Scenario 1 - LNB with OFA, Dry FGD, ESP	Scenario 1 - LNB with OFA, Dry FGD, ESP	Scenario 1 - LNB with OFA, Dry FGD, ESP	Scenario 1 - LNB with OFA, Dry FGD, Fabric Filter
Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	Scenario 2 - LNB with OFA and SCR, Dry FGD, ESP
Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	Scenario 3 - LNB with OFA and SCR, Wet FGD, Fabric Filter
Scenario 4 - LNB with OFA and SCR, Wet FGD, Existing ESP, New Stack	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	Scenario 4 - LNB with OFA and SCR, Wet FGD, ESP, New Stack	Scenario 4 - LNB with OFA and SCR, Wet FGD, ESP, New Stack	Scenario 4 - LNB with OFA and SCR, Wet FGD, ESP, New Stack	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter
Scenario 1 - LNB with OFA, Wet FGD, ESP	Scenario 1 - LNB with OFA, Wet FGD, ESP	Scenario 1 - LNB with OFA, Wet FGD, ESP	Scenario 1 - LNB with OFA, Wet FGD, ESP	Scenario 1 - LNB with OFA, Wet FGD, ESP	Scenario 1 - LNB with OFA, Wet FGD, ESP	Scenario 1 - LNB with OFA, Dry FGD, Fabric Filter
Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	Scenario 2 - LNB with OFA and SCR, Dry FGD, Fabric Filter
Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	Scenario 3 - LNB with OFA and SCR, Wet FGD, Fabric Filter
Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter

INPUT CALCULATIONS

Boiler Design: Tangential-Fired PC
Jim Bridger Unit 3

Parameter	NOX Control					SO2 Control			PM Control		Comments
	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	Upgraded Wet FGD	Flue Gas Conditioning	Flue Gas Conditioning	Fabric Filter		
Case	1	2	3	4	5	8	9	10			
LNCF-1 & Windbox Moeds. Wet FGD	LNCF-1 & Windbox Moeds. Wet FGD	LNB w/OFA Wet FGD	ROFA Wet FGD	LNB w/OFA & SNCR Wet FGD	LNB w/OFA & SCR Wet FGD	LNCF-1 & Windbox Moeds. Upgraded Wet FGD	LNCF-1 & Windbox Moeds. Wet FGD	LNCF-1 & Windbox Moeds. Wet FGD			
PM Emission Control System	ESP	ESP	ESP	ESP	ESP	ESP		Fabric Filter			
Unit Design and Coal Characteristics											
Type of Unit	PC	PC	PC	PC	PC	PC	PC	PC	PC	PC	
Net Power Output (KW)	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000	
Net Plant Heat Rate (Btu/KWHr)	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	
Boiler Fuel	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	
Coal Heating Value (Btu/Lb)	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660	
Coal Sulfur Content (wt.%)	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	
Coal Ash Content (wt.%)	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	
Boiler Heat Input, each (MMBtu/Hr)	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	
Coal Flow Rate (Lb/Hr)	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077	
(Ton/Yr)	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	
(MMBtu/Yr)	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	
Emissions											
Uncontrolled SO2 (Lb/Hr)	7,210	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	
(Lb/MMBtu)	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	
(Lb Moles/Hr)	112,64	25,00	25,00	25,00	25,00	25,00	25,00	25,00	25,00	25,00	
(Tons/Yr)	28,421	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	
SO2 Removal Rate (%)	77.8%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	
(Lb/Hr)	6,608	0	0	0	0	0	0	0	0	0	
(Ton/Yr)	22,106	0	0	0	0	0	0	0	0	0	
SO2 Emission Rate (Lb/Hr)	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	
(Lb/MMBtu)	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	
(Ton/Yr)	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	
Uncontrolled NOX (Lb/Hr)	2,700	2,700	2,700	2,700	2,700	2,700	2,700	2,700	2,700	2,700	
(Lb/MMBtu)	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	
(Lb Moles/Hr)	89,96	89,96	89,96	89,96	89,96	89,96	89,96	89,96	89,96	89,96	
(Tons/Yr)	10,643	10,643	10,643	10,643	10,643	10,643	10,643	10,643	10,643	10,643	
NOX Removal Rate (%)	0.0%	45.7%	51.1%	55.6%	58.4%	0%	0%	0%	0%	0%	
(Lb/Hr)	0	1,260	1,360	1,500	2,280	0	0	0	0	0	
(Ton/Yr)	0	41,98	45,98	48,98	75,97	0	0	0	0	0	
NOX Emission Rate (Lb/Hr)	2,700	1,440	1,320	1,200	420	2,700	2,700	2,700	2,700	2,700	
(Lb/MMBtu)	0.45	0.24	0.22	0.20	0.07	0.45	0.45	0.45	0.45	0.45	
(Ton/Yr)	10,643	5,676	5,203	4,730	1,658	10,643	10,643	10,643	10,643	10,643	
Uncontrolled Fly Ash (Lb/Hr)	51,177	342	342	342	342	342	342	342	342	342	
(Lb/MMBtu)	8,530	0.057	0.057	0.057	0.057	0.057	0.057	0.057	0.057	0.057	
(Lb Moles/Hr)	1,705.3	11.4	11.4	11.4	11.4	11.4	11.4	11.4	11.4	11.4	
(Tons/Yr)	201,739	1,348	1,348	1,348	1,348	1,348	1,348	1,348	1,348	1,348	
Fly Ash Removal Rate (%)	99.93%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	
(Lb/Hr)	50,835	0	0	0	0	0	0	0	0	0	
(Ton/Yr)	200,391	0	0	0	0	0	0	0	0	0	
Fly Ash Emission Rate (Lb/Hr)	342	342	342	342	342	342	342	342	342	342	
(Lb/MMBtu)	0.057	0.057	0.057	0.057	0.057	0.057	0.057	0.057	0.057	0.057	
(Ton/Yr)	1,348	1,348	1,348	1,348	1,348	1,348	1,348	1,348	1,348	1,348	

Parameter	Current Operation		NOx Control				SO2 Control		PM Control			Comments				
	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter	Case	1	2	3		4	5	8	9
General Plant Data																
Annual Operation (Hours/Year)	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884
Annual On-Site Power Plant Capacity Factor	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90
Economic Factors																
Interest Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%
Discount Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%
Plant Economic Life (Years)	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20
Installed Capital Costs																
NOx Emission Control System (\$2006)	0	8,700,001	20,528,122	21,973,632	129,575,495	12,993,900	0	0	0	0	0	0	0	0	0	0
SO2 Emission Control System (\$2006)	0	0	0	0	0	12,993,900	0	0	0	0	0	0	0	0	0	0
PM Emission Control System (\$2006)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Emission Control Systems (\$2006)	0	8,700,001	20,528,122	21,973,632	129,575,495	12,993,900	0	0	0	0	0	0	0	0	0	0
NOx Emission Control System (\$1M)	0	16	39	41	244	26	0	0	0	0	0	0	0	0	0	0
SO2 Emission Control System (\$1M)	0	0	0	0	0	25	0	0	0	0	0	0	0	0	0	0
PM Emission Control System (\$1M)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Emission Control Systems (\$1M)	0	16	39	41	244	25	0	0	0	0	0	0	0	0	0	0
Total Fixed Operating & Maintenance Costs																
Operating Labor (\$)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Maintenance Material (\$)	0	26,000	42,000	122,000	180,000	25,550	0	0	0	0	0	0	0	0	0	0
Maintenance Labor (\$)	0	42,000	63,000	185,000	285,000	17,033	0	0	0	0	0	0	0	0	0	0
Administrative Labor (\$)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Fixed O&M Cost (\$)	0	70,000	105,000	306,000	475,000	42,583	0	0	0	0	0	0	0	0	0	0
Annual Fixed O&M Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%
Water Cost																
Makeup Water Usage (Gpm)	0	0	0	0	0	52	0	0	0	0	0	0	0	0	0	0
Unit Price (\$/1000 Gallons)	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22
First Year Water Cost (\$)	0	0	0	0	0	29,927	0	0	0	0	0	0	0	0	0	0
Annual Water Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%
Reagent Cost																
Unit Cost (\$/Ton)	None	None	None	Urea	None	Soda Ash	Elemental Sulfur	None	None	None	None	None	None	None	None	None
(\$/Lb)	0.00	0.00	0.00	370	0.00	80.00	370	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Molar Stoichiometry	0.000	0.000	0.000	0.185	0.040	0.200	0.185	0.040	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Reagent Purity (Wt.%)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
Reagent Usage (Lb/Hr)	0	0	0	690	579	1,691	100	0	0	0	0	0	0	0	0	0
First Year Reagent Cost (\$)	0	0	0	1,005,811	912,848	633,206	145,854	0	0	0	0	0	0	0	0	0
Annual Reagent Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%
SCR Catalyst / FF Bag Replacement Cost																
Annual SCR Catalyst (m3) / No. FF Bags	0	0	0	3,000	3,000	104	0	0	0	0	0	0	0	0	0	0
SCR Catalyst (\$/m3) / Bag Cost (\$/ea.)	3,000	3,000	3,000	3,000	3,000	104	3,000	104	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000
First Year SCR Catalyst / Bag Replac. Cost (\$)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Annual SCR Catalyst / Bag Cost Esc. Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%
FGD Waste Disposal Cost																
FGD Solid Waste Disposal Rate, Dry (Lb/Hr)	0	0	0	0	0	4,618	0	0	0	0	0	0	0	0	0	0
FGD Waste Disposal Unit Cost (\$/Dry Ton)	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33
First Year FGD Waste Disposal Cost (\$)	0	0	0	0	0	442,968	0	0	0	0	0	0	0	0	0	0
Annual Waste Disposal Cost Esc. Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%
Auxiliary Power Cost																
Auxiliary Power Requirement (% of Plant Output) (MW)	0.00%	0.00%	1.21%	0.10%	0.61%	0.10%	0.01%	0.63%	0.01%	0.01%	0.01%	0.01%	0.01%	0.01%	0.01%	0.01%
Unit Cost (\$2006/MW-Hr)	0.00	0.00	6.41	6.00	3.22	6.00	0.05	3.33	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05
First Year Auxiliary Power Cost (\$)	0	0	50,000	60,000	50,000	50,000	50,000	50,000	50,000	50,000	50,000	50,000	50,000	50,000	50,000	50,000
Annual Power Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%

Input Tables

Table 1 - Cases

Index No.	Name of Unit Case	NOx Control			SO2 Control			PM Control			
		Existing	2	3	4	5	6	7	8	9	10
1	Dave Johnston Unit 3	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Dry FGD w/Fabric Filter	Dry FGD w/Fabric Filter	Wet FGD w/ESP	N/A	Fabric Filter
2	Dave Johnston Unit 4	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Dry FGD w/Fabric Filter	Dry FGD w/Fabric Filter	Wet FGD w/ESP	N/A	Fabric Filter
3	Jim Bridger Unit 1	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Upgraded Wet FGD	Upgraded Wet FGD	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
4	Jim Bridger Unit 2	Current Operation	Exist LNB w/OFA	ROFA	SNCR	SNCR	Upgraded Wet FGD	Upgraded Wet FGD	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
5	Jim Bridger Unit 3	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Upgraded Wet FGD	Upgraded Wet FGD	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
6	Jim Bridger Unit 4	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Upgraded Wet FGD	Upgraded Wet FGD	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
7	Naughton Unit 1	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Wet FGD w/ESP	Wet FGD w/ESP	Wet FGD w/ESP	Flue Gas Conditioning	Fabric Filter
8	Naughton Unit 2	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Wet FGD w/ESP	Wet FGD w/ESP	Wet FGD w/ESP	Flue Gas Conditioning	Fabric Filter
9	Naughton Unit 3	Current Operation	Exist LNB w/OFA	ROFA	SNCR	SNCR	Upgraded Wet FGD	Upgraded Wet FGD	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
10	Wyodak Unit 1	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Upgraded Dry FGD	N/A	Wet FGD	Flue Gas Conditioning	Fabric Filter

Table 2 - Unit Design and Coal Characteristics

Index No.	Name of Unit	Current Emission Control Systems			Unit Design			Coal Quality		
		NOx	SO2	PM	Boiler Design	Net Power Output (MW)	NET Plant Heat Rate (Btu/kWh-Hr)	Heating Value, HHV (Btu/Lb)	Sulfur Content (Wt.%)	Ash Content (Wt.%)
1	Dave Johnston Unit 3	None	None	ESP	3-Cal Burner, Opposed Wall-Fired PC	250,000	11,200	7,784	0.47%	5.01%
2	Dave Johnston Unit 4	Windbox Mode, LINGFS-1 & Windbox Mode	Lime Added to Venturi Scrubber	Venturi Scrubber	Tangentia-Fired PC	360,000	11,390	7,784	0.47%	5.01%
3	Jim Bridger Unit 1	Windbox Mode, LINGFS-1 & Windbox Mode	Wet FGD	ESP	Tangentia-Fired PC	530,000	11,320	9,660	0.58%	10.30%
4	Jim Bridger Unit 2	LNB - TFS 2000	Wet FGD	ESP	Tangentia-Fired PC	530,000	11,320	9,660	0.58%	10.30%
5	Jim Bridger Unit 3	Windbox Mode, LINGFS-1 & Windbox Mode	Wet FGD	ESP	Tangentia-Fired PC	530,000	11,320	9,660	0.58%	10.30%
6	Jim Bridger Unit 4	Windbox Mode, LINGFS-1 & Windbox Mode	Wet FGD	ESP	Tangentia-Fired PC	530,000	11,320	9,660	0.58%	10.30%
7	Naughton Unit 1	None	None	ESP	Tangentia-Fired PC	173,000	10,684	9,970	0.60%	4.64%
8	Naughton Unit 2	None	None	ESP	Tangentia-Fired PC	226,000	10,574	9,970	0.60%	4.64%
9	Naughton Unit 3	LINGFS II LNB	Wet FGD	ESP	Tangentia-Fired PC	356,000	10,336	9,970	0.60%	4.64%
10	Wyodak Unit 1	LNB	Dry FGD	ESP	Opposed Wall-Fired PC	335,000	12,087	7,977	0.65%	7.46%

EY102007001SLCApp A_PCorp JB3 BART Economic Analysis_01-11-07.xls

Table 3 - Emissions

Index No.	Name of Unit	Current Emission Rates (Lb/MMBtu)		NOx Control Emission Rates (Lb/MMBtu)		SO2 Control Emission Rates (Lb/MMBtu)		PM Emission Rates (Lb/MMBtu)				
		Controlled	Controlled NOx	Case 2	Case 3	Case 4	Case 5	Case 6	Case 7	Case 8	Case 9	Case 10
1	Dave Johnston Unit 3	1.20	0.70	0.27	0.21	0.20	0.07	0.21	0.15	0.10	N/A	0.015
2	Dave Johnston Unit 4	0.33	0.48	0.15	0.19	0.12	0.07	N/A	0.15	0.10	N/A	0.015
3	Jim Bridger Unit 1	0.27	0.45	0.24	0.22	0.20	0.07	N/A	N/A	0.10	0.030	0.015
4	Jim Bridger Unit 2	0.27	0.24	0.24	0.22	0.20	0.07	N/A	N/A	0.10	0.030	0.015
5	Jim Bridger Unit 3	0.17	0.45	0.24	0.22	0.20	0.07	N/A	N/A	0.10	0.030	0.015
6	Jim Bridger Unit 4	1.20	0.54	0.24	0.23	0.18	0.07	N/A	0.15	0.10	0.040	0.015
7	Naughton Unit 1	1.20	0.54	0.24	0.23	0.18	0.07	N/A	0.15	0.10	0.040	0.015
8	Naughton Unit 2	0.50	0.45	0.35	0.30	0.25	0.07	N/A	N/A	0.10	0.040	0.015
9	Naughton Unit 3	0.50	0.45	0.23	0.22	0.18	0.07	N/A	N/A	0.10	0.040	0.015
10	Wyodak Unit 1	0.50	0.50	0.23	0.22	0.18	0.07	0.25	N/A	0.10	0.025	0.015

Table 4 - Case 1 O&M Costs (Current Operation)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ -	\$ -	\$ -	-	None	-	-
2	Dave Johnston Unit 4	\$ -	\$ -	\$ -	\$ -	-	None	-	-
3	Jim Bridger Unit 1	\$ -	\$ -	\$ -	\$ -	-	None	-	-
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	-	None	-	-
5	Jim Bridger Unit 3	\$ -	\$ -	\$ -	\$ -	-	None	-	-
6	Jim Bridger Unit 4	\$ -	\$ -	\$ -	\$ -	-	None	-	-
7	Naughton Unit 1	\$ -	\$ -	\$ -	\$ -	-	None	-	-
8	Naughton Unit 2	\$ -	\$ -	\$ -	\$ -	-	None	-	-
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	-	None	-	-
10	Wyodak Unit 1	\$ -	\$ -	\$ -	\$ -	-	None	-	-

Table 5 - Case 2 O&M Costs (LNB w/OFA)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ 40,000	\$ 60,000	\$ -	-	None	-	-
2	Dave Johnston Unit 4	\$ -	\$ 36,000	\$ 54,000	\$ -	-	None	-	-
3	Jim Bridger Unit 1	\$ -	\$ 28,000	\$ 42,000	\$ -	-	None	-	-
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	-	None	-	-
5	Jim Bridger Unit 3	\$ -	\$ 28,000	\$ 42,000	\$ -	-	None	-	-
6	Jim Bridger Unit 4	\$ -	\$ 28,000	\$ 42,000	\$ -	-	None	-	-
7	Naughton Unit 1	\$ -	\$ 32,000	\$ 48,000	\$ -	-	None	-	-
8	Naughton Unit 2	\$ -	\$ 32,000	\$ 48,000	\$ -	-	None	-	-
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	-	None	-	-
10	Wyodak Unit 1	\$ -	\$ 24,000	\$ 36,000	\$ -	-	None	-	-

Table 6 - Case 3 O&M Costs (Mobotec ROFA)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ 60,000	\$ 90,000	\$ -	-	None	-	2.76
2	Dave Johnston Unit 4	\$ -	\$ 54,000	\$ 81,000	\$ -	-	None	-	4.33
3	Jim Bridger Unit 1	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41
4	Jim Bridger Unit 2	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41
5	Jim Bridger Unit 3	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41
6	Jim Bridger Unit 4	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41
7	Naughton Unit 1	\$ -	\$ 48,000	\$ 72,000	\$ -	-	None	-	1.42
8	Naughton Unit 2	\$ -	\$ 48,000	\$ 72,000	\$ -	-	None	-	2.61
9	Naughton Unit 3	\$ -	\$ 48,000	\$ 72,000	\$ -	-	None	-	4.47
10	Wyodak Unit 1	\$ -	\$ 36,000	\$ 54,000	\$ -	-	None	-	5.22

Table 7 - Case 4 O&M Costs (LNB W/OFA & SNCR)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ 98,000	\$ 147,000	\$ -	-	Urea	0.41	0.23
2	Dave Johnston Unit 4	\$ -	\$ 105,000	\$ 157,500	\$ -	-	Urea	0.45	0.33
3	Jim Bridger Unit 1	\$ -	\$ 123,000	\$ 184,500	\$ -	-	Urea	0.45	0.63
4	Jim Bridger Unit 2	\$ -	\$ 96,000	\$ 142,500	\$ -	-	Urea	0.45	0.63
5	Jim Bridger Unit 3	\$ -	\$ 122,000	\$ 183,000	\$ -	-	Urea	0.45	0.62
6	Jim Bridger Unit 4	\$ -	\$ 123,000	\$ 184,500	\$ -	-	Urea	0.45	0.53
7	Naughton Unit 1	\$ -	\$ 83,000	\$ 124,500	\$ -	-	Urea	0.45	0.16
8	Naughton Unit 2	\$ -	\$ 98,000	\$ 139,500	\$ -	-	Urea	0.51	0.22
9	Naughton Unit 3	\$ -	\$ 75,000	\$ 112,500	\$ -	-	Urea	0.45	0.33
10	Wyodak Unit 1	\$ -	\$ 93,000	\$ 139,500	\$ -	-	Urea	0.45	0.34

Table 8 - Case 5 O&M Costs (LNB W/OFA & SCR)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ 155,000	\$ 232,500	\$ -	-	Anhydrous NH3	1.00	1.57
2	Dave Johnston Unit 4	\$ -	\$ 155,000	\$ 232,500	\$ -	-	Anhydrous NH3	1.00	2.28
3	Jim Bridger Unit 1	\$ -	\$ 190,000	\$ 285,000	\$ -	-	Anhydrous NH3	1.00	3.28
4	Jim Bridger Unit 2	\$ -	\$ 162,000	\$ 243,000	\$ -	-	Anhydrous NH3	1.00	3.26
5	Jim Bridger Unit 3	\$ -	\$ 190,000	\$ 285,000	\$ -	-	Anhydrous NH3	1.00	3.22
6	Jim Bridger Unit 4	\$ -	\$ 190,000	\$ 285,000	\$ -	-	Anhydrous NH3	1.00	3.36
7	Naughton Unit 1	\$ -	\$ 132,000	\$ 198,000	\$ -	-	Anhydrous NH3	1.00	0.98
8	Naughton Unit 2	\$ -	\$ 160,000	\$ 240,000	\$ -	-	Anhydrous NH3	1.00	1.34
9	Naughton Unit 3	\$ -	\$ 156,000	\$ 234,000	\$ -	-	Anhydrous NH3	1.00	1.99
10	Wyodak Unit 1	\$ -	\$ 181,000	\$ 271,500	\$ -	-	Anhydrous NH3	1.00	2.42

Table 9 - Case 6 O&M Costs (Dry FGD)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent Stoich.	Reagent Molar Annual FF Bag Replace.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 506,128	\$ 714,175	\$ 476,928	\$ -	173	1.15	-	2.49
2	Dave Johnston Unit 4	\$ -	\$ -	\$ -	\$ -	-	-	-	-
3	Jim Bridger Unit 1	\$ -	\$ -	\$ -	\$ -	-	-	-	-
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	-	-	-	-
5	Jim Bridger Unit 3	\$ -	\$ -	\$ -	\$ -	-	-	-	-
6	Jim Bridger Unit 4	\$ -	\$ -	\$ -	\$ -	-	-	-	-
7	Naughton Unit 1	\$ 606,128	\$ 587,643	\$ 391,762	\$ -	120	1.40	-	1.64
8	Naughton Unit 2	\$ 606,128	\$ 860,174	\$ 673,044	\$ -	165	1.40	-	2.25
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	-	-	-	-
10	Wyodak Unit 1	\$ -	\$ 21,900	\$ 14,600	\$ -	25	1.10	-	0.11

Table 10 - Case 7 O&M Costs (Dry FGD w/Fabric Filter)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent Stoich.	Reagent Molar Annual FF Bag Replace.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 606,128	\$ 714,175	\$ 476,928	\$ -	173	1.15	1,457	3.88
2	Dave Johnston Unit 4	\$ 606,128	\$ 1,102,288	\$ 734,868	\$ -	248	1.10	1,788	4.54
3	Jim Bridger Unit 1	\$ -	\$ -	\$ -	\$ -	-	-	-	-
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	-	-	-	-
5	Jim Bridger Unit 3	\$ -	\$ -	\$ -	\$ -	-	-	-	-
6	Jim Bridger Unit 4	\$ -	\$ -	\$ -	\$ -	-	-	-	-
7	Naughton Unit 1	\$ 606,128	\$ 632,660	\$ 469,286	\$ -	120	1.15	865	2.66
8	Naughton Unit 2	\$ 606,128	\$ 905,190	\$ 640,668	\$ -	165	1.15	1,193	3.63
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	-	-	-	-
10	Wyodak Unit 1	\$ -	\$ -	\$ -	\$ -	-	-	-	-

Table 11 - Case 8 O&M Costs (Wet FGD)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent Stoich.	Reagent Molar Annual FF Bag Replace.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 809,804	\$ 1,182,687	\$ 786,391	\$ -	230	1.02	-	3.45
2	Dave Johnston Unit 4	\$ 809,804	\$ 1,430,784	\$ 983,856	\$ -	330	1.02	1,798	6.29
3	Jim Bridger Unit 1	\$ -	\$ 25,560	\$ 17,033	\$ -	53	1.02	-	0.63
4	Jim Bridger Unit 2	\$ -	\$ 25,560	\$ 17,033	\$ -	53	1.02	-	0.63
5	Jim Bridger Unit 3	\$ -	\$ 25,560	\$ 17,033	\$ -	52	1.02	-	0.52
6	Jim Bridger Unit 4	\$ -	\$ 25,560	\$ 17,033	\$ -	27	1.02	-	0.55
7	Naughton Unit 1	\$ 809,804	\$ 963,689	\$ 642,393	\$ -	160	1.05	-	2.40
8	Naughton Unit 2	\$ 809,804	\$ 1,226,386	\$ 817,691	\$ -	220	1.05	-	3.30
9	Naughton Unit 3	\$ -	\$ 21,900	\$ 14,600	\$ -	66	1.02	-	0.33
10	Wyodak Unit 1	\$ 303,677	\$ 328,486	\$ 218,998	\$ -	62	1.02	-	1.75

Table 12 - Case 9 O&M Costs (Flue Gas Conditioning)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements					
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Usage (Lb/Hr)	Annual FF Bag Replaces.	Aux. Power Usage (MW)	
1	Dave Johnston Unit 3	\$ -	\$ -	\$ -	\$ -	-	None	-	-	-	
2	Dave Johnston Unit 4	\$ -	\$ -	\$ -	\$ -	-	None	-	-	-	
3	Jim Bridger Unit 1	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	100	-	0.05	
4	Jim Bridger Unit 2	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	100	-	0.05	
5	Jim Bridger Unit 3	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	100	-	0.05	
6	Jim Bridger Unit 4	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	100	-	0.05	
7	Naughton Unit 1	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	33	-	0.05	
8	Naughton Unit 2	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	45	-	0.05	
9	Naughton Unit 3	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	67	-	0.05	
10	Wyodak Unit 1	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	65	-	0.05	

Table 13 - Case 10 O&M Costs (Fabric Filter)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements					
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Annual FF Bag Replaces.	Aux. Power Usage (MW)	
1	Dave Johnston Unit 3	\$ -	\$ 45,018	\$ 67,524	\$ -	-	None	-	1,457	1.38	
2	Dave Johnston Unit 4	\$ -	\$ 65,133	\$ 102,193	\$ -	-	None	-	1,798	2.36	
3	Jim Bridger Unit 1	\$ -	\$ 51,099	\$ 76,649	\$ -	-	None	-	2,885	3.39	
4	Jim Bridger Unit 2	\$ -	\$ 51,099	\$ 76,649	\$ -	-	None	-	2,885	3.37	
5	Jim Bridger Unit 3	\$ -	\$ 51,099	\$ 76,649	\$ -	-	None	-	2,827	3.33	
6	Jim Bridger Unit 4	\$ -	\$ 51,099	\$ 76,649	\$ -	-	None	-	2,885	3.39	
7	Naughton Unit 1	\$ -	\$ 45,018	\$ 67,524	\$ -	-	None	-	865	1.01	
8	Naughton Unit 2	\$ -	\$ 45,018	\$ 67,524	\$ -	-	None	-	1,193	1.38	
9	Naughton Unit 3	\$ -	\$ 48,668	\$ 72,999	\$ -	-	None	-	1,799	2.06	
10	Wyodak Unit 1	\$ -	\$ 48,668	\$ 72,999	\$ -	-	None	-	1,798	2.06	

Table 14 - Major Materials Design and Supply Costs

Index No.	Name of Unit Case ->	NOx Control		SO2 Control		PM Control					
		3	4	6	7	8	9	10			
1	Dave Johnston Unit 3	\$ 3,221,912	\$ 3,566,617	\$ 5,773,000	\$ 49,355,000	\$ 83,871,000	\$ 142,077,000	\$ 108,865,869	\$ -	\$ -	\$ 18,359,000
2	Dave Johnston Unit 4	\$ 2,673,501	\$ 4,343,192	\$ 7,171,085	\$ 66,200,000	\$ -	\$ 137,267,000	\$ 178,174,384	\$ -	\$ -	\$ 30,853,530
3	Jim Bridger Unit 1	\$ 2,981,982	\$ 6,056,955	\$ 9,528,000	\$ 80,923,000	\$ -	\$ -	\$ 8,010,093	\$ -	\$ -	\$ 29,814,000
4	Jim Bridger Unit 2	\$ -	\$ 6,056,955	\$ 9,528,000	\$ 80,923,000	\$ -	\$ -	\$ 8,010,093	\$ -	\$ -	\$ 29,814,000
5	Jim Bridger Unit 3	\$ 2,981,982	\$ 6,056,955	\$ 9,419,000	\$ 83,008,000	\$ -	\$ -	\$ 8,010,093	\$ -	\$ -	\$ 29,814,000
6	Jim Bridger Unit 4	\$ 2,981,982	\$ 6,056,955	\$ 9,528,000	\$ 83,008,000	\$ -	\$ -	\$ 8,010,093	\$ -	\$ -	\$ 29,814,000
7	Naughton Unit 1	\$ 2,502,123	\$ 2,675,792	\$ 7,257,000	\$ 37,292,000	\$ 26,819,000	\$ 42,301,000	\$ 44,000,000	\$ -	\$ 800,000	\$ 15,482,000
8	Naughton Unit 2	\$ 2,570,674	\$ 3,423,533	\$ 8,784,000	\$ 47,934,000	\$ 39,262,000	\$ 57,621,000	\$ 56,000,000	\$ -	\$ 800,000	\$ 15,482,000
9	Naughton Unit 3	\$ -	\$ 4,354,377	\$ 11,903,578	\$ 67,373,000	\$ -	\$ 2,953,000	\$ -	\$ -	\$ 800,000	\$ 20,105,000
10	Wyodak Unit 1	\$ 3,187,636	\$ 4,500,245	\$ 7,234,868	\$ 72,479,000	\$ 996,100	\$ -	\$ 178,174,384	\$ -	\$ 1,247,081	\$ 20,105,000

CAPITAL COST

Jim Bridger Unit 3

Parameter	NOX Control			SO2 Control			PM Control							
	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	N/A	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	N/A	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
Cost	Factor/Source	Factor/Source	Factor/Source	Factor/Source	Factor/Source	Factor/Source	Factor/Source	Factor/Source	Factor/Source	Factor/Source	Factor/Source	Factor/Source	Factor/Source	Factor/Source
NOx Emission Control System	\$9,059,855	\$2,851,982	\$2,851,982	\$2,851,982	\$2,851,982	\$2,851,982	\$2,851,982	\$2,851,982	\$2,851,982	\$2,851,982	\$2,851,982	\$2,851,982	\$2,851,982	\$2,851,982
SO2 Emission Control System	\$5,081,038	\$2,544,638	\$2,544,638	\$2,544,638	\$2,544,638	\$2,544,638	\$2,544,638	\$2,544,638	\$2,544,638	\$2,544,638	\$2,544,638	\$2,544,638	\$2,544,638	\$2,544,638
PM Emission Control System	\$1,817,087	\$1,817,087	\$1,817,087	\$1,817,087	\$1,817,087	\$1,817,087	\$1,817,087	\$1,817,087	\$1,817,087	\$1,817,087	\$1,817,087	\$1,817,087	\$1,817,087	\$1,817,087
CAPITAL COST COMPONENT														
LNB w/OFA or ROFA	\$395,089	\$395,089	\$395,089	\$395,089	\$395,089	\$395,089	\$395,089	\$395,089	\$395,089	\$395,089	\$395,089	\$395,089	\$395,089	\$395,089
Major Materials Design and Supply	\$894,884	\$894,884	\$894,884	\$894,884	\$894,884	\$894,884	\$894,884	\$894,884	\$894,884	\$894,884	\$894,884	\$894,884	\$894,884	\$894,884
Construction	\$377,291	\$377,291	\$377,291	\$377,291	\$377,291	\$377,291	\$377,291	\$377,291	\$377,291	\$377,291	\$377,291	\$377,291	\$377,291	\$377,291
Electrical (Allowance)	\$18,444	\$18,444	\$18,444	\$18,444	\$18,444	\$18,444	\$18,444	\$18,444	\$18,444	\$18,444	\$18,444	\$18,444	\$18,444	\$18,444
Owner's Costs	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274
Surcharge and AFUDC	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352
Subtotal	\$1,071,038	\$1,071,038	\$1,071,038	\$1,071,038	\$1,071,038	\$1,071,038	\$1,071,038	\$1,071,038	\$1,071,038	\$1,071,038	\$1,071,038	\$1,071,038	\$1,071,038	\$1,071,038
Contingency	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231
Total Capital Cost for LNB w/OFA or ROFA	\$1,101,269	\$1,101,269	\$1,101,269	\$1,101,269	\$1,101,269	\$1,101,269	\$1,101,269	\$1,101,269	\$1,101,269	\$1,101,269	\$1,101,269	\$1,101,269	\$1,101,269	\$1,101,269
SNCR or SCR	\$9,419,000	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800
Major Materials Design and Supply	\$826,800	\$826,800	\$826,800	\$826,800	\$826,800	\$826,800	\$826,800	\$826,800	\$826,800	\$826,800	\$826,800	\$826,800	\$826,800	\$826,800
Construction	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231
Electrical (Allowance)	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274
Owner's Costs	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274
Surcharge and AFUDC	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352
Subtotal	\$9,419,000	\$9,419,000	\$9,419,000	\$9,419,000	\$9,419,000	\$9,419,000	\$9,419,000	\$9,419,000	\$9,419,000	\$9,419,000	\$9,419,000	\$9,419,000	\$9,419,000	\$9,419,000
Contingency	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231
Total Capital Cost for SNCR or SCR	\$9,449,231	\$9,449,231	\$9,449,231	\$9,449,231	\$9,449,231	\$9,449,231	\$9,449,231	\$9,449,231	\$9,449,231	\$9,449,231	\$9,449,231	\$9,449,231	\$9,449,231	\$9,449,231
Dry or Wet FGD, FGD or Fabric Filter	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800
Major Materials Design and Supply	\$826,800	\$826,800	\$826,800	\$826,800	\$826,800	\$826,800	\$826,800	\$826,800	\$826,800	\$826,800	\$826,800	\$826,800	\$826,800	\$826,800
Construction	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231
Electrical (Allowance)	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274
Owner's Costs	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274	\$13,274
Surcharge and AFUDC	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352	\$364,352
Subtotal	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800	\$1,633,800
Contingency	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231	\$30,231
Total Capital Cost for Dry/Wet FGD, FGD or FF	\$1,664,031	\$1,664,031	\$1,664,031	\$1,664,031	\$1,664,031	\$1,664,031	\$1,664,031	\$1,664,031	\$1,664,031	\$1,664,031	\$1,664,031	\$1,664,031	\$1,664,031	\$1,664,031

Jim Bridger Unit 3											LNB w/OFA										
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton NOx Removed)										
0	2013																				
1	2014	70,000							827,612	887,612	181										
2	2015	71,400							827,612	899,012	161										
3	2016	72,828							827,612	900,440	161										
4	2017	74,285							827,612	901,897	162										
5	2018	75,770							827,612	903,382	162										
6	2019	77,286							827,612	904,888	162										
7	2020	78,831							827,612	906,443	163										
8	2021	80,408							827,612	908,020	163										
9	2022	82,016							827,612	909,628	163										
10	2023	83,656							827,612	911,269	163										
11	2024	85,330							827,612	912,942	164										
12	2025	87,038							827,612	914,648	164										
13	2026	88,777							827,612	916,389	165										
14	2027	90,552							827,612	918,165	165										
15	2028	92,364							827,612	919,976	165										
16	2029	94,211							827,612	921,823	166										
17	2030	96,095							827,612	923,707	166										
18	2031	98,017							827,612	925,629	166										
19	2032	99,977							827,612	927,589	167										
20	2033	101,977							827,612	929,589	167										
Present Worth (% of PW)		855,250	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	8,700,001	9,555,250	96										
									91.0%	100.0%											

Jim Bridger Unit 3											ROFA										
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton NOx Removed)										
0	2013																				
1	2014	105,000					2,528,012	2,528,012	1,952,796	4,580,808	843										
2	2015	107,100					2,578,573	2,578,573	1,952,796	4,638,468	853										
3	2016	109,242					2,630,144	2,630,144	1,952,796	4,692,182	863										
4	2017	111,427					2,682,747	2,682,747	1,952,796	4,746,970	873										
5	2018	113,655					2,736,402	2,736,402	1,952,796	4,802,853	883										
6	2019	115,928					2,791,130	2,791,130	1,952,796	4,859,854	893										
7	2020	118,247					2,846,953	2,846,953	1,952,796	4,917,995	904										
8	2021	120,612					2,903,882	2,903,882	1,952,796	4,977,299	915										
9	2022	123,024					2,961,970	2,961,970	1,952,796	5,037,789	926										
10	2023	125,485					3,021,208	3,021,208	1,952,796	5,099,489	937										
11	2024	127,994					3,081,593	3,081,593	1,952,796	5,162,423	949										
12	2025	130,554					3,143,266	3,143,266	1,952,796	5,226,616	961										
13	2026	133,165					3,206,131	3,206,131	1,952,796	5,292,092	973										
14	2027	135,829					3,270,254	3,270,254	1,952,796	5,358,878	985										
15	2028	138,545					3,335,659	3,335,659	1,952,796	5,427,000	998										
16	2029	141,316					3,402,372	3,402,372	1,952,796	5,496,484	1,010										
17	2030	144,142					3,470,419	3,470,419	1,952,796	5,567,358	1,023										
18	2031	147,025					3,539,828	3,539,828	1,952,796	5,639,649	1,037										
19	2032	149,966					3,610,624	3,610,624	1,952,796	5,713,386	1,050										
20	2033	152,965					3,682,837	3,682,837	1,952,796	5,788,598	1,064										
Present Worth (% of PW)		1,262,875	0.0%	0.0%	0.0%	0.0%	30,865,856	30,865,856	20,536,176	52,567,893	484										
							58.8%	58.8%	36.0%	100.0%											

Jim Bridger Unit 3												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton NOx Removed)	
0	2013											
1	2014	305,000		1,005,814	600,000		2,094,984	1,210,795	2,090,304	9,895,089	610	
2	2015	311,100		1,035,927	612,000		2,094,984	1,235,011	2,090,304	9,595,415	615	
3	2016	317,322		1,046,446	624,240		2,094,984	1,259,227	2,090,304	9,567,337	620	
4	2017	323,568		1,057,975	636,725		2,094,984	1,283,443	2,090,304	9,569,877	625	
5	2018	330,192		1,069,504	649,459		2,094,984	1,307,659	2,090,304	9,731,049	631	
6	2019	336,745		1,100,486	662,448		2,094,984	1,331,875	2,090,304	9,753,864	637	
7	2020	343,480		1,127,706	675,697		2,094,984	1,356,091	2,090,304	9,787,333	642	
8	2021	350,349		1,155,351	702,986		2,094,984	1,380,307	2,090,304	9,831,478	646	
9	2022	357,356		1,178,466	720,986		2,094,984	1,404,522	2,090,304	9,885,289	651	
10	2023	364,503		1,202,037	739,986		2,094,984	1,428,738	2,090,304	9,939,049	656	
11	2024	371,793		1,226,078	759,986		2,094,984	1,452,954	2,090,304	9,992,809	661	
12	2025	379,229		1,250,599	780,986		2,094,984	1,477,170	2,090,304	10,046,569	666	
13	2026	386,814		1,275,611	802,986		2,094,984	1,501,386	2,090,304	10,100,329	671	
14	2027	394,550		1,301,124	825,986		2,094,984	1,525,602	2,090,304	10,154,089	676	
15	2028	402,441		1,327,146	849,986		2,094,984	1,549,818	2,090,304	10,207,849	681	
16	2029	410,490		1,353,689	874,986		2,094,984	1,574,034	2,090,304	10,261,609	686	
17	2030	418,700		1,380,732	899,986		2,094,984	1,598,250	2,090,304	10,315,369	691	
18	2031	427,074		1,408,378	925,986		2,094,984	1,622,466	2,090,304	10,369,129	696	
19	2032	435,615		1,436,546	951,986		2,094,984	1,646,682	2,090,304	10,422,889	701	
20	2033	444,327		1,465,276	978,986		2,094,984	1,670,900	2,090,304	10,476,649	706	
Present Worth		3,726,445	9.2%	12,288,849	30.3%	0.0%	2,504,464	14,795,314	21,973,632	40,493,381	342	
(% of PW)							6.2%	36.5%	54.3%	100.0%		


Jim Bridger Unit 3												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton NOx Removed)	
0	2013											
1	2014	475,000		612,848	600,000		1,289,718	2,782,566	12,326,235	16,583,801	1,754	
2	2015	484,500		591,105	612,000		1,285,113	2,836,218	12,326,235	16,548,952	1,741	
3	2016	494,190		649,727	624,240		1,321,015	2,894,982	12,326,235	15,715,407	1,749	
4	2017	504,074		668,722	636,725		1,347,455	2,952,882	12,326,235	15,783,190	1,756	
5	2018	514,155		688,096	649,459		1,374,384	3,011,893	12,326,235	15,852,329	1,764	
6	2019	524,438		1,007,858	662,448		1,401,871	3,072,178	12,326,235	15,922,851	1,772	
7	2020	534,927		1,028,015	675,697		1,429,909	3,133,622	12,326,235	15,994,783	1,780	
8	2021	545,626		1,048,575	689,211		1,458,507	3,195,294	12,326,235	16,068,154	1,788	
9	2022	556,538		1,069,547	702,986		1,487,677	3,260,220	12,326,235	16,142,993	1,796	
10	2023	567,668		1,090,938	717,056		1,517,491	3,325,424	12,326,235	16,219,328	1,805	
11	2024	579,022		1,112,757	731,397		1,547,779	3,391,933	12,326,235	16,297,190	1,813	
12	2025	590,603		1,135,012	746,025		1,578,795	3,459,771	12,326,235	16,376,608	1,822	
13	2026	602,415		1,157,712	760,945		1,610,310	3,528,967	12,326,235	16,457,616	1,831	
14	2027	614,463		1,180,866	776,154		1,642,516	3,599,546	12,326,235	16,540,244	1,840	
15	2028	626,752		1,204,484	791,687		1,675,366	3,671,537	12,326,235	16,624,524	1,850	
16	2029	639,287		1,228,572	807,521		1,708,874	3,744,968	12,326,235	16,710,480	1,859	
17	2030	652,073		1,253,145	823,671		1,743,051	3,819,867	12,326,235	16,798,175	1,869	
18	2031	665,115		1,278,208	840,145		1,777,912	3,896,284	12,326,235	16,887,614	1,879	
19	2032	678,417		1,303,772	856,948		1,813,470	3,974,190	12,326,235	16,978,842	1,889	
20	2033	691,985		1,329,847	874,087		1,849,740	4,053,674	12,326,235	17,071,894	1,900	
Present Worth		5,903,480	3.4%	11,153,043	7.3%	4.3%	15,513,231	33,965,945	129,575,495	169,375,951	942	
(% of PW)							9.2%	20.1%	76.5%	100.0%		

Jim Bridger Unit 3											
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton SO2 Removed)
0	2013										
1	2014	42,583	29,927	533,206		442,958	204,984	1,211,075	1,236,652	2,400,310	631
2	2015	43,435	30,526	543,870		451,918	209,984	1,236,297	1,236,652	2,515,384	637
3	2016	44,303	31,136	554,747		460,954	214,984	1,260,003	1,236,652	2,540,958	643
4	2017	45,189	31,759	565,842		470,071	219,984	1,283,033	1,236,652	2,567,044	650
5	2018	46,093	32,384	577,155		479,172	224,984	1,305,907	1,236,652	2,593,652	657
6	2019	47,015	33,042	588,702		488,262	229,984	1,328,688	1,236,652	2,620,792	664
7	2020	47,955	33,702	600,476		497,343	234,984	1,351,389	1,236,652	2,648,475	671
8	2021	48,914	34,377	612,486		506,420	239,984	1,374,015	1,236,652	2,676,714	678
9	2022	49,893	35,065	624,735		515,498	244,984	1,396,566	1,236,652	2,705,513	685
10	2023	50,890	35,766	637,235		524,576	249,984	1,419,042	1,236,652	2,734,890	692
11	2024	51,908	36,481	649,975		533,654	254,984	1,441,464	1,236,652	2,764,885	700
12	2025	52,946	37,201	662,974		542,732	259,984	1,463,832	1,236,652	2,795,419	708
13	2026	54,005	37,935	676,234		551,810	264,984	1,486,156	1,236,652	2,826,594	716
14	2027	55,085	38,714	689,755		560,888	269,984	1,508,436	1,236,652	2,858,383	724
15	2028	56,187	39,535	703,554		569,966	274,984	1,530,672	1,236,652	2,890,791	732
16	2029	57,311	40,406	717,625		579,044	279,984	1,552,864	1,236,652	2,923,811	740
17	2030	58,457	41,324	731,977		588,122	284,984	1,575,012	1,236,652	2,957,464	749
18	2031	59,628	42,291	746,617		597,200	289,984	1,597,116	1,236,652	2,991,758	758
19	2032	60,819	43,304	761,345		606,278	294,984	1,619,176	1,236,652	3,026,706	768
20	2033	62,033	43,358	776,360		615,356	299,984	1,641,192	1,236,652	3,062,395	778
Present Worth (% of PW)		520,271	365,648	6,514,628	0.0%	5,412,000	2,304,464	14,756,741	12,989,900	28,316,512	358
		1.8%	1.3%	23.0%		19.1%	8.8%	52.3%	45.9%	100.0%	


Jim Bridger Unit 3											
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton PM Removed)
0	2013										
1	2014	10,000		145,854			19,710	165,564	-	175,564	275
2	2015	10,200		146,771			20,104	166,875	-	179,075	280
3	2016	10,404		151,747			20,506	172,253	-	182,657	286
4	2017	10,612		154,781			20,916	175,698	-	186,310	292
5	2018	10,824		157,877			21,335	179,212	-	190,036	298
6	2019	11,041		161,035			21,761	182,796	-	193,837	304
7	2020	11,262		164,255			22,197	186,452	-	197,714	310
8	2021	11,487		167,540			22,641	190,181	-	201,668	316
9	2022	11,717		170,891			23,093	193,985	-	205,701	322
10	2023	11,951		174,309			23,555	197,864	-	209,815	329
11	2024	12,190		177,795			24,026	201,822	-	214,012	335
12	2025	12,434		181,351			24,507	205,858	-	218,292	342
13	2026	12,682		184,978			24,997	209,975	-	222,658	349
14	2027	12,936		188,678			25,497	214,175	-	227,111	356
15	2028	13,195		192,451			26,007	218,468	-	231,653	363
16	2029	13,459		196,300			26,527	222,827	-	236,286	370
17	2030	13,728		200,226			27,058	227,284	-	241,012	377
18	2031	14,002		204,231			27,599	231,830	-	245,832	385
19	2032	14,282		208,315			28,151	236,468	-	250,749	393
20	2033	14,568		212,482			28,714	241,195	-	255,754	401
Present Worth (% of PW)		122,179	0.0%	1,782,023	0.0%	0.0%	240,814	2,022,837	0.0%	2,145,015	188
		5.7%		83.1%			11.2%	54.3%		100.0%	

Jim Bridger Unit 3												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton PM Removed)	
0	2013											
1	2014	127,749			284,008		1,313,474	1,607,482	4,602,887	6,338,118	6,381	
2	2015	130,304			289,888		1,339,744	1,639,632	4,602,887	6,372,822	6,416	
3	2016	132,910			305,886		1,366,539	1,672,425	4,602,887	6,408,221	6,451	
4	2017	135,568			312,004		1,393,870	1,705,873	4,602,887	6,444,328	6,488	
5	2018	138,279			318,244		1,421,747	1,739,991	4,602,887	6,481,155	6,525	
6	2019	141,045			324,609		1,450,182	1,774,790	4,602,887	6,518,722	6,563	
7	2020	143,888			331,101		1,479,186	1,810,286	4,602,887	6,557,038	6,601	
8	2021	146,743			337,723		1,508,769	1,846,482	4,602,887	6,596,121	6,640	
9	2022	149,678			344,477		1,538,945	1,883,422	4,602,887	6,635,886	6,681	
10	2023	152,671			351,357		1,569,723	1,921,030	4,602,887	6,676,648	6,722	
11	2024	155,725			358,384		1,601,118	1,959,512	4,602,887	6,718,123	6,763	
12	2025	158,839			365,562		1,633,140	1,998,702	4,602,887	6,760,428	6,806	
13	2026	162,016			372,873		1,665,803	2,038,676	4,602,887	6,803,579	6,849	
14	2027	165,256			380,331		1,699,119	2,079,450	4,602,887	6,847,583	6,894	
15	2028	168,562			387,937		1,733,102	2,121,039	4,602,887	6,892,487	6,938	
16	2029	171,933			395,696		1,767,784	2,163,460	4,602,887	6,938,279	6,985	
17	2030	175,371			403,610		1,803,119	2,206,729	4,602,887	6,984,987	7,032	
18	2031	178,879			411,882		1,839,181	2,250,883	4,602,887	7,032,629	7,080	
19	2032	182,456			419,916		1,875,965	2,295,881	4,602,887	7,081,224	7,129	
20	2033	186,106			428,314		1,913,484	2,341,758	4,602,887	7,130,790	7,179	
Present Worth (% of PW)		1,560,919	0.0%	0.0%	5.2%	0.0%	16,017,858	19,653,584	48,386,353	69,587,130	3,503	
		2.2%					23.1%	23.2%	59.5%	100.0%		

First Year Cost for Air Pollution Control Options



Present Worth Cost for Air Pollution Control Options



APPENDIX B

2006 Wyoming BART Protocol

BART Air Modeling Protocol
Individual Source Visibility Assessments
for BART Control Analyses

September, 2006

State of Wyoming
Department of Environmental Quality
Air Quality Division
Cheyenne, WY 82002

Table of Contents

1.0	INTRODUCTION	3
2.0	OVERVIEW	4
3.0	EMISSIONS DATA FOR MODELING	7
3.1	Baseline Modeling	7
3.2	Post-Control Modeling.....	8
4.0	METEOROLOGICAL DATA.....	9
5.0	CALPUFF MODEL APPLICATION.....	12
6.0	POST PROCESSING	15
7.0	REPORTING.....	19

1.0 INTRODUCTION

The U.S. EPA has issued final amendments to the Regional Haze Regulations, along with Guidelines for Best Available Retrofit Technology (BART) Determinations.⁽¹⁾ The guidelines address the methodology for determining which facilities must apply BART (sources subject-to-BART) and the evaluation of control options.

The State of Wyoming used air quality modeling in accordance with the EPA Guidelines to determine the Wyoming sources which are subject-to-BART. This Protocol defines the specific methodology to be used by those sources for determining the improvement in visibility to be achieved by BART controls.

The methodology presented in this Protocol is consistent with EPA guidance and the Air Quality Division (AQD) determination of subject-to-BART sources. It is intended that all Wyoming sources that must conduct BART analyses will use this Protocol for their evaluation of control technology visibility improvement. Any deviations from the procedures described herein must be approved by the Division prior to implementation.

⁽¹⁾ 40 CFR Part 51: Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations; Final Rule. 70 Federal Register, 39103-39172, July 6, 2005.

2.0 OVERVIEW

Wyoming AQD determined that eight facilities (sources) in the state are subject-to-BART. The sources are listed in Table 1. Division modeling indicated that each of these sources causes or contributes to visibility impairment in one or more Class I areas. Each source must conduct a BART analysis to define Best Available Retrofit Technology (BART) applicable to that source, and quantify the improvement in Class I visibility associated with BART controls. This Protocol sets out the procedures for quantifying visibility improvement. Other aspects of the full BART analysis are not addressed here.

There are many Class I areas within and surrounding Wyoming (See Figure 1). On the basis of distance from subject-to-BART sources, topography, meteorology, and prior modeling, the AQD has determined that only five Class I areas need be addressed in BART individual source analyses. These are Badlands and Wind Cave National Parks in South Dakota, Mt. Zirkel Wilderness Area in Colorado, and Bridger and Fitzpatrick Wilderness Areas in Wyoming. Sources in eastern Wyoming have been shown to have greatest visibility impacts at the two South Dakota Class I areas, and western Wyoming sources have maximum impacts at Bridger and Fitzpatrick Wilderness Areas, and Mt. Zirkel. Visibility improvement at these highest impact areas will provide the best measure of the effectiveness of BART controls.

Each facility should carry out modeling with the CALPUFF modeling system for the Class I areas specified in Table 2. The AQD will provide meteorological input for CALMET for the years 2001, 2002, and 2003. The model domain covered by the AQD meteorological data is centered in southwest Wyoming, and extends roughly from Twin Falls, ID in the west to the Missouri River in the east, and from Denver in the south to Helena, MT in the north. The domain is shown, along with Class I areas, in Figure 1.

Sources may wish to utilize a smaller domain for CALPUFF modeling. Smaller domains are acceptable if they provide adequate additional area beyond the specific source and Class I areas being addressed. Figure 1 includes a "southwest Wyoming" domain which represents the minimum acceptable area for sources impacting the Bridger and Fitzpatrick Wilderness Areas, and the Mt. Zirkel Wilderness Area, and a "northeast Wyoming" domain as a minimum area for Badlands and Wind Cave National Parks modeling.

The CALPUFF model should be used with each of the three years of meteorological data to calculate visibility impacts for a baseline (existing emissions) case, and for cases reflecting BART controls. The control scenarios are to include individual scenarios for proposed BART controls for each pollutant (SO₂, NO_x, and particulate matter), and a combined scenario representing application of all proposed BART controls. If desired, additional modeling may be performed for controls that are not selected as BART. This might be done, for example, to provide data useful in identifying the control technologies that represent BART. However, visibility modeling is required only for the proposed BART controls.

Table 1. Wyoming Sources Subject-to-BART

Basin Electric	Laramie River Power Plant	Boilers #1,2,3
FMC Corporation	Granger Soda Ash Plant	Boilers #1,2
FMC Corporation	Green River Sodium Plant	Three boilers
General Chemical Co.	Green River Soda Ash	Two boilers
PacifiCorp	Dave Johnson Power Plant	Boilers #3,4
PacifiCorp	Jim Bridger Power Plant	Boilers #1-4
PacifiCorp	Naughton Power Plant	Boilers #1,2,3
PacifiCorp	Wyodak Power Plant	Boiler

Results of visibility modeling will be presented as a comparison between baseline impacts and those calculated for the BART control scenarios. Quantitative measures of impact will be the 98th percentile deciview change (Δv) relative to the 20% best days natural background, and the number of days with deciview change exceeding 0.5 (EPA Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations, 70 FR 39103). Results should be presented for each year.

Table 2. Source-Specific Class I Areas to be Addressed

Source	Class I Areas to be Evaluated
Basin Electric Laramie River	Wind Cave NP, Badlands NP
FMC Corporation Granger Soda Ash	Bridger WA, Fitzpatrick WA
FMC Corporation Sodium Products	Bridger WA, Fitzpatrick WA
General Chemical Green River Soda Ash	Bridger WA, Fitzpatrick WA
Pacificorp Dave Johnston	Wind Cave NP, Badlands NP
Pacificorp Jim Bridger	Bridger WA, Fitzpatrick WA, Mt. Zirkel WA
Pacificorp Naughton Plant	Bridger WA, Fitzpatrick WA
Pacificorp Wyodak	Wind Cave NP, Badlands NP

3.0 EMISSIONS DATA FOR MODELING

CALPUFF model input requires source (stack) – specific emission rates for each pollutant, and stack parameters (height, diameter, exit gas temperature, and exit gas velocity). Per EPA BART guidance, these parameters must be representative of maximum actual 24-hour average emitting conditions for baseline (existing) operation, and maximum proposed 24-hour average emissions for future (BART) operations.

3.1 Baseline Modeling

Sources are required to utilize representative baseline emission conditions if data are available; baseline emissions must be documented. Possible sources of emission data are stack tests, CEM data, fuel consumption data, etc. Remember that emissions should represent maximum 24-hour rates. EPA BART guidance states that you should “Use the 24-hour average actual emission rate from the highest emitting day of the meteorological period modeled (for the pre-control scenario).” Thus, baseline conditions should reference data from 2001 through 2003 (or 2004).

As a minimum, modeled emissions must include:

SO ₂	sulfur dioxide
NO _x	oxides of nitrogen
PM _{2.5}	particles with diameter less than 2.5µm
PM _{10-2.5}	particles with diameters greater than 2.5µm but less than or equal to 10 µm

If the fraction of PM₁₀ in the PM_{2.5} (fine) and PM_{10-2.5} (coarse) categories cannot be determined all particulate matter should be assumed to be PM_{2.5}.

In addition, direct emissions of sulfate (SO₄) should be included where possible. Sulfate can be emitted as sulfuric acid (H₂SO₄), sulfur trioxide (SO₃), or as sulfate compounds; emissions should be quantified as the equivalent mass of SO₄.

When test or engineering data are not available to specify SO₄ emissions or the relative fractions of fine and coarse particles, use can be made of speciation profiles available from Federal Land Managers at the website <http://ww2.nature.nps.gov/air/permits/ect/index.cfm>. Profiles are available for a number of source type and control technology combinations. The FLM speciation factors are acceptable if data are available for the appropriate source type.

Emissions of VOC (volatile organic compounds), condensable organics measured in stack tests, and elemental carbon components of PM₁₀ do not need to be included for BART modeling. The only other pollutant noted in EPA BART guidance is ammonia (NH₃). Though ammonia is not believed to be a significant contributor to visibility

impairment in most cases in Wyoming, it could be important for sources with significant ammonia emissions – for example from some NO_x control systems. Sources that are expected to emit ammonia (in pre-or post-control configurations) should include ammonia emissions in their model input.

If quantitative baseline emissions data are unavailable and sources believe that the maximum 24-hour emission rates estimated by the Division (presented in the Subject-to-BART final report) are representative of baseline conditions for their facility, they may be used for baseline modeling. However, emissions of sulfate and ammonia (if applicable) should be included based on the best available test information or speciation factors from current literature.

3.2 Post-Control Modeling

All pollutants described above should be included for each post-control scenario. Post-control emissions (maximum 24-hour average) will generally be the baseline emissions multiplied by a control factor appropriate to the BART control. However, some proposed controls may simply increase the efficiency of existing controls; others may result in an increase in emissions of one pollutant while controlling another. These factors must all be considered in defining emission rates for post-control modeling. Any changes in stack parameters resulting from control application must also be included.

The required visibility assessment will include the effect of each proposed BART control. For example, if a source proposes to add a scrubber for SO₂ control, low NO_x burners for NO_x control, and a baghouse for particulate control, four sets of visibility results should be developed:

- Use of SO₂ control alone
- Use of NO_x control alone
- Use of particulate control alone
- Use of proposed combination of all three controls

All pollutants should be modeled in each CALPUFF model run, but the modeled emissions should reflect only the specific controls or combination of controls addressed in that run.

Additional modeling could be necessary in situations where a facility is comprised of more than one subject-to-BART source, and different BART controls are applicable to different sources. Excessive modeling to address multiple control combinations is not necessary; however, visibility modeling should quantify the effect of BART controls on all affected sources for each pollutant, and of all facility BART controls combined.

4.0 METEOROLOGICAL DATA

Wyoming AQD will provide MM5 meteorological data fields for years 2001, 2002, and 2003 that can be utilized as input to CALMET. The MM5 output will have 12 kilometer resolution and cover the full domain shown in Figure 1.

Mesoscale meteorological data (MM5) were developed and evaluated as part of the AQD's southwest Wyoming NO₂ increment analysis. Three years of MM5 data at 36 km resolution were used to initialize 12 km MM5 simulations. The 12km MM5 modeling used identical physics options to the original 36 km runs. CALMM5 was then used as a preprocessor to produce CALMET - ready MM5 data input files. Quality assurance was performed by comparing the original MM5 output on the 36km national RPO grid to the 12 km MM5 output and observations.

The CALMET model (version 5.53a, level 040716) should be used to prepare meteorological input for CALPUFF. The user may select a domain smaller than the MM5 domain for CALMET and CALPUFF modeling if desired. Figure 1 shows minimum domain areas for modeling of western and eastern Wyoming BART sources. Four kilometer resolution should be specified for CALMET output.

CALMET processing should use the AQD MM5 data, and appropriate surface, upper air, and precipitation data. Figure 2 shows the locations of surface and upper air stations within the MM5 model domain. The MM5 data are used as the initial guess wind field; this wind field is then adjusted by CALMET for terrain and land use to generate a step 1 wind field, and refined using surface and upper air data to create the final step 2 wind field.

Surface, upper air, and precipitation data can be obtained from the National Climatic Data Center. Land use and terrain data are available from the U.S. Geological Survey. Data can be formatted for use in CALMET with standard conversion and processing programs available with the CALMET/CALPUFF software.

Table 3 provides a listing of applicable CALMET input variables for BART meteorological processing. The table includes inputs that are specific to Wyoming BART modeling. Inputs not shown in Table 3 are not relevant to the present application, are dependent on the specific model domain of the user, use model default values, or are obvious from the context.

Table 3. CALMET Control File Inputs

Variable	Description	Value
Input Group 1		
IBYR	Year	2001
		2002
		2003
IBTZ	Base time zone	7
IRTYPE	Run type	1
LCALGRD	Compute data fields for CALGRID	T
Input Group 2		
PMAP	Map projection	LCC
DGRIDKM	Grid spacing (km)	4
NZ	Number of layers	10
ZFACE	Cell face heights (m)	0
		20
		40
		100
		140
		320
		580
		1020
		1480
		2220
		3500
Input Group 4		
NOOBS	No observation Mode	0
Input Group 5		
IWFCOD	Model selection variable	1
IFRADJ	Froude number adjustment	1
IKINE	Kinematic effects	0
IOBR	Use O'Brien procedure	0
ISLOPE	Slope flow effects	1
IBXTRP	Extrapolate surface wind observations	-4
ICALM	Extrapolate calm surface winds	0
BIAS	Biases for weights of surface and upper air stations	All 0
RMIN2	Minimum distance for extrapolation	-1
I PROG	Use gridded prognostic model output	14
ISTEPPG	Time Step (hours)	1
LVARY	Use varying radius of influence	F

Table 3. CALMET Control File Inputs (continued)

Variable	Description	Value
RMAX 1	Maximum radius of influence (km)	30
RMAX 2	Maximum radius of influence (km)	50
RMIN	Minimum radius of influence (km)	0.1
TERRAD	Radius of influence for terrain (km)	15
R1	Relative weighting of first guess wind field and observations (km)	5
R2	Relative weighting aloft (km)	25
IDIOPT 1	Surface temperature	0
IDIOPT 2	Upper air lapse rate	0
ZUPT	Lapse rate depth (m)	200
IDIOPT 3	Average wind components	0
IUPWND	Upper air station	-1
ZUPWND (1)	Bottom and top of layer for domain	1, 1000
ZUPWND (2)	scale winds (m)	1, 1000
IDIOPT4	Surface wind components	0
IDIOPT5	Upper air wind components	0
Input Group 6		
IAVEZI	Spatial averaging	1
MNMDAV	Max search radius	1
HAFANG	Half angle for averaging (deg)	30
ILEVZI	Layer of winds in averaging	1
ZIMAX	Maximum overland mixing height (m)	3500
ITPROG	3D temperature source	1
IRAD	Interpolation type	1
TRADKM	Radius of influence -- temperature (km)	500
NUMTS	Maximum number of Stations	5
IAVET	Spatial averaging of temperatures	1
NFLAGP	Precipitation interpolation	2

5.0 CALPUFF MODEL APPLICATION

The CALPUFF model (version 5.711a, level 040716) will be used to calculate pollutant concentrations at receptors in each Class I area. Application of CALPUFF should, in general, follow the guidance presented in the Interagency Workgroup on Air Quality Modeling (IWAQM) Phase 2 report (EPA - 454/R98-019) and the EPA Regional Haze Regulations and Guidelines for BART Determinations (70 FR 39103).

Appropriate CALPUFF control file inputs are in Table 4. Note should be taken of the basis for several of the recommended CALPUFF inputs.

- Building downwash effects need not be included. Because of the transport distances involved and the fact that most sources have tall stacks, building downwash is unlikely to have a significant effect on model-predicted concentrations
- Puff splitting is not required. The additional computation time necessary for puff splitting is not justified for purposes of BART analyses.
- Hourly ozone files should be used to define background ozone concentration. Data are available from the following sites within the model domain.
 - Rocky Mountain NP, CO
 - Craters of the Moon NP, ID
 - AIRS - Highland UT
 - Mountain Thunder, WY
 - Yellowstone NP, WY
 - Centennial, WY
 - Pinedale, WY

The background ozone concentration shown in Table 4 is used only when hourly data are missing.

- A constant background ammonia concentration of 2.0 ppb is specified. This value is based upon monitoring data from nearby states and IWAQM guidance. Experience suggests that 2.0 ppb is conservative in that it is unlikely to significantly limit nitrate formation in the model computations.
- MESOPUFF II chemical transformation rates should be used.
- The species to be modeled should be the seven identified in CALPUFF: SO₂, SO₄, NO_x, HNO₃, NO₃, PM_{2.5}, and PM_{10-2.5}. If ammonia (NH₃) is emitted it should be added to the species list. In most cases, all pollutants modeled will also be emitted, except for HNO₃ and NO₃.

Concentration calculations should be made for receptors covering the areas of the Class I areas being addressed. Receptors in each Class I area will be those designated by the Federal Land Managers and available from the National Park Service website.

Table 4. CALPUFF Control File Inputs

Variable	Description	Value
	Input Group 1	
METRUN	Control parameter for running all periods in met file	1
IBYR	Starting year	2001 2002 2003
XBTZ	Base time zone	7
NSPEC	Number of chemical species modeled	7 (or 8)
NSE	Number of species emitted	5 (or 6)
METFM	Meteorological data format	1
	Input Group 2	
MGAUSS	Vertical distribution in near field	1
MCTADJ	Terrain adjustment method	3
MCTSG	Subgrid scale complex terrain	0
MSLUG	Elongated puffs	0
MTRANS	Transitional plume rise	1
MTIP	Stack tip downwash	1
MSHEAR	Vertical wind shear	0
MSPLIT	Puff splitting allowed?	0
MCHEM	Chemical mechanism	1
MAQCHEM	Aqueous phase transformation	0
MWET	Wet removal	1
MDRY	Dry deposition	1
MDISP	Dispersion Coefficients	3
MROUGH	Adjust sigma for roughness	0
MPARTL	Partial plume penetration of inversions	1
MPDF	PDF for convective conditions	0
	Input Group 4	
PMAP	Map projection	LCC
DGRIDKM	Grid spacing	4

Table 4. CALPUFF Control File Inputs (continued)

ZFACE	Cell face heights (m)	0
		20
		40
		100
		140
		320
		580
		1020
		1480
		2220
		3500
	Input Group 6	
NHILL	Number of terrain features	0
	Input Group 7	
Dry Gas Depo	Chemical parameters for dry gas deposition	Defaults
	Input Group 8	
Dry Part. Depo	Size parameters for dry particle deposition SO ₄ , NO ₃ , PM25 PM10	Defaults 6.5, 1.0
	Input Group 11	
MOZ	Ozone Input option	1
BCK03	Background ozone -- all months (ppb)	44.0
BCKNH3	Background ammonia -- all months (ppb)	2.0
	Input Group 12	
XMAXZI	Maximum mixing height (m)	3500
XMINZI	Minimum mixing height (m)	50

6.0 POST PROCESSING

Visibility impacts are calculated from the CALPUFF concentration results using CALPOST. CALPOST version 5.51, level 030709 should be used; the output from CALPOST will provide the highest deciview impact on each day from all receptors within each Class I area modeled.

For some CALPUFF applications such as deposition calculations, the POSTUTIL program is used prior to CALPOST. POSTUTIL is also used to repartition total nitrate by accounting for ammonia limiting. The ammonia limiting calculation in POSTUTIL should not be applied for Wyoming BART modeling. If you believe that ammonia limiting is appropriate for a specific BART analysis, justification should be discussed with the Division prior to its used.

Visibility calculations by CALPOST for BART purposes use Method 6. This method requires input of monthly relative humidity factors, $f(RH)$, for each Class I area. The EPA guidance document provides appropriate data for each area. Table 5 lists monthly $f(RH)$ factors to use for the Wyoming, Colorado, and South Dakota areas to be addressed in BART modeling. The factors shown in Table 5 include averages for the adjacent Class I areas, and are within 0.2 units of the Guideline table values for the individual Class I areas.

Natural background conditions as a reference for determination of the delta-dv change due to a source should be representative of the 20% best natural visibility days. EPA BART guidance provides the 20% best days deciview values for each Class I area on an annual basis, but does not provide species concentration data for the 20% best background conditions. These concentrations are needed for input to CALPOST.

Annual species concentrations corresponding to the 20% best days were calculated for each Class I area to be addressed, by scaling back the annual average concentrations given in Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule (Table 2-1). A separate scaling factor was derived for each Class I area such that, when multiplied by the Guidance table annual concentrations, the 20% best days deciview value for that area would be calculated. The scaled aerosol concentrations were averaged for the Bridger and Fitzpatrick WAs, and for Wind Cave and Badlands NPs, because of their geographical proximity and similar annual background visibility. The 20% best days aerosol concentrations to be used for each month for Wyoming BART evaluations are listed in Table 6.

Table 7 is a list of inputs for CALPOST. These inputs should be used for all BART visibility calculations. Output from CALPOST should be configured to provide a ranked list of the highest delta-deciview values in each Class I area. The 98th percentile delta-deciview value and the number of values exceeding 0.5 can then be determined directly from the CALPOST output.

Table 5. Monthly f(RH) Factors for Class I Areas

Month	Wind Cave NP Badlands NP	Bridger WA Fitzpatrick WA	Mt. Zirkel WA
January	2.65	2.50	2.20
February	2.65	2.30	2.20
March	2.65	2.30	2.00
April	2.55	2.10	2.10
May	2.70	2.10	2.20
June	2.60	1.80	1.80
July	2.30	1.50	1.70
August	2.30	1.50	1.80
September	2.20	1.80	2.00
October	2.25	2.00	1.90
November	2.75	2.50	2.10
December	2.65	2.40	2.10

Table 6. Natural Background Concentrations of Aerosol Components for 20% Best Days for BART Analyses ($\mu\text{g}/\text{m}^3$)

Aerosol Component	Wind Cave NP Badlands NP	Fitzpatrick WA Bridger WA	Mt. Zirkel WA
Ammonium Sulfate	.047	.045	.046
Ammonium Nitrate	.040	.038	.038
Organic Carbon	.186	.178	.179
Elemental Carbon	.008	.008	.008
Soil	.198	.189	.190
Coarse Mass	1.191	1.136	1.141

Table 7. CALPOST Control File Inputs

Variable	Description	Value
	Input Group 1	
ASPEC	Species to Process	VISIB
ILAYER	Layer/deposition code	1
A,B	Scaling factors	0,0
LBACK	Add background concentrations?	F
BTZONE	Base time zone	7
LVSO4	Species to be included in extinction	T
LVNO3		T
LVOC		F
LVPMC		T
LVPMF		T
LVEC		F
LVBK	Include background?	T
SPECPMC	Species name for particulates	PM10
SPECPMF		PM25
EEPMC	Extinction efficiencies	0.6
EEPMF		1.0
EEPMCCK		0.6
EESO4		3.0
EENO3		3.0
EEOC		4.0
EESOIL		1.0
EEEC		10.0
MVISBK	Visibility calculation method	6
RHFAC	Monthly RH adjustment factors	Table 5
BKSO4	Background concentrations	Table 6
BKNO3		Table 6
BKPMC		Table 6
BK OC		Table 6
BKSOIL		Table 6
BKEC		Table 6
BEXTRAY	Extinction due to Rayleigh scattering	10.0

7.0 REPORTING

A report on the BART visibility analysis should be submitted that clearly compares impacts for post-control emissions to those for baseline emissions. Data for baseline and BART scenarios should include both the 98th percentile values and the number of days with delta-deciview values exceeding 0.5. Results should be given for each model year.

Table 8 is an example of a recommended format for presentation of model input and model results. The example is for baseline conditions; similar tables should be provided for each control scenario (SO₂, NO_x, and PM10) and for the combination of all BART controls. Your report tables need not follow the exact format shown in Table 8; but the same information should be provided in a concise and clear form. If additional scenarios were modeled or you wish to present supplemental information, they should be provided in an appendix or separate from the specified final results.

Table 8. Example Format for Presentation of Model Input and Results

Baseline Conditions Model Input Data												
Source (Unit) Description And ID	SO ₂ Emission Rate (lb/day)	NO _x Emission Rate (lb/day)	PM _{2.5} Emission Rate (lb/day)	PM _{10-2.5} Emission Rate (lb/day)	SO ₄ Emission Rate (lb/day)	NH ₃ Emission Rate (lb/day)	Location Easting (m)	Location Northing (m)	Stack Height (m)	Stack Diameter (m)	Exit Velocity (m/s)	Exit Gas Temp (deg K)
							UTM (m)	UTM (m)				

Baseline Visibility Modeling Results

Name of Facility	Class I Area	2001		2002		2003	
		98 th Percentile Value (dv)	No. of days exceeding 0.5 dv	98 th Percentile Value (dv)	No. of days exceeding 0.5 dv	98 th Percentile Value (dv)	No. of days exceeding 0.5 dv

Final Report

BART Analysis for Jim Bridger Unit 4



Prepared For:

PacifiCorp

1407 West North Temple
Salt Lake City, Utah 84116

October 2007

Prepared By:

CH2MHILL

215 South State Street, Suite 1000
Salt Lake City, Utah 84111

Final Report

BART Analysis for Jim Bridger Unit 4

Submitted to
PacifiCorp

October 2007

CH2MHILL

Executive Summary

Background

In response to the Regional Haze Rule and Best Available Retrofit Technology (BART) regulations and guidelines, CH2M HILL was requested to perform a BART analysis for PacifiCorp's Jim Bridger Unit 4 (hereafter referred to as Jim Bridger 4). A BART analysis has been conducted for the following criteria pollutants: nitrogen oxides (NO_x), sulfur dioxide (SO₂), and particulate matter less than 10 micrometers in aerodynamic diameter (PM₁₀). The Jim Bridger Station consists of four 530-megawatt (MW) units with a total generating capacity of 2,120 MW. Because the total generating capacity of the Jim Bridger Station exceeds 750 MW, presumptive BART emission limits apply to Jim Bridger 4, based on the United States Environmental Protection Agency's (EPA) guidelines. BART emissions limits must be achieved within 5 years after the State Implementation Plan (SIP) is approved by the EPA. A compliance date of 2014 was assumed for this analysis.

In completing the BART analysis, technology alternatives were investigated and potential reductions in NO_x, SO₂, and PM₁₀ emissions rates were identified. The following technology alternatives were investigated, listed below by pollutant:

- NO_x emission controls:
 - Low-NO_x burners (LNBS) with over-fire air (OFA)
 - LNBS with rotating opposed fire air (ROFA)
 - LNBS with selective non-catalytic reduction (SNCR) system
 - LNBS with selective catalytic reduction (SCR) system
- SO₂ emission controls:
 - Dry flue gas desulfurization (FGD) system with existing electrostatic precipitator (ESP)
 - Dry FGD system with new polishing fabric filter
 - Wet FGD system and new stack with existing ESP
- PM₁₀ emission controls:
 - Sulfur trioxide (SO₃) injection flue gas conditioning system on existing ESP
 - Polishing fabric filter

BART Engineering Analysis

The specific steps in a BART engineering analysis are identified in the Code of Federal Regulations (CFR) at 40 CFR 51, Appendix Y, Section IV. The evaluation must include:

- The identification of available, technically feasible, retrofit control options
- Consideration of any pollution control equipment in use at the source (which affects the availability of options and their impacts)
- The costs of compliance with the control options
- The remaining useful life of the facility
- The energy and non-air quality environmental impacts of compliance
- The degree of visibility improvement that may reasonably be anticipated from the use of BART

The following steps are incorporated into the BART analysis:

- Step 1 – Identify All Available Retrofit Control Technologies
- Step 2 – Eliminate Technically Infeasible Options
 - The identification of available, technically feasible, retrofit control options
 - Consideration of any pollution control equipment in use at the source (which affects the applicability of options and their impacts)
- Step 3 – Evaluate Control Effectiveness of Remaining Control Technologies
- Step 4 – Evaluate Impacts and Document the Results.
 - The costs of compliance with the control options
 - The remaining useful life of the facility
 - The energy and non-air quality environmental impacts of compliance
- Step 5 – Evaluate Visibility Impacts
 - The degree of visibility improvement that may reasonably be anticipated from the use of BART

Separate analyses have been conducted for NO_x, SO₂, and PM₁₀ emissions. All costs included in the BART analyses are in 2006 dollars, and costs have not been escalated to the assumed 2014 BART implementation date.

Coal Characteristics

The main source of coal burned at Jim Bridger 4 will be the Bridger Underground Mine. Secondary sources are the Bridger Surface Mine, the Bridger Highwall Mine, the Black Butte Mine, and the Leucite Hills Mine. These coals are ranked as sub-bituminous, but are closer in

characteristics to bituminous coal in many of the parameters influencing NO_x formation. These coals have higher nitrogen content than coals from the Powder River Basin (PRB), which represent the bulk of sub-bituminous coal use in the U.S. This BART analysis has considered the higher nitrogen content and different combustion characteristics of PRB coals as compared to those coals used at Jim Bridger 4, and has evaluated the effect of these qualities on NO_x formation and achievable emission rates.

Recommendations

CH2M HILL recommends installing the following control devices, which include LNBS with OFA, upgrading the existing FGD system, and operating the existing electrostatic precipitator with an SO₃ flue gas conditioning system. This combination of control devices is identified as Scenario 1 throughout this report.

NO_x Emission Control

The BART presumptive NO_x limit assigned by the EPA for tangentially fired boilers burning sub-bituminous coal is 0.15 pound (lb) per million British thermal units (MMBtu). However, as documented in this analysis, the characteristics of the Jim Bridger coals are more closely aligned with bituminous coals, and have been assigned a presumptive BART NO_x limit of 0.28 lb per MMBtu.

CH2M HILL recommends LNBS with OFA as BART for Jim Bridger 4, based on the projected significant reduction in NO_x emissions, reasonable control costs, and the advantages of no additional power requirements or non-air quality environmental impacts. NO_x reductions are expected to be similar to those realized at Jim Bridger 2. CH2M HILL recommends that the unit be permitted at a rate of 0.26 lb per MMBtu.

SO₂ Emission Control

CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 4, based on the significant reduction in SO₂ emissions, reasonable control costs, and the advantages of minimal additional power requirements and minimal non-air quality environmental impacts. This upgrade approach will meet the BART presumptive SO₂ limit of 0.15 lb per MMBtu.

PM₁₀ Emission Control

CH2M HILL recommends finalizing the permitting of the flue gas conditioning (FGC) system to enhance the performance of the existing ESP as BART for Jim Bridger 4, based on the significant reduction in PM₁₀ emissions, reasonable control costs, and the advantages of minimal additional power requirements and no non-air quality environmental impacts.

BART Modeling Analysis

CH2M HILL used the CALPUFF modeling system to assess the visibility impacts of emissions from Jim Bridger 4 at Class I areas. The Class I areas potentially affected are located more than 50 kilometers, but less than 300 kilometers, from the Jim Bridger Plant.

The Class I areas include the following wilderness areas:

- Bridger Wilderness Area
- Fitzpatrick Wilderness Area
- Mt. Zirkel Wilderness Area

Because Jim Bridger 4 will simultaneously control NO_x, SO₂, and PM₁₀ emissions, four post-control atmospheric dispersion modeling scenarios were developed to cover the range of effectiveness for combining the individual NO_x, SO₂, and PM₁₀ control technologies under evaluation. These modeling scenarios, and the controls assumed, are as follows:

- **Scenario 1:** New LNB with OFA modifications, upgraded wet FGD system, and FGC for enhanced ESP performance. As indicated previously, this scenario represents CH2M HILL's preliminary BART recommendation.
- **Scenario 2:** New LNB with OFA modifications, upgraded wet FGD system, and new polishing fabric filter.
- **Scenario 3:** New LNB with OFA modifications and SCR, upgraded wet FGD system, and FGC for enhanced ESP performance.
- **Scenario 4:** New LNB with OFA modifications and SCR, upgraded wet FGD system, and new polishing fabric filter.

Visibility improvements for all emission control scenarios were analyzed, and the results were compared using a least-cost envelope, as outlined in the New Source Review Workshop Manual.¹

Least-cost Envelope Analysis

The EPA has adopted the least-cost envelope analysis methodology as an accepted methodology for selecting the most reasonable, cost-effective controls. Incremental cost-effectiveness comparisons focus on annualized cost and emission reduction differences between dominant alternatives. The dominant set of control alternatives is determined by generating the envelope of least-cost alternatives. This is a graphical plot of total annualized costs for a total emissions reductions for all control alternatives identified in the BART analysis.

To evaluate the impacts of the modeled control scenarios on the three Class I areas, the total annualized cost, cost per deciview (dV) reduction, and cost per reduction in number of days above 0.5 dV were analyzed. This report provides a comparison of the average incremental costs between relevant scenarios for the three Class I areas; the total annualized cost versus number of days above 0.5 dV, and the total annualized cost versus 98th percentile delta-deciview (Δ dV) reduction.

Results of the least-cost envelope analysis validate the selection of Scenario 1, based on incremental cost and visibility improvements. Scenario 2 (LNB with OFA, upgraded wet FGD, and polishing fabric filter) is eliminated, because it is to the left of the curve formed by

¹ EPA, 1990. *New Source Review Workshop Manual*. Draft. Environmental Protection Agency. October, 1990.

the dominant control alternative scenario, which indicates a scenario with lower improvement and/or higher costs. Scenario 3 (LNB with OFA and SCR, upgraded wet FGD, and FGC for enhanced ESP performance) is not selected due to very high incremental costs, on the basis of both a cost per day of improvement and cost per dV reduction. While Scenario 4 (LNB with OFA and SCR, upgraded wet FGD, and polishing fabric filter) provides some potential visibility advantage over Scenario 1, the projected improvement is less than 0.5 dV, and the projected costs are excessive. Therefore, Scenario 1 represents BART for Jim Bridger 4.

Just-Noticeable Differences in Atmospheric Haze

Studies have been conducted that demonstrate only dV differences of approximately 1.5 to 2.0 dV or more are perceptible by the human eye. Deciview changes of less than 1.5 cannot be distinguished by the average person. Therefore, the modeling analysis results indicate that only minimal, if any, observable visibility improvements at the Class I areas studied would be expected under any of the control scenarios. Thus, the results indicate that only minimal discernable visibility improvements may result, even though PacifiCorp will be spending many millions of dollars at this single unit, and over a billion dollars when considering its entire fleet of coal-fired power plants:

Contents

1.0	Introduction.....	1-1
2.0	Present Unit Operation.....	2-1
3.0	BART Engineering Analysis.....	3-1
3.1	Applicability.....	3-1
3.2	BART Process.....	3-1
3.2.1	BART NO _x Analysis.....	3-2
3.2.2	BART SO ₂ Analysis.....	3-14
3.2.3	BART PM ₁₀ Analysis.....	3-16
4.0	BART Modeling Analysis.....	4-1
4.1	Model Selection.....	4-1
4.2	CALMET Methodology.....	4-1
4.2.1	Dimensions of the Modeling Domain.....	4-1
4.2.2	CALMET Input Data.....	4-3
4.2.3	Validation of CALMET Wind Field.....	4-6
4.3	CALPUFF Modeling Approach.....	4-6
4.3.1	Background Ozone and Ammonia.....	4-6
4.3.2	Stack Parameters.....	4-6
4.3.3	Emission Rates.....	4-7
4.3.4	Post-control Scenarios.....	4-7
4.3.5	Modeling Process.....	4-8
4.3.6	Receptor Grids.....	4-8
4.4	CALPOST.....	4-10
4.5	Presentation of Modeling Results.....	4-11
4.5.1	Visibility Changes for Baseline vs. Preferred Scenario.....	4-11
5.0	Preliminary Assessment and Recommendations.....	5-1
5.1	Least-cost Envelope Analysis.....	5-1
5.1.1	Analysis Methodology.....	5-1
5.1.2	Analysis Results.....	5-9
5.2	Recommendations.....	5-9
5.2.1	NO _x Emission Control.....	5-9
5.2.2	SO ₂ Emission Control.....	5-9
5.2.3	PM ₁₀ Emission Control.....	5-9
5.3	Just-Noticeable Differences in Atmospheric Haze.....	5-10
6.0	References.....	6-1

Tables

- 2-1 Unit Operation and Study Assumptions
- 2-2 Coal Sources and Characteristics
- 3-1 Coal Characteristics Comparison
- 3-2 NO_x Control Technology Projected Emission Rates
- 3-3 NO_x Control Cost Comparison
- 3-4 SO₂ Control Technology Emission Rates
- 3-5 Sulfur Dioxide Control Cost Comparison (Incremental to Existing Flue Gas Desulfurization System)
- 3-6 PM₁₀ Control Technology Emission Rates
- 3-7 PM₁₀ Control Cost Comparison (Incremental to Existing ESP)
- 4-1 User-specified CALMET Options
- 4-2 BART Model Input Data
- 4-3 Average Natural Levels of Aerosol Components
- 4-4 Costs and Visibility Modeling Results for Baseline Vs. Post-Control Scenarios at Class I Areas
- 5-1 Control Scenario Results for the Bridger Class I Wilderness Area
- 5-2 Control Scenario Results for the Fitzpatrick Class I Wilderness Area
- 5-3 Control Scenario Results for the Mt. Zirkel Class I Wilderness Area
- 5-4 Bridger Class I Wilderness Area Incremental Analysis Data
- 5-5 Fitzpatrick Class I Wilderness Area Incremental Analysis Data
- 5-6 Mt. Zirkel Class I Wilderness Area Incremental Analysis Data

Figures

- 3-1 Illustration of the Effect of Agglomeration on the Speed of Coal Combustion**
- 3-2 Plot of Typical Nitrogen Content of Various Coals and Applicable Presumptive BART NO_x Limits**
- 3-3 Plot of Typical Oxygen Content of Various Coals and Applicable Presumptive BART NO_x Limits**
- 3-4 First Year Control Cost for NO_x Air Pollution Control Options**
- 3-5 First Year Control Cost for PM Air Pollution Control Options**
- 4-1 Jim Bridger Source-specific Class I Areas to be Addressed**
- 4-2 Surface and Upper Air Stations Used in the Jim Bridger BART Analysis**
- 5-1 Least-cost Envelope Bridger Class I WA Days Reduction**
- 5-2 Least-cost Envelope Bridger Class I WA 98th Percentile Reduction**
- 5-3 Least-cost Envelope Fitzpatrick Class I WA Days Reduction**
- 5-4 Least-cost Envelope Fitzpatrick Class I WA 98th Percentile Reduction**
- 5-5 Least-cost Envelope Mt. Zirkel Class I WA Days Reduction**
- 5-6 Least-cost Envelope Mt. Zirkel Class I WA 98th Percentile Reduction**

Appendices

- A Economic Analysis
- B 2006 Wyoming BART Protocol

Acronyms and Abbreviations

BACT	Best Available Control Technology
BART	Best Available Retrofit Technology
CALDESK	Program to Display Data and Results
CALMET	Meteorological Data Preprocessing Program for CALPUFF
CALPOST	Post-Processing Program for Calculating Visibility Impacts
CALPUFF	Gaussian Puff Dispersion Model
COHPAC	Compact Hybrid Particulate Collector
°C	Degrees Celsius
°F	Degrees Fahrenheit
dV	Deciview
ΔV	Delta Deciview, Change in Deciview
DEQ	Department of Environmental Quality
ESP	Electrostatic Precipitator
EPA	United States Environmental Protection Agency
Fuel NO _x	Oxidation of Fuel Bound Oxides of Nitrogen
FGC	Flue Gas Conditioning
FGD	Flue Gas Desulfurization
f(RH)	Relative Humidity Factors
ID	Internal Diameter or Induced Draft
kW	Kilowatts
kW-Hr	Kilowatt-Hour
LAER	Lowest Achievable Emission Rate
lb	Pound(s)
LNB	Low-NO _x Burner
LOI	Loss on Ignition
MMBtu	Million British Thermal Units
MM5	Mesoscale Meteorological Model, Version 5
MW	Megawatts
N ₂	Nitrogen
NO	Nitric Oxide
NO _x	Nitrogen Oxides
NWS	National Weather Service

OFA	Over-fire Air
PM ₁₀	Particulate Matter Less than 10 Micrometers in Aerodynamic Diameter
PRB	Powder River Basin
ROFA	Rotating Opposed Fire Air
S&L	Sargent & Lundy
SCR	Selective catalytic Reduction System
SIP	State Implementation Plan
SNCR	Selective Non-Catalytic Reduction System
SO ₂	Sulfur Dioxide
SO ₃	Sulfur Trioxide
Thermal NO _x	High Temperature Fixation of Atmospheric Nitrogen in Combustion Air
USGS	U.S. Geological Survey
WA	Wilderness Area
WDEQ-AQD	Wyoming Department of Environmental Quality—Air Quality Division

1.0 Introduction

Best Available Retrofit Technology (BART) guidelines were established as a result of United States Environmental Protection Agency (EPA) regulations intended to reduce the occurrence of regional haze in national parks and other Class I protected air quality areas in the United States (40 CFR Part 51). These guidelines provide guidance for states when determining which facilities must install additional controls, and the type of controls that must be used. Facilities eligible for BART installation were built between 1962 and 1977, and have the potential to emit more than 250 tons per year of visibility-impairing pollutants.

The Wyoming Department of Environmental Quality (WDEQ) BART regulations state that each source subject to BART must submit a BART application for a construction permit by December 15, 2006. PacifiCorp received an extension from the WDEQ to submit the BART report for Jim Bridger Unit 4 (hereafter referred to as Jim Bridger 4) by January 12, 2007. The BART Report that was submitted to WDEQ in January 2007 included a BART analysis, and a proposal and justification for BART at the source. This revised report—submitted in October 2007—incorporates editorial revisions since the January 2007 version.

The State of Wyoming has identified those eligible in-state facilities that are required to reduce emissions under BART, and will set BART emissions limits for those facilities. This information will be included in the State of Wyoming State Implementation Plan (SIP), which the State has estimated will be formally submitted to the EPA by early 2008. The EPA BART guidelines also state that the BART emission limits must be fully implemented within 5 years of EPA's approval of the SIP.

Five elements related to BART address the issue of emissions for the identified facilities:

- Any existing pollution control technology in use at the source
- The cost of the controls
- The remaining useful life of the source
- The energy and non-air quality environmental impacts of compliance
- The degree of improvement in visibility that may reasonably be anticipated from the use of such technology

This report documents the BART analysis that was performed on Jim Bridger 4 by CH2M HILL for PacifiCorp. The analysis was performed for the pollutants nitrogen oxides, (NO_x), sulfur dioxide (SO₂), and particulate matter less than 10 micrometers in aerodynamic diameter (PM₁₀), because they are the primary criteria pollutants that affect visibility.

Section 2 of this report provides a description of the present unit operation, including a discussion of coal sources and characteristics. The BART Engineering Analysis is provided in Section 3. Section 4 provides the methodology and results of the BART Modeling Analysis, followed by recommendations in Section 5 and references in Section 6. Appendices provide more detail on the economic analysis and the 2006 Wyoming BART Protocol.

2.0 Present Unit Operation

The Jim Bridger Station consists of four units with a total generating capacity of 2,120 megawatts (MW). Jim Bridger 4 is a nominal 530 net-MW unit located approximately 35 miles northeast of Rock Springs, Wyoming. Unit 4 is equipped with a tangentially-fired pulverized coal boiler with low NO_x burners (LNBs) manufactured by Combustion Engineering. The unit was constructed with a Flakt wire frame electrostatic precipitator (ESP). The unit contains a Babcock & Wilcox wet sodium flue gas desulfurization (FGD) system with three absorber towers installed in 1982. An Emerson Ovation distributed control system was installed in 2004.

Jim Bridger 4 was placed in service in 1979. Its current economic depreciation life is through 2040; however, this analysis is based on a 20-year life for BART control technologies. Assuming a BART implementation date of 2014, this will result in an approximate remaining useful life for Jim Bridger 4 of 20 years from the installation date of any new or modified BART-related equipment. This report does not attempt to quantify any additional life extension costs needed to allow the unit and these control devices at Jim Bridger 4 to operate until 2040.

Table 2-1 lists additional unit information and study assumptions for this analysis.

The BART-presumptive NO_x limit for tangential-fired boilers burning sub-bituminous coal is 0.15 lb per MMBtu and the BART-presumptive NO_x limit for burning bituminous coal is 0.28 lb per MMBtu. The main sources of coal burned at Jim Bridger 4 are the Bridger Mine and secondarily the Black Butte Mine and Leucite Hills Mine. These coals are ranked as sub-bituminous, but are closer in characteristics to bituminous coal in many of the parameters influencing NO_x formation. These coals have higher nitrogen content than coals from the Powder River Basin (PRB), which represent the bulk of sub-bituminous coal use in the U.S. This BART analysis has considered the higher nitrogen content and different combustion characteristics of PRB coals as compared to those coals used at Jim Bridger 4, and has evaluated the effect of these qualities on NO_x formation and achievable emission rates. Coal sources and characteristics are summarized in Table 2-2. The primary source of coal will be the Bridger Underground Mine, and data on coal from this source were used in the modeling analysis. For the coal analysis that is presented in Section 3.2.1, the data from all the coal sources were used.

TABLE 2-1
Unit Operation and Study Assumptions
Jim Bridger 4

General Plant Data	
Site Elevation (feet above mean sea level)	6669
Stack Height (feet)	500
Stack Exit Inside Diameter (feet) and Exit Area (square feet)	31 /755
Stack Exit Temperature (degrees Fahrenheit)	120
Stack Exit Velocity (feet per second)	42.4
Stack Flow (actual cubic feet per minute)	1,920,610
Latitude deg: min : sec	41:44:20.82 north
Longitude deg: min : sec	108:47:15.17 west
Annual Unit Capacity Factor (percentage)	90
Net Unit Output (megawatts)	530
Net Unit Heat Rate (British thermal units [Btu] per kilowatt-hour)(100% load)	10,400 (as measured by fuel throughout)
Boiler Heat Input (million Btu [MMBtu] per hour)(100% load)	6,000 (as measured by CEM)
Type of Boiler	Tangentially fired
Boiler Fuel	Coal
Coal Sources	Bridger Mine, Black Butte Mine, Leucite Hills Mine
Coal Heating Value (Btu per pound)*	9,660
Coal Sulfur Content (wt. %) ^(a)	0.58
Coal Ash Content (wt. %) ^(a)	10.3
Coal Moisture Content (wt. %) ^(a)	19.3
Coal Nitrogen Content (wt. %) ^(a)	0.98
Current NO _x Controls	Low-NO _x burners
NO _x Emission Rate (pound per MMBtu)	0.45
Current Sulfur Dioxide Controls	Sodium based wet scrubber
Sulfur Dioxide Emission Rate (pound per MMBtu)	0.167
Current PM ₁₀ Controls ^(b)	Electrostatic Precipitator
PM ₁₀ Emission Rate (pound per MMBtu) ^(c)	0.030

NOTES:

^(a)Coal characteristics based on Bridger Underground Mine (primary coal source)

^(b)PM₁₀ refers to particulate matter less than 10 micrometers in aerodynamic diameter

^(c)Based on maximum historic emission rate from 1999 – 2001, prior to installation of the SO₃ injection system.

TABLE 2-2
Coal Sources and Characteristics
Jim Bridger 4

Mines	Ultimate Analysis (% dry basis)												
	Moisture (%)	Ash (%)	Volatile Matter (%)	Fixed Carbon (%)	British thermal units per pound (Btu/lb)	Sulfur (%)	Moisture and Ash Free (Btu/lb)	Hydrogen	Carbon	Sulfur	Nitrogen	Oxygen	Ash
Bridger Mine Underground	19.3	10.3	32.2	38.3	9660	0.58	13712	4.66	69.2	0.72	1.22	11.8	12.4
Maximum	Not enough data yet to run statistical analysis for variability												
Minimum	Not enough data yet to run statistical analysis for variability												
Bridger Mine Surface	19.1	10.6	32.3	38.0	9390	0.57	13340	4.38	37.4	0.71	1.26	13.2	13.0
Maximum	20.5	12.5	35.5	41.9	9800	0.72	13500	4.69	4.0	0.90	1.43	14.8	15.8
Minimum	17.5	9.0	31.0	36.0	9000	0.49	13100	4.00	64.3	0.60	1.14	11.7	11.2
Bridger Mine Highwall	18.0	9.5	33.0	39.5	9700	0.58	13500	No samples of separate highwall coal					
Maximum	Not enough data yet to run statistical analysis for variability												
Minimum	Not enough data yet to run statistical analysis for variability												
Black Butte Mine	20.0	9.2	33.3	35.6	9450	0.45	13330	4.43	68.7	0.56	1.47	13.4	11.5
Maximum	21.1	10.8	35.4	41.9	10275	0.62	13500	4.66	70.5	0.78	1.69	14.8	13.6
Minimum	18.0	7.6	29.9	36.8	9180	0.33	13140	4.21	66.1	0.41	1.25	11.6	9.7
Leucite Hills Mine (through 2009)	19.4	11.5	30.7	38.3	9080	0.64	13140	4.20	66.0	0.81	1.48	13.2	14.4
Maximum	23.0	15.0	33.0	43.0	10250	0.90	13800	4.70	70.0	1.20	1.64	17.1	19.0
Minimum	17.0	8.0	28.3	33.6	8000	0.40	12300	3.70	61.0	0.50	1.32	10.5	10.0

3.0 BART Engineering Analysis

This section presents the required BART engineering analysis.

3.1 Applicability

In compliance with regional haze requirements, the State of Wyoming must prepare and submit visibility SIPs to the EPA for Class I areas. The State has estimated that the formal submittal of the SIPs will occur by early 2008. The first phase of the regional haze program is the implementation of BART emission controls on all BART eligible units, within 5 years after EPA approval of the SIP.

3.2 BART Process

The specific steps in a BART engineering analysis are identified in the Code of Federal Regulations (CFR) at 40 CFR 51, Appendix Y, Section IV. The evaluation must include:

- The identification of available, technically feasible, retrofit control options
- Consideration of any pollution control equipment in use at the source (which affects the availability of options and their impacts)
- The costs of compliance with the control options
- The remaining useful life of the facility
- The energy and non-air quality environmental impacts of compliance
- The degree of visibility improvement that may reasonably be anticipated from the use of BART

The following steps are incorporated into the BART analysis:

- Step 1 – Identify All Available Retrofit Control Technologies
- Step 2 – Eliminate Technically Infeasible Options
 - The identification of available, technically feasible, retrofit control options
 - Consideration of any pollution control equipment in use at the source (which affects the applicability of options and their impacts)
- Step 3 – Evaluate Control Effectiveness of Remaining Control Technologies
- Step 4 – Evaluate Impacts and Document the Results
 - The costs of compliance with the control options
 - The remaining useful life of the facility
 - The energy and non-air quality environmental impacts of compliance

- Step 5 – Evaluate Visibility Impacts
 - The degree of visibility improvement that may reasonably be anticipated from the use of BART

To minimize costs in the BART analysis, consideration was made of any pollution control equipment in use at the source, the costs of compliance associated with the control options, and the energy and non-air quality environmental impacts of compliance using these existing control devices. In some cases, enhancing the performance of the existing control equipment was considered. Other scenarios with new control equipment were also developed.

Separate analyses have been conducted for NO_x, SO₂, and PM₁₀ emissions. All costs included in the BART analysis are in 2006 dollars, and costs have not been escalated to the assumed 2014 BART implementation date.

3.2.1 BART NO_x Analysis

Nitrogen oxide formation in coal-fired boilers is a complex process that is dependent on a number of variables, including operating conditions, equipment design, and coal characteristics.

Formation of NO_x

During coal combustion, NO_x is formed in three different ways. The dominant source of NO_x formation is the oxidation of fuel-bound nitrogen. During combustion, part of the fuel-bound nitrogen is released from the coal with the volatile matter, and part is retained in the solid portion (char). The nitrogen chemically bound in the coal is partially oxidized to nitrogen oxides (nitric oxide and nitrogen dioxide) and partially reduced to molecular nitrogen. A smaller part of NO_x formation is due to high temperature fixation of atmospheric nitrogen in the combustion air. A very small amount of NO_x is called prompt NO_x. Prompt NO_x results from an interaction of hydrocarbon radicals, nitrogen, and oxygen.

In a conventional pulverized coal burner, air is introduced with turbulence to promote good mixing of fuel and air, which provides stable combustion. However, not all of the oxygen in the air is used for combustion. Some of the oxygen combines with the fuel nitrogen to form NO_x.

Coal characteristics directly and significantly affect NO_x emissions from coal combustion. Coal ranking is a means of classifying coals according to their degree of metamorphism in the natural series, from lignite to sub-bituminous to bituminous and on to anthracite. Lower rank coals, such as the sub-bituminous coals from the PRB, produce lower NO_x emissions than higher rank bituminous coals, due to their higher reactivity and lower nitrogen content. The fixed carbon to volatile matter ratio (fuel ratio), coal oxygen content, and rank are good relative indices of the reactivity of a coal. Lower rank coals release more organically bound nitrogen earlier in the combustion process than do higher rank bituminous coals. When used with LNBs, sub-bituminous coals create a longer time for the kinetics to promote more stable molecular nitrogen, and therefore result in lower NO_x emissions.

Coals from the PRB are classified as sub-bituminous C and demonstrate the high reactivity and low NO_x production characteristics described above. Based on data from the Energy Information Administration, PRB coals currently represent 88 percent of total U.S. sub-bituminous production and 73 percent of western coal production (Energy Information Administration, 2006). Most references to western coal and sub-bituminous coal infer PRB

origin and characteristics. Emissions standards differentiating between bituminous and sub-bituminous coals are presumed to use PRB coal as the basis for the sub-bituminous standards, due to its dominant market presence and unique characteristics.

There are a number of western coals that are classified as sub-bituminous, however, they border on being ranked as bituminous and do not display many of the qualities of PRB coals, including most of the low NO_x forming characteristics. Coals from the Bridger, Black Butte, and Leucite Hills mines fall into this category.

As defined by the American Society for Testing and Materials, the only distinguishing characteristic that classifies the coals used at Jim Bridger 4 as sub-bituminous rather than bituminous—that is, they are “agglomerating” as compared to “non-agglomerating”. Agglomerating as applied to coal is “the property of softening when it is heated to above about 400 degrees Celsius ($^{\circ}\text{C}$) in a non-oxidizing atmosphere, and then appearing as a coherent mass after cooling to room temperature.” Because the agglomerating property of coals is the result of particles transforming into a plastic or semi-liquid state when heated, it reflects a change in surface area of the particle. Thus, with the application of heat, agglomerating coals would tend to develop a non-porous surface, while the surface of non-agglomerating coals would become even more porous with combustion. As shown by Figure 3-1, the increased porosity provides more particle surface area, resulting in more favorable combustion conditions. This non-agglomerating property assists in making sub-bituminous coals more amenable to controlling NO_x , by allowing less air to be introduced during the initial ignition portion of the combustion process. The coals from the Bridger, Black Butte, and Leucite Hills mines just barely fall into the category of non-agglomerating coals. While each of these coals is considered non-agglomerating, they either do not exhibit the properties of non-agglomerating coals or exhibit them to only a minor degree. The conditions during combustion of typical non-agglomerating coals that make it easier to control NO_x emissions do not exist for the Bridger blends of coals.

FIGURE 3-1
Illustration of the Effect of Agglomeration on the Speed of Coal Combustion
Jim Bridger 4




Table 3-1 shows key characteristics of a typical PRB coal compared to coals from the Bridger Mine, Black Butte, and Leucite Hills, as well as Twentymile, which is a representative western bituminous coal.

TABLE 3-1
Coal Characteristics Comparison
Jim Bridger 4

Parameter	Typical PRB	Bridger Mine	Black Butte	Leucite Hills	Twentymile
Nitrogen (% dry)	1.10	1.26	1.47	1.48	1.85
Oxygen (% dry)	16.2	13.2	13.4	13.2	7.19
Coal rank	Sub C	Sub B	Sub B	Sub B	Bitum. high volatility B

As shown in Table 3-1, although Bridger, Black Butte, and Leucite Hills are classified as sub-bituminous, they all exhibit higher nitrogen content and lower oxygen content than the PRB coal. The higher nitrogen content is an indication that more nitrogen is available to the combustion process and higher NO_x emissions are likely. Oxygen content can be correlated to the reactivity of the coal, with more reactive coals generally containing higher levels of oxygen. More reactive coals tend to produce lower NO_x emissions, and they are also more conducive to reduction of NO_x emissions through the use of combustion control measures, such as LNBS and over-fire air (OFA). These characteristics indicate that higher NO_x formation is likely with coal from the Bridger, Black Butte, and Leucite Hills mines, rather than with PRB coal. The Bridger, Black Butte, and Leucite Hills coals all contain quality characteristics that fall between a typical PRB coal and Twentymile. Twentymile is a clearly bituminous coal that produces higher NO_x, as has been demonstrated at power plants burning this fuel.

Figures 3-2 and 3-3 graphically illustrate the relationship of nitrogen and oxygen content to the BART-presumptive NO_x limits for the coals listed in Table 3-1. Each chart identifies the presumptive BART limit associated with a typical bituminous and sub-bituminous coal, and demonstrates how the Jim Bridger coal falls between these two general coal classifications.

The Bridger blend data point represents a combination of coals from the Bridger Mine, Black Butte, and Leucite Hills that has been used at Jim Bridger 4, and indicates the average NO_x emission rate achieved during the years 2003 through 2005. The Jim Bridger 2 data point consists of the same blend of coals as Jim Bridger 4, and represents the NO_x emission rate achieved after installation of Alstom's current state of the art TFS2000 LNB and OFA system. The long-term sustainable emission rate for this system is expected to be 0.24 lb per MMBtu. All four units at Jim Bridger consist of identical boilers; and while there may be some differences in performance among them, installation of the TFS2000 firing system at Jim Bridger 4 would likely result in performance and NO_x emission rates comparable to those at Jim Bridger 2.

Figures 3-2 and 3-3 both demonstrate that for the Jim Bridger units with the TFS2000 low-NO_x emission system installed and burning a combination of the Bridger, Black Butte, and Leucite Hill coals, the likely NO_x emission rate will be closer to the bituminous end (0.28) of the BART-presumptive NO_x limit range, rather than the BART-presumptive NO_x limit of 0.15 lb

per MMBtu for sub-bituminous coal. All these factors are consistent with the observed sustainable rate of 0.24 lb per MMBtu.

FIGURE 3-2
Plot of Typical Nitrogen Content of Various Coals and Applicable Presumptive BART NO_x Limits
Jim Bridger 4





FIGURE 3-3
Plot of Typical Oxygen Content of Various Coals and Applicable Presumptive BART NO_x Limits
Jim Bridger 4



Coal quality characteristics also impact the design and operation of the boiler and associated auxiliary equipment. Minor changes in quality can sometimes be accommodated through operational adjustments or changes to equipment. It is important to note, however, that consistent variations in quality or assumptions of "average" quality for performance projections can be problematic. This is particularly troublesome when dealing with performance issues that are very sensitive to both coal quality and combustion conditions, such as NO_x formation. There is significant variability in the quality of coals burned at Jim Bridger 4. In addition to burning coal from Black Butte and Leucite Hills, Jim Bridger 4 burns coal supplied from the Bridger Mine consisting of three sources: underground, surface, and highwall operations. Each of these coal sources has different quality characteristics, as well as inherent variability in composition of the coal within the mine.

Several of the coal quality characteristics and their effect on NO_x formation have been previously discussed. There are some additional considerations that illustrate the complexity of achieving and maintaining consistent low NO_x emissions with pulverized coal on a shorter term, such as a 30-day rolling average basis.

Good combustion is based on the "three Ts": time, temperature, and turbulence. These parameters, along with a "design" coal, are taken into consideration when designing a boiler and associated firing equipment such as fans, burners, and pulverizers. If a performance requirement such as NO_x emission limits is subsequently changed, conflicts with and between other performance issues can result.

Jim Bridger 4 is located at an altitude of 6,669 feet above sea level. At this elevation, atmospheric pressure is lower (11.5 lbs per square inch) as compared with sea level pressure of 14.7 lbs per square inch. This lower pressure means that less oxygen is available for combustion for each volume of air. In order to provide adequate oxygen to meet the requirements for efficient combustion, larger volumes of air are required. When adjusting air flows and distribution to reduce NO_x emissions, using LNBs and OFA, original boiler design restrictions again limit the modifications that can be made and still achieve satisfactory combustion performance.

Another significant factor in controlling NO_x emissions is the fineness of the coal entering the burners. Fineness is influenced by the grindability index (Hardgrove) of the coal. Finer coal particles promote release of volatiles and assist char burnout as a result of more surface area exposed to air. NO_x reduction with high volatile coals is improved with greater fineness and with proper air staging. The lower rank sub-bituminous coals such as PRB coals are quite friable and easy to grind. Coals with lower Hardgrove Grindability Index values, such as those used at Jim Bridger 4, are more difficult to grind and can contribute to higher NO_x levels. In addition, coal fineness can deteriorate over time periods between pulverizer maintenance and service as pulverizer grinding surfaces wear.

In summary, when all the factors of agglomeration versus non-agglomeration, nitrogen and oxygen content of the coals, and the grindability index are taken into account, this analysis demonstrates that, for the coal used at Jim Bridger 4, the more applicable presumptive BART limit for NO_x emissions is 0.28 lb per MMBtu. The BART analysis for NO_x emissions from Jim Bridger 4 is further described below.

Step 1: Identify All Available Retrofit Control Technologies

The first step of the BART process is to evaluate NO_x control technologies with practical potential for application to Jim Bridger 4, including those control technologies identified as Best Available Control Technology (BACT) or lowest achievable emission rate (LAER) by permitting agencies across the United States. Broad-ranging information sources were reviewed in an effort to identify potentially applicable emission control technologies. NO_x emissions at Jim Bridger 4 are currently controlled through good combustion practices and OFA.

The following potential NO_x control technology options were considered:

- New/modified LNBS with advanced OFA
- Rotating opposed fire air (ROFA)
- LNB with OFA and conventional selective non-catalytic reduction (SNCR) system
- LNB with OFA and selective catalytic reduction (SCR) system

Step 2: Eliminate Technically Infeasible Options

For Jim Bridger 4, a tangential-fired configuration burning sub-bituminous coal, technical feasibility will primarily be determined by physical constraints, boiler configuration, and the ability to achieve the regulatory presumptive limit of 0.28 lb per MMBtu. Jim Bridger 4 has an uncontrolled NO_x emission rate of 0.45 lb per MMBtu.

For this BART analysis, information pertaining to LNBS, OFA, SNCR, and SCR were based on the *Multi-Pollutant Control Report* (Sargent and Lundy, 2002, hereafter referred to as the S&L Study). Updated cost estimates for SCR and SNCR were used (Sargent & Lundy, 2006). PacifiCorp provided additional emissions data and costs developed by boiler vendors for LNBS and OFA. Also, CH2M HILL solicited a proposal from Mobotec for their ROFA technology.

With SNCR, an amine-based reagent such as ammonia, or more commonly urea, is injected into the furnace within a temperature range of 1,600 degrees Fahrenheit (°F) to 2,100°F, where it reduces NO_x to nitrogen and water. NO_x reductions of up to 40 to 60 percent have been achieved, although 15 to 30 percent is more realistic for most applications. SNCR is typically applied on smaller units. Adequate reagent distribution in the furnaces of large units can be problematic.

Table 3-2 summarizes the control technology options evaluated in this BART analysis, along with projected NO_x emission rates. All technologies can meet the applicable presumptive BART limit of 0.28 lb per MMBTU.

TABLE 3-2
 NO_x Control Technology Projected Emission Rates
Jim Bridger 4

Technology	Projected Emission Rate (pounds per million British thermal units)
Presumptive Best Available Retrofit Technology Limit	0.28
Low NO _x Blower (LNB) with Over-Fire Air (OFA)	0.24
Rotating Opposed Fire Air	0.22
LNB with OFA and Selective Non-Catalytic Reduction System	0.20
LNB with OFA and Selective Catalytic Reduction System	0.07

Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

Preliminary vendor proposals, such as those used to support portions of this BART analysis, may be technically feasible and provide expected or guaranteed emission rates; however, the proposals include inherent uncertainties. These proposals are usually prepared in a limited timeframe, may be based on incomplete information, may contain over-optimistic conclusions, and are non-binding. Therefore, emission rate values obtained in such preliminary proposals must be qualified, and it must be recognized that contractual guarantees are established only after more detailed analysis has been completed. The following subsections describe the control technologies and the control effectiveness evaluated in this BART analysis.

New LNBS with OFA System. The mechanism used to lower NO_x with LNBS is to stage the combustion process and provide a fuel-rich condition initially; this is so oxygen needed for combustion is not diverted to combine with nitrogen and form NO_x. Fuel-rich conditions favor the conversion of fuel nitrogen to N₂ instead of NO_x. Additional air (or OFA) is then introduced downstream in a lower temperature zone to burn out the char.

Both LNBS and OFA are considered to be capital cost, combustion technology retrofits. For LNB retrofits to units configured with tangential-firing such as Jim Bridger 4, it is generally necessary to increase the burner spacing; this prevents interaction of the flames from adjacent burners and reduces burner zone heat flux. These modifications usually require boiler waterwall tube replacement.

Information provided to CH2M HILL by PacifiCorp—based on the S&L Study and data from boiler vendors—indicates that new LNB and OFA retrofit at Jim Bridger 4 would result in an expected NO_x emission rate of 0.24 lb per MMBtu. PacifiCorp has indicated that this rate corresponds to a vendor guarantee, not a vendor prediction, and they believe that this emission rate can be sustained as an average between overhauls. This emission rate represents a significant reduction from the current NO_x emission rate, and is below the more applicable presumptive NO_x emission rate of 0.28 lb per MMBtu.

ROFA. Mobotec markets ROFA as an improved second generation OFA system. Mobotec states that "the flue gas volume of the furnace is set in rotation by asymmetrically placed air nozzles. Rotation is reported to prevent laminar flow, so that the entire volume of the furnace can be used more effectively for the combustion process. In addition, the swirling action reduces the maximum temperature of the flames and increases heat absorption. The combustion air is also mixed more effectively." A typical ROFA installation would have a booster fan(s) to supply the high velocity air to the ROFA boxes, and Mobotec would propose two 4,000 to 4,300 horsepower fans for Jim Bridger 4.

Mobotec proposes to achieve a NO_x emission rate of 0.18 lb per MMBtu using ROFA technology. An operating margin of 0.04 lb per MMBtu was added to the expected rate due to Mobotec's limited ROFA experience with western sub-bituminous coals. Under the Mobotec proposal, which is primarily based on ROFA equipment, the operation of existing LNB and OFA ports would be analyzed. While a typical installation does not require modification to the existing LNB system and the existing OFA ports are not used, results of computational fluid dynamics modeling would determine the quantity and location of new ROFA ports. The Mobotec proposal includes bent tube assemblies for OFA port installation.

Mobotec would not provide installation services, because they believe that the Owner can more cost-effectively contract for these services. However, they would provide one onsite construction supervisor during installation and startup.

SNCR. Selective non-catalytic reduction is generally used to achieve modest NO_x reductions on smaller units. With SNCR, an amine-based reagent such as ammonia—or more commonly urea—is injected into the furnace within a temperature range of 1,600°F to 2,100°F, where it reduces NO_x to nitrogen and water. NO_x reductions of up to 60 percent have been achieved, although 20 to 40 percent is more realistic for most applications.

Reagent utilization, which is a measure of the efficiency with which the reagent reduces NO_x , can range from 20 to 60 percent, depending on the amount of reduction, unit size, operating conditions, and allowable ammonia slip. With low reagent utilization, low temperatures, or inadequate mixing, ammonia slip occurs, allowing unreacted ammonia to create problems downstream. The ammonia may render fly ash unsaleable, react with sulfur to foul heat exchange surfaces, and/or create a visible stack plume. Reagent utilization can have a significant impact on economics, with higher levels of NO_x reduction generally resulting in lower reagent utilization and higher operating cost.

Reductions from higher baseline concentrations (inlet NO_x) are lower in cost per ton, but result in higher operating costs, due to greater reagent consumption. To reduce reagent costs, S&L has assumed that combustion modifications including LNBs and advanced OFA, capable of achieving a projected NO_x emission rate of 0.24 lb per MMBtu. At a further reduction of 15 percent in NO_x emission rates for SNCR would result in a projected emission rate of 0.20 lb per MMBtu.

SCR. SCR works on the same chemical principle as SNCR, but SCR uses a catalyst to promote the chemical reaction. Ammonia is injected into the flue-gas stream, where it reduces NO_x to nitrogen and water. Unlike the high temperatures required for SNCR, in SCR the reaction takes place on the surface of a vanadium/titanium-based catalyst at a temperature range between 580°F to 750°F. As a result of the catalyst, the SCR process is more efficient than SNCR and

results in lower NO_x emissions. The most common type of SCR is the high-dust configuration, where the catalyst is located downstream from the boiler economizer and upstream of the air heater and any particulate control equipment. In this location, the SCR is exposed to the full concentration of fly ash in the flue gas that leaves the boiler. The high-dust configuration is assumed for Jim Bridger 4. In a full-scale SCR, the flue ducts are routed to a separate large reactor containing the catalyst. With in-duct SCR, the catalyst is located in the existing gas duct, which may be expanded in the area of the catalyst to reduce flue gas flow velocity and increase flue gas residence time. Due to the higher removal rate, a full-scale SCR was used as the basis for analysis at Jim Bridger 4.

S&L prepared the design conditions and cost estimates for SCR at Jim Bridger 4. As with SNCR, it is generally more cost effective to reduce NO_x emission levels as much as possible through combustion modifications, in order to minimize the catalyst surface area and ammonia requirements of the SCR. The S&L design basis for LNB with OFA and SCR results in a projected NO_x emission rate of 0.07 lb per MMBtu. Additional catalyst surface was included in the SCR design to accommodate the characteristics of the coal used at Jim Bridger 4.

Level of Confidence for Vendor Post-Control Emissions Estimates: To determine the level of NO_x emissions needed to consistently achieve compliance with an established goal, a review of typical NO_x emissions from coal-fired generating units was completed. As a result of this review, it was noted that NO_x emissions can vary significantly around an average emissions level. Variations may result for many reasons, including coal characteristics, unit load, boiler operation including excess air, boiler slagging, burner equipment condition, coal mill fineness, and so forth.

The steps used for determining a level of confidence for the vendor expected values are as follows:

1. Establish expected NO_x emissions value from vendor.
2. Evaluate vendor experience and historical basis for meeting expected values.
3. Review and evaluate unit physical and operational characteristics and restrictions. The fewer variations there are in operations, coal supply, etc., the more predictable and less variant the NO_x emissions are.
4. For each technology expected value, there is a corresponding potential for actual NO_x emissions to vary from this expected value. From the vendor information presented, along with anticipated unit operational data, an adjustment to the expected value can be made.

Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

Energy Impacts. Installation of LNBs and modification to the existing OFA systems are not expected to significantly impact the boiler efficiency or forced-draft fan power usage. Therefore, these technologies will not have energy impacts.

The Mobotec ROFA system would require installation and operation of two 4,000 to 4,300 horsepower ROFA fans (6,410 kilowatts [kW] total). The SNCR system would require approximately 530 kW of additional power.

SCR retrofit impacts the existing flue gas fan systems, due to the additional pressure drop associated with the catalyst, which is typically a 6- to 8-inch water gage increase. Total additional power requirements for SCR installation at Jim Bridger 4 are estimated at approximately 3,360 kW, based on the S&L Study.

Environmental Impacts: Mobotec has predicted that carbon monoxide (CO) emissions, and unburned carbon in the ash, commonly referred to as loss on ignition (LOI), would be the same or lower than previous levels for the ROFA system.

SNCR and SCR installation could impact the saleability and disposal of fly ash due to ammonia levels, and could potentially create a visible stack plume, which may negate other visibility improvements. Other environmental impacts involve the storage of ammonia, especially if anhydrous ammonia is used, and the transportation of the ammonia to the power plant site.

Economic Impacts. Costs and schedules for the LNBs, OFA, SNCR, and SCR were furnished to CH2M HILL by PacifiCorp, developed using S&L's internal proprietary database, and supplemented (as needed) by vendor-obtained price quotes. The relative accuracy of these cost estimates is stated by S&L to be in the range of plus or minus 20 percent. Cost for the ROFA system was obtained from Mobotec.

A comparison of the technologies on the basis of costs, design control efficiencies, and tons of NO_x removed is summarized in Table 3-3, and the first year control costs are presented in Figure 3-4. The complete economic analysis is contained in Appendix A.

Preliminary BART Selection. CH2M HILL recommends selection of LNBs with OFA as BART for Jim Bridger 4 based on its significant reduction in NO_x emissions, reasonable control cost, and no additional power requirements or environmental impacts. LNB with OFA does not meet the EPA-presumptive limit of 0.15 lb per MMBtu for sub-bituminous coal, but it does meet an emission rate that falls between the presumptive limit of 0.28 lb per MMBtu for bituminous coal and the limit of 0.15 lb per MMBtu for sub-bituminous coal. As discussed in the section on coal quality, the recommended technology and the achieved emission rate are deemed appropriate as BART for NO_x emissions from the coals combusted at Jim Bridger 4.


Step 5: Evaluate Visibility Impacts

Please see Section 4, BART Modeling Analysis.

TABLE 3-3
 NO_x Control Cost Comparison
 Jim Bridger 4

Factor	Low NO _x Blower (LNB) with Over- Fire Air (OFA)	Rotating Opposed Fire Air	LNB with OFA & Selective Non- Catalytic Reduction System	LNB with OFA Selective Catalytic Reduction System
Total Installed Capital Costs	\$8.7 million	\$20.5 million	22.1 million	\$147.6 million
Total First Year Fixed & Variable Operation and Maintenance Costs	\$0.1 million	\$2.6 million	\$1.5 million	\$3.4 million
Total First Year Annualized Cost	\$0.9 million	\$4.6 million	\$3.6 million	\$17.4 million
Power Consumption (megawatts)	0	6.4	0.5	3.4
Annual Power Usage (1000 megawatt-hours per year)	0	50.6	4.2	26.5
Nitrogen Oxides Design Control Efficiency	46.7%	51.1%	55.6%	84.4%
Nitrogen Oxides Removed per Year (Tons)	4,967	5,440	5,913	8,987
First Year Average Control Cost (\$ per Ton of Nitrogen Oxides Removed)	\$181/ton	\$843/ton	\$613/ton	\$1,936/ton
Incremental Control Cost (\$ per Ton of Nitrogen Oxides Removed)	\$181/ton	\$7,797/ton	\$2,885/ton	\$4,479/ton

FIGURE 3-4
First Year Control Cost for NO_x Air Pollution Control Options
Jim Bridger 4



3.2.2 BART SO₂ Analysis

Sulfur dioxide forms in the boiler during the combustion process, and is primarily dependent on coal sulfur content. The BART analysis for SO₂ emissions on Jim Bridger 4 is described below.

Step 1: Identify All Available Retrofit Control Technologies

A broad range of information sources were reviewed, in an effort to identify potentially applicable emission control technologies for SO₂ at Jim Bridger 4. This included control technologies identified as BACT or LAER by permitting agencies across the United States.

The following potential SO₂ control technology options were considered:

- Optimize current operation of existing wet sodium FGD system
- Upgrade wet sodium FGD system to meet SO₂ emission rate of 0.10 lb per MMBtu
- New dry FGD system

Step 2: Eliminate Technically Infeasible Options

Technical feasibility will primarily be based on the regulatory presumptive limit (used as a guideline) of 95 percent reduction in SO₂ emissions, or 0.15 lb per MMBtu. Based on the coal that Jim Bridger 4 currently burns, the unit would be required to achieve an 87.5 percent SO₂ removal efficiency to meet the presumptive limit of 0.15 lb per MMBtu.

Table 3-4 summarizes the control technology options evaluated in this BART analysis, along with projected SO₂ emission rates. Only one technology option can meet the applicable presumptive BART limit of 0.15 lb per MMBtu.

TABLE 3-4
SO₂ Control Technology Emission Rates
Jim Bridger 4

Technology	Projected Emission Rate (pounds per million British thermal units)
Presumptive Best Available Retrofit Technology Limit	0.15
Upgrade Existing Wet Sodium System	0.10
Optimize Existing Wet Sodium System	0.17
New Dry Flue Gas Desulfurization System	0.21

Wet Sodium FGD System Wet sodium FGD systems operate by treating the flue gas in large scrubber vessels with a soda ash solution. The scrubber mixes the flue gas and alkaline reagent using a series of spray nozzles to distribute the reagent across the scrubber vessel. The sodium in the reagent reacts with the SO₂ in the flue gas to form sodium sulfite and sodium bisulfite, which are removed from the scrubber and disposed.

The wet sodium FGD system at Jim Bridger 4 currently achieves approximately 86 percent SO₂ removal to achieve an SO₂ outlet emission rate of 0.17 lb per MMBtu. Upgrading the wet FGD system would achieve an SO₂ outlet emission rate of 0.10 lb per MMBtu (91.7 percent SO₂

removal) by closing the bypass damper to eliminate routine bypass flue gas flow used to reheat the treated flue gas from the scrubber, relocating the opacity monitor, adding new fans, adding a stack liner and drains for wet operation, and using a refined soda ash reagent. It is considered to be technically infeasible for the present wet FGD system to achieve 95 percent SO₂ removal (0.06 lb per MMBtu) on a continuous basis since this high level of removal must be incorporated into the original design of the scrubber.

The wet FGD system is achieving an outlet SO₂ emission rate of 0.17 lb per MMBtu. It is not expected that any significant additional SO₂ reduction would occur with optimization of the wet sodium scrubbing FGD system. This option would not meet the presumptive limit of 0.15 lb per MMBtu. Therefore, this option is eliminated as technically infeasible for this analysis. An upgraded wet sodium scrubbing FGD system is projected to achieve an outlet emission rate of 0.10 lb per MMBtu (91.7 percent SO₂ removal), which would meet the presumptive limit of 0.15 lb per MMBtu for Jim Bridger 4.

New Dry FGD System. The lime spray dryer typically injects lime slurry in the top of the absorber vessel with a rapidly rotating atomizer wheel. The rapid speed of the atomizer wheel causes the lime slurry to separate into very fine droplets that intermix with the flue gas. The SO₂ in the flue gas reacts with the calcium in the lime slurry to form dry calcium sulfate particles. At Jim Bridger 4 this dry particulate matter would be captured downstream in the existing ESP, along with the fly ash. A lime spray dryer system typically produces a dry waste product suitable for landfill disposal.

The dry FGD system with the existing ESP is projected to achieve 82.5 percent SO₂ removal at Jim Bridger 4. This would result in a controlled SO₂ emission rate of 0.21 lb per MMBtu, based on an uncontrolled SO₂ emission rate of 1.20 lb per MMBtu. Therefore, this option cannot meet the presumptive limit of 0.15 lb per MMBtu, and is eliminated from further analysis as technically infeasible.

Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

When evaluating the control effectiveness of SO₂ reduction technologies, each option can be compared against benchmarks of performance. One such benchmark is the presumptive BART emission limit because Jim Bridger 4 is required to meet this limit. As indicated previously, the presumptive limit for SO₂ on a BART-eligible coal burning unit is 95 percent removal, or 0.15 lb per MMBtu.

The projected emission rate for an upgraded wet sodium FGD system for Jim Bridger 4 would be 0.10 lb per MMBtu. This option would meet the presumptive SO₂ limit of 0.15 lb per MMBtu.

Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

Energy Impacts. Upgrading the existing wet sodium FGD system would require an additional 520 kW of power.

Environmental Impacts. There will be incremental additions to scrubber waste disposal and makeup water requirements.

Economic Impacts. A summary of the costs and amount of SO₂ removed for the upgraded wet sodium FGD system is provided in Table 3-5. The complete economic analysis is contained in Appendix A.

TABLE 3-5
Sulfur Dioxide Control Cost Comparison (Incremental to Existing Flue Gas Desulfurization System)
Jim Bridger 4

Factor	Upgraded Wet Flue Gas Desulfurization
Total Installed Capital Costs	\$5.8 Million
Total First Year Fixed & Variable O&M Costs	\$0.7 Million
Total First Year Annualized Cost	\$1.2 Million
Additional Power Consumption (megawatts)	0.5
Additional Annual Power Usage (1000 megawatt-hours per year)	4.2
Incremental Sulfur Dioxide Design Control Efficiency	40.1% (91.7% based on Uncontrolled Sulfur Dioxide)
Incremental Tons Sulfur Dioxide Removed per Year	1,585
First Year Average Control Cost (\$ per Ton of Sulfur Dioxide Removed)	761
Incremental Control Cost (\$ per Ton of Sulfur Dioxide Removed)	761

Preliminary BART Selection. CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 4 based on its significant reduction in SO₂ emissions (meeting presumptive limit of 0.15 lb per MMBtu), reasonable control costs, and the advantages of minimal additional power requirements, and environmental impacts.

Step 5: Evaluate Visibility Impacts

Please see Section 4, BART Modeling Analysis.

3.2.3 BART PM₁₀ Analysis

Jim Bridger 4 is currently equipped with an ESP. ESPs remove particulate matter from the flue gas stream by charging fly ash particles with a very high direct current voltage, and attracting these charged particles to grounded collection plates. A layer of collected particulate matter forms on the collecting plates and is removed by periodically rapping the plates. The collected ash particles drop into hoppers below the precipitator and are removed periodically by the fly ash-handling system. Historically, the ESP at Jim Bridger 4 has controlled PM₁₀ emissions to levels below 0.030 lb per MMBtu.

The BART analysis for PM₁₀ emissions at Jim Bridger 4 is described below. For the modeling analysis in Section 4, PM₁₀ was used as an indicator for particulate matter, and PM₁₀ includes PM_{2.5} as a subset.

Step 1: Identify All Available Retrofit Control Technologies

Two retrofit control technologies have been identified for additional particulate matter control:

- Flue gas conditioning (FGC)
- Polishing fabric filter (baghouse) downstream of existing ESP

Another available control technology is replacing the existing ESP with a new fabric filter. However, because the environmental benefits that would be achieved by a replacement fabric filter are also achieved by installing a polishing fabric filter downstream of the existing ESP at lower costs, installation of a full fabric filter was not considered in the analysis.

Step 2: Eliminate Technically Infeasible Options

Flue Gas Conditioning. If the fly ash from coal has high resistivity, such as fly ash from sub-bituminous coal, the ash is not collected effectively in an ESP. This is because the high resistivity makes the particles less willing to accept an electrical charge. Adding FGC, which is typically accomplished by injection of sulfur trioxide (SO₃), will lower the resistivity of the particles so that they will accept more charge and allow the ESP to collect the ash more effectively. FGC systems can account for large improvements in collection efficiency for small ESPs.

Polishing Fabric Filter. A polishing fabric filter could be added downstream of the existing ESP at Jim Bridger 4. One such technology is licensed by the Electric Power Research Institute, and referred to as a Compact Hybrid Particulate Collector (COHPAC). The COHPAC collects the ash that is not collected by the ESP, thus acting as a polishing device. The ESP needs to be kept in service for the COHPAC fabric filter to operate effectively.

The COHPAC fabric filter is about one-half to two-thirds the size of a full size fabric filter, because the COHPAC has a higher air-to-cloth ratio (7 to 9:1), compared to a full size pulse jet fabric filter (3.5 to 4.1).

Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

The existing ESP at Jim Bridger 4 is achieving a controlled particulate matter emission rate of 0.030 lb per MMBtu. Using FGC upstream of the existing ESP is projected to not reduce particulate matter emissions, but it would help maintain long term operation at an emission level of 0.030 lb per MMBtu. Adding a COHPAC fabric filter downstream of the existing ESP is projected to reduce particulate matter emissions to approximately 0.015 lb per MMBtu.

The PM₁₀ control technology emission rates are summarized in Table 3-6.

TABLE 3-6
PM₁₀ Control Technology Emission Rates
Jim Bridger 4

Control Technology	Short-Term Expected PM ₁₀ Emission Rate (pounds per million British thermal units)
Flue Gas Conditioning	0.030
Polishing Fabric Filter	0.015

Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

Energy Impacts. Energy is required to overcome the additional pressure drop from the COHPAC fabric filter and associated ductwork. Therefore, a COHPAC retrofit will require an induced draft (ID) fan upgrade and upgrade of the auxiliary power supply system. A COHPAC fabric filter at Jim Bridger 4 would require approximately 3.4 MW of power, equating to an annual power usage of approximately 26.7 million kilowatt-hours (kW-Hr). There is only a small power requirement of approximately 50 kW associated with FGC.

Environmental Impacts. There are no negative environmental impacts from the addition of a COHPAC polishing fabric filter or flue gas conditioning system.

Economic Impacts. A summary of the costs and particulate matter removed for COHPAC and FGCs are recorded in Table 3-7, and the first-year control costs for FGC and fabric filters are shown in Figure 3-5. The complete economic analysis is contained in Appendix A.

TABLE 3-7
PM₁₀ Control Cost Comparison (Incremental to Existing ESP)
Jim Bridger 4


Factor	Flue Gas Conditioning	Polishing Fabric Filter
Total Installed Capital Costs	\$0	\$48.4 million
Total First Year Fixed & Variable O&M Costs	\$0.2 million	\$1.8 million
Total First Year Annualized Cost	\$0.2 million	\$ 6.4 million
Additional Power Consumption (megawatts)	0.05	3.39
Additional Annual Power Usage (Million kilowatt-hours per year)	0.4	26.7
Incremental Particulate Matter Design Control Efficiency	0.0%	50.0%
Incremental Tons Particulate Matter Removed per Year	0	355
First Year Average Control Cost (\$ per Ton of Particulate Matter Removed)	N/A	17,946
Incremental Control Cost (\$ per Ton of Particulate Matter Removed)	N/A	17,452

Preliminary BART Selection. CH2M HILL recommends selection of FGC upstream of the existing ESP as BART for Jim Bridger 4 based on the significant reduction in particulate matter emissions, reasonable control costs, and advantages of minimal additional power requirements and no environmental impacts.

Step 5: Evaluate Visibility Impacts

Please see Section 4, BART Modeling Analysis.

FIGURE 3-5
First Year Control Cost for PM Air Pollution Control Options
Jim Bridger-4



4.0 BART Modeling Analysis

4.1 Model Selection

CH2M HILL used the CALPUFF modeling system to assess the visibility impacts of emissions from Jim Bridger 4 at nearby Class I areas. The Class I areas potentially affected are located more than 50 kilometers but less than 300 kilometers from the Jim Bridger 4 facility. The Class I areas include the following wilderness areas:

- Bridger Wilderness Area
- Fitzpatrick Wilderness Area
- Mt. Zirkel Wilderness Area

The CALPUFF modeling system includes the CALMET meteorological model, a Gaussian puff dispersion model (CALPUFF) with algorithms for chemical transformation and deposition, and a post processor capable of calculating concentrations, visibility impacts, and deposition (CALPOST). The CALPUFF modeling system was applied in a full, refined mode. The following version numbers of the various programs in the CALPUFF system were used by CH2M HILL:

- CALMET Version 5.53a, Level 040716
- CALPUFF Version 5.711a, Level 040716
- CALPOST Version 5.51, Level 030709

4.2 CALMET Methodology

4.2.1 Dimensions of the Modeling Domain

CH2M HILL used the CALMET model to generate a three-dimensional wind field and other meteorological parameters suitable for use by the CALPUFF model. A modeling domain was established to encompass the Jim Bridger 4 facility and allow for a 50-km buffer around the Class I areas that were within 300 km of the facility. Grid resolution was 4 km. Figure 4-1 shows the extent of the modeling domain. Except when specifically instructed otherwise by the Wyoming Department of Environmental Quality-Air Quality Division (WDEQ-AQD), CH2M HILL followed the methodology spelled out in the WDEQ-AQD BART Modeling Protocol, a copy of which is included in this report as Appendix B.

CH2M HILL used the Lambert Conformal Conic map projection for the analysis due to the large extent of the domain. The latitude of the projection origin and the longitude of the central meridian were chosen at the approximate center of the domain. Standard parallels were drawn to represent one-sixth and five-sixths of the north-south extent of the domain to minimize distortion in the north-south direction.




Figure 4-1
Jim Bridger Source-Specific
Class I Areas to be Addressed



CH2MHILL

S:\C\B\GIS\PROJECTS\HUNTER\MAPPFILES\JIM_BRIDGER_CLASSI.MXD 11/9/2006 MSLAYDEN

The default technical options listed in TRC Companies, Inc.'s (TRC) current example CALMET.inp file were used for CALMET. Vertical resolution of the wind field included ten layers, with vertical face heights as follows (in meters):

- 0, 20, 40, 100, 140, 320, 580, 1020, 1480, 2220, 3500

Other user-specified model options were set to values established by WDEQ-AQD, which appear in Table 3 of Appendix B. Table 4-1 lists the key user-specified options used for this analysis.

TABLE 4-1
User-specified CALMET Options
Jim Bridger 4

CALMET Input Parameter	Value
CALMET Input Group 2	
Map projection (PMAP)	Lambert Conformal
Grid spacing (DGRIDKM)	4
Number vertical layers (NZ)	10
Top of lowest layer (m)	20
Top of highest layer (m)	3500
CALMET Input Group 4	
Observation mode (NOOBS)	0
CALMET Input Group 5	
Prog. Wind data (IPROG)	14
(RMAX1)	30
(RMAX2)	50
Terrain influence (TERRAD)	15
(R1)	5
(R2)	25
CALMET Input Group 6	
Max mixing ht (ZIMAX)	3500

4.2.2 CALMET Input Data

CH2M HILL ran the CALMET model to produce 3 years of analysis: 2001, 2002, and 2003. WDEQ-AQD provided 12-km resolution Mesoscale Meteorological Model, Version 5 (MM5) meteorological data fields that covered the entire modeling domain for each study year.

These three data sets were chosen because they are current and have been evaluated for quality. The MM5 data were used as input to CALMET as the "initial guess" wind field. The initial guess wind field was adjusted by CALMET for local terrain and land use effects to generate a

Step 1 wind field, and further refined using local surface observations to create a final Step 2 wind field.

Surface data for 2001 through 2003 were obtained from the National Climatic Data Center. CH2M HILL processed the data from the National Weather Service's Automated Surface Observing System (ASOS) network for all stations that are in the domain. The surface data were obtained in abbreviated DATSAV3 format. A conversion routine available from the TRC Web site was used to convert the DATSAV3 files to CD-144 format for input into the SMERGE preprocessor and CALMET.

Land use and terrain data were obtained from the U.S. Geological Survey (USGS). Land use data were obtained in Composite Theme Grid format from the USGS, and the Level I USGS land use categories were mapped into the 14 primary CALMET land use categories. Surface properties such as albedo, Bowen ratio, roughness length, and leaf area index were computed from the land use values. Terrain data were taken from USGS 1-degree Digital Elevation Model data, which primarily derive from USGS 1:250,000 scale topographic maps. Missing land use data were filled with values that were assumed appropriate for the missing area.

Precipitation data were obtained from the National Climatic Data Center. All available data in fixed-length, TD-3240 format were obtained for the modeling domain. The list of available stations that have collected complete data varies by year, but CH2M HILL processed all available stations/data within the domain for each year. Precipitation data were prepared with the PEXTRACT/PMERGE processors in preparation for use within CALMET.

Upper-air data were prepared for the CALMET model with the READ62 preprocessor for the following stations:

- Denver, Colorado
- Salt Lake City, Utah
- Riverton, Wyoming
- Rapid City, South Dakota

Figure 4-2 shows the locations of surface and upper air stations within the MM5 modeling domain.

4.2.3 Validation of CALMET Wind Field

CH2M HILL used the CALDESK data display and analysis system (v2.97, Enviromodeling Ltd.) to view plots of wind vectors and other meteorological parameters to evaluate the CALMET wind fields. The CALDESK displays were compared to observed weather conditions, as depicted in surface and upper-air weather maps (National Oceanic and Atmospheric Administration, 2006).

4.3 CALPUFF Modeling Approach

For the BART control technology visibility improvement modeling, CH2M HILL followed WDEQ-AQD guidance provided in the document titled *BART Air Modeling Protocol-Individual Source Visibility Assessments for BART Control Analyses* (September, 2006).

CH2M HILL drove the CALPUFF model with the meteorological output from CALMET over the modeling domain described earlier. The CALPUFF model was used to predict visibility impacts for the pre-control (baseline) scenario for comparison to the predicted impacts for post-control scenarios for Jim Bridger 4.

4.3.1 Background Ozone and Ammonia

Hourly values of background ozone concentrations were used by CALPUFF for the calculation of SO₂ and NO_x transformation with the MESOPUFF II chemical transformation scheme. CH2M HILL obtained hourly ozone data from the following stations located within the modeling domain for 2001, 2002, and 2003:

- Rocky Mountain National Park, Colorado
- Craters of the Moon National Park, Idaho
- Highland, Utah
- Thunder Basin National Grasslands, Wyoming
- Yellowstone National Park, Wyoming
- Centennial, Wyoming
- Pinedale, Wyoming

For periods of missing hourly ozone data, the chemical transformation relied on a monthly default value of 44 parts per billion. Background ammonia was set to 2 parts per billion. Both of these background values were taken from the guidance document (WDEQ-AQD, 2006).

4.3.2 Stack Parameters

The stack parameters used for the baseline modeling reflect those that are in place under the current permit for Jim Bridger 4. Post-control stack parameters reflect the anticipated changes associated with installation of the control technology alternatives that are being evaluated. The maximum heat input rate of 6,000 MMBtu per hour was used to calculate a maximum emission rate. Measured velocities and stack flow rates were used in the modeling to represent a worst-case situation.

4.3.3 Emission Rates

Pre-control emission rates for Dave Johnston 3 reflect peak 24-hour average emissions that may occur under the source's current permit. The emission rates reflect actual emissions under normal operating conditions, as described by the EPA in the *Regional Haze Regulations and Guidelines for Best Available Retrofit Technology Determinations; Final Rule* (40 CFR Part 51).

CH2M HILL used available continuous emission monitoring data to determine peak 24-hour emission rates. Data reflected operations from the most recent 3- to 5-year period, unless a more recent period was more representative. Allowable short-term (24-hour or shorter period) emissions or short-term emission limits were used if continuous emission monitoring data were not available.

Emissions were modeled for the following pollutants:

- SO₂
- NO_x
- Coarse particulate (PM_{2.5}<diameter<PM₁₀)
- Fine particulate (diameter<PM_{2.5})
- Sulfates

Post-control emission rates reflect the effects of the emissions control scenario under consideration. Modeled pollutants were the same as those listed for the pre-control scenario.

4.3.4 Post-control Scenarios

Four post-control modeling scenarios were developed to cover the range of effectiveness for the combination of the individual NO_x, SO₂, and PM control technologies being evaluated. The selection of each control device was made based on the engineering analyses performed in Section 3 for reasonable technologies that would meet or exceed the presumptive BART levels for each pollutant.

- **Scenario 1:** New LNB with OFA Modifications, upgraded wet FGD system and FGC for enhanced ESP performance. As indicated previously, this scenario represents CH2M HILL's preliminary BART recommendation.
- **Scenario 2:** New LNB with OFA modifications, upgraded wet FGD system and new polishing fabric filter
- **Scenario 3:** New LNB with OFA modifications and SCR, upgraded wet FGD system and FGC for enhanced ESP performance.
- **Scenario 4:** New LNB with OFA modifications and SCR, upgraded wet FGD system and new polishing fabric filter.

The ROFA option and LNB with OFA and SCR option for NO_x control were not included in the modeling scenarios because their control effectiveness is between the LNB with OFA option and the SCR option. Modeling of NO_x, SO₂, and particulate matter controls alone was not performed because any final BART solution will include a combination of control technologies for NO_x, SO₂, and particulate matter.

Table 4-2 presents the stack parameters and emission rates used for the Jim Bridger 4 analysis for baseline and post-control modeling. In accordance with the WDEQ BART modeling protocol, elemental carbon stack emissions and organic aerosol emissions were not modeled.

4.3.5 Modeling Process

The CALPUFF modeling for the control technology options for Jim Bridger 4 followed this sequence:

- Model pre-control (baseline) emissions
- Model preferred post-control scenario (if applicable)
- Determine degree of visibility improvement
- Model other control scenarios
- Determine degree of visibility improvement
- Factor visibility results into the BART "five-step" evaluation

4.3.6 Receptor Grids

Discrete receptors for the CALPUFF modeling were placed at uniform receptor spacing along the boundary and in the interior of each area of concern. Class I area receptors were taken from the National Park Service database for Class I area modeling receptors. The TRC COORDS program was used to convert all latitude/longitude coordinates to Lambert Conformal Conic coordinates, including receptors, meteorological stations, and source locations.

4.4 CALPOST

The CALPOST processor was used to determine 24-hour average visibility results with output specified in deciview (dV) units. Calculations of light extinction were made for each pollutant modeled. The sum of all extinction values were used to calculate the delta-dV (ΔdV) change relative to natural background. Default light extinction coefficients for each pollutant, as follows, were used.

- Ammonium sulfate 3.0
- Ammonium nitrate 3.0
- Particulate matter coarse (PM_{10}) 0.6
- Particulate matter fine ($PM_{2.5}$) 1.0
- Organic carbon 4.0
- Elemental carbon 10.0

CALPOST Visibility Method 6 was used to determine the visibility impacts. Monthly relative humidity factors [$f(RH)$] were used in the light extinction calculations to account for the hygroscopic characteristics of nitrate and sulfate particles. Table 5 of the Wyoming BART Air Modeling Protocol (Appendix B) lists the monthly $f(RH)$ factors for the Class I areas. These values were used for the particular Class I area being modeled.

The natural background conditions as a reference for determining the delta-dV (ΔdV) change represented the 20 percent best natural visibility days. The EPA BART guidance document provided dV values for the 10 percent best days for each Class I area, but did not provide individual species concentration data for the 20 percent best background conditions. Species concentrations corresponding to the 20 percent best days were calculated for each Class I area by scaling back the annual average species concentrations given in Table 2-1 of *Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule* (EPA, 2003). A separate scaling factor was derived for each Class I area such that, when multiplied by the guidance table annual concentrations, the 20 percent best days dV value for that area would be calculated. This procedure was taken from *Protocol for BART-Related Visibility Improvement Modeling Analysis in North Dakota* (North Dakota Department of Health, 2005). However, the Wyoming BART Air Modeling Protocol (see Appendix B) provided natural background concentrations of aerosol components to use in the BART analysis. Table 4-3 lists the annual average species concentrations from the BART protocol.

TABLE 4-3
Average Natural Levels of Aerosol Components
Jim Bridger 4

Aerosol Component	Average Natural Concentration (micrograms per cubic meter) for Mt. Zirkel Class I Wilderness Area	Average Natural Concentration (micrograms per cubic meter) for Fitzpatrick and Bridger Class I Wilderness Areas
Ammonium Sulfate	0.046	0.045
Ammonium Nitrate	0.038	0.038
Organic Carbon	0.179	0.178
Elemental Carbon	0.008	0.008
Soil	0.190	0.189
Coarse Mass	1.141	1.136

NOTE:

Source: Table 6 of the Wyoming BART Air Modeling Protocol

4.5 Presentation of Modeling Results

This section presents the results of the CALPUFF visibility improvement modeling analysis for Jim Bridger 4.

4.5.1 Visibility Changes for Baseline vs. Preferred Scenario

CH2M HILL modeled Jim Bridger 4 for the baseline conditions and four post-control scenarios. The post-control scenarios included emission rates for NO_x, SO₂, and PM₁₀ that would be achieved if BART technology were installed on Unit 4.

Baseline (and post-control) 98th percentile results were greater than 0.5 ΔdV for the Bridger, Fitzpatrick, and Mt. Zirkel Wilderness Areas. The 98th percentile results for each Class I area are presented in Table 4-4.

TABLE A-4
Costs and Visibility Modeling Results for Baseline Vs. Post-Control Scenarios at Class / Areas
Jim Bridger Unit 4

Scenario	Class / Area	Highest Delta- (elective) [dV]	98 th Percentile Delta- (dV)	No. of Days Above 0.5 dV	Cost per dV Reduction	Cost per Reduction in No. of Days Above 0.5 dV	Incremental Cost per dV Reduction	Incremental Cost per Reduction in No. of Days Above 0.5 dV
2001								
Baseline: current operation with wet Flue Gas Desulfurization (FGD), Electrostatic Precipitator (ESP)	Bridger WA Flitzpatrick WA Mt. Zirkel WA	2.275 2.234 1.809	0.655 0.406 1.129	12 5 24	-- -- --	-- -- --	-- -- --	-- -- --
Scenario 1: Low-NO _x Burner (LNB) with Over-Fire Air (OFA), upgrade wet FGD, Flue Gas Conditioning (FGC) for enhanced ESP performance	Bridger WA Flitzpatrick WA Mt. Zirkel WA	1.356 1.338 1.107	0.366 0.223 0.688	7 3 16	\$6,808,752 \$11,498,434 \$4,771,459	\$420,843 \$1,052,107 \$253,027	\$2,122,205,301 NA NA	NA NA NA
Scenario 2: LNB with OFA, upgrade wet FGD, polishing fabric filter	Bridger WA Flitzpatrick WA Mt. Zirkel WA	1.340 1.317 1.084	0.383 0.232 0.671	7 3 15	\$27,150,104 \$48,682,944 \$18,495,267	\$1,684,166 \$4,235,416 \$941,204	\$2,122,205,301 NA NA	NA NA NA
Scenario 3: LNB with OFA and Selective Catalytic Reduction (SCR) System, upgrade wet FGD, FGC for enhanced ESP performance	Bridger WA Flitzpatrick WA Mt. Zirkel WA	0.956 0.756 0.722	0.285 0.143 0.425	3 2 4	\$45,374,034 \$70,795,187 \$26,462,808	\$2,067,089 \$6,201,118 \$930,168	\$103,393,079 \$113,848,559 \$41,357,232	\$2,533,130 \$10,132,522 \$921,138
Scenario 4: LNB with OFA and SCR system, upgrade wet FGD, polishing fabric filter	Bridger WA Flitzpatrick WA Mt. Zirkel WA	0.914 0.732 0.698	0.273 0.136 0.410	3 1 3	\$59,170,552 \$92,481,381 \$34,728,752	\$2,774,441 \$6,242,493 \$1,189,046	\$530,551,575 \$909,516,986 \$397,913,681	NA NA NA
2002								
Baseline: current operation with wet FGD, ESP	Bridger WA Flitzpatrick WA Mt. Zirkel WA	3.975 1.869 2.530	1.330 0.615 1.380	23 11 25	-- -- --	-- -- --	-- -- --	-- -- --
Scenario 1: LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	Bridger WA Flitzpatrick WA Mt. Zirkel WA	2.435 1.082 1.494	0.821 0.379 0.800	14 3 14	\$4,134,015 \$6,916,159 \$3,627,854	\$233,801 \$263,027 \$181,282	-- -- --	-- -- --
Scenario 2: LNB with OFA, upgrade wet FGD, polishing fabric filter	Bridger WA Flitzpatrick WA Mt. Zirkel WA	2.412 1.082 1.477	0.802 0.361 0.790	14 3 13	\$16,043,243 \$33,348,733 \$14,357,343	\$941,204 \$1,058,854 \$705,903	\$335,085,205 \$363,701,050 \$836,681,890	NA NA NA
Scenario 3: LNB with OFA and SCR, upgrade wet FGD, FGC for enhanced ESP performance	Bridger WA Flitzpatrick WA Mt. Zirkel WA	1.367 0.591 0.877	0.472 0.233 0.442	7 1 5	\$21,682,231 \$48,689,880 \$19,893,000	\$1,162,710 \$1,860,335 \$930,168	\$30,704,811 \$79,180,326 \$29,116,442	\$1,447,503 \$5,066,261 \$1,266,565
Scenario 4: LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	Bridger WA Flitzpatrick WA Mt. Zirkel WA	1.341 0.561 0.857	0.466 0.230 0.434	7 1 5	\$28,900,432 \$64,857,073 \$26,395,320	\$1,560,623 \$2,486,997 \$1,248,499	\$2,122,205,301 NA NA	NA NA NA

TABLE 4A
Costs and Visibility Modeling Results for Baseline Vs. Post-Control Scenarios at Class I Areas
Jim Bridger Unit 4

Scenario	Total First Year Annualized Cost	Class / Area	Highest Delta- (deciview [dV])	98th Percentile Delta- (dV)	No. of Days Above 0.5 dV	Cost per dV Reduction	Cost per Reduction In No. of Days Above 0.5 dV	Incremental Cost per dV Reduction	Incremental Cost in No. of Days Above 0.5 dV
2003									
Baseline: current operation with wet FGD, ESP		Bridger WA Fitzpatrick WA Mt. Zirkel WA	1,583 1,825 1,786	0.786 0.946 1.201	13 7 33	-- -- --	-- -- --	-- -- --	-- -- --
Scenario 1: LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	\$2,104,213 \$2,104,213 \$2,104,213	Bridger WA Fitzpatrick WA Mt. Zirkel WA	0.861 1.098 1.098	0.428 0.207 0.688	5 2 17	\$6,854,115 \$15,138,226 \$4,101,781	\$283,027 \$420,843 \$181,513	\$1,591,854,726 \$1,273,323,781 \$636,661,890	NA NA NA
Scenario 2: LNB with OFA, upgrade wet FGD, polishing fabric filter	\$8,470,832 \$8,470,832	Bridger WA Fitzpatrick WA Mt. Zirkel WA	0.841 1.081 1.025	0.425 0.202 0.678	5 2 17	\$27,237,403 \$8,825,224 \$16,196,620	\$1,058,854 \$1,694,166 \$529,427	\$1,591,854,726 \$1,273,323,781 \$636,661,890	NA NA NA
Scenario 3: LNB with OFA and SCR, upgrade wet FGD, FGC for enhanced ESP performance	\$18,603,354 \$18,603,354 \$18,603,354	Bridger WA Fitzpatrick WA Mt. Zirkel WA	0.799 0.662 0.769	0.275 0.129 0.409	2 2 5	\$40,354,347 \$95,728,742 \$23,489,083	\$1,691,214 \$3,720,671 \$684,406	\$87,550,145 \$138,801,668 \$37,667,567	\$9,377,507 NA \$84,377
Scenario 4: LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	\$24,969,973 \$24,969,973 \$24,969,973	Bridger WA Fitzpatrick WA Mt. Zirkel WA	0.759 0.645 0.731	0.263 0.124 0.399	2 1 4	\$2,790,641 \$12,477,358 \$31,134,630	\$2,269,988 \$4,181,862 \$861,034	\$50,551,575 \$1,273,323,781 \$636,661,890	NA \$8,366,619 \$8,366,619
3-year Averages									
Baseline: current operation with wet FGD, ESP		Bridger WA Fitzpatrick WA Mt. Zirkel WA	0.820 0.456 1.237	0.920 0.456 1.237	16.0 7.7 27.3	-- -- --	-- -- --	-- -- --	-- -- --
Scenario 1: LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	\$2,104,213 \$2,104,213 \$2,104,213	Bridger WA Fitzpatrick WA Mt. Zirkel WA	0.545 0.270 0.725	0.545 0.270 0.725	8.7 2.7 15.7	\$5,611,236 \$11,312,975 \$4,115,150	\$286,988 \$420,843 \$180,361	\$734,608,873 \$1,364,275,479 \$516,212,343	NA NA \$9,549,928
Scenario 2: LNB with OFA, upgrade wet FGD, polishing fabric filter	\$8,470,832 \$8,470,832	Bridger WA Fitzpatrick WA Mt. Zirkel WA	0.537 0.285 0.713	0.537 0.285 0.713	8.7 2.7 15.0	\$22,078,625 \$44,427,442 \$16,176,001	\$1,155,113 \$1,684,166 \$686,824	\$734,608,873 \$1,364,275,479 \$516,212,343	NA NA \$9,549,928
Scenario 3: LNB with OFA and SCR, upgrade wet FGD, FGC for enhanced ESP performance	\$18,603,354 \$18,603,354 \$18,603,354	Bridger WA Fitzpatrick WA Mt. Zirkel WA	0.344 0.168 0.426	0.344 0.168 0.426	4.0 1.7 4.7	\$32,278,810 \$84,744,852 \$22,938,784	\$1,550,280 \$3,100,559 \$820,736	\$52,590,943 \$104,819,191 \$35,263,997	\$2,171,255 \$10,182,522 \$980,567
Scenario 4: LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	\$24,969,973 \$24,969,973 \$24,969,973	Bridger WA Fitzpatrick WA Mt. Zirkel WA	0.334 0.183 0.414	0.334 0.183 0.414	4.0 1.0 4.0	\$42,586,651 \$85,416,089 \$30,364,783	\$2,080,831 \$3,745,496 \$1,070,142	\$636,661,890 \$1,273,323,781 \$661,760,491	NA \$9,549,928 \$9,549,928

NOTES:
Sample Calculations: Cost per dV Reduction for Scenario 1 for 2001: = \$2,104,213 / (0.727 - 0.415) = \$6,744,274
Sample Calculations: Cost per Reduction in No. of Days Exceeding 0.5 dV for 2001: = \$2,104,213 / (16 - 7) = \$263,027

5.0 Preliminary Assessment and Recommendations

As a result of the completed technical and economic evaluations, and consideration of the modeling analysis for Jim Bridger 4, the preliminary recommended BART controls for NO_x, SO₂, and PM₁₀ are as follows:

- New LNBS and modifications to the OFA system for NO_x control
- Upgrade wet sodium FGD for SO₂ control
- Add flue gas conditioning upstream of existing ESPs for PM control

These recommendations were identified as Scenario 1 for the modeling analysis described in Section 4. Visibility improvements for all emission control scenarios were analyzed, and the results are compared below, utilizing a least-cost envelope, as outlined in the *New Source Review Workshop Manual* (EPA, 1990, hereafter referred to as NSR Manual).

5.1 Least-cost Envelope Analysis

For the control scenarios modeled in Section 4, Tables 5-1 through 5-3 list the total annualized cost, cost per dV reduction, and cost per reduction in number of days above 0.5 dV for each of the three Class I areas. A comparison of the incremental results between selected scenarios is provided in Tables 5-4 through 5-6. Figures 5-1 to 5-6 show the total annualized cost versus number of days above 0.5 dV, and the total annualized cost versus 98th percentile ΔdV reduction, for the three Class I areas.

5.1.1 Analysis Methodology

On page B-41 of the New Source Review (NSR) Manual, EPA states that “Incremental cost-effectiveness comparisons should focus on annualized cost and emission reduction differences between dominant alternatives. Dominant set of control alternatives are determined by generating what is called the envelope of least-cost alternatives. This is a graphical plot of total annualized costs for a total emissions reductions for all control alternatives identified in the BACT analysis...”

An analysis of incremental cost effectiveness has been conducted. This analysis was performed in the following way. First, the control option scenarios are ranked in ascending order of annualized total costs, as shown in Tables 5-1 through 5-3. The incremental cost effectiveness data, expressed per day and per dV, represents a comparison of the different scenarios, and is summarized in Tables 5-4 through 5-6 for each of the three wilderness areas. Then the most reasonable smooth curve of least-cost control option scenarios is plotted for each analysis. Figures 5-1 through 5-6 present the two analyses (cost per dV reduction and cost per reduction in number of days above 0.5 dV) for each of the three Class I areas impacted by the operation of Jim Bridger 4.

In Figure 5-1, the four scenarios are compared as a graph of total annualized cost versus number of days above 0.5 dV. The EPA states that "In calculating incremental costs, the analysis should only be conducted for control options that are dominant among all possible options." In Figure 5-1, the dominant set of control options (Scenarios 1, 3, and 4) represent the least-cost envelope depicted by the curvilinear line connecting them. Scenario 2 is an inferior option and should not be considered in the derivation of incremental cost effectiveness. Scenario 2 represents inferior controls because Scenario 1 provides approximately the same amount of visibility impact reduction for less cost than Scenario 2. The incremental cost effectiveness is determined by the difference in total annual costs between two contiguous scenarios divided by the difference in emissions reduction.

TABLE 5-1
Control Scenario Results for the Bridger Class I Wilderness Area
Jim Bridger Unit 4

Scenario	Controls	98 th Percentile deciview (dV) Reduction	Reduction in Average Number of Days Above 0.5 dV (days)	Total Annualized Cost (million\$)	Cost per dV Reduction (million\$ per dV reduced)	Cost per Reduction in No. of Days Above 0.5 dV (million\$ per day reduced)
Base	Current Operation with Wet Flue Gas Desulfurization (FGD), Electrostatic Precipitator (ESP)	0.00	0.0	\$0.0	\$0.0	\$0.0
1	Low-NO _x Burner (LNB) with Over-Fire Air (OFA), upgrade wet FGD and Flue Gas Conditioning (FGC) for enhanced ESP performance	0.38	7.3	\$2.1	\$5.6	\$0.3
2	LNB with OFA, Upgrade Wet FGD, new polishing fabric filter	0.38	7.3	\$8.5	\$22.1	\$1.2
3	LNB with OFA and Selective Catalytic Reduction (SCR) System, upgrade wet FGD and FGC for enhanced ESP performance	0.58	12.0	\$18.6	\$32.3	\$1.6
4	LNB with OFA and SCR, upgrade wet FGD, new polishing fabric filter	1.25	20	\$25.0	\$19.9	\$1.2

TABLE 5-2
Control Scenario Results for the Fitzpatrick Class I Wilderness Area
Jim Bridger Unit 4

Scenario	Controls	98 th Percentile deciview (dV) Reduction	Reduction in Average Number of Days Above 0.5 dV (days)	Total Annualized Cost (million\$)	Cost per dV Reduction (million\$ per dV reduced)	Cost per Reduction in No. of Days Above 0.5 dV (million\$ per Day reduced)
Base	Current Operation with Wet Flue Gas Desulfurization (FGD), Electrostatic Precipitator (ESP)	0.00	0.0	\$0.0	\$0.0	\$0.0
1	Low-NO _x Burner (LNB) with Over-Fire Air (OFA), upgrade wet FGD and Flue Gas Conditioning (FGC) for enhanced ESP performance	0.19	5.0	\$2.1	\$11.3	\$0.4
2	LNB with OFA, Upgrade Wet FGD, new polishing fabric filter	0.19	5.0	\$8.5	\$44.4	\$1.7
3	LNB with OFA and Selective Catalytic Reduction (SCR) System, upgrade wet FGD and FGC for enhanced ESP performance	0.29	6.0	\$18.6	\$64.7	\$3.1
4	LNB with OFA and SCR, upgrade wet FGD, new polishing fabric filter	0.29	6.7	\$25.0	\$85.4	\$3.7

TABLE 5-3
Control Scenario Results for the Mt. Zirkel Class I Wilderness Area
Jim Bridger 4

Scenario	Controls	98 th Percentile deciview (dV) Reduction	Reduction in Average Number of Days Above 0.5 dV (days)	Total Annualized Cost (million\$)	Cost per dV Reduction (million\$ per dV reduced)	Cost per Reduction in No. of Days Above 0.5 dV (million\$ per Day reduced)
Base	Current Operation with Wet Flue Gas Desulfurization (FGD), Electrostatic Precipitator (ESP)	0.00	0.0	\$0.0	\$0.0	\$0.0
1	Low-NO _x Burner (LNB) with Over-Fire Air (OFA), upgrade wet FGD and Flue Gas Conditioning (FGC) for enhanced ESP performance	0.51	11.7	\$2.1	\$4.1	\$0.2
2	LNB with OFA, Upgrade Wet FGD, new polishing fabric filter	0.52	12.3	\$8.5	\$16.2	\$0.7
3	LNB with OFA and Selective Catalytic Reduction (SCR) System, upgrade wet FGD and FGC for enhanced ESP performance	0.81	22.7	\$18.6	\$22.9	\$0.8
4	LNB with OFA and SCR, upgrade wet FGD, new polishing fabric filter	0.82	23.3	\$25.0	\$30.4	\$1.1

TABLE 5-4
Bridger Class I Wilderness Area Incremental Analysis Data
Jim Bridger Unit 4

Options Compared	Incremental Reduction in Days Above 0.5 deciview (dV) (days)	Incremental dV Reductions (dV)	Incremental Cost-Effectiveness (million\$ per days)	Incremental Cost-Effectiveness (million\$ per dV)
Baseline and Scenario 1	7.3	0.38	\$0.29	\$5.61
Scenario 1 and Scenario 2	0.0	0.01	N/A	\$734.6
Scenario 1 and Scenario 3	4.7	0.20	\$3.5	\$81.9
Scenario 1 and Scenario 4	12.7	0.88	\$1.8	\$26.0

TABLE 5-5
Fitzpatrick Class I Wilderness Area Incremental Analysis Data
Jim Bridger Unit 4

Options Compared	Incremental Reduction in Days Above 0.5 deciview (dV) (days)	Incremental dV Reductions (dV)	Incremental Cost-Effectiveness (million\$ per days)	Incremental Cost-Effectiveness (million\$ per dV)
Baseline and Scenario 1	5.0	0.19	\$0.42	\$45.54
Scenario 1 and Scenario 2	0.0	0.00	NA	\$1,364.3
Scenario 1 and Scenario 3	1.0	0.10	\$16.5	\$162.8
Scenario 1 and Scenario 4	1.7	0.11	\$13.7	\$215.0

TABLE 5-6
Mt. Zirkel Class I Wilderness Area Incremental Analysis Data
Jim Bridger Unit 4

Options Compared	Incremental Reduction in Days Above 0.5 dV (days)	Incremental dV Reductions (dV)	Incremental Cost-Effectiveness (million\$/days)	Incremental Cost-Effectiveness (million\$ per dV)
Baseline and Scenario 1	11.7	0.51	\$0.18	\$4.12
Scenario 1 and Scenario 2	0.7	0.01	\$9.5	\$516.2
Scenario 1 and Scenario 3	11.0	0.30	\$1.5	\$55.1
Scenario 1 and Scenario 4	11.7	0.31	\$2.0	\$73.5

FIGURE 5-1
 Least-cost Envelope Bridger Class I WA Days Reduction
 Jim Bridger Unit 4




FIGURE 5-2
 Least-cost Envelope Bridger Class I WA 98th Percentile Reduction
 Jim Bridger Unit 4




FIGURE 5-3
Least-cost Envelope Fitzpatrick Class I WA Days Reduction
Jim Bridger Unit 4




FIGURE 5-4
Least-cost Envelope Fitzpatrick Class I WA 98th Percentile Reduction
Jim Bridger Unit 4




FIGURE 5-5
 Least-cost Envelope Mt. Zirkel Class I WA Days Reduction
 Jim Bridger Unit 4





FIGURE 5-6
 Least-cost Envelope Mt. Zirkel Class I WA 98th Percentile Reduction
 Jim Bridger Unit 4



5.1.2 Analysis Results

Results of the least-cost analysis, shown in Tables 5-1 through 5-6 and Figures 5-1 through 5-6 on the preceding pages, confirm the selection of Scenario 1, based on incremental cost and visibility improvements. Scenario 2 is eliminated because it is to the left of the curve formed by the "dominant" control alternative scenarios, which indicates a scenario with lower improvement and/or higher costs. Scenario 3 is not selected due to very high incremental costs for both a cost per day of improvement and a cost per dV reduction. While Scenario 4 provides some potential visibility advantage over Scenario 1, the projected improvement is less than 0.5 dV, and the projected costs are excessive.

Analysis of the results for the Jim Bridger Class I Wilderness Area in Tables 5-1 and 5-4 and Figures 5-1 and 5-2 illustrates the conclusions stated above. The greatest reduction in 98th percentile dV and number of days above 0.5 dV is between the Baseline and Scenario 1. The incremental cost effectiveness for Scenario 1 compared to the Baseline for the Bridger Wilderness Area, for example, is reasonable at \$290,000 per day and \$5.6 million per dV. However, the incremental cost effectiveness for Scenario 3 compared to Scenario 1, again for the Bridger Wilderness Area, is excessive at \$3.5 Million per day and \$81.9 million per dV. The same conclusions are reached for each of the three wilderness areas studied. Therefore, Scenario 1 represents BART for Jim Bridger 4.

5.2 Recommendations

5.2.1 NO_x Emission Control

The BART presumptive NO_x limit assigned by EPA for tangentially-fired boilers burning sub-bituminous coal is 0.15 lb per MMBtu. However, as documented in Section 3.2.1, the characteristics of the Jim Bridger coals are more closely aligned with bituminous coals, and have been assigned a presumptive BART NO_x limit of 0.28 lb per MMBtu.

CH2M HILL recommends LNBs with OFA as BART for Jim Bridger 4, based on the projected significant reduction in NO_x emissions, reasonable control costs, and the advantages of no additional power requirements or non-air quality environmental impacts. NO_x reductions are expected to be similar to those realized at Jim Bridger 2. CH2M HILL recommends that the unit be permitted at a rate of 0.26 lb per MMBtu.

5.2.2 SO₂ Emission Control

CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 4, based on the significant reduction in SO₂ emissions, reasonable control costs, and the advantages of minimal additional power requirements and minimal non-air quality environmental impacts. This upgrade approach will meet the BART presumptive SO₂ limit of 0.15 lb per MMBtu.

5.2.3 PM₁₀ Emission Control

CH2M HILL recommends finalizing the permitting of the FGC system to enhance the performance of the existing ESP as BART for Jim Bridger 4, based on the significant

reduction in PM_{10} emissions, reasonable control costs, and the advantages of minimal additional power requirements and no non-air quality environmental impacts.

5.3 Just-Noticeable Differences in Atmospheric Haze

Conclusions reached in the reference document "Just-Noticeable Differences in Atmospheric Haze" by Dr. Ronald Henry of the University of Southern California (Henry, 2002), state that only dV differences of approximately 1.5 to 2.0 dV, or more are perceptible by the human eye. Deciview changes of less than 1.5 cannot be distinguished by the average person. Therefore, the modeling analysis results indicate that only minimal, if any, observable visibility improvements at the Class I areas studied would be expected under any of the scenarios. Thus the results indicate that even though many millions of dollars will be spent, only minimal if any visibility improvements may result.

Finally, it should be noted that none of the data were corrected for natural obscuration. Water in various forms (fog, clouds, snow, or rain) or other naturally caused aerosols may obscure the atmosphere and reduce visibility. During the period of 2001 through 2003, there were several mega-wildfires that lasted for many days, with a significant impact on background visibility in these Class I areas. If natural obscuration lessens the achievable reduction in visibility impacts modeled for BART controls at the Jim Bridger 4 facility, the overall effect would be to increase the costs per dV reduction that are presented in this report.

6.0 References

- 40 CFR Part 51. *Regional Haze Regulations and Guidelines for Best Available Retrofit Technology Determinations; Final Rule*. July 6, 2005.
- Energy Information Administration, 2006. *Official Energy Statistics from the U.S. Government: Coal*. <http://www.eia.doe.gov/fuelcoal.html>. Accessed October 2006.
- EPA, 1990. *New Source Review Workshop Manual—Prevention of Significant Deterioration and Nonattainment Area Permitting*. Draft. October 1990.
- EPA, 2003. *Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule*. Environmental Protection Agency. EPA-454/8-03-005. September 2003.
- Henry, Ronald, 2002. "Just-Noticeable Differences in Atmospheric Haze," *Journal of the Air & Waste Management Association*. Volume 52, p. 1238.
- National Oceanic and Atmospheric Administration, 2006. U.S. Daily Weather Maps Project. http://docs.lib.noaa.gov/rescue/dwm/data_rescue_daily_weather_maps.html. Accessed October 2006.
- North Dakota Department of Health, 2005. *Protocol for BART-Related Visibility Improvement Modeling Analysis in North Dakota*. North Dakota Department of Health. October 26, 2005.
- Sargent & Lundy, 2002. *Multi-Pollutant Control Report*. October 2002.
- Sargent & Lundy, 2006. *Multi-Pollutant Control Report*. Revised. October 2006.
- WDEQ-AQD, 2006. *BART Air Modeling Protocol—Individual Source Visibility Assessments for BART Control Analyses*. Wyoming Department of Environmental Quality – Air Quality Division. September 2006.

APPENDIX A

Economic Analysis

PacifiCorp BART Analysis Scenarios

Select Unit: **6** Jim Bridger Unit 4

Index No.	Name of Unit
1	Dave Johnston Unit 3
2	Dave Johnston Unit 4
3	Jim Bridger Unit 1
4	Jim Bridger Unit 2
5	Jim Bridger Unit 3
6	Jim Bridger Unit 4
7	Naughton Unit 1
8	Naughton Unit 2
9	Naughton Unit 3
10	Wyodak Unit 1

Scenario	Dave Johnston		Naughton		First Year Cost
	DJ Unit 3	DJ Unit 4	NTN Unit 1	NTN Unit 2	
Baseline - Current Operation with ESP	Scenario 1 - LNB with OFA, Dry FGD, Existing ESP	Scenario 1 - LNB with OFA, Dry FGD, Fabric Filter	Scenario 1 - LNB with OFA, Dry FGD, ESP	Scenario 1 - LNB with OFA, Wet FGD, ESP	N/A
Scenario 1 - LNB with OFA, Dry FGD, Existing ESP	N/A	N/A	N/A	N/A	N/A
Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	N/A	N/A	N/A	N/A	N/A
Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	N/A	N/A	N/A	N/A	N/A
Scenario 4 - LNB with OFA and SCR, Wet FGD, Existing ESP, New Stack	N/A	N/A	N/A	N/A	N/A

Scenario	Jim Bridger		Wyodak		First Year Cost
	JB Unit 1	JB Unit 2	JB Unit 3	JB Unit 4	
Baseline - Current Operation with Wet FGD and ESP	Scenario 1 - LNB with OFA, Wet FGD, ESP	Scenario 1 - LNB with OFA, Wet FGD, ESP	Scenario 1 - LNB with OFA, Wet FGD, ESP	Scenario 1 - LNB with OFA, Dry FGD, Fabric Filter	N/A
Scenario 1 - LNB with OFA, Wet FGD, ESP	N/A	N/A	N/A	N/A	2,104,213
Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	N/A	N/A	N/A	N/A	2,104,213
Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	N/A	N/A	N/A	N/A	8,470,832
Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A	N/A	N/A	N/A	8,470,832
Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	N/A	N/A	N/A	N/A	18,605,354
Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A	N/A	N/A	N/A	18,605,354

ECONOMIC ANALYSIS SUMMARY										
Boiler Design: Tangential-Fired PC										
Jim Bridger Unit 4										
Parameter	Current Operation	NOx Control			SO2 Control			PM Control		
		LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter		
Case	1	2	3	4	5	6	7	8	9	10
LNCF-1 & Windbox Mechs. Wet FGD ESP	LNCF-1 & Windbox Mechs. Wet FGD ESP	LNB w/OFA Wet FGD ESP	ROFA Wet FGD ESP	LNB w/OFA & SNCR Wet FGD ESP	LNB w/OFA & SCR Wet FGD ESP	LNB w/OFA & SCR Wet FGD ESP	LNCF-1 & Windbox Mechs. Upgraded Wet FGD ESP	LNCF-1 & Windbox Mechs. Wet FGD ESP	LNCF-1 & Windbox Mechs. Wet FGD ESP	LNCF-1 & Windbox Mechs. Fabric Filter
NOx Emission Control System	0	8,700,001	20,628,122	22,127,239	147,628,474	0	5,759,814	0	0	48,386,333
SO2 Emission Control System	0	0	0	0	0	0	0	0	0	0
PM Emission Control System	0	0	0	0	0	0	0	0	0	0
TOTAL INSTALLED CAPITAL COST (\$)										
FIRST YEAR O&M COST (\$)										
Operating Labor (\$)	0	0	0	0	0	0	0	0	0	0
Maintenance Material (\$)	0	28,000	42,000	123,000	190,000	0	25,550	0	0	51,089
Maintenance Labor (\$)	0	42,000	63,000	184,500	285,000	0	17,033	10,000	0	78,648
Administrative Labor (\$)	0	0	0	0	0	0	0	0	0	0
TOTAL FIXED O&M COST	0	70,000	105,000	307,500	475,000	0	42,583	10,000	0	127,749
Makeup Water Cost	0	0	0	0	0	0	15,589	0	0	0
Reagent Cost	0	0	0	0	0	0	213,921	145,854	0	0
SCR Catalyst / FF Bag Cost	0	0	0	1,005,811	912,848	0	0	0	0	300,040
Waste Disposal Cost	0	0	0	0	0	0	177,714	0	0	0
Electric Power Cost	0	0	2,528,012	208,926	1,323,329	208,926	19,710	185,564	1,335,944	1,335,944
TOTAL VARIABLE O&M COST	0	0	2,528,012	1,214,737	2,876,177	616,100	658,683	175,564	1,635,984	1,635,984
TOTAL FIRST YEAR O&M COST	0	70,000	2,633,012	1,522,237	3,353,177	0	858,683	175,564	1,635,984	1,635,984
FIRST YEAR DEBT SERVICE (\$)	0	827,612	1,952,796	2,104,916	14,045,575	0	547,919	0	0	4,602,887
TOTAL FIRST YEAR COST (\$)	0	897,612	4,586,808	3,627,153	17,398,753	0	1,206,601	175,564	0	6,366,619
Power Consumption (MW)	0.0	0.0	6.4	0.5	3.4	0.1	0.5	0.1	0.1	3.4
Annual Power Usage (Million MW-Hr/yr)	0.0	0.0	50.6	4.2	26.5	0.4	4.2	0.4	0.4	26.7
CONTROL COST (\$/Ton Removed)										
NOx Removal Rate (%)	0.0%	46.7%	51.1%	55.8%	84.4%	0.0%	0.0%	0.0%	0.0%	0.0%
NOx Removed (Tons/yr)	0	4,967	5,440	5,913	8,987	0	0	0	0	0
First Year Average Control Cost (\$/Ton NOx Rem.)	0	181	643	613	1,936	0	0	0	0	0
Incremental Control Cost (\$/Ton NOx Removed)	0	181	7,787	2,865	4,479	0	0	0	0	0
SO2 Removal Rate (%)	86.1%	0.0%	0.0%	0.0%	0.0%	0.0%	40.1%	0.0%	0.0%	0.0%
SO2 Removed (Tons/yr)	0	0	0	0	0	0	1,585	0	0	0
First Year Average Control Cost (\$/Ton SO2 Rem.)	0	0	0	0	0	0	761	0	0	0
Incremental Control Cost (\$/Ton SO2 Removed)	Base	0	0	0	0	0	8-1	0	0	0
PM Removal Rate (%)	99.85%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	50.00%
PM Removed (Tons/yr)	0	0	0	0	0	0	0	0	0	365
First Year Average Control Cost (\$/Ton PM Rem.)	0	0	0	0	0	0	#DN/01	#DN/01	#DN/01	17,946
Incremental Control Cost (\$/Ton PM Removed)	Base	0	0	0	0	0	9-1	9-1	9-1	17,452
PRESENT WORTH COST (\$)	0	9,555,250	52,897,883	40,725,706	188,597,104	0	13,807,503	2,145,015	0	69,935,356

INPUT CALCULATIONS											
Boiler Design: Tangential-Fired PC											
Parameter	Current Operation			NOx Control			SO2 Control		PM Control		Comments
	1	2	3	4	5	8	9	10			
Case	LNCFS-1 & Windbox Mods. Wet FGD	LNB w/OFA Wet FGD	ROFA Wet FGD	LNB w/OFA & SNCR	LNB w/OFA & SCR	LNCFS-1 & Windbox Mods. Upgraded Wet FGD	LNCFS-1 & Windbox Mods. Wet FGD Flue Gas Conditioning	LNCFS-1 & Windbox Mods. Wet FGD			
PM Emission Control System	ESP	ESP	ESP	ESP	ESP	ESP	ESP	Fabric Filter			
Unit Design and Coal Characteristics											
Type of Unit	PC	PC	PC	PC	PC	PC	PC	PC	PC	PC	
Net Power Output (KW)	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000	
Net Plant Heat Rate (Btu/kWh)	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	
Boiler Fuel	Bridger Mine	Bridger Mine	Bridger Mine	Bridger Mine	Bridger Mine	Bridger Mine	Bridger Mine	Bridger Mine	Bridger Mine	Bridger Mine	
Coal Heating Value (Btu/lb)	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660	
Coal Sulfur Content (wt %)	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	
Coal Ash Content (wt %)	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	
Boiler Heat Input, each (MMBtu/Hr)	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	
Coal Flow Rate (Lb/Hr)	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077	
(Ton/Yr)	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	
(MMBtu/Yr)	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	
Emissions											
Uncontrolled SO2 (Lb/Hr)	7,210	1,002	1,002	1,002	1,002	1,002	1,002	1,002	1,002	1,002	
(Lb/MMBtu)	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	
(Lb Moles/Hr)	112.64	15.64	15.64	15.64	15.64	15.64	15.64	15.64	15.64	15.64	
(Tons/Yr)	28,421	3,950	3,950	3,950	3,950	3,950	3,950	3,950	3,950	3,950	
SO2 Removal Rate (%)	86.4%	0.0%	0.0%	0.0%	0.0%	40.7%	0.0%	0.0%	0.0%	0.0%	
(Lb/Hr)	6,208	0	0	0	0	402	0	0	0	0	
(Ton/Yr)	24,471	0	0	0	0	1,585	0	0	0	0	
SO2 Emission Rate (Lb/Hr)	1,002	1,002	1,002	1,002	1,002	600	1,002	1,002	1,002	1,002	
(Lb/MMBtu)	0.17	0.17	0.17	0.17	0.17	0.10	0.17	0.17	0.17	0.17	
(Ton/Yr)	3,950	3,950	3,950	3,950	3,950	2,365	3,950	3,950	3,950	3,950	
Uncontrolled NOx (Lb/Hr)	2,700	2,700	2,700	2,700	2,700	2,700	2,700	2,700	2,700	2,700	
(Lb/MMBtu)	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	
(Lb Moles/Hr)	89.96	89.96	89.96	89.96	89.96	89.96	89.96	89.96	89.96	89.96	
(Tons/Yr)	10,643	10,643	10,643	10,643	10,643	10,643	10,643	10,643	10,643	10,643	
NOx Removal Rate (%)	0.0%	46.7%	51.1%	55.6%	84.4%	0%	0%	0%	0%	0%	
(Lb/Hr)	0	1,260	1,380	1,500	2,280	0	0	0	0	0	
(Lb Moles/Hr)	0.00	41.98	45.98	49.98	75.97	0.00	0.00	0.00	0.00	0.00	
(Ton/Yr)	0	4,957	5,440	5,913	8,987	0	0	0	0	0	
NOx Emission Rate (Lb/Hr)	2,700	1,440	1,320	1,200	420	2,700	2,700	2,700	2,700	2,700	
(Lb/MMBtu)	0.45	0.24	0.22	0.20	0.07	0.45	0.45	0.45	0.45	0.45	
(Ton/Yr)	10,643	5,676	5,203	4,730	1,656	10,643	10,643	10,643	10,643	10,643	
Uncontrolled Fly Ash (Lb/Hr)	51,177	180	180	180	180	180	180	180	180	180	
(Lb/MMBtu)	8.530	0.030	0.030	0.030	0.030	0.030	0.030	0.030	0.030	0.030	
(Lb Moles/Hr)	1,706.3	6.0	6.0	6.0	6.0	6.0	6.0	6.0	6.0	6.0	
(Tons/Yr)	201,739	710	710	710	710	710	710	710	710	710	
Fly Ash Removal Rate (%)	89.65%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	
(Lb/Hr)	50,997	0	0	0	0	0	0	0	0	0	
(Ton/Yr)	201,029	0	0	0	0	0	0	0	0	0	
Fly Ash Emission Rate (Lb/Hr)	180	180	180	180	180	180	180	180	180	180	
(Lb/MMBtu)	0.030	0.030	0.030	0.030	0.030	0.030	0.030	0.030	0.030	0.030	
(Ton/Yr)	710	710	710	710	710	710	710	710	710	710	

Parameter	Current Operation	NOx Control				SO2 Control		PM Control			Comments
		LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter			
Case	1	2	3	4	5	6	7	8	9	10	
General Plant Data											
Annual Operation (Hours/Year)	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	
Annual On-Site Power Plant Capacity Factor	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	
Economic Factors											
Interest Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	
Discount Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	
Plant Economic Life (Years)	20	20	20	20	20	20	20	20	20	20	
Installed Capital Costs											
NOx Emission Control System (\$2006)	0	8,709,001	20,628,122	22,127,239	147,628,474	0	0	0	0	0	
SO2 Emission Control System (\$2006)	0	0	0	0	0	5,769,814	0	0	0	0	
PM Emission Control System (\$2006)	0	0	0	0	0	0	0	0	0	0	
Total Emission Control System (\$2006)	0	8,709,001	20,628,122	22,127,239	147,628,474	5,769,814	0	0	0	0	
NOx Emission Control System (\$8kW)	0	16	39	42	279	0	0	0	0	0	
SO2 Emission Control System (\$8kW)	0	0	0	0	0	11	0	0	0	0	
PM Emission Control System (\$8kW)	0	0	0	0	0	0	0	0	0	0	
Total Emission Control Systems (\$8kW)	0	16	39	42	279	11	0	0	0	0	
Total Fixed Operating & Maintenance Costs											
Operating Labor (\$)	0	0	0	0	0	0	0	0	0	0	
Maintenance Material (\$)	0	29,000	42,000	125,000	190,000	25,550	0	0	0	0	
Maintenance Labor (\$)	0	42,000	63,000	184,500	285,000	17,033	0	0	10,000	51,999	
Administrative Labor (\$)	0	0	0	0	0	0	0	0	0	0	
Total Fixed O&M Cost (\$)	0	70,000	105,000	307,500	475,000	42,583	0	0	10,000	127,749	
Annual Fixed O&M Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
Water Cost											
Makeup Water Usage (Gpm)	0	0	0	0	0	0	0	0	0	0	
Unit Price (\$/1000 Gallons)	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	
First Year Water Cost (\$)	0	0	0	0	0	0	0	0	0	0	
Annual Water Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
Reagent Cost											
Unit Cost (\$/Ton)	None	None	None	Urea	Anhydrous NH3	Soda Ash	Elemental Sulfur	None	None	None	
Unit Cost (\$/Lb)	0.00	0.00	0.00	0.370	400	80.00	370	0.00	0.00	0.00	
Molar Stoichiometry	0.00	0.00	0.00	0.185	0.200	0.040	0.185	0.00	0.00	0.00	
Reagent Purity (wt %)	0.00	0.00	0.00	0.45	1.00	1.02	0.00	0.00	0.00	0.00	
Reagent Usage (Lb/Hr)	0	0	0	100%	100%	100%	100%	100%	100%	90%	
First Year Reagent Cost (\$)	0	0	0	630	579	678	100	0	0	0	
Annual Reagent Cost Escalation Rate (%)	2.00%	2.00%	2.00%	1,005,811	912,848	213,921	145,864	0	0	0	
SCR Catalyst Life Basis Escalation Cost											
SCR Catalyst (lb) / No. FF Bags	0	0	0	0	SCR Catalyst	Bags	Bags	Bags	Bags	Bags	
SCR Catalyst (\$/lb) / Bag Cost (\$/ea)	3,000	3,000	3,000	3,000	244	104	104	104	104	104	
First Year SCR Catalyst / Bag Replac. Cost (\$)	0	0	0	0	642,000	0	0	0	0	0	
Annual SCR Catalyst / Bag Cost Esc. Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
FGD Waste Disposal Cost											
FGD Solid Waste Disposal Rate, Dry (Lb/Hr)	0	0	0	0	0	1,853	0	0	0	0	
FGD Waste Disposal Unit Cost (\$/Dry Ton)	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	
First Year FGD Waste Disposal Cost (\$)	0	0	0	0	0	177,714	0	0	0	0	
Annual Waste Disposal Cost Esc. Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
Auxiliary Power Cost											
Auxiliary Power Requirement (% of Plant Output)	0.00%	0.00%	1.21%	0.10%	0.63%	0.10%	0.01%	0.64%	0.01%	0.64%	
Unit Cost (\$/006MWH) (MW)	0.00	0.00	6.41	0.53	3.36	0.53	0.05	3.39	0.05	3.39	
First Year Auxiliary Power Cost (\$)	0	0	50.00	50.00	50.00	50.00	50.00	50.00	50.00	50.00	
Annual Power Cost Escalation Rate (%)	2.00%	2.00%	2,628,012	208,926	1,323,329	208,926	19,710	1,335,944	19,710	1,335,944	
	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	

Input Tables

Table 1 - Cases

Index No.	Name of Unit / Case	NOx Control			SO2 Control			PM Control		
		Existing	2	3	4	5	6	7	8	9
1	Dave Johnston Unit 3	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Dry FGD w/Fabric Filter	Wet FGD w/ESP	N/A	Fabric Filter
2	Dave Johnston Unit 4	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Dry FGD w/Fabric Filter	Wet FGD w/Fabric Filter	N/A	Fabric Filter
3	Jim Bridger Unit 1	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	N/A	Upgraded Wet FGD	Plus Gas Conditioning	Fabric Filter
4	Jim Bridger Unit 2	Current Operation	Exhst. LNB w/OFA	ROFA	SNCR	SNCR	N/A	Upgraded Wet FGD	Plus Gas Conditioning	Fabric Filter
5	Jim Bridger Unit 3	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	N/A	Upgraded Wet FGD	Plus Gas Conditioning	Fabric Filter
6	Jim Bridger Unit 4	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	N/A	Upgraded Wet FGD	Plus Gas Conditioning	Fabric Filter
7	Naughton Unit 1	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	N/A	Upgraded Wet FGD	Plus Gas Conditioning	Fabric Filter
8	Naughton Unit 2	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Dry FGD w/ESP	Wet FGD w/ESP	Plus Gas Conditioning	Fabric Filter
9	Naughton Unit 3	Current Operation	Exhst. LNB w/OFA	ROFA	SNCR	SNCR	Dry FGD w/ESP	Wet FGD w/ESP	Plus Gas Conditioning	Fabric Filter
10	Wyodak Unit 1	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Upgraded Dry FGD	Wet FGD	Plus Gas Conditioning	Fabric Filter

Table 2 - Unit Design and Coal Characteristics

Index No.	Name of Unit	Current Emission Control Systems			Unit Design			Coal Quality		
		NOx	SO2	PM	Boiler Design	Net Power Output (kW)	NET Plant Heat Rate (Btu/kWhr)	Coal	Heating Value, HHV (Btu/Lb)	Ash Content (Wt.%)
1	Dave Johnston Unit 3	None	None	ESP	3-Cal Burner, Opposed, Wall-Fired FC	250,000	11,200	Dry Fork PRB	7,784	5.01%
2	Dave Johnston Unit 4	Windbox Mode, LNCFS-1 & Windbox Mode	Lime Added to Venturi Scrubber	Venturi Scrubber	Tangential-Fired FC	360,000	11,390	Dry Fork PRB, Bridger Mine	7,784	5.01%
3	Jim Bridger Unit 1	None	Wet FGD	ESP	Tangential-Fired FC	530,000	11,320	Underground	9,660	10.30%
4	Jim Bridger Unit 2	LNB - TFS 2000	Wet FGD	ESP	Tangential-Fired FC	530,000	11,320	Underground	9,660	10.30%
5	Jim Bridger Unit 3	Windbox Mode, LNCFS-1 & Windbox Mode	Wet FGD	ESP	Tangential-Fired FC	530,000	11,320	Underground	9,660	10.30%
6	Jim Bridger Unit 4	Windbox Mode, LNCFS-1 & Windbox Mode	Wet FGD	ESP	Tangential-Fired FC	530,000	11,320	Underground	9,660	10.30%
7	Naughton Unit 1	None	None	ESP	Tangential-Fired FC	173,000	10,684	Kemmerer Mine	9,970	4.64%
8	Naughton Unit 2	None	None	ESP	Tangential-Fired FC	225,000	10,574	Kemmerer Mine	9,970	4.64%
9	Naughton Unit 3	LNCFS II LNB	Wet FGD	ESP	Tangential-Fired FC	356,000	10,336	Kemmerer Mine	9,970	4.64%
10	Wyodak Unit 1	LNB	Dry FGD	ESP	Opposed Wall-Fired FC	335,000	12,087	Clovis Point Mine	7,977	7.46%

Table 3 - Emissions

Index No.	Name of Unit	Current Emission Rates (Lb/MMBtu)		Controlled		Controlled		Controlled		Controlled		Controlled		Controlled		Controlled	
		SO2	PM	SO2	PM	SO2	PM	SO2	PM	SO2	PM	SO2	PM	SO2	PM	SO2	PM
1	Dave Johnston Unit 3	1.20	0.70	0.200	0.200	0.27	0.21	0.20	0.07	0.07	0.15	0.10	0.21	0.15	0.10	0.10	0.015
2	Dave Johnston Unit 4	0.33	0.48	0.061	0.061	0.15	0.19	0.12	0.07	0.07	0.15	0.10	N/A	0.15	0.10	0.10	0.015
3	Jim Bridger Unit 1	0.27	0.45	0.045	0.045	0.24	0.22	0.20	0.07	0.07	N/A	0.10	N/A	N/A	0.10	0.10	0.015
4	Jim Bridger Unit 2	0.27	0.24	0.074	0.074	0.24	0.22	0.20	0.07	0.07	N/A	0.10	N/A	N/A	0.10	0.10	0.015
5	Jim Bridger Unit 3	0.27	0.45	0.057	0.057	0.24	0.22	0.20	0.07	0.07	N/A	0.10	N/A	N/A	0.10	0.10	0.015
6	Jim Bridger Unit 4	0.17	0.45	0.030	0.030	0.24	0.22	0.20	0.07	0.07	N/A	0.10	N/A	N/A	0.10	0.10	0.015
7	Naughton Unit 1	1.20	0.88	0.086	0.086	0.24	0.28	0.18	0.07	0.07	0.18	0.10	0.18	0.15	0.10	0.10	0.015
8	Naughton Unit 2	1.20	0.54	0.064	0.064	0.24	0.28	0.18	0.07	0.07	0.18	0.10	0.18	0.15	0.10	0.10	0.015
9	Naughton Unit 3	0.60	0.45	0.084	0.084	0.23	0.30	0.25	0.07	0.07	N/A	0.10	N/A	N/A	0.10	0.10	0.015
10	Wyodak Unit 1	0.60	0.60	0.030	0.030	0.23	0.22	0.18	0.07	0.07	N/A	0.10	0.23	N/A	0.10	0.10	0.015

Table 4 - Case 1 O&M Costs (Current Operation)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ -	\$ -	\$ -	-	None	-	-
2	Dave Johnston Unit 4	\$ -	\$ -	\$ -	\$ -	-	None	-	-
3	Jim Bridger Unit 1	\$ -	\$ -	\$ -	\$ -	-	None	-	-
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	-	None	-	-
5	Jim Bridger Unit 3	\$ -	\$ -	\$ -	\$ -	-	None	-	-
6	Jim Bridger Unit 4	\$ -	\$ -	\$ -	\$ -	-	None	-	-
7	Naughton Unit 1	\$ -	\$ -	\$ -	\$ -	-	None	-	-
8	Naughton Unit 2	\$ -	\$ -	\$ -	\$ -	-	None	-	-
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	-	None	-	-
10	Wyodak Unit 1	\$ -	\$ -	\$ -	\$ -	-	None	-	-

Table 5 - Case 2 O&M Costs (LNB w/OFA)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ 40,000	\$ 60,000	\$ -	-	None	-	-
2	Dave Johnston Unit 4	\$ -	\$ 35,000	\$ 64,000	\$ -	-	None	-	-
3	Jim Bridger Unit 1	\$ -	\$ 28,000	\$ 42,000	\$ -	-	None	-	-
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	-	None	-	-
5	Jim Bridger Unit 3	\$ -	\$ 28,000	\$ 42,000	\$ -	-	None	-	-
6	Jim Bridger Unit 4	\$ -	\$ 28,000	\$ 42,000	\$ -	-	None	-	-
7	Naughton Unit 1	\$ -	\$ 32,000	\$ 48,000	\$ -	-	None	-	-
8	Naughton Unit 2	\$ -	\$ 32,000	\$ 48,000	\$ -	-	None	-	-
9	Naughton Unit 3	\$ -	\$ 24,000	\$ 36,000	\$ -	-	None	-	-
10	Wyodak Unit 1	\$ -	\$ -	\$ -	\$ -	-	None	-	-

Table 6 - Case 3 O&M Costs (Mobotec ROFA)

Index No.	Name of Unit	Annual Fixed O&M Costs					Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Aux. Power Usage (MW)		
1	Dave Johnston Unit 3	\$ -	\$ 60,000	\$ 90,000	\$ -	-	None	-	2.76		
2	Dave Johnston Unit 4	\$ -	\$ 54,000	\$ 81,000	\$ -	-	None	-	4.33		
3	Jim Bridger Unit 1	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41		
4	Jim Bridger Unit 2	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41		
5	Jim Bridger Unit 3	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41		
6	Jim Bridger Unit 4	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41		
7	Naughton Unit 1	\$ -	\$ 48,000	\$ 72,000	\$ -	-	None	-	1.42		
8	Naughton Unit 2	\$ -	\$ 48,000	\$ 72,000	\$ -	-	None	-	2.81		
9	Naughton Unit 3	\$ -	\$ 48,000	\$ 72,000	\$ -	-	None	-	4.47		
10	Wyodak Unit 1	\$ -	\$ 35,000	\$ 54,000	\$ -	-	None	-	5.22		

Table 7 - Case 4 O&M Costs (LNB w/OFA & SNCR)

Index No.	Name of Unit	Annual Fixed O&M Costs					Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Aux. Power Usage (MW)		
1	Dave Johnston Unit 3	\$ -	\$ 98,000	\$ 147,000	\$ -	-	Urea	0.41	0.23		
2	Dave Johnston Unit 4	\$ -	\$ 105,000	\$ 157,500	\$ -	-	Urea	0.45	0.33		
3	Jim Bridger Unit 1	\$ -	\$ 123,000	\$ 184,500	\$ -	-	Urea	0.45	0.53		
4	Jim Bridger Unit 2	\$ -	\$ 95,000	\$ 142,500	\$ -	-	Urea	0.45	0.63		
5	Jim Bridger Unit 3	\$ -	\$ 122,000	\$ 183,000	\$ -	-	Urea	0.45	0.52		
6	Jim Bridger Unit 4	\$ -	\$ 123,000	\$ 184,500	\$ -	-	Urea	0.45	0.53		
7	Naughton Unit 1	\$ -	\$ 83,000	\$ 124,500	\$ -	-	Urea	0.45	0.16		
8	Naughton Unit 2	\$ -	\$ 93,000	\$ 139,500	\$ -	-	Urea	0.51	0.22		
9	Naughton Unit 3	\$ -	\$ 75,000	\$ 112,500	\$ -	-	Urea	0.45	0.33		
10	Wyodak Unit 1	\$ -	\$ 93,000	\$ 139,500	\$ -	-	Urea	0.45	0.34		

Table 8 - Case 5 O&M Costs (LNB w/OFA & SCR)

Index No.	Name of Unit	Annual Fixed O&M Costs					Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Annual SCR Catalyst Replace. (m3)	Aux. Power Usage (MW)	
1	Dave Johnston Unit 3	\$ -	\$ 165,000	\$ 232,500	\$ -	-	Anhydrous NH3	1.00	128	1.57	
2	Dave Johnston Unit 4	\$ -	\$ 166,000	\$ 249,000	\$ -	-	Anhydrous NH3	1.00	123	2.29	
3	Jim Bridger Unit 1	\$ -	\$ 190,000	\$ 285,000	\$ -	-	Anhydrous NH3	1.00	198	3.28	
4	Jim Bridger Unit 2	\$ -	\$ 162,000	\$ 243,000	\$ -	-	Anhydrous NH3	1.00	188	3.25	
5	Jim Bridger Unit 3	\$ -	\$ 190,000	\$ 285,000	\$ -	-	Anhydrous NH3	1.00	200	3.22	
6	Jim Bridger Unit 4	\$ -	\$ 190,000	\$ 285,000	\$ -	-	Anhydrous NH3	1.00	214	3.36	
7	Naughton Unit 1	\$ -	\$ 132,000	\$ 198,000	\$ -	-	Anhydrous NH3	1.00	67	0.98	
8	Naughton Unit 2	\$ -	\$ 160,000	\$ 240,000	\$ -	-	Anhydrous NH3	1.00	101	1.34	
9	Naughton Unit 3	\$ -	\$ 166,000	\$ 234,000	\$ -	-	Anhydrous NH3	1.00	167	1.99	
10	Wyodak Unit 1	\$ -	\$ 181,000	\$ 271,500	\$ -	-	Anhydrous NH3	1.00	180	2.42	

Table 9 - Case 6 O&M Costs (Dry FGD)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Annual FF Bag Replace.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 606,128	\$ 714,176	\$ 476,928	\$ -	173	Line	1.15	-	2.49
2	Dave Johnston Unit 4	\$ -	\$ -	\$ -	\$ -	-	Line	-	-	-
3	Jim Bridger Unit 1	\$ -	\$ -	\$ -	\$ -	-	Line	-	-	-
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	-	Line	-	-	-
5	Jim Bridger Unit 3	\$ -	\$ -	\$ -	\$ -	-	Line	-	-	-
6	Jim Bridger Unit 4	\$ -	\$ -	\$ -	\$ -	-	Line	-	-	-
7	Naughton Unit 1	\$ 606,128	\$ 687,643	\$ 391,762	\$ -	120	Line	1.40	-	1.64
8	Naughton Unit 2	\$ 606,128	\$ 869,174	\$ 573,044	\$ -	185	Line	1.40	-	2.25
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	-	Line	-	-	-
10	Wyodak Unit 1	\$ -	\$ 21,900	\$ 14,600	\$ -	25	Line	1.10	-	0.11

Table 10 - Case 7 O&M Costs (Dry FGD w/Fabric Filter)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Annual FF Bag Replace.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 606,128	\$ 714,176	\$ 476,928	\$ -	173	Line	1.15	1,457	3.88
2	Dave Johnston Unit 4	\$ 606,128	\$ 1,102,288	\$ 734,858	\$ -	248	Line	1.10	1,798	4.54
3	Jim Bridger Unit 1	\$ -	\$ -	\$ -	\$ -	-	Line	-	-	-
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	-	Line	-	-	-
5	Jim Bridger Unit 3	\$ -	\$ -	\$ -	\$ -	-	Line	-	-	-
6	Jim Bridger Unit 4	\$ -	\$ -	\$ -	\$ -	-	Line	-	-	-
7	Naughton Unit 1	\$ 606,128	\$ 632,660	\$ 459,286	\$ -	120	Line	1.15	865	2.66
8	Naughton Unit 2	\$ 606,128	\$ 905,190	\$ 640,568	\$ -	165	Line	1.15	1,193	3.63
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	-	Line	-	-	-
10	Wyodak Unit 1	\$ -	\$ -	\$ -	\$ -	-	Line	-	-	-

Table 11 - Case 8 O&M Costs (Wet FGD)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Annual FF Bag Replace.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 809,804	\$ 1,182,687	\$ 783,391	\$ -	230	Line	1.02	-	3.45
2	Dave Johnston Unit 4	\$ 809,804	\$ 1,430,784	\$ 953,866	\$ -	330	Line	1.02	1,798	6.29
3	Jim Bridger Unit 1	\$ -	\$ 26,960	\$ 17,033	\$ -	53	Soda Ash	1.02	-	0.53
4	Jim Bridger Unit 2	\$ -	\$ 26,960	\$ 17,033	\$ -	53	Soda Ash	1.02	-	0.53
5	Jim Bridger Unit 3	\$ -	\$ 26,960	\$ 17,033	\$ -	52	Soda Ash	1.02	-	0.52
6	Jim Bridger Unit 4	\$ -	\$ 26,960	\$ 17,033	\$ -	27	Soda Ash	1.02	-	0.53
7	Naughton Unit 1	\$ 809,804	\$ 963,589	\$ 642,393	\$ -	160	Line	1.05	-	2.40
8	Naughton Unit 2	\$ 809,804	\$ 1,226,386	\$ 817,591	\$ -	220	Line	1.05	-	3.30
9	Naughton Unit 3	\$ -	\$ 21,900	\$ 14,600	\$ -	66	Soda Ash	1.02	-	0.33
10	Wyodak Unit 1	\$ 303,677	\$ 328,496	\$ 219,388	\$ -	82	Line	1.02	-	1.75

Table 12 - Case 9 O&M Costs (Flue Gas Conditioning)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements					
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup-Water Use (Gpm)	Reagent	Reagent Usage (Lb/Hr)	Annual FF Bag Replace.	Aux. Power Usage (MW)	
1	Dave Johnston Unit 3	\$ -	\$ -	\$ -	\$ -	-	None	-	-	-	-
2	Dave Johnston Unit 4	\$ -	\$ -	\$ -	\$ -	-	None	-	-	-	-
3	Jim Bridger Unit 1	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	100	-	-	0.05
4	Jim Bridger Unit 2	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	100	-	-	0.05
5	Jim Bridger Unit 3	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	100	-	-	0.05
6	Jim Bridger Unit 4	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	100	-	-	0.05
7	Naughton Unit 1	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	33	-	-	0.05
8	Naughton Unit 2	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	45	-	-	0.05
9	Naughton Unit 3	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	67	-	-	0.05
10	Wyodak Unit 1	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	63	-	-	0.05

Table 13 - Case 10 O&M Costs (Fabric Filter)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements					
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Annual FF Bag Replace.	Aux. Power Usage (MW)	
1	Dave Johnston Unit 3	\$ -	\$ 45,016	\$ 67,524	\$ -	-	None	-	1,467	1.38	
2	Dave Johnston Unit 4	\$ -	\$ 68,133	\$ 102,199	\$ -	-	None	-	1,788	2.35	
3	Jim Bridger Unit 1	\$ -	\$ 51,089	\$ 76,649	\$ -	-	None	-	2,885	3.39	
4	Jim Bridger Unit 2	\$ -	\$ 51,089	\$ 76,649	\$ -	-	None	-	2,885	3.37	
5	Jim Bridger Unit 3	\$ -	\$ 51,089	\$ 76,649	\$ -	-	None	-	2,827	3.33	
6	Jim Bridger Unit 4	\$ -	\$ 51,089	\$ 76,649	\$ -	-	None	-	2,885	3.39	
7	Naughton Unit 1	\$ -	\$ 45,016	\$ 67,524	\$ -	-	None	-	865	1.01	
8	Naughton Unit 2	\$ -	\$ 45,016	\$ 67,524	\$ -	-	None	-	1,193	1.38	
9	Naughton Unit 3	\$ -	\$ 48,666	\$ 72,999	\$ -	-	None	-	1,793	2.06	
10	Wyodak Unit 1	\$ -	\$ 48,666	\$ 72,999	\$ -	-	None	-	1,798	2.06	

Table 14 - Major Materials Design and Supply Costs

Index No.	Name of Unit	NOx Control			SO2 Control			PM Control		
		2	3	4	5	6	7	8	9	10
1	Dave Johnston Unit 3	\$ 3,221,912	\$ 3,856,617	\$ 6,173,000	\$ 49,355,000	\$ 83,871,000	\$ 142,077,000	\$ 108,865,869	\$ -	\$ 18,359,000
2	Dave Johnston Unit 4	\$ 2,673,501	\$ 4,343,192	\$ 7,171,085	\$ 66,200,000	\$ -	\$ 137,267,000	\$ 178,174,384	\$ -	\$ 30,853,530
3	Jim Bridger Unit 1	\$ 2,991,992	\$ 6,055,955	\$ 9,528,000	\$ 80,923,000	\$ -	\$ -	\$ 8,010,093	\$ -	\$ 29,814,000
4	Jim Bridger Unit 2	\$ -	\$ 6,055,955	\$ 9,528,000	\$ 80,923,000	\$ -	\$ -	\$ 8,010,093	\$ -	\$ 29,814,000
5	Jim Bridger Unit 3	\$ 2,991,992	\$ 6,055,955	\$ 9,528,000	\$ 83,019,000	\$ -	\$ -	\$ 3,549,000	\$ -	\$ 29,814,000
6	Jim Bridger Unit 4	\$ 2,602,423	\$ 2,675,792	\$ 7,257,000	\$ 37,232,000	\$ -	\$ -	\$ -	\$ -	\$ -
7	Naughton Unit 1	\$ 2,570,674	\$ 3,123,533	\$ 6,176,000	\$ 47,934,000	\$ 26,819,000	\$ 42,301,000	\$ 44,000,000	\$ 800,000	\$ 15,462,000
8	Naughton Unit 2	\$ -	\$ 4,351,377	\$ 11,203,578	\$ 67,373,000	\$ 39,262,000	\$ 57,621,000	\$ 56,000,000	\$ 800,000	\$ 18,359,000
9	Naughton Unit 3	\$ 3,167,636	\$ 4,800,245	\$ 7,234,960	\$ 72,479,000	\$ 995,100	\$ -	\$ 176,174,584	\$ 1,247,061	\$ 20,105,000
10	Wyodak Unit 1	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -

Jim Bridger Unit 4											
Year	Date	TOTAL FIXED O&M COST		Makeup Water Cost	Reagent Cost	SCR Catalyst/FF Bag Cost	Waste Disposal Cost	LNB w/OFA		TOTAL ANNUAL COST	Control Cost (\$/Ton NOx Removed)
		Electric Power Cost	Debt Service								
0	2013										
1	2014	70,000								827,612	843
2	2015	71,400								827,612	853
3	2016	72,828								827,612	863
4	2017	74,285								827,612	873
5	2018	75,770								827,612	883
6	2019	77,286								827,612	893
7	2020	78,831								827,612	904
8	2021	80,408								827,612	915
9	2022	82,016								827,612	926
10	2023	83,656								827,612	937
11	2024	85,330								827,612	949
12	2025	87,036								827,612	961
13	2026	88,777								827,612	973
14	2027	90,552								827,612	985
15	2028	92,364								827,612	997
16	2029	94,211								827,612	1,010
17	2030	96,095								827,612	1,023
18	2031	98,017								827,612	1,037
19	2032	99,977								827,612	1,050
20	2033	101,977								827,612	1,064
Present Worth (% of PW)		855,250	9.0%	0.0%	0.0%	0.0%	0.0%	0.0%	8,700,001	9,555,250	100.0%

Jim Bridger Unit 4											
Year	Date	TOTAL FIXED O&M COST		Makeup Water Cost	Reagent Cost	SCR Catalyst/FF Bag Cost	Waste Disposal Cost	ROFA		TOTAL ANNUAL COST	Control Cost (\$/Ton NOx Removed)
		Electric Power Cost	Debt Service								
0	2013										
1	2014	105,000								2,528,012	843
2	2015	107,100								2,578,573	853
3	2016	109,242								2,630,144	863
4	2017	111,427								2,682,747	873
5	2018	113,655								2,736,402	883
6	2019	115,928								2,791,130	893
7	2020	118,247								2,846,953	904
8	2021	120,612								2,903,892	915
9	2022	123,024								2,961,970	926
10	2023	125,485								3,021,209	937
11	2024	127,994								3,081,633	949
12	2025	130,554								3,143,266	961
13	2026	133,165								3,206,131	973
14	2027	135,829								3,270,254	985
15	2028	138,548								3,335,659	997
16	2029	141,316								3,402,372	1,010
17	2030	144,142								3,470,413	1,023
18	2031	147,028								3,539,828	1,037
19	2032	149,965								3,610,624	1,050
20	2033	152,953								3,682,837	1,064
Present Worth (% of PW)		1,282,875	2.4%	0.0%	0.0%	0.0%	0.0%	0.0%	30,885,886	33,615,886	100.0%

Jim Bridger Unit 4												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton NOx Removed)	
0	2013											
1	2014	307,900		1,005,811			208,926	1,214,737	2,104,916	3,627,153	613	
2	2015	313,650		1,025,927			213,105	1,239,032	2,104,916	3,657,598	619	
3	2016	319,923		1,046,446			217,367	1,263,612	2,104,916	3,686,651	624	
4	2017	326,321		1,067,375			221,714	1,289,088	2,104,916	3,720,326	629	
5	2018	332,848		1,088,722			226,148	1,314,870	2,104,916	3,752,634	635	
6	2019	339,505		1,110,496			230,671	1,341,168	2,104,916	3,785,589	640	
7	2020	346,295		1,132,705			235,285	1,367,991	2,104,916	3,819,202	646	
8	2021	353,221		1,155,381			239,990	1,395,351	2,104,916	3,853,488	652	
9	2022	360,285		1,178,468			244,790	1,423,258	2,104,916	3,888,459	658	
10	2023	367,491		1,202,037			249,686	1,451,723	2,104,916	3,924,130	664	
11	2024	374,841		1,226,078			254,680	1,480,757	2,104,916	3,960,514	670	
12	2025	382,338		1,250,599			259,773	1,510,373	2,104,916	3,997,626	676	
13	2026	389,984		1,275,611			264,969	1,540,580	2,104,916	4,035,481	683	
14	2027	397,784		1,301,124			270,268	1,571,392	2,104,916	4,074,082	689	
15	2028	405,740		1,327,146			275,673	1,602,819	2,104,916	4,113,475	696	
16	2029	413,855		1,353,689			281,187	1,634,876	2,104,916	4,153,648	703	
17	2030	422,132		1,380,763			286,811	1,667,573	2,104,916	4,194,621	709	
18	2031	430,574		1,408,378			292,547	1,700,925	2,104,916	4,236,415	717	
19	2032	439,185		1,436,546			298,398	1,734,943	2,104,916	4,279,045	724	
20	2033	447,959		1,465,276			304,366	1,769,642	2,104,916	4,322,528	731	
Present Worth		3,756,930		12,288,849			2,552,627	14,841,477	22,127,239	40,725,705	344	
(% of PW)		9.2%	0.0%	30.2%	0.0%	0.0%	6.3%	96.4%	54.3%	100.0%		

Jim Bridger Unit 4												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton NOx Removed)	
0	2013											
1	2014	475,000		912,848	642,000		1,323,329	2,878,177	14,043,575	17,386,753	1,936	
2	2015	484,500		931,105	654,840		1,349,736	2,935,741	14,043,575	17,463,816	1,943	
3	2016	494,190		949,722	667,937		1,376,782	2,994,456	14,043,575	17,532,221	1,951	
4	2017	504,074		968,722	681,296		1,404,328	3,054,395	14,043,575	17,601,964	1,959	
5	2018	514,155		988,096	694,920		1,432,414	3,115,432	14,043,575	17,673,162	1,966	
6	2019	524,438		1,007,658	709,820		1,461,053	3,177,740	14,043,575	17,745,754	1,975	
7	2020	534,927		1,028,015	725,968		1,490,284	3,241,295	14,043,575	17,819,768	1,983	
8	2021	545,626		1,048,575	737,456		1,520,080	3,306,121	14,043,575	17,895,322	1,991	
9	2022	556,668		1,069,547	752,205		1,550,491	3,372,244	14,043,575	17,972,357	2,000	
10	2023	567,989		1,090,938	767,249		1,581,501	3,439,688	14,043,575	18,050,933	2,009	
11	2024	579,622		1,112,757	782,594		1,613,131	3,509,482	14,043,575	18,131,080	2,017	
12	2025	590,603		1,135,012	798,246		1,645,394	3,579,652	14,043,575	18,212,830	2,027	
13	2026	602,415		1,157,712	814,211		1,678,302	3,650,225	14,043,575	18,296,215	2,036	
14	2027	614,463		1,180,866	830,485		1,711,868	3,723,229	14,043,575	18,381,268	2,045	
15	2028	626,752		1,204,484	847,105		1,746,105	3,797,684	14,043,575	18,468,022	2,055	
16	2029	639,287		1,228,573	864,047		1,781,027	3,873,648	14,043,575	18,556,511	2,065	
17	2030	652,073		1,253,145	881,328		1,816,648	3,951,121	14,043,575	18,646,769	2,075	
18	2031	665,115		1,278,208	898,955		1,850,981	4,030,143	14,043,575	18,739,933	2,085	
19	2032	678,417		1,303,772	916,934		1,890,040	4,110,746	14,043,575	18,835,736	2,095	
20	2033	691,985		1,329,847	935,273		1,932,841	4,192,951	14,043,575	18,935,522	2,105	
Present Worth		5,803,480		11,153,043	7,643,882		15,166,244	35,165,169	147,628,474	188,597,104	1,049	
(% of PW)		3.1%	0.0%	5.9%	4.2%	0.0%	8.6%	18.6%	76.3%	100.0%		


Jim Bridger Unit 4												
Year	Date	TOTAL FIXED O&M COST	Water Cost	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton SO2 Removed)
0	2013											
1	2014	42,593	15,539	213,921	208,926		177,714	208,926	616,100	547,919	1,206,604	761
2	2015	43,435	15,850	218,189	213,105		181,268	213,105	628,422	547,919	1,219,775	770
3	2016	44,303	16,167	222,583	217,387		184,693	217,387	640,960	547,919	1,233,212	778
4	2017	45,189	16,490	227,014	221,714		188,169	221,714	653,810	547,919	1,246,516	787
5	2018	46,093	16,820	231,555	226,148		192,563	226,148	667,098	547,919	1,260,888	795
6	2019	47,015	17,157	236,186	230,671		196,910	230,671	680,234	547,919	1,275,165	805
7	2020	47,955	17,500	240,910	235,286		200,137	235,286	693,263	547,919	1,289,702	814
8	2021	48,914	17,850	245,728	240,020		203,264	240,020	706,189	547,919	1,304,538	823
9	2022	49,893	18,207	250,645	244,866		206,291	244,866	719,022	547,919	1,319,670	833
10	2023	50,890	18,571	255,655	249,804		209,218	249,804	731,854	547,919	1,335,105	843
11	2024	51,905	18,942	260,758	254,842		212,034	254,842	744,686	547,919	1,350,849	852
12	2025	52,936	19,321	265,954	259,980		214,741	259,980	757,518	547,919	1,366,908	863
13	2026	54,005	19,707	271,243	265,218		217,339	265,218	770,350	547,919	1,383,286	873
14	2027	55,085	20,102	276,629	270,556		220,026	270,556	783,182	547,919	1,399,985	884
15	2028	56,187	20,504	282,109	275,793		222,703	275,793	796,014	547,919	1,417,036	895
16	2029	57,311	20,914	287,689	281,031		225,370	281,031	808,846	547,919	1,434,419	905
17	2030	58,457	21,332	293,367	286,268		228,037	286,268	821,678	547,919	1,452,148	916
18	2031	59,625	21,759	299,145	291,506		230,694	291,506	834,510	547,919	1,470,233	928
19	2032	60,818	22,194	305,023	296,742		233,341	296,742	847,342	547,919	1,488,690	939
20	2033	62,035	22,638	311,002	302,080		235,988	302,080	860,174	547,919	1,507,495	951
Present Worth (% of PW)		520,271	189,886	2,613,863	2,613,863	18.9%	2,171,282	2,552,627	7,527,418	5,799,814	13,807,593	436
		3.8%	1.4%				15.7%	18.5%	54.5%	41.7%	100.0%	

Flue Gas Conditioning												
Year	Date	TOTAL FIXED O&M COST	Water Cost	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton PM Removed)
0	2013											
1	2014	10,000			145,854			19,710	165,564		175,564	#DIV/0!
2	2015	10,200			148,771			20,104	168,875		179,075	#DIV/0!
3	2016	10,404			151,747			20,506	172,253		182,657	#DIV/0!
4	2017	10,612			154,781			20,916	175,698		186,310	#DIV/0!
5	2018	10,824			157,877			21,335	179,212		190,036	#DIV/0!
6	2019	11,041			161,035			21,761	182,796		193,837	#DIV/0!
7	2020	11,262			164,255			22,197	186,452		197,714	#DIV/0!
8	2021	11,487			167,540			22,641	190,181		201,668	#DIV/0!
9	2022	11,717			170,881			23,093	193,985		205,701	#DIV/0!
10	2023	11,951			174,288			23,555	197,864		209,815	#DIV/0!
11	2024	12,190			177,755			24,026	201,822		214,012	#DIV/0!
12	2025	12,434			181,281			24,507	205,858		218,292	#DIV/0!
13	2026	12,682			184,878			24,987	209,975		222,658	#DIV/0!
14	2027	12,936			188,541			25,467	214,175		227,111	#DIV/0!
15	2028	13,195			192,269			25,947	218,458		231,653	#DIV/0!
16	2029	13,459			196,060			26,427	222,827		236,286	#DIV/0!
17	2030	13,728			200,226			26,907	227,284		241,012	#DIV/0!
18	2031	14,002			204,231			27,387	231,830		245,832	#DIV/0!
19	2032	14,282			208,315			27,867	236,466		250,749	#DIV/0!
20	2033	14,568			212,482			28,347	241,195		255,764	#DIV/0!
Present Worth (% of PW)		122,179			1,782,023	83.1%		240,814	2,022,837		2,145,015	#DIV/0!
		5.7%	0.0%				0.0%	11.2%	94.3%	0.0%	100.0%	

Jim Bridger Unit 4											
Year	Date	TOTAL FIXED O&M COST	Milkout Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton PM Removed)
0	2013										
1	2014	127,749			300,040		1,335,944	1,635,984	4,602,887	6,365,619	17,946
2	2015	130,304			306,041		1,392,633	1,688,703	4,602,887	6,401,894	18,046
3	2016	132,910			312,162		1,399,916	1,702,078	4,602,887	6,437,874	18,147
4	2017	135,568			318,405		1,417,714	1,736,119	4,602,887	6,474,573	18,251
5	2018	138,279			324,773		1,445,059	1,770,841	4,602,887	6,512,007	18,355
6	2019	141,045			331,269		1,474,980	1,806,258	4,602,887	6,550,190	18,464
7	2020	143,866			337,894		1,504,490	1,842,383	4,602,887	6,589,136	18,574
8	2021	146,743			344,652		1,534,579	1,879,231	4,602,887	6,628,861	18,686
9	2022	149,678			351,545		1,565,271	1,916,815	4,602,887	6,669,380	18,800
10	2023	152,671			358,576		1,598,577	1,955,152	4,602,887	6,710,710	18,916
11	2024	155,725			365,747		1,634,508	1,994,255	4,602,887	6,752,868	19,035
12	2025	158,839			373,062		1,671,078	2,034,140	4,602,887	6,795,868	19,156
13	2026	162,016			380,523		1,709,300	2,074,823	4,602,887	6,839,726	19,280
14	2027	165,256			388,134		1,748,186	2,116,318	4,602,887	6,884,462	19,406
15	2028	168,562			395,896		1,787,749	2,158,646	4,602,887	6,930,094	19,535
16	2029	171,933			403,814		1,798,004	2,201,819	4,602,887	6,976,638	19,666
17	2030	175,371			411,891		1,833,965	2,245,855	4,602,887	7,024,113	19,800
18	2031	178,879			420,128		1,870,644	2,290,772	4,602,887	7,072,538	19,936
19	2032	182,456			428,531		1,908,057	2,336,568	4,602,887	7,121,931	20,076
20	2033	186,106			437,102		1,946,218	2,383,319	4,602,887	7,172,312	20,218
Present Worth (% of PW)		1,560,813	0.0%	0.0%	3,665,645	0.0%	15,822,365	19,988,210	48,386,333	69,935,356	9,857
		2.2%			5.2%		23.3%	28.6%	69.2%	100.0%	


Fabric Filter

First Year Cost for Air Pollution Control Options



Air Pollution Control Option

Present Worth Cost for Air Pollution Control Options



APPENDIX B

2006 Wyoming BART Protocol

BART Air Modeling Protocol
Individual Source Visibility Assessments
for BART Control Analyses

September, 2006

State of Wyoming
Department of Environmental Quality
Air Quality Division
Cheyenne, WY 82002

Table of Contents

1.0 INTRODUCTION 3
2.0 OVERVIEW 4
3.0 EMISSIONS DATA FOR MODELING 7
 3.1 Baseline Modeling 7
 3.2 Post-Control Modeling..... 8
4.0 METEOROLOGICAL DATA..... 9
5.0 CALPUFF MODEL APPLICATION..... 12
6.0 POST PROCESSING 15
7.0 REPORTING 19

1.0 INTRODUCTION

The U.S. EPA has issued final amendments to the Regional Haze Regulations, along with Guidelines for Best Available Retrofit Technology (BART) Determinations.⁽¹⁾ The guidelines address the methodology for determining which facilities must apply BART (sources subject-to-BART) and the evaluation of control options.

The State of Wyoming used air quality modeling in accordance with the EPA Guidelines to determine the Wyoming sources which are subject-to-BART. This Protocol defines the specific methodology to be used by those sources for determining the improvement in visibility to be achieved by BART controls.

The methodology presented in this Protocol is consistent with EPA guidance and the Air Quality Division (AQD) determination of subject-to-BART sources. It is intended that all Wyoming sources that must conduct BART analyses will use this Protocol for their evaluation of control technology visibility improvement. Any deviations from the procedures described herein must be approved by the Division prior to implementation.

⁽¹⁾ 40 CFR Part 51: Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations; Final Rule. 70 Federal Register, 39103-39172, July 6, 2005.

2.0 OVERVIEW

Wyoming AQD determined that eight facilities (sources) in the state are subject-to-BART. The sources are listed in Table 1. Division modeling indicated that each of these sources causes or contributes to visibility impairment in one or more Class I areas. Each source must conduct a BART analysis to define Best Available Retrofit Technology (BART) applicable to that source, and quantify the improvement in Class I visibility associated with BART controls. This Protocol sets out the procedures for quantifying visibility improvement. Other aspects of the full BART analysis are not addressed here.

There are many Class I areas within and surrounding Wyoming (See Figure 1). On the basis of distance from subject-to-BART sources, topography, meteorology, and prior modeling, the AQD has determined that only five Class I areas need be addressed in BART individual source analyses. These are Badlands and Wind Cave National Parks in South Dakota, Mt. Zirkel Wilderness Area in Colorado, and Bridger and Fitzpatrick Wilderness Areas in Wyoming. Sources in eastern Wyoming have been shown to have greatest visibility impacts at the two South Dakota Class I areas, and western Wyoming sources have maximum impacts at Bridger and Fitzpatrick Wilderness Areas, and Mt. Zirkel. Visibility improvement at these highest impact areas will provide the best measure of the effectiveness of BART controls.

Each facility should carry out modeling with the CALPUFF modeling system for the Class I areas specified in Table 2. The AQD will provide meteorological input for CALMET for the years 2001, 2002, and 2003. The model domain covered by the AQD meteorological data is centered in southwest Wyoming, and extends roughly from Twin Falls, ID in the west to the Missouri River in the east, and from Denver in the south to Helena, MT in the north. The domain is shown, along with Class I areas, in Figure 1.

Sources may wish to utilize a smaller domain for CALPUFF modeling. Smaller domains are acceptable if they provide adequate additional area beyond the specific source and Class I areas being addressed. Figure 1 includes a "southwest Wyoming" domain which represents the minimum acceptable area for sources impacting the Bridger and Fitzpatrick Wilderness Areas, and the Mt. Zirkel Wilderness Area, and a "northeast Wyoming" domain as a minimum area for Badlands and Wind Cave National Parks modeling.

The CALPUFF model should be used with each of the three years of meteorological data to calculate visibility impacts for a baseline (existing emissions) case, and for cases reflecting BART controls. The control scenarios are to include individual scenarios for proposed BART controls for each pollutant (SO₂, NO_x, and particulate matter), and a combined scenario representing application of all proposed BART controls. If desired, additional modeling may be performed for controls that are not selected as BART. This might be done, for example, to provide data useful in identifying the control technologies that represent BART. However, visibility modeling is required only for the proposed BART controls.

Table 1. Wyoming Sources Subject-to-BART

Basin Electric	Laramie River Power Plant	Boilers #1,2,3
FMC Corporation	Granger Soda Ash Plant	Boilers #1,2
FMC Corporation	Green River Sodium Plant	Three boilers
General Chemical Co.	Green River Soda Ash	Two boilers
PacifiCorp	Dave Johnson Power Plant	Boilers #3,4
PacifiCorp	Jim Bridger Power Plant	Boilers #1-4
PacifiCorp	Naughton Power Plant	Boilers #1,2,3
PacifiCorp	Wyodak Power Plant	Boiler

Results of visibility modeling will be presented as a comparison between baseline impacts and those calculated for the BART control scenarios. Quantitative measures of impact will be the 98th percentile deciview change (Δdv) relative to the 20% best days natural background, and the number of days with deciview change exceeding 0.5 (EPA Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations, 70 FR 39103). Results should be presented for each year.

Table 2. Source-Specific Class I Areas to be Addressed

Source	Class I Areas to be Evaluated
Basin Electric Laramie River	Wind Cave NP, Badlands NP
FMC Corporation Granger Soda Ash	Bridger WA, Fitzpatrick WA
FMC Corporation Sodium Products	Bridger WA, Fitzpatrick WA
General Chemical Green River Soda Ash	Bridger WA, Fitzpatrick WA
Pacificorp Dave Johnston	Wind Cave NP, Badlands NP
Pacificorp Jim Bridger	Bridger WA, Fitzpatrick WA, Mt. Zirkel WA
Pacificorp Naughton Plant	Bridger WA, Fitzpatrick WA
Pacificorp Wyodak	Wind Cave NP, Badlands NP

3.0 EMISSIONS DATA FOR MODELING

CALPUFF model input requires source (stack) – specific emission rates for each pollutant, and stack parameters (height, diameter, exit gas temperature, and exit gas velocity). Per EPA BART guidance, these parameters must be representative of maximum actual 24-hour average emitting conditions for baseline (existing) operation, and maximum proposed 24-hour average emissions for future (BART) operations.

3.1 Baseline Modeling

Sources are required to utilize representative baseline emission conditions if data are available; baseline emissions must be documented. Possible sources of emission data are stack tests, CEM data, fuel consumption data, etc. Remember that emissions should represent maximum 24-hour rates. EPA BART guidance states that you should “Use the 24-hour average actual emission rate from the highest emitting day of the meteorological period modeled (for the pre-control scenario).” Thus, baseline conditions should reference data from 2001 through 2003 (or 2004).

As a minimum, modeled emissions must include:

SO ₂	sulfur dioxide
NO _x	oxides of nitrogen
PM _{2.5}	particles with diameter less than 2.5µm
PM _{10-2.5}	particles with diameters greater than 2.5µm but less than or equal to 10 µm

If the fraction of PM₁₀ in the PM_{2.5} (fine) and PM_{10-2.5} (coarse) categories cannot be determined all particulate matter should be assumed to be PM_{2.5}.

In addition, direct emissions of sulfate (SO₄) should be included where possible. Sulfate can be emitted as sulfuric acid (H₂SO₄), sulfur trioxide (SO₃), or as sulfate compounds; emissions should be quantified as the equivalent mass of SO₄.

When test or engineering data are not available to specify SO₄ emissions or the relative fractions of fine and coarse particles, use can be made of speciation profiles available from Federal Land Managers at the website <http://ww2.nature.nps.gov/air/permits/ect/index.cfm>. Profiles are available for a number of source type and control technology combinations. The FLM speciation factors are acceptable if data are available for the appropriate source type.

Emissions of VOC (volatile organic compounds), condensable organics measured in stack tests, and elemental carbon components of PM₁₀ do not need to be included for BART modeling. The only other pollutant noted in EPA BART guidance is ammonia (NH₃). Though ammonia is not believed to be a significant contributor to visibility

impairment in most cases in Wyoming, it could be important for sources with significant ammonia emissions – for example from some NO_x control systems. Sources that are expected to emit ammonia (in pre- or post-control configurations) should include ammonia emissions in their model input.

If quantitative baseline emissions data are unavailable and sources believe that the maximum 24-hour emission rates estimated by the Division (presented in the Subject-to-BART final report) are representative of baseline conditions for their facility, they may be used for baseline modeling. However, emissions of sulfate and ammonia (if applicable) should be included based on the best available test information or speciation factors from current literature.

3.2 Post-Control Modeling

All pollutants described above should be included for each post-control scenario. Post-control emissions (maximum 24-hour average) will generally be the baseline emissions multiplied by a control factor appropriate to the BART control. However, some proposed controls may simply increase the efficiency of existing controls; others may result in an increase in emissions of one pollutant while controlling another. These factors must all be considered in defining emission rates for post-control modeling. Any changes in stack parameters resulting from control application must also be included.

The required visibility assessment will include the effect of each proposed BART control. For example, if a source proposes to add a scrubber for SO₂ control, low NO_x burners for NO_x control, and a baghouse for particulate control, four sets of visibility results should be developed:

- Use of SO₂ control alone
- Use of NO_x control alone
- Use of particulate control alone
- Use of proposed combination of all three controls

All pollutants should be modeled in each CALPUFF model run, but the modeled emissions should reflect only the specific controls or combination of controls addressed in that run.

Additional modeling could be necessary in situations where a facility is comprised of more than one subject-to-BART source, and different BART controls are applicable to different sources. Excessive modeling to address multiple control combinations is not necessary; however, visibility modeling should quantify the effect of BART controls on all affected sources for each pollutant, and of all facility BART controls combined.

4.0 METEOROLOGICAL DATA

Wyoming AQD will provide MM5 meteorological data fields for years 2001, 2002, and 2003 that can be utilized as input to CALMET. The MM5 output will have 12 kilometer resolution and cover the full domain shown in Figure 1.

Mesoscale meteorological data (MM5) were developed and evaluated as part of the AQD's southwest Wyoming NO₂ increment analysis. Three years of MM5 data at 36 km resolution were used to initialize 12 km MM5 simulations. The 12km MM5 modeling used identical physics options to the original 36 km runs. CALMM5 was then used as a preprocessor to produce CALMET – ready MM5 data input files. Quality assurance was performed by comparing the original MM5 output on the 36km national RPO grid to the 12 km MM5 output and observations.

The CALMET model (version 5.53a, level 040716) should be used to prepare meteorological input for CALPUFF. The user may select a domain smaller than the MM5 domain for CALMET and CALPUFF modeling if desired. Figure 1 shows minimum domain areas for modeling of western and eastern Wyoming BART sources. Four kilometer resolution should be specified for CALMET output.

CALMET processing should use the AQD MM5 data, and appropriate surface, upper air, and precipitation data. Figure 2 shows the locations of surface and upper air stations within the MM5 model domain. The MM5 data are used as the initial guess wind field; this wind field is then adjusted by CALMET for terrain and land use to generate a step 1 wind field, and refined using surface and upper air data to create the final step 2 wind field.

Surface, upper air, and precipitation data can be obtained from the National Climatic Data Center. Land use and terrain data are available from the U.S. Geological Survey. Data can be formatted for use in CALMET with standard conversion and processing programs available with the CALMET/CALPUFF software.

Table 3 provides a listing of applicable CALMET input variables for BART meteorological processing. The table includes inputs that are specific to Wyoming BART modeling. Inputs not shown in Table 3 are not relevant to the present application, are dependent on the specific model domain of the user, use model default values, or are obvious from the context.

Table 3. CALMET Control File Inputs

Variable	Description	Value
	Input Group 1	
IBYR	Year	2001
		2002
		2003
IBTZ	Base time zone	7
IRTYPE	Run type	1
LCALGRD	Compute data fields for CALGRID	T
	Input Group 2	
PMAP	Map projection	LCC
DGRIDKM	Grid spacing (km)	4
NZ	Number of layers	10
ZFACE	Cell face heights (m)	0
		20
		40
		100
		140
		320
		580
		1020
		1480
		2220
		3500
	Input Group 4	
NOOBS	No observation Mode	0
	Input Group 5	
IWFCOD	Model selection variable	1
IFRADJ	Froude number adjustment	1
IKINE	Kinematic effects	0
IOBR	Use O'Brien procedure	0
ISLOPE	Slope flow effects	1
IEXTRP	Extrapolate surface wind observations	-4
ICALM	Extrapolate calm surface winds	0
BIAS	Biases for weights of surface and upper air stations	All 0
RMIN2	Minimum distance for extrapolation	-1
I PROG	Use gridded prognostic model output	14
ISTEPPG	Time Step (hours)	1
LVARY	Use varying radius of influence	F

Table 3. CALMET Control File Inputs (continued)

Variable	Description	Value
RMAX 1	Maximum radius of influence (km)	30
RMAX 2	Maximum radius of influence (km)	50
RMIN	Minimum radius of influence (km)	0.1
TERRAD	Radius of influence for terrain (km)	15
R1	Relative weighting of first guess wind field and observations (km)	5
R2	Relative weighting aloft (km)	25
IDIOPT 1	Surface temperature	0
IDIOPT 2	Upper air lapse rate	0
ZUPT	Lapse rate depth (m)	200
IDIOPT 3	Average wind components	0
IUPWND	Upper air station	-1
ZUPWND (1)	Bottom and top of layer for domain	1, 1000
ZUPWND (2)	scale winds (m)	1, 1000
IDIOPT4	Surface wind components	0
IDIOPT5	Upper air wind components	0
Input Group 6		
LAVEZI	Spatial averaging	1
MNMDAV	Max search radius	1
HAFANG	Half angle for averaging (deg)	30
ILEVZI	Layer of winds in averaging	1
ZIMAX	Maximum overland mixing height (m)	3500
ITPROG	3D temperature source	1
IRAD	Interpolation type	1
TRADKM	Radius of influence - temperature (km)	500
NUMTS	Maximum number of Stations	5
IAVET	Spatial averaging of temperatures	1
NFLAGP	Precipitation interpolation	2

5.0 CALPUFF MODEL APPLICATION

The CALPUFF model (version 5.711a, level 040716) will be used to calculate pollutant concentrations at receptors in each Class I area. Application of CALPUFF should, in general, follow the guidance presented in the Interagency Workgroup on Air Quality Modeling (IWAQM) Phase 2 report (EPA - 454/R98-019) and the EPA Regional Haze Regulations and Guidelines for BART Determinations (70 FR 39103).

Appropriate CALPUFF control file inputs are in Table 4. Note should be taken of the basis for several of the recommended CALPUFF inputs.

- Building downwash effects need not be included. Because of the transport distances involved and the fact that most sources have tall stacks, building downwash is unlikely to have a significant effect on model-predicted concentrations.
- Puff splitting is not required. The additional computation time necessary for puff splitting is not justified for purposes of BART analyses.
- Hourly ozone files should be used to define background ozone concentration. Data are available from the following sites within the model domain.
 - Rocky Mountain NP, CO
 - Craters of the Moon NP, ID
 - AIRS - Highland UT
 - Mountain Thunder, WY
 - Yellowstone NP, WY
 - Centennial, WY
 - Pinedale, WY

The background ozone concentration shown in Table 4 is used only when hourly data are missing.

- A constant background ammonia concentration of 2.0 ppb is specified. This value is based upon monitoring data from nearby states and IWAQM guidance. Experience suggests that 2.0 ppb is conservative in that it is unlikely to significantly limit nitrate formation in the model computations.
- MBSOPUFF II chemical transformation rates should be used.
- The species to be modeled should be the seven identified in CALPUFF: SO₂, SO₄, NO_x, HNO₃, NO₃, PM_{2.5}, and PM_{10-2.5}. If ammonia (NH₃) is emitted it should be added to the species list. In most cases, all pollutants modeled will also be emitted, except for HNO₃ and NO₃.

Concentration calculations should be made for receptors covering the areas of the Class I areas being addressed. Receptors in each Class I area will be those designated by the Federal Land Managers and available from the National Park Service website.

Table 4. CALPUFF Control File Inputs

Variable	Description	Value
	Input Group 1	
METRUN	Control parameter for running all periods in met file	1
IBYR	Starting year	2001 2002 2003
XBTZ	Base time zone	7
NSPEC	Number of chemical species modeled	7 (or 8)
NSE	Number of species emitted	5 (or 6)
METFM	Meteorological data format	1
	Input Group 2	
MGAUSS	Vertical distribution in near field	1
MCTADJ	Terrain adjustment method	3
MCTSG	Subgrid scale complex terrain	0
MSLUG	Elongated puffs	0
MTRANS	Transitional plume rise	1
MTIP	Stack tip downwash	1
MSHEAR	Vertical wind shear	0
MSPLIT	Puff splitting allowed?	0
MCHEM	Chemical mechanism	1
MAQCHEM	Aqueous phase transformation	0
MWET	Wet removal	1
MDRY	Dry deposition	1
MDISP	Dispersion Coefficients	3
MROUGH	Adjust sigma for roughness	0
MPARTL	Partial plume penetration of inversions	1
MPDF	PDF for convective conditions	0
	Input Group 4	
PMP	Map projection	LCC
DGRIDKM	Grid spacing	4

Table 4. CALPUFF Control File Inputs (continued)

ZFACE	Cell face heights (m)	0
		20
		40
		100
		140
		320
		580
		1020
		1480
		2220
		3500
	Input Group 6	
NHILL	Number of terrain features	0
	Input Group 7	
Dry Gas Depo	Chemical parameters for dry gas deposition	Defaults
	Input Group 8	
Dry Part. Depo	Size parameters for dry particle deposition SO ₄ , NO ₃ , PM25 PM10	Defaults 6.5, 1.0
	Input Group 11	
MOZ	Ozone input option	1
BCKO3	Background ozone – all months (ppb)	44.0
BCKNH3	Background ammonia – all months (ppb)	2.0
	Input Group 12	
XMAXZI	Maximum mixing height (m)	3500
XMINZI	Minimum mixing height (m)	50

6.0 POST PROCESSING

Visibility impacts are calculated from the CALPUFF concentration results using CALPOST. CALPOST version 5.51, level 030709 should be used; the output from CALPOST will provide the highest deciview impact on each day from all receptors within each Class I area modeled.

For some CALPUFF applications such as deposition calculations, the POSTUTIL program is used prior to CALPOST. POSTUTIL is also used to repartition total nitrate by accounting for ammonia limiting. The ammonia limiting calculation in POSTUTIL should not be applied for Wyoming BART modeling. If you believe that ammonia limiting is appropriate for a specific BART analysis, justification should be discussed with the Division prior to its used.

Visibility calculations by CALPOST for BART purposes use Method 6. This method requires input of monthly relative humidity factors, $f(RH)$, for each Class I area. The EPA guidance document provides appropriate data for each area. Table 5 lists monthly $f(RH)$ factors to use for the Wyoming, Colorado, and South Dakota areas to be addressed in BART modeling. The factors shown in Table 5 include averages for the adjacent Class I areas, and are within 0.2 units of the Guideline table values for the individual Class I areas.

Natural background conditions as a reference for determination of the delta-dv change due to a source should be representative of the 20% best natural visibility days. EPA BART guidance provides the 20% best days deciview values for each Class I area on an annual basis, but does not provide species concentration data for the 20% best background conditions. These concentrations are needed for input to CALPOST.

Annual species concentrations corresponding to the 20% best days were calculated for each Class I area to be addressed, by scaling back the annual average concentrations given in Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule (Table 2-1). A separate scaling factor was derived for each Class I area such that, when multiplied by the Guidance table annual concentrations, the 20% best days deciview value for that area would be calculated. The scaled aerosol concentrations were averaged for the Bridger and Fitzpatrick WAs, and for Wind Cave and Badlands NPs, because of their geographical proximity and similar annual background visibility. The 20% best days aerosol concentrations to be used for each month for Wyoming BART evaluations are listed in Table 6.

Table 7 is a list of inputs for CALPOST. These inputs should be used for all BART visibility calculations. Output from CALPOST should be configured to provide a ranked list of the highest delta-deciview values in each Class I area. The 98th percentile delta-deciview value and the number of values exceeding 0.5 can then be determined directly from the CALPOST output.

Table 5. Monthly f(RH) Factors for Class I Areas

Month	Wind Cave NP Badlands NP	Bridger WA Fitzpatrick WA	Mt. Zirkel WA
January	2.65	2.50	2.20
February	2.65	2.30	2.20
March	2.65	2.30	2.00
April	2.55	2.10	2.10
May	2.70	2.10	2.20
June	2.60	1.80	1.80
July	2.30	1.50	1.70
August	2.30	1.50	1.80
September	2.20	1.80	2.00
October	2.25	2.00	1.90
November	2.75	2.50	2.10
December	2.65	2.40	2.10

Table 6. Natural Background Concentrations of Aerosol Components for 20% Best Days for BART Analyses ($\mu\text{g}/\text{m}^3$)

Aerosol Component	Wind Cave NP Badlands NP	Fitzpatrick WA Bridger WA	Mt. Zirkel WA
Ammonium Sulfate	.047	.045	.046
Ammonium Nitrate	.040	.038	.038
Organic Carbon	.186	.178	.179
Elemental Carbon	.008	.008	.008
Soil	.198	.189	.190
Coarse Mass	1.191	1.136	1.141

Table 7. CALPOST Control File Inputs

Variable	Description	Value
	Input Group 1	
ASPEC	Species to Process	VISIB
ILAYER	Layer/deposition code	1
A,B	Scaling factors	0,0
LBACK	Add background concentrations?	F
BTZONE	Base time zone	7
LVSO4	Species to be included in extinction	T
LVNO3		T
LVOC		F
LVPMC		T
LVPMF		T
LVEC		F
LVBK	Include background?	T
SPECPMC	Species name for particulates	PM10
SPECPMF		PM25
BEPMC	Extinction efficiencies	0.6
BEPMF		1.0
BEPMCBK		0.6
EESO4		3.0
EENO3		3.0
EEOC		4.0
EESOIL		1.0
EEEC		10.0
MVISBK	Visibility calculation method	6
RHFAC	Monthly RH adjustment factors	Table 5
BKSO4	Background concentrations	Table 6
BKNO3		Table 6
BKPMC		Table 6
BK OC		Table 6
BKSOIL		Table 6
BKEC		Table 6
BEXTRAY	Extinction due to Rayleigh scattering	10.0

7.0 REPORTING

A report on the BART visibility analysis should be submitted that clearly compares impacts for post-control emissions to those for baseline emissions. Data for baseline and BART scenarios should include both the 98th percentile values and the number of days with delta-deciview values exceeding 0.5. Results should be given for each model year.

Table 8 is an example of a recommended format for presentation of model input and model results. The example is for baseline conditions; similar tables should be provided for each control scenario (SO₂, NO_x, and PM10) and for the combination of all BART controls. Your report tables need not follow the exact format shown in Table 8; but the same information should be provided in a concise and clear form. If additional scenarios were modeled or you wish to present supplemental information, they should be provided in an appendix or separate from the specified final results.

Table 8. Example Format for Presentation of Model Input and Results

Source (Unit) Description And ID	Baseline Conditions Model Input Data											
	SO ₂ Emission Rate (lb/day)	NO _x Emission Rate (lb/day)	PM _{2.5} Emission Rate (lb/day)	PM _{10-2.5} Emission Rate (lb/day)	SO ₄ Emission Rate (lb/day)	NH ₃ Emission Rate (lb/day)	Location Easting (m)	Location Northing (m)	Stack Height (m)	Stack Diameter (m)	Exit Velocity (m/s)	Exit Gas Temp (deg K)
							UTM (m)	UTM (m)				

Baseline Visibility Modeling Results

Name of Facility	Class I Area	2001		2002		2003	
		98 th Percentile Value (dv)	No. of days exceeding 0.5 dv	98 th Percentile Value (dv)	No. of days exceeding 0.5 dv	98 th Percentile Value (dv)	No. of days exceeding 0.5 dv