

Department of Environmental Quality


John Corra, Director

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

December 31, 2009

Ms. Angie Skinner Plant Managing Director PacifiCorp PO Box 191 Kemmerer, WY 83101



Re: Air Quality Permit MD-6042 BART Permit: Naughton Power Plant

Dear Ms. Skinner:

The Division of Air Quality of the Wyoming Department of Environmental Quality has enclosed a copy of the Best Available Control Technology (BART) permit for PacifiCorp's Naughton Power Plant, dated December 31, 2009. Comments received during the public comment period and the public hearing were considered in the final permit. A copy of the decision document for the permit is also enclosed. No permit conditions required revision as a result of the public comment period.


If you have any questions, please feel free to contact this office.

Sincerely,

mley

David A. Finley Administrator Air Quality Division

cc: Tony Hoyt/AQD Lander



Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • http://deq.state.wy.us

		-				-	
ADMIN/OUTREACH	ABANDONED MINES	AIR QUALITY	INDUSTRIAL SITING	LAND QUALITY	SOLID & HAZ. WASTE	WATER QUALITY	
(307) 777-7937	(307) 777-6145	(307) 777-7391	(307) 777-7369	(307) 777-7756	(307) 777-7752	(307) 777-7781	
FAX 777-3610	FAX 777-6462	FAX 777-5616	FAX 777-5973	FAX 777-5864	FAX 777-5973	FAX 777-5973	(All a)



Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



John Corra, Director

December 31, 2009

Ms. Angie Skinner Plant Managing Director PacifiCorp PO Box 191 Kemmerer, WY 83101

> Permit No. MD-6042 (BART Permit for the Naughton Plant)

Dear Ms. Skinner:

The Division of Air Quality of the Wyoming Department of Environmental Quality has completed final review of PacifiCorp's application for a Best Available Retrofit Technology (BART) permit for the three coal-fired boilers at the Naughton Power Plant. The Naughton Power Plant is located in Sections 32 and 33, T21N, R116W, approximately six miles southwest of Kemmerer in Lincoln County, Wyoming.

Following the Division's proposed approval of the permit as published June 4, 2009, a 62-day public notice period ran from June 4, 2009 to August 4, 2009, and a public hearing was held on August 4, 2009 at 1 p.m. in the Lincoln County Library, located at 519 Emerald Street in Kemmerer, Wyoming. Comments were received on the proposed permit and those comments have been considered by the Division in the final permit. Therefore, on the basis of the information provided to the Division, a BART permit is hereby granted pursuant to Chapter 6, Sections 2 and 9 of the Wyoming Air Quality Standards and Regulations (WAQSR) with the following conditions:

- 1. Authorized representatives of the Division of Air Quality be given permission to enter and inspect any property, premise or place on or at which an air pollution source is located or is being constructed or installed for the purpose of investigating actual or potential sources of air pollution, and for determining compliance or non-compliance with any rules, standards, permits or orders.
- 2. All substantive commitments and descriptions set forth in the application for this permit, unless superseded by a specific condition of this permit, are incorporated herein by this reference and are enforceable as conditions of this permit.
- 3. That PacifiCorp shall modify their Operating Permit in accordance with Chapter 6, Section 9(e)(vi) and Chapter 6, Section 3 of the WAQSR.
- 4. All notifications, reports and correspondence associated with this permit shall be submitted to the Stationary Source Compliance Program Manager, Air Quality Division, 122 West 25th Street, Cheyenne, WY 82002 and a copy shall be submitted to the District Engineer, Air Quality Division, 510 Meadowview Drive, Lander, WY 82520.

Herschler Building + 122 West 25th Street + Cheyenne, WY 82002 + http://deg.state.wy.us





5. Effective upon completion of the performance tests to verify the emission levels below, as required by Condition 6 of this permit, emissions from Naughton Units 1 and 2 shall not exceed the levels below. The lb/hr and tpy limits shall apply during all operating periods. The lb/MMBtu limits shall apply during all operating periods except startup. Startup begins with the introduction of natural gas into the boiler and ends no later than the point in time when the ESP reaches a temperature of 225°F.

Unit	Pollutant	lb/MMBtu	lb/hr	tpy
1	PM/PM ₁₀ ^(a)	0.040	74	324
2	PM/PM ₁₀ ^(a)	0.040	96	421

⁽a) Filterable portion only.

- 6. That no later than 90 days after the installation of new low NO_x burners with advanced overfire air, PM/PM₁₀ performance tests shall be conducted and a written report of the results shall be submitted. If a maximum design rate is not achieved within 90 days of installing new low NO_x burners with advanced overfire air, the Administrator may require testing be done at the rate achieved and again when a maximum rate is achieved.
- 7. Effective upon completion of the initial performance tests to verify the emission levels below, as required by Condition 8 of this permit, emissions from Naughton Units 1-3 shall not exceed the levels below. The NO_x limits shall apply during all operating periods. Unit 3 PM/PM₁₀ lb/hr and tpy limits shall apply during all operating periods. Unit 3 PM/PM₁₀ lb/hr Bu limit shall apply during all operating periods except startup. Startup begins with the introduction of natural gas into the boiler and ends when the boiler is switched over to coal as fuel.

Unit	Pollutant	lb/MMBtu	lb/hr	tpy
1	NO _x	0.26 (30-day rolling)	481 (30-day rolling)	2,107
2	NOx	0.26 (30-day rolling)	624 (30-day rolling)	2,733
3	NOx	0.07 (30-day rolling)	259 (30-day rolling)	1,134
3	PM/PM ₁₀ ^(a)	0.015 ^(b)	56 ^(b)	243

(a) Filterable portion only.

^(b) Upon installation of a PM continuous emissions monitoring system, the averaging period shall become a 24-hour block average.

8. That initial performance tests be conducted, in accordance with Chapter 6, Section 2(j) of the WAQSR, within 30 days of achieving a maximum design rate but not later than 90 days following initial start-up, and a written report of the results be submitted. If a maximum design rate is not achieved within 90 days of start-up, the Administrator may require testing be done at the rate achieved and again when a maximum rate is achieved.

9. Performance tests shall consist of the following:

Coal-fired Boilers (Naughton Units 1 through 3):

 $\underline{NO_x Emissions}$ – Compliance with the NO_x 30-day rolling average shall be determined using a continuous emissions monitoring system (CEMS) certified in accordance with 40 CFR part 60.

<u>PM/PM₁₀ Emissions</u> – Testing shall follow 40 CFR 60.46 and EPA Reference Test Methods 1-4 and 5.

Testing required by the Chapter 6, Section 3 Operating Permit may be submitted to satisfy the testing required by this condition. If a PM CEMS is installed on Unit 3, PM CEMS monitoring data collected in accordance with 40 CFR part 60, subpart Da may be submitted to satisfy the testing required by this condition for Unit 3.

- 10. Prior to any testing required by this permit, a test protocol shall be submitted to the Division for approval, at least 30 days prior to testing. Notification should be provided to the Division at least 15 days prior to any testing. Results of the tests shall be submitted to this office within 45 days of completing the tests.
- 11. PacifiCorp shall comply with all requirements of the Regional SO₂ Milestone and Backstop Trading Program in accordance with Chapter 14, Sections 2 and 3, of the WAQSR.
- Compliance with the NO_x limits set forth in this permit for the coal-fired boilers (Naughton Units 1-3) shall be determined with data from the continuous monitoring systems required by 40 CFR Part 75 as follows:
 - a. Exceedances of the NO_x limits shall be defined as follows:
 - i. Any 30-day rolling average of NO_x emissions which exceeds the lb/MMBtu limits calculated in accordance with the compliance provisions and monitoring requirements of §60.48Da and §60.49Da. The definition of "boiler operating day" shall be consistent with the definition as specified in 40 CFR part 60, subpart Da.
 - ii. Any 30-day rolling average calculated using valid data (output concentration and average hourly volumetric flowrate) from the existing CEM equipment which exceeds the lb/hr NO_x limit established in this permit. Valid data shall meet the requirements of WAQSR, Chapter 5, Section 2(j) and follow the compliance provisions and monitoring requirements of §60.48Da and §60.49Da. The 30-day average emission rate shall be calculated as the arithmetic average of hourly emissions with valid data during the previous 30-day period. The definition of "boiler operating day" shall be consistent with the definition as specified in 40 CFR part 60, subpart Da.

- b. PacifiCorp shall comply with all reporting and record keeping requirements as specified in WAQSR, Chapter 5, Section 2(g) and 40 CFR part 60, subpart D. All excess emissions shall be reported using the procedures and reporting format specified in WAQSR, Chapter 5, Section 2(g).
- 13. PacifiCorp shall use EPA's Clean Air Markets reporting program to convert the monitoring system data to annual emissions. PacifiCorp shall provide substituted data according to the missing data procedures of 40 CFR, Part 75 during any period of time that there is not monitoring data. All monitoring data must meet the requirements of WAQSR, Chapter 5, Section 2(j).
- 14. Compliance with the PM/PM₁₀ limits set forth in this permit for Naughton Units 1-3 shall be determined with data from testing for PM conducted annually, or more frequently as specified by the Administrator, following 40 CFR 60.46 and EPA Reference Test Methods 1-4 and 5. Testing required by the Chapter 6, Section 3 Operating Permit may be submitted to satisfy the testing required by this condition. If a PM CEMS is installed on Unit 3, PM CEMS monitoring data collected in accordance with 40 CFR part 60, subpart Da may be submitted to satisfy the testing required by this condition for Unit 3.
- 15. Records required by this permit shall be maintained for a period of at least five (5) years and shall be made available to the Division upon request.
- 16. PacifiCorp shall install new low NO_x burners with advanced overfire air on Units 1 and 2, in accordance with the Division's BART determination, and conduct the performance tests required in Conditions 6 and 8 no later than December 31, 2012 for Unit 1 and June 1, 2012 for Unit 2.
- 17. PacifiCorp shall, for Units 1 and 2, install flue gas conditioning on the existing ESPs, in accordance with the Division's BART determination, within 90 days of permit issuance.
- 18. PacifiCorp shall tune the existing low NOx burners with overfire air and install selective catalytic reduction and a full-scale fabric filter on Unit 3, in accordance with the Division's BART determination, and conduct the initial performance tests required in Condition 8 no later than December 31, 2014.

It must be noted that this approval does not relieve you of your obligation to comply with all applicable county, state, and federal standards, regulations or ordinances. Special attention must be given to Chapter 6, Section 3 of the Wyoming Air Quality Standards and Regulations, which details the requirements for compliance with condition 3. Attention must be given to Chapter 14, Sections 2 and 3 of the Wyoming Air Quality Standards and Regulations for compliance with condition 11. Any appeal of this permit as a final action of the Department must be made to the Environmental Quality Council within sixty (60) days of permit issuance per Section 16, Chapter I, General Rules of Practice and Procedure, Department of Environmental Quality.

If we may be of further assistance to you, please feel free to contact this office.

Sincerely,

David A. Emley

Administrator Air Quality Division

cc: Tony Hoyt/AQD Lander

John V. Corra Director Dept. of Environmental Quality

IN THE MATTER OF A PERMIT APPLICATION (AP-6042) FROM PACIFICORP FOR A BEST AVAILABLE RETROFIT TECHNOLOGY (BART) PERMIT FOR THE NAUGHTON POWER PLANT

DECISION

I. Introduction:

The Air Quality Division received a BART permit application from PacifiCorp for the three coalfired boilers that operate at their Naughton Power Plant in Lincoln County, Wyoming. Regulations governing the BART program have been established by the U.S. EPA in 40 CFR Part 51 - Appendix Y. As stated in the regulations, a source is eligible for BART if it belongs within a particular group of stationary source categories, was not in operation prior to August 7, 1962, was in existence on August 7, 1977, and has the potential to emit 250 tons per year (tpy) or more of any visibility impairing air pollutant. Fossil fuel boilers with more than 250 million Btu (MMBtu) per hour heat input are listed as an eligible source type. The three boilers at the Naughton plant have heat inputs between 1,850 and 3,700 MMBtu per hour, and were installed between 1963 and 1971. Potential emissions from each boiler for two visibility impairing air pollutants, nitrogen oxides (NO_x) and sulfur dioxide (SO₂), exceed 250 tpy and therefore the units are eligible for BART.

The Division conducted an analysis of the BART permit application for the Naughton plant, and published on June 4, 2009 in the Kemmerer Gazette a public notice and notice of public hearing of the proposed intent to issue BART determinations. Copies of the BART application and the Division's analysis were placed in the Lincoln County clerk's office in Kemmerer, Wyoming in accordance with regulations. A 62-day public notice period ran from June 4, 2009 to August 4, 2009, and a public hearing was held on August 4, 2009 at 1 p.m. in the Lincoln County Library, located at 519 Emerald Street in Kemmerer, Wyoming.

The Division received numerous comment letters on the proposed permit during the public comment period: 1) a letter dated July 21, 2009 from the USDA Forest Service; 2) a letter dated August 3, 2009 from EPA Region 8; 3) a letter dated August 4, 2009 from PacifiCorp; 4) a letter dated August 4, 2009 from the National Park Service; 5) a letter dated August 4, 2009 from the Powder River Basin Resource Council, et al.; 6) a letter received July 20, 2009 from Joanna Taylor; 7) a letter dated July 16, 2009 from Andrew H. Salter; 8) a letter received July 20, 2009 from Evelyn and Marvin Griffin; 9) a letter received July 23, 2009 from Mimi McMillen; 10) a letter received July 24, 2009 from William M. Anderson; 11) a letter received July 24, 2009 from Rebekah Smith; 12) a letter dated July 24, 2009 from Mike Shonsey; 13) a letter dated July 24, 2009 from Susie Mohrmann; 14) a letter dated July 28, 2009 from Janice H. Harris; 15) a letter dated July 28, 2009 from M. Christensen; 16) a letter dated July 27, 2009 from Clint Morrison; 17) a letter dated August 3, 2009 from Ann Fuller; 18) a letter dated August 3, 2009 from Mary Fenton: 19) 725 unsigned letters received under a signed cover letter dated July 28, 2009 from Brad Mohrmann, Sierra Club Associate Regional Representative; and 20) 89 signatures received under a signed cover letter dated July 24, 2009 from Brad Mohrmann, Sierra Club Associate Regional Representative.

Due to the number of public comments with similar concerns, the Division grouped individual comments and developed summary comments and responses. Comments from the EPA, Forest Service, National Park Service, Powder River Basin Resource Council, et al., and PacifiCorp are addressed individually. The comments and responses are presented on the following pages. The Division also received positive comments supporting this project. The Division appreciates these comments but they are not included in this document as no response is required.

PacifiCorp Naughton Power Plant Decision Document, BART Permit Application, AP-6042 Page 2 of 28

> The Division received numerous comments that were descriptive of environmental impacts other than the impacts from BART-eligible sources in Wyoming on Class I area visibility. The Division's responses are limited to the comments that dealt with the State's BART analyses.

> The Division is also preparing a revised Wyoming State Implementation Plan (SIP) for Regional Haze, and has solicited comments on that SIP. Some comments have been received which were submitted as comments on the Regional Haze SIP, but were principally directed at the Division's BART analyses. These comments will be addressed by the Division as it prepares the response to comments on the Regional Haze SIP.

II. Analysis of Comments from the USDA Forest Service:

II.1 BART Conclusions for NO_x Controls: SCR for Naughton – The Forest Service commented that based on their review of the five statutory BART factors, Selective Catalytic Reduction (SCR) should be BART for NO_x control for all units at the Jim Bridger and Naughton power plants. The Forest Service applauds the proposal to install SCR at the four units at the Jim Bridger plant for a long-term strategy, but SCRs at Jim Bridger should be installed as BART on all units by 2015-2016.

<u>Response</u> – The Division determined BART for NO_x control at the Jim Bridger and Naughton power plants based on consideration of all five statutory BART factors, as required by EPA's Appendix Y BART guidance. No single factor was weighted as being more important than another, because the Division looked at all five statutory factors in their entirety. The BART determination for NO_x control on all four units at Jim Bridger included low NO_x burners (LNB) with overfire air (OFA). The BART determinations for NO_x control at Naughton included LNB/OFA on Units 1 and 2 and SCR on Unit 3. The Division's BART analyses provide the basis for the BART determination for both plants.

Regarding the installation of additional control equipment at the Jim Bridger plant, PacifiCorp is required by the BART permit to install SCR on Jim Bridger Unit 3 in 2015 and Jim Bridger Unit 4 in 2016 as well as add-on NO_x control on Units 1 and 2 no later than 2023. The schedule for installation is based on the incorporation of SCR add-on control on these units under the long-term strategy component of Wyoming's SIP for regional haze as well as PacifiCorp's construction plan for pollution control projects. The schedule for the installation of SCR controls at other plants is uncertain at this point due to the demands on PacifiCorp for compliance with BART and other regulatory programs. PacifiCorp operates 19 coal-fired units, 14 of which are BART-eligible. Additional BART-eligible units are owned or partly owned in Arizona, Colorado, and Montana. Table 1 presents a summary of the pollution control projects that are included in PacifiCorp's construction plan through 2014.

PacifiCorp Naughton Power Plant Decision Document, BART Permit Application, AP-6042 Page 3 of 28

Tr	ible 1: Status	of Pollution Contro	ol Projects Undert	aken by PacifiCo	rp
Power Plant	Location	SO ₂ Scrubbers New = N Upgrade = U	LNB Installations	Baghouse Installations	SO ₂ /LNB Project Status
Hunter 3	Utah	Installed	2008	Installed	Completed
Huntington 2	Utah	2007 – N	2007	2007	Completed
Cholla 4	Arizona	2008 – U	2008	2008	Completed
Jim Bridger 4	Wyoming	<u>2008 – U</u>	2008	n/a	Completed
Jim Bridger 2	Wyoming	2009 – U	2005	n/a	Completed
Dave Johnston 3	Wyoming	2010 – N	2010	2010	Under Construction
Huntington 1	Utah	2010 – U	2010	2010	Permitted
Jim Bridger 1	Wyoming	2010 – U	2010	n/a	Under Construction
Naughton 2	Wyoming	2011 – N	2011	n/a	Under Construction
Hunter 2	Utah	2011 – U	2011	2011	Permitted
Jim Bridger 3	Wyoming	2011 – U	2007	n/a	Under Construction
Wyodak	Wyoming	2011 – U	2011	2011	Permitted
Dave Johnston 4	Wyoming	2012 – N	2009	2012	Under Construction
Naughton 1	Wyoming	2012 – N	2012	n/a	Under Construction
Hunter 1	Utah	2014 – U	2014	2014	Permitted
Naughton 3	Wyoming	2013 – U	2013	2013	Permitted

II.2 <u>BART Conclusions for SO₂ Controls: WFGD</u> – The Forest Service commented that, based on their review of the five statutory factors for BART, wet flue gas desulfurization (WFGD) should be BART for SO₂ control for all units at the Jim Bridger and Naughton power plants.

<u>**Response</u>** – WFGD upgrades have already been (or are scheduled to be) installed on all units at the Jim Bridger plant. For the Naughton plant, WFGD is scheduled to be installed on Units 1 and 2 and WFGD is scheduled to be upgraded for Unit 3. BART limits for SO₂ will not be set because Wyoming is a §309 state participating in the Regional SO₂ Milestone and Backstop Trading Program. §308(e)(2) provides states within the Transport Region addressed by the Grand Canyon Visibility Transport Commission with the option to implement or require participation in an emissions trading program or other alternative measure rather than to require sources subject to BART to install, operate, and maintain additional control technology to meet an established emission limit on a continuous basis.</u>

II.3 NO_x Step 5: Visibility Improvement Determination (Class I areas modeled) - The Forest Service commented that all Class I areas within 300 km of a given source should be modeled and the cost of each BART alternative divided by the sum of the deciview (dv) improvement at all impacted Class I areas. If modeling exists for Class I areas that yield impacts above 0.5 dv just beyond 300 km, those results should be considered also. Savage Run Wilderness Area should also be modeled and considered. PacifiCorp Naughton Power Plant Decision Document, BART Permit Application, AP-6042 Page 4 of 28

<u>Response</u> – Only those Class I areas most likely to be impacted by sources subject to BART at a given facility were modeled, as determined by source/Class I area locations, distances to each Class I area, and professional judgment considering meteorological and terrain factors. The Division recognizes that more distant Class I areas may yield modeled impacts of some magnitude, but the Division is also satisfied that Class I areas at a greater distance and in directions of less frequent plume transport would not yield modeled impacts greater than those yielded by the Class I areas chosen for BART modeling. The modeling results for the Class I areas chosen for analysis allowed the Division to make an informed decision on the effect on visibility from the various BART control options. Additionally, EPA's Appendix Y BART guidance does not include any requirements for modeling distance.

EPA's Appendix Y BART guidance does mention that "dollars per deciview" (\$/dv) is a metric that could be used to evaluate the cost of BART compliance, but by no means identifies \$/dv as an essential or required metric. The Division considered capital cost, annual cost, cost effectiveness, and incremental cost effectiveness in the cost evaluation of each proposed BART control option. The Division chose not to use a hybrid metric such as \$/dv primarily because of the lack of historical precedent regarding reasonable/acceptable levels for such a metric. Additionally, the use of a hybrid cost metric such as \$/deciview can introduce uncertainty as to how the value was calculated. The value of "/deciview" could be based on the highest modeled value in a given area or the 98th percentile modeled value. It could be based on the 98th percentile value for any one modeled year or it could be an average for multiple years. It could even be based on an average modeled value across an entire Class I area or the sum of deciview changes across multiple areas. The Division has found that \$/dv values are often presented without explanation of the basis for the calculation. To avoid these confounding factors, the Division chose to evaluate and present the cost analyses and visibility analyses separately.

EPA's Regional Haze Rule affects sources that may cause or contribute to visibility impairment at any mandatory, federal Class I Area. Because Savage Run is a state-designated Class I area, the Division was not required to include it in the BART modeling. Additionally, the Division did not include Savage Run in any of its analyses for the State's Regional Haze Visibility SIP. For BART, the Division did model the impacts at several mandatory Class I areas that are located in the same general plume transport direction downwind of Savage Run, including Mt. Zirkel Wilderness, Rawah Wilderness, and Rocky Mountain National Park. Based on the modeling results for these Class I Areas in the proximity of Savage Run, the Division anticipates similar improvements in visibility from the analyzed emission reductions.

II.4 <u>NO_x Step 5: Visibility Improvement Determination (significant impact)</u> – The Forest Service commented that it is incorrect to dismiss a control strategy on the basis that the modeled visibility improvement is not perceptible or significant.

<u>Response</u> – The Division used 0.5 dv as the threshold level to exempt a source from BART or to deem modeled impacts as insignificant. EPA's *Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations* (Appendix Y to 40 CFR part 51), suggest that 0.5 dv can represent the level at which a source "contributes" to visibility impairment. This is also consistent with the rules which are being applied by most states in the Western Regional Air Partnership (WRAP) region.

PacifiCorp Naughton Power Plant Decision Document, BART Permit Application, AP-6042 Page 5 of 28

II.5 <u>Five Factor Analysis for BART Selection: Coal Composition</u> – The Forest Service commented that PacifiCorp's analysis of coal composition is flawed and it does not meet the requirement for a demonstration of why presumptive limits cannot be reached.

<u>Response</u> – Although the BART emission limits for NO_x for Naughton Units 1 and 2 exceed the presumptive BART limit for tangential-fired boilers burning sub-bituminous coal, PacifiCorp's analysis of coal composition was not a factor in the Division's determination. The Division established NO_x emission limits for BART at the Naughton plant based on consideration of all five statutory factors, as required by EPA's Appendix Y BART guidance. The Division interpreted the presumptive emission levels for NO_x and SO_2 as recommended control levels proposed by EPA after reviewing technical data related to BART. Requiring sources to meet presumptive emission levels was not required as one of the five statutory factors. Conversely, the Division did not automatically determine emission levels below presumptive levels to be BART, but considered all five statutory factors before making a BART determination.

II.6 <u>NO_x Controls: SCR</u> – The Forest Service commented that significant, cumulative visibility improvements modeled for SCR installations at the Jim Bridger and Naughton plants indicate that SCR should be BART for all units at those two plants. The Forest Service questions why DEQ chose SCR as BART only for Naughton Unit 3 when SCR costs for other Naughton units and all Jim Bridger units are similar. Also, environmental degradation from the operation of SCR should not be a factor in the BART determinations and energy impacts from SCR should not be a factor because they have already been considered in the cost analysis.

Response – The costs for SCR controls, as described in the Division's BART analyses, were deemed by the Division to be reasonable for all units at the Jim Bridger and Naughton plants, but the Division's BART determinations for the two plants were based on consideration of all five statutory BART factors, as required by EPA's Appendix Y BART guidance. PacifiCorp proposed a BART limit for NO_x emissions from Naughton Unit 3 of 0.37 lb/MMBtu, which would be achieved by tuning the existing LNB/OFA system. For Naughton Units 1 and 2, PacifiCorp proposed a BART limit for NOx of 0.26 lb/MMBtu for each unit using new LNB/OFA. Visibility modeling showed that the NO_x emission level proposed by PacifiCorp for Naughton Unit 3 provided less in terms of modeled visibility reductions from baseline as compared to other units at the two plants. For example, Naughton Units 1 and 2 showed a 72% to 73% reduction in the number of days with predicted impacts of 0.5 dv or more at the nearest Class I area (Bridger Wilderness) for LNB/OFA as compared to baseline. The reduction for Naughton Unit 3 for LNB/OFA vs. baseline was only 31%. Appendix A includes graphs of the modeled results at the Class I area that yielded the highest modeled impacts for the Jim Bridger and Naughton plants (Bridger Wilderness) and the Class I area that yielded the highest modeled impacts for the Wyodak, Dave Johnston, and Laramie River Station plants (Wind Cave National Park). As shown in the graphs, the LNB/OFA option reduces the 98th percentile result to less than 1.0 dv for every unit with the exception of Naughton Unit 3 (1.4 dv). The predicted number of days above 0.5 dv for the LNB/OFA option was 40 for Naughton Unit 3, and 16 or less for each of the other twelve units. The Division determined that SCR would be required on Naughton Unit 3 to bring about additional NO_x emissions reductions and modeled visibility improvement, and these factors differentiated the Naughton Unit 3 BART analysis from the others.

It was the full consideration of all five statutory BART factors, principally the pronounced visibility improvement for LNB/OFA as compared to baseline and the lack of non-air quality

PacifiCorp Naughton Power Plant Decision Document, BART Permit Application, AP-6042 Page 6 of 28

environmental impacts that led the Division to conclude that LNB/OFA would be BART for NO_x control at the Jim Bridger plant and for Units 1 and 2 at the Naughton Plant. Modeled visibility impacts for Naughton Unit 3 were reduced to levels comparable to those yielded by LNB/OFA controls on Naughton Units 1 and 2 only through the addition of SCR as BART on Naughton Unit 3. Potential energy losses and environmental impacts from the operation of SCR were mentioned in the Division's BART analysis for both the Naughton and Jim Bridger plants, but were only part of the larger evaluations that considered all five statutory factors.

II.7 <u>NO_x Controls: SCR Efficiencies</u> – The Forest Service commented that greater SCR control efficiencies should be factored into the cost and visibility analyses.

<u>Response</u> – The Division conducted a search of the EPA RACT/BACT/LAER Clearinghouse (RBLC) to find NO_x emission limits as BACT associated with SCR control in recently issued permits. Table 2 presents a summary of the Division's RBLC search. Two plants have limits of 0.05 lb/MMBtu NO_x with a 12-month rolling average, which is significantly longer than a 30-day averaging period. Because the 0.05 lb/MMBtu limits are based on a 12-month averaging period, they are not comparable to the 30-day limits established by the Division. The two plants with 30-day averaging periods will be subjected to either a 0.08 lb/MMBtu or 0.07 lb/MMBtu limit, and the limits established by the Division meet these lower limits. A spreadsheet compiled by the National Park Service with a summary of nationwide BART determinations shows that both units outside of Wyoming for which SCR is proposed as BART will be subject to a NO_x emission limit of 0.07 lb/MMBtu, and both will be based on a 30-day averaging period.

The RBLC search showed two plants that will be subject to 24-hour NO_x limits of less than 0.07 lb/MMBtu (0.067 lb/MMBtu), but these limits are for newly constructed plants which have been engineered to meet these levels. BART will require the retrofit of significant controls at plants that were not designed to meet these lower levels. Based on the Division's evaluation, the Division is satisfied that the NO_x emission limit of 0.07 lb/MMBtu (30-day rolling average) that was evaluated for SCR control under BART is the most stringent control level likely to be achieved in a retrofit.

PacifiCorp Naughton Power Plant Decision Document, BART Permit Application, AP-6042 Page 7 of 28

Table 2: SCR Permit Limits from the RBLC				
Facility/Location	Size of Source	Source Description	NO _x Permit Limit(s) for SCR Control	Permit Date
John W. Turk Power Plant/Arkansas	600 MW	6,000 MMBtu/hr PC Boiler (PRB Coal)	1) 0.067 lb/MMBtu (24-hr rolling) 2) 0.05 lb/MMBtu (12-month rolling) [SCR, BACT]	Nov 2008
Dry Fork Station/Wyoming	385 MW	PC Boiler	0.05 lb/MMBtu (12-month rolling) [SCR, BACT]	Oct 2007
WYGEN3/Wyoming	100 MW	1,300 MMBtu/hr PC Boiler	0.05 lb/MMBtu (12-month rolling) [SCR, BACT]	Feb 2007
latan Station/Missouri		PC Boiler	0.08 lb/MMBtu (30-day rolling) [SCR, BACT]	Jan 2006
Big Cajun II Power Plant/Louisiana	675 MW	PC Boil e r	0.07 lb/MMBtu (annual average) [SCR, BACT]	Aug 2005
TS Power Plant/Nevada	200 MW	PC Boiler	0.067 lb/MMBtu (24-hour rolling) [SCR, BACT]	May 2005
OPPD – Nebraska City Station/Nebraska		-	0.07 lb/MMBtu (30-day rolling) [SCR, BACT]	Mar 2005

Note: "--" indicates that this value was not provided in the RBLC

II.8 <u>Reasonable Progress Controls</u> – The Forest Service asked why Naughton Units 1 and 2 are not required to install SCR as part of reasonable progress like other PacifiCorp units.

<u>Response</u> – See response to Forest Service comment II.1.

II.9 <u>SO₂ Controls (cost effectiveness)</u> - The Forest Service commented that performance for a wet scrubber on Naughton Unit 3 was stated to be 0.10 lb/MMBtu, but the cost effectiveness was based on 0.15 lb/MMBtu. Cost per ton for SO₂ reduction should be based on 0.10 lb/MMBtu if that is the correct value.

<u>Response</u> – The application of wet FGD on Unit 3 is anticipated to lower SO₂ emissions to 0.10 lb/MMBtu, based on an average coal sulfur content of 0.58% by weight, and to 0.15 lb/MMBtu, based on an average coal sulfur content of 1.02% by weight. Because both low sulfur and high sulfur coals are used to fuel the boilers at Naughton, 0.15 lb/MMBtu was used as the basis for cost effectiveness. The cost effectiveness is not relevant because BART limits for SO₂ will not be set. Wyoming is a §309 state participating in the Regional SO₂ Milestone and Backstop Trading Program. §308(e)(2) provides states with the option to implement or require participation in an emissions trading program or other alternative measure rather than to require sources subject to BART to install, operate, and maintain additional control technology to meet an established emission limit on a continuous basis.

PacifiCorp Naughton Power Plant Decision Document, BART Permit Application, AP-6042 Page 8 of 28

II.10 SO₂ Controls (Section 309) – The Forest Service understands the role of Section 309 in exempting the State of Wyoming from making BART determinations for SO₂ controls based on the demonstration that the benefits from SO₂ emissions reductions under Section 309 exceed those that would have resulted from BART. Are the existing SO₂ controls in place at the Jim Bridger and Naughton plants at least equivalent to the control scenario used in the demonstration, i.e., are the existing controls needed to accomplish the "Better than BART" demonstration for Section 309? They also note that the 309 program sunsets in 2018 and added SO₂ controls may be needed for reasonable progress at that time.

<u>Response</u> – The State of Wyoming submitted a 309 SIP as is allowed by the Regional Haze Rule. Part of the SIP submittal is a "Better than BART" demonstration, required by rule, which does not require that each and every unit demonstrate emission controls that are "Better than BART". The demonstration is a regional demonstration. The Division is aware than the 309 program only establishes milestones through 2018, and that following 2018 another strategy may be necessary to reduce visibility-impairing pollutants. Additional strategies will be addressed in future SIP revisions.

II.11 <u>Visibility Impairment</u> – The Forest Service commented that because EPA BART guidelines state that 0.5 dv "contributes" to visibility impairment, and 1.0 dv "causes" visibility impairment, the discussion from Ronald Henry regarding perceptibility in the BART applications from PacifiCorp is irrelevant and used in an improper context.

<u>**Response**</u> – The Division did not attempt to endorse a particular threshold for human eye "perceptibility" since the level of perceptibility has long been disputed. Instead, the Division has relied on EPA's Appendix Y BART guidance, which suggests a value of 0.5 dv as the level that a source "contributes" to visibility impairment. One of the metrics used by the Division to evaluate the relative benefit of a given BART control option was the number of days yielding a modeled impact of 0.5 dv or more.

III. Analysis of Comments from EPA Region 8:

III.1 Background Ozone Concentration in CALPUFF – EPA Region 8 commented that the Division's visibility modeling used 44 ppb as a background ozone concentration as the default value for periods when measured data was missing. This value appears to be too low based on the average annual concentrations at sites near the facilities (Thunder Basin = 50-55 ppb, Jonah = 55-58 ppb). DEQ should provide an analysis of how higher ozone background concentrations would affect results.

<u>Response</u> – The default ozone background concentration is used by CALPUFF as a domain-wide substitute for any hour for which all measured ozone concentrations are missing. For the Division's visibility modeling for BART, hourly ozone concentrations measured at seven monitoring stations spaced across the modeling domain were input to CALPUFF. A visual inspection of the ozone files that were input to CALPUFF reveals that at least one valid ozone observation was available for every hour of the modeled period (2001-2003), making it unnecessary for the model to use the default background of 44 ppb.

Although the model did not use the default background value for the BART analyses, the Division calculated annual average concentrations for recent years (2007-2008) and all available data for 2009 for many of the stations that were used for input to CALPUFF, including Thunder

PacifiCorp Naughton Power Plant Decision Document, BART Permit Application, AP-6042 Page 9 of 28

> Basin, Jonah, Rocky Mountain National Park, Centennial, and Pinedale. Annual average values for these stations ranged from 35 ppb to 49 ppb, with an overall average of approximately 40 ppb. The Division is confident that the default background value of 44 ppb was appropriate for the BART modeling, and that there is no need for additional analyses to explore alternate background concentrations.

III.2 Weight of Visibility Modeling Results in BART Determinations – EPA Region 8 commented that DEQ should provide an explanation of how modeled visibility improvements were weighed in making BART determinations.

<u>**Response</u>** – The Division's BART determinations were based on consideration of all five statutory factors, as required by EPA's Appendix Y BART guidance. The modeled visibility improvements for a given control strategy were one of the five factors that were considered. No single factor was weighted as being more important than another, because the Division looked at all five statutory factors in their entirety. EPA guidance did not provide a quantification of the amount of modeled visibility improvement that would be acceptable or significant. The Division used two metrics that were mentioned in the EPA BART guidance, the 98th percentile result for a given year and the level at which a source "contributes" to visibility degradation (0.5 Δ dv), to present the results of the BART visibility modeling. Also see the response to USDA Forest Service comment II.6.</u>

III.3 <u>Cumulative Modeled Impacts</u> - EPA Region 8 commented that cumulative, modeled Class I impacts from all units at a facility (or combined impacts from multiple facilities) should be presented in addition to the results for individual units.

<u>Response</u> – The visibility impacts from BART-eligible sources are to be modeled separately. As stated in the EPA's Appendix Y guidance, relative to the use of the CALPUFF model for BART determinations, "We believe that CALPUFF is an appropriate application for States to use for the particular purposes of this rule, to determine if an individual source is reasonably anticipated to cause or contribute to impairment of visibility in Class I areas, and to predict the degree of visibility improvement which could reasonably be anticipated to result from the use of retrofit technology <u>at an individual source</u>. We encourage States to use it for these purposes." [emphasis added]

III.4 Language from BART Determinations – EPA Region 8 commented that the Division should clarify the statements of "3-year average visibility improvements". Are dv improvements calculated for each Class I area added together? If so, what is the meaning of the number? Are three Class I areas sufficient to quantify cumulative impacts? Were all Class I areas within 300 km considered?

<u>**Response**</u> – To arrive at the "3-year average visibility improvements" that were reported in the Division's BART analyses, the modeled 98^{th} percentile dv change or the number of days above 0.5 dv predicted for a given year of meteorology was averaged with the similar result from the other two years of meteorology. These 3-year average values were determined for each modeled Class I area separately, and were devised to allow a straightforward, direct comparison of one control option to another. Regarding the sufficiency of the number of modeled Class I areas and the question of other Class I areas within 300 km, see response to USDA Forest Service comment II.3.

PacifiCorp Naughton Power Plant Decision Document, BART Permit Application, AP-6042 Page 10 of 28

III.5 <u>NO_x Controls</u> – EPA Region 8 commented that the most stringent emission control levels for NO_x controls have not been evaluated, resulting in inflated calculated cost effectiveness values. Lower emission limits should be evaluated for selective non-catalytic reduction (SNCR) and SCR.

<u>**Response</u>** – The Division has analyzed the most stringent levels for SNCR and SCR, and does not agree that the cost effectiveness numbers have been inflated. See response to USDA Forest Service comment II.7. Furthermore, the Division has deemed the costs associated with all analyzed BART NO_x control options, including SNCR and SCR, to be reasonable (see the conclusions listed under the section: NOx: EVALUATE IMPACTS AND DOCUMENT RESULTS in each of the five BART Application Analyses).</u>

III.6 <u>12-Month Average for NO_x</u> – EPA Region 8 commented that there is no formula to calculate if the 12-month rolling emission limit has exceeded the permit condition. A permit condition to match condition 12.a.iii from the Laramie River Station analysis should be created.

<u>**Response**</u> – The BART limits for NO_x emissions from the PacifiCorp plants include 30-day rolling limits in terms of lb/MMBtu and lb/hr. The ton per year limit is based on a calendar year rather than a rolling average, and therefore the formula associated with the annual BART limit for NO_x at the Laramie River Station is not relevant.

III.7 <u>PM Controls: Averaging Periods</u> – EPA Region 8 commented that the BART conclusions and the permit conditions should include associated averaging periods for all PM/PM₁₀ limits.

<u>**Response**</u> – The averaging periods for the PM/PM₁₀ limits are dictated by the performance test requirements in the BART permits. Compliance with the lb/MMBtu and lb/hr PM/PM₁₀ limits is based on the average of three 1-hour tests per 40 CFR 60.46.

III.8 <u>PM Controls: Control Effectiveness</u> – EPA Region 8 commented that the Division should explain why 0.015 lb/MMBtu for baghouse/fabric filter control effectiveness is acceptable, when 0.012 lb/MMBtu has been approved by the Division for other permits and 0.010 lb/MMBtu was approved for the Desert Rock project. The BART determinations should include analyses of electrostatic precipitators (ESPs) and baghouses at lower control levels.

<u>Response</u> – Recent Prevention of Significant Deterioration (PSD) permits issued by the Division did include PM/PM_{10} limits of 0.012 lb/MMBtu for fabric filter controls, but those limits (and PM/PM_{10} limits established for the Desert Rock Project in New Mexico) were determined through Best Available Control Technology (BACT) analyses for new sources. The BART process deals with retrofit controls on existing units, and therefore is not directly comparable to BACT determinations. Additionally, visibility modeling described in the Division's BART analysis for the Jim Bridger plant showed that the addition of a fabric filter to replace an Electrostatic Precipitator (ESP) provided very little in the way of visibility improvement, with predicted cumulative improvements across three Class I areas of only 0.03 to 0.1 Δdv for Units 1-4. These results indicate that requiring more stringent control levels for a fabric filter would not provide significant visibility improvement.

As described on page 17 of the Division's BART analysis for the Naughton plant, ESP performance enhancements using FGC were considered for Units 1 and 2, and will be utilized for BART control. For Unit 3, a new full-scale fabric filter will be installed for BART control.

PacifiCorp Naughton Power Plant Decision Document, BART Permit Application, AP-6042 Page 11 of 28

III.9 <u>PM Controls: Permit Exemption</u> – EPA Region 8 commented that Condition 5 in the proposed EGU BART permits contains an inappropriate exemption for startup. The exemption from the lb/MMBtu PM limit during startup should be removed or it may be appropriate to analyze the need for a startup BART limit.

<u>**Response**</u> – For each EGU subject to BART in Wyoming, only the BART limits for PM/PM₁₀ that are expressed in lb/MMBtu will not apply during startup. The BART limits for PM/PM₁₀ that are expressed in lb/hr and tpy (as based on the lb/MMBtu limits) will apply during all operating periods including startup.

The Division considers the BART limits expressed in terms of lb/hr and tpy to be appropriate limits for startup. For the four units at the Jim Bridger plant, PacifiCorp calculated that the particulate emissions from the startup fuel (fuel oil) would be no greater than 10.9 lb/hr per unit, conservatively assuming that the ESP controls had zero control efficiency during the startup process. As a comparison, the BART limit that would apply for each unit during startup is 180 lb/hr. Further, PacifiCorp has agreed to minimize startup emissions from the four units at the plant by placing the ESPs in service prior to the introduction of coal to the boilers, which is contrary to the manufacturer's recommendation to energize the ESP only after the unit is at full operating temperature and combustion of fuel oil has ceased.

Similarly for Unit 1 at Wyodak, particulates are controlled by an ESP and startup is accomplished with fuel oil. The maximum emissions estimated for startup (8.9 lb/hr) would be well below the BART limit of 71 lb/hr. The three units at LRS are also started on fuel oil and controlled with ESPs, and the particulate emissions during startup are expected to be well below the BART limits, which are set at 193 lb/hr to 198 lb/hr for the three units.

For units with baghouse controls for particulate matter such as Dave Johnston Units 3 and 4, emissions from fuel oil during the startup process are also estimated to be well below the allowable lb/hr BART limits.

In the case of the Naughton plant, particulate controls will include a mixture of ESPs (Units 1 and 2) and a fabric filter/baghouse (Unit 3). Natural gas is the startup fuel for each of these units, and particulate emissions during startup are expected to be well below the established lb/hr BART limits.

III.10 <u>PM Controls: FGC</u> – EPA Region 8 commented that flue gas conditioning (FGC) must be applied only after FGD is installed or upgraded to avoid increases in the emissions of sulfuric acid (H₂SO₄) mist. A control option should not be considered as a BART option if it will result in an increase in visibility-reducing pollutants.

<u>Response</u> – The Division has already evaluated the impacts of FGC at the Naughton plant as part of the review of PacifiCorp's permit application for permit MD-5156, which was issued on May 1, 2009. Permit MD-5156 authorized FGC to enhance the performance of the ESPs on Units 1 and 2. The permit application included a modeling evaluation of the impacts to Class I area visibility from the FGC, and the impacts were predicted to be insignificant. PacifiCorp Naughton Power Plant Decision Document, BART Permit Application, AP-6042 Page 12 of 28

III.11 <u>SO₂ Controls: Reasonable Progress</u> – EPA Region 8 commented that the Division must evaluate the visibility impacts of SO₂ controls and demonstrate reasonable progress for the Class I areas away from the Colorado Plateau.

<u>Response</u> – Wyoming, along with other 309 states in the WRAP region, evaluated the impact of the 309 program on all Class I areas in the west, even though the requirement by rule was to demonstrate improvement in Class I areas on the Colorado Plateau. The WRAP modeling for sulfates shows that all Class I areas in and around Wyoming sources are benefiting from the sulfur dioxide emission reductions instituted in the 309 program. Sulfate extinction levels show improvement on the 20% worst days and improvement or at least no degradation on the 20% best days. Furthermore, the Regional Haze rule allows a state to take full credit for strategies implemented under 309 when addressing Class I Areas away from the Colorado Plateau (51.309(g)(4)(i)).

III.12 <u>CALPUFF Visibility Modeling: Other Class I Areas</u> – EPA Region 8 commented that visibility impacts at Flattops Wilderness Area in Colorado should have been modeled for the Jim Bridger and Naughton plants.

Response - See response to USDA Forest Service comment II.3.

III.13 <u>NO_x Controls</u> - EPA Region 8 commented that the control efficiencies assumed for all NO_x technologies are underestimated, resulting in inflated calculated cost effectiveness values. A revised analysis should indicate that SCR is cost effective at Naughton.

<u>Response</u> – See response to EPA Region 8 comment III.5.

III.14 <u>PM Controls: FGC</u> – EPA Region 8 commented that flue gas conditioning (FGC) will be applied to Naughton Units 1 and 2 and decommissioned from Unit 3 upon installation of a fabric filter permitted under PSD. The application of FGC prior to FGD upgrades will result in a significant increase in emissions of sulfuric acid (H₂SO₄) mist. This collateral increase should be avoided to maintain visibility improvements at Class I areas.

<u>Response</u> – See response to EPA Region 8 comment III.10.

- IV. Analysis of Comments from PacifiCorp:
- IV.1 <u>General Comments: Cost Metrics</u> PacifiCorp commented that EPA's Appendix Y BART guidance states that a proper BART evaluation should include "other cost-effectiveness measures (such as \$/deciview)". Thus, any BART determination that is limited to use only cost effectiveness and incremental cost effectiveness may be unacceptably narrow.

<u>**Response**</u> – EPA's Appendix Y BART guidance does mention that "dollars per deciview" ($\frac{1}{\sqrt{v}}$) is a metric that could be used to evaluate the cost of BART compliance, but by no means identifies $\frac{1}{\sqrt{v}}$ as an essential or required metric. The Division considered capital cost, annual cost, cost effectiveness, and incremental cost effectiveness in the cost evaluation of each proposed BART control option. The Division chose not to use a hybrid metric such as $\frac{1}{\sqrt{v}}$ primarily because of the lack of historical precedent regarding reasonable/acceptable levels for such a metric. Additionally, the use of a hybrid cost metric such as $\frac{1}{\sqrt{ecv}}$ could be based on the

PacifiCorp Naughton Power Plant Decision Document, BART Permit Application, AP-6042 Page 13 of 28

> highest modeled value in a given area or the 98^{th} percentile modeled value. It could be based on the 98^{th} percentile value for any one modeled year or it could be an average for multiple years. It could even be based on an average modeled value across an entire Class I area or the sum of deciview changes across multiple areas. The Division has found that dv values are often presented without explanation of the basis for the calculation. To avoid these confounding factors, the Division chose to evaluate and present the cost analyses and visibility analyses separately.

IV.2 <u>General Comments: Cost Effectiveness</u> – PacifiCorp commented that any BART determination requiring a source to install post-combustion controls like SCR or spend more than \$1,500 per ton of NO_x removed would be contrary to EPA Appendix Y BART guidance.

<u>Response</u> – The EPA's Appendix Y guidance describes the EPA's selection of presumptive NO_x limits for coal-fired EGUs, and provides approximate cost levels for meeting the presumptive limits with current combustion controls and a somewhat higher cost level for a subset of units that would require advanced combustion controls such as rotating opposed fire air (ROFA). The EPA guidance does not attempt to establish cost thresholds that would be considered unreasonable for a given control technology, nor does it present the approximate costs associated with the presumptive levels as absolute limits above which cost should be deemed unreasonable. The guidance also states that states may in specific cases find that the use of SCR is appropriate. As stated previously, the Division established NO_x emission limits for BART based on consideration of all five statutory factors in their entirety, as required by the Appendix Y guidance.

IV.3 <u>General Comments: Power Plants More Than 750 MW</u> – PacifiCorp commented that Appendix Y indicates that states must follow Appendix Y guidelines in making BART determinations on a source-by-source basis for 750 MW plants. Wyoming rules impose similar requirements for power plants greater than 750 MW.

<u>**Response</u>** – The Division followed EPA and State of Wyoming rules for the BART analyses. Specifically, the Division followed WAQSR Chapter 6, $\S9(c)(ii)$, which states that power plants with generating capacities greater than seven hundred fifty megawatts shall comply with EPA Appendix Y, and that Appendix Y should be used as guidance for preparing BART analyses for all other facilities.</u>

IV.4 <u>General Comments: Post-Combustion Controls</u> – PacifiCorp commented that EPA never contemplated the use of post-combustion controls to meet BART limits for tangentially-fired boilers, and that it is nearly impossible under Appendix Y guidance to show that anything other than combustion controls should be required as BART.

<u>**Response**</u> – See response to PacifiCorp comment IV.2.

IV.5 <u>General Comments: Visibility Improvement</u> – PacifiCorp commented that a BART determination that only relied on the 98th percentile, three-year average results from CALPUFF may be too narrow to satisfy Appendix Y.

<u>Response</u> – The Division did not rely solely on the three-year average of the 98^{th} percentile CALPUFF results to evaluate the expected visibility changes for the BART control options. The 98^{th} percentile values and the number of days with predicted results above 0.5 dv were presented in the Division's BART analyses for each of three modeled years, for each Class I area, and for

PacifiCorp Naughton Power Plant Decision Document, BART Permit Application, AP-6042 Page 14 of 28

each control option. The three-year average of the 98^{th} percentile results and the number of days above 0.5 dv were chosen for graphical representation and were mentioned prominently in the Division's conclusions because they offered the clearest comparison of one control option to another (see graphs in Appendix A).

IV.6 <u>General Comments: Modeling</u> – PacifiCorp commented that visibility modeling contains inherent bias or exaggeration because it assumes that a particular source will operate at its maximum capacity 100% of the time and that each unit at a facility operates in the same way.

<u>Response</u> – The results from BART visibility modeling, as required by EPA guidance, are based on daily (24-hour) averages. Reported results for a given control scenario, expressed in units of deciviews, represent the predicted change in visibility as compared to natural background over the course of 24-hour periods of meteorology. The modeled emission rates for a given unit at a power plant should reflect the highest rate that could be achieved over a 24-hour period, and therefore the assumption that a given unit is operating at its maximum operating capacity is appropriate for each unit at a base-load power plant such as Naughton. Additionally, the conclusions drawn from BART visibility modeling primarily involve comparisons between control scenarios for which the emissions are determined similarly.

IV.7 <u>General Comments: NO_x Emissions</u> – PacifiCorp commented that emissions of NO_x during the 20% best and 20% worst days at Class I areas in Wyoming are not a significant contributor to regional haze as compared to other emissions, and therefore the Division should consider this before requiring extreme NO_x control measures such as SCR as BART.

<u>**Response</u>** – For the 20% worst days during the years 2000-2004 at the Bridger Wilderness Area, 6.21% of the total visibility degradation was attributable to nitrates. Source apportionment modeling provided by the WRAP showed that 19% of the nitrates come from Wyoming sources. The Division recognizes that pollutants other than nitrates contribute more toward the total visibility degradation at the Bridger Wilderness Area, but the Division has concluded that the contribution from Wyoming sources toward the formation of nitrates at the Bridger Wilderness Area and other Class I areas warrants a full consideration of prospective NO_x controls under the BART process.</u>

IV.8 <u>Perceptibility</u> - PacifiCorp commented that credible studies indicate that only changes in visibility as high as 1.5-2.0 dv are perceptible to the human eye. The Division should consider this while drawing conclusions based on the results of the visibility modeling and before requiring extreme NO_x control measures such as SCR.

<u>**Response**</u> – See response to USDA Forest Service comment II.11.

IV.9 Cost Metrics for Naughton Unit 3 – PacifiCorp commented that it opposes the determination that SCR is BART for NO_x control, and that the Division should have considered other cost-benefit metrics such as \$/dv. Using \$/dv, the cost for 1 dv of visibility improvement is more than \$15 million per year. If one considers that changes of less than 1.5 dv are not perceptible to the human eye, the cost per deciview reduction is not reasonable.

<u>Response</u> – See responses to PacifiCorp comment IV.1 and USDA Forest Service comment II.11.

PacifiCorp Naughton Power Plant Decision Document, BART Permit Application, AP-6042 Page 15 of 28

IV.10 Presumptive BART – PacifiCorp commented that the Division's reference in the BART analysis for the Naughton plant to a presumptive BART limit for NO_x of 0.15 lb/MMBtu is not correct. For reasons stated in PacifiCorp's most recent submittals to the Division, primarily an argument regarding coal characteristics, the correct presumptive BART limit for Naughton Units 1-2 is 0.28 lb/MMBtu.

<u>Response</u> – See response to USDA Forest Service comment II.5.

IV.11 <u>Reasonable Costs for SCR on Naughton Unit 3</u> – PacifiCorp commented that the calculated costs for SCR on Naughton Unit 3 are not reasonable, according to EPA's Appendix Y guidance.

<u>**Response</u>** – The EPA's Appendix Y guidance describes the EPA's selection of presumptive NO_x limits for coal-fired EGUs, and provides approximate cost levels for meeting the presumptive limits with current combustion controls and a somewhat higher cost level for a subset of units that would require advanced combustion controls such as ROFA. The EPA guidance does not attempt to establish cost thresholds that would be considered unreasonable for a given control technology, nor does it present the approximate costs associated with the presumptive levels as absolute limits above which cost should be deemed unreasonable. The guidance also states that states may in specific cases find that the use of SCR is appropriate. As stated previously, The Division established NO_x emission limits for BART at the Naughton power plant based on consideration of all five statutory factors, as required by the Appendix Y guidance.</u>

IV.12 Incremental Costs for SCR on Naughton Unit 3 – PacifiCorp commented that the incremental costs per ton of NOx reduction for SCR on Naughton Unit 3 shown in Table 10, page 15 of the Division's BART analysis is incorrect. The correct value is more than \$4,000 per ton rather than the value of \$1,783 that is shown in Table 10. When considering the true incremental costs of SCR, the Division's BART determination cannot stand.

<u>Response</u> – The incremental cost listed for SCR control in Table 10 of the Division's BART analysis for Naughton Unit 3 was incorrect, and should have been listed as \$4,049 per ton. However, the Division concluded that the correct cost per ton of NO_x reduction (\$2,830/ton) and the incremental cost per ton of NO_x reduction (\$4,049) are both reasonable for SCR control on Naughton Unit 3. Table 3 below presents a comparison of the costs associated with SCR control for Naughton Units 1 through 3 which shows that the costs associated with all three units are comparable and the incremental costs for Unit 3 are lower compared to the other two units at the plant. Furthermore, costs for Units 1 and 2 were identified in the analysis as reasonable and the costs for Unit 3 are within that range. The Division's error had no bearing on the BART determination.

Table 3: Costs for SCR Control on Naughton Units 1 Through 3				
		Incremental Cost Per Ton of		
Unit	Cost Per Ton of NO _x Reduction	NO _x Reduction		
1	\$2,750	\$8,089		
2	\$2,848	\$7,852		
3	\$2,830	\$4,049		

PacifiCorp Naughton Power Plant Decision Document, BART Permit Application, AP-6042 Page 16 of 28

IV.13 <u>Boardman, Oregon BART Determination</u> – PacifiCorp commented that the state of Oregon determined that SCR control was not appropriate for the Boardman Power Plant, yet the cost-benefit values for Boardman are more favorable for SCR installation than for Naughton Unit 3.

<u>Response</u> – The Division determined BART for NO_x control for Naughton Unit 3 based on consideration of all five statutory factors, as required by EPA's Appendix Y BART guidance. The costs for SCR controls, as described in the Division's BART analysis, were deemed by the Division to be reasonable. Modeled visibility reductions from baseline for the LNB/OFA option on Naughton Unit 3 were not nearly as pronounced as they were for other BART-eligible units in the state. The Division determined that SCR would be required on Naughton Unit 3 to bring about additional NO_x emission reductions and additional modeled visibility improvement, and these factors differentiated the Naughton Unit 3 analysis from the others. For additional details, see response to USDA Forest Service comment II.6 and the graphs in Appendix A.

IV.14 Presumptive BART for Naughton Unit 3 and LNB/OFA Emissions Compared to Units 1/2 – PacifiCorp commented that presumptive BART for NO_x control on Naughton Unit 3 is not 0.15 lb/MMBtu as stated in the Division's BART analysis, but is 0.28 lb/MMBtu. Sufficient justification exists under Appendix Y to select a higher calculated BART limit of 0.35 lb/MMBtu. Even if the 0.015 lb/MMBtu presumptive limit is assumed to be correct, the requirements for SCR control at 0.07 lb/MMBtu cannot be justified as BART because it is so far below the EPA's presumptive limit of 0.15 lb/MMBtu. PacifiCorp also commented that the modeled deciview reductions for Naughton Units 1 and 2 as compared to Unit 3 are interesting but not relevant in making a BART determination. The fact that Units 1 and 2 can achieve greater modeled visibility improvements is only an indication that Unit 3 has already installed and achieved a significant level of NO_x reductions.

Response – The Division determined BART for NO_x control for Naughton Unit 3 based on consideration of all five statutory factors, as required by EPA's Appendix Y BART guidance. PacifiCorp's analysis of coal composition and how it might affect the presumptive NO, limit for Naughton Unit 3 was not a factor in the Division's determination. The NO_x emission level proposed by PacifiCorp for Naughton Unit 3 using LNB/OFA provided less in the way of modeled visibility reductions from baseline as compared to other BART-eligible units in the state. For example, Naughton Units 1 and 2 showed a 72% to 73% reduction in the number of days with predicted impacts of 0.5 dv or more at the Bridger Wilderness Area for LNB/OFA as compared to baseline. The reduction for Naughton Unit 3 with LNB/OFA vs. baseline was only 31%. Modeled visibility impacts for Naughton Unit 3 were reduced to levels comparable to those yielded by LNB/OFA controls on Naughton Units 1 and 2 only through the addition of SCR on Naughton Unit 3 (see graphs in Appendix A). A comparison between the modeled visibility for Naughton Units 1 and 2 at the proposed level for LNB/OFA control (0.26 lb/MMBtu) and the proposed level for LNB/OFA control for Naughton Unit 3 (0.37 lb/MMBtu) is certainly relevant for making a BART determination for Naughton Unit 3. Also see response to USDA Forest Service comment II.6.

PacifiCorp Naughton Power Plant Decision Document, BART Permit Application, AP-6042 Page 17 of 28

V. Analysis of Comments from the National Park Service:

V.1 NO_x Step 3: Evaluate Effectiveness of Remaining Control Technologies (SCR capabilities) – The NPS commented that the Division underestimated the ability of SCR to reduce emissions. The proposed NO_x limit for SCR (0.07 lb/MMBtu) is not low enough. SCR can achieve greater reductions. NPS suggests 0.06 lb/MMBtu for 30-day limit, 0.05 lb/MMBtu or lower for an annual limit.

Response - See response to USDA Forest Service comment II.7.

V.2 <u>NO_x Step 4: Evaluate Impacts and Document Results (SCR costs)</u> – The NPS commented that SCR costs were generally overestimated because the OAQPS Control Cost Manual was not used for cost estimates.

<u>Response</u> – PacifiCorp developed cost estimates for SCR control using a combination of the OAQPS Control Cost Manual, vendor-obtained price quotes, and a database developed by the engineering firm Sargent & Lundy. The degree to which the SCR costs may have been overestimated does not require further review because the Division has concluded that the estimated costs are reasonable and that costs alone would not preclude the use of SCR.

V.3 <u>NO_x Step 4: Evaluate Impacts and Document Results (incremental costs for SCR)</u> – The NPS commented that the Division over-emphasized the incremental costs for the addition of SCR in the BART determinations. The Division should consider the average costs calculated for combustion controls plus SCR.

<u>Response</u> – See response to PacifiCorp comment IV.1 and NPS comment V.2.

V.4 <u>NO_x Step 4: Evaluate Impacts and Document Results (basis for costs)</u> – The NPS commented that cost estimates should be documented by vendor or by the EPA Control Cost Manual.

<u>**Response**</u> – See response to NPS comment V.2.

V.5 <u>NO_x Step 5: Visibility Improvement Determination (Class I Areas Modeled)</u> – The NPS commented that the Division should consider visibility impacts at all Class I areas within 300 kilometers (km) of a source.

<u>Response</u> – See response to USDA Forest Service comment II.3.

V.6 <u>NO_x Step 5: Visibility Improvement Determination (incremental benefits of SCR)</u> – The NPS commented that the Division placed too much emphasis on the incremental improvement in visibility that was predicted for the addition of SCR. The total predicted visibility improvement resulting from a combination of control options should have been presented.

<u>Response</u> – The incremental improvement in modeled visibility with the addition of SCR was mentioned prominently in the summary of the Division's BART conclusions, but all visibility modeling results were considered. For more information on the presentation of the visibility modeling results in the Division's BART analyses, see the response to EPA Region 8 comment III.2 and PacifiCorp's comment IV.5.

PacifiCorp Naughton Power Plant Decision Document, BART Permit Application, AP-6042 Page 18 of 28

V.7 <u>NO_x Step 5: Visibility Improvement Determination (sulfuric acid mist emissions)</u> – The NPS commented that the modeled sulfuric acid mist emissions increased for the SCR control scenario, and the Division should provide a detailed explanation of how the sulfuric acid mist emissions were calculated by PacifiCorp.

<u>Response</u> – PacifiCorp's consultant, CH2M HILL, used the following methodology to calculate sulfate emissions for SCR for the PacifiCorp coal-fired power plants (as provided in a letter from PacifiCorp that was submitted to the Division on September 16, 2009):

- 1.0% of the SO₂ in the boiler is converted to SO₃
- An additional 1.0% of the SO₂ is converted to SO₃ in an SCR unit
- The SO₃ is converted to H₂SO₄ mist in the flue gas
- 50% of the H₂SO₄ mist is removed in a wet FGD unit
- 95% of the H₂SO₄ mist is removed in a dry FGD unit
- An SCR unit has 2.0 ppmvd NH₃ slip
- 50% of the NH₃ slip is converted to ammonium sulfate and 50% is converted to ammonium bisulfate
- 50% of the ammonium sulfate and bisulfate are removed in a wet FGD unit and 90% of the ammonium sulfate and bisulfate are removed in a dry FGD unit
- Total sulfate emissions are made up of H₂SO₄ mist, ammonium sulfate and ammonium bisulfate
- V.8 <u>BART Conclusions for NO_x Controls: \$/dv</u> The NPS commented that the Division should use \$/dv as an additional metric for evaluating BART controls.

Response - See response to PacifiCorp response IV.1.

V.9 <u>BART Conclusions for NO_x Controls: Cost Benchmarks</u> – The NPS commented that the Division determined that the costs for SCR were reasonable, yet rejected SCR for BART control. DEQ should explain why and provide the cost benchmarks used to determine reasonable costs.

<u>**Response**</u> – The Division established NO_x emission limits for BART based on consideration of all five statutory factors (as required by EPA's Appendix Y BART guidance) and not merely based on cost. The Division relied on past experience with BACT determinations for similar sources/control options to determine the range of control costs that were reasonable.

V.10 **BART Conclusions for NO_x Controls: Non-Air Ouality Impacts** – The NPS commented that the Division mentioned non-air quality impacts as reasons to reject SCR for BART controls. Recent PSD permits issued by DEQ and requiring SCR did not mention such impacts. Why were such impacts mentioned in these particular cases? SCR has been used at many facilities with minimal problems with transport and storage of ammonia, why would this be a particular problem for SCR as BART control?

<u>**Response**</u> – The Division's BART determinations for the Naughton plant were based on consideration of the five statutory factors, including the cost of compliance and the energy and non-air quality environmental impacts of compliance. Potential energy losses and environmental impacts from the operation of SNCR and SCR were mentioned in the Division's BART analysis, but were only part of the larger evaluation that considered all five statutory factors.

PacifiCorp Naughton Power Plant Decision Document, BART Permit Application, AP-6042 Page 19 of 28

V.11 BART Conclusions for NO_x Controls: Parasitic Power Loss – The NPS commented that the Division mentioned parasitic power loss in association with the operation of OFA and SCR. Parasitic power loss associated with SCR has already been accounted for in the cost analysis for NO_x and should not be "double-counted" by using it to draw conclusions for BART control unless it would cause a power shortage.

<u>Response</u> – See response to NPS comment V.10.

V.12 **BART Conclusions for NO_x Controls: Fly Ash Sales** – The NPS commented that the Division stated that the operation of SCR could impact the "salability" of fly ash. Evidence should be presented and the economic impact quantified.

<u>Response</u> – See response to NPS comment V.10.

V.13 <u>BART Conclusions for NO_x Controls: Ammonia Injection</u> – The NPS commented that the Division stated that SCR could create "blue plume" if the ammonia injection rate is not well controlled. NPS states that it assumes that PacifiCorp can properly control the injection rate.

<u>Response</u> – See response to NPS comment V.10.

V.14 **<u>BART</u>** Conclusions for NO_x Controls: SCR Installation – The NPS commented that PacifiCorp states that SCR would take a minimum of six years to plan and install. NPS states that Minnesota Power plans to install SCR, fabric filter, and a new chimney on the 330 MW Boswell Unit #3 in half of that time. PacifiCorp should explain why so much extra time is needed.

<u>Response</u> – A letter provided to the Division by PacifiCorp dated September 16, 2009 provided information on the time needed to plan, design, and install SCR:

- Develop and Permit: 18-24 months
- Design: 9-12 months
- Procurement: 9-13 months
- Construct: 18-24 months
- Start, Tune, and Test 4-6 months
- Total (including overlap of individual tasks): 60-66 months
- V.15 <u>BART Conclusions for PM₁₀ Controls: Control Effectiveness</u> The NPS commented that the Division should explain why 0.015 lb/MMBtu was acceptable to the Division as a control effectiveness for a ESP/polishing fabric filter combination, when 0.012 lb/MMBtu has been approved by the Division for other recent permits involving fabric filters and limits as low as 0.010 lb/MMBtu have recently been approved for fabric filters (e.g., Desert Rock Project).

Response - See response to EPA Region 8 comment III.8.

V.16 **BART Conclusions for PM₁₉ Controls: Fabric Filters** – NPS believes that PacifiCorp would not have agreed to install fabric filters unless it finds the option to be reasonable or is compelled to do so. DEQ should accept fabric filters as a reasonable BART alternative in the context of the PM reductions and associated costs, or state what it considers reasonable average and incremental costs for a fabric filter.

PacifiCorp Naughton Power Plant Decision Document, BART Permit Application, AP-6042 Page 20 of 28

<u>Response</u> – The Division concluded that the costs of a fabric filter for Naughton Unit 3 was not reasonable. However, as stated on page 51 of the Division's BART analysis for Naughton: "PacifiCorp is committed to installing this control device and has permitted the installation of a full-scale fabric filter on Naughton Unit 3 in a recently issued New Source Review construction permit. A full-scale fabric filter is the most stringent PM/PM₁₀ control technology and therefore the Division will accept it as BART."

VI. <u>Analysis of Comments from the Powder River Basin Resource Council, et al.</u>:

VI.1 <u>Modeled Class I Areas</u> – The Powder River Basin Resource Council, et al. commented that all Class I areas within 300 km of a given source should be modeled for visibility impacts.

<u>Response</u> – See response to USDA Forest Service comment II.3.

VI.2 <u>Presumptive BART</u> – The Powder River Basin Resource Council, et al. commented that DEQ failed to impose the presumptive BART limit for NO_x of 0.15 lb/MMBtu for Naughton Units 1 and 2, applying the mistaken logic that the presumptive limits do not apply because Naughton's cumulative capacity is less than 750 MW.

<u>Response</u> – See response to USDA Forest Service comment II.5.

VI.3 <u>Reasonably Attributable Visibility Impairment</u> – The Powder River Basin Resource Council, et al. commented that because of the magnitude of modeled visibility impacts, DEQ should certify that Wyoming power plants are causing reasonably attributable visibility impairment, and establish more stringent BART controls. A single source that is responsible for a 1.0 deciview change or more should be considered to "cause" visibility impairment, according to WAQSR Chapter 6, §9(d)(i)(A). Because of the reasonably attributable visibility impairment, BART must be determined under WAQSR Chapter 9, §2(d)(ii) and 40 CFR §51.302(c)(4)(iii). These regulations provide that BART is presumed to be at least at NSPS levels. This would require at least 0.11 lb/MMBtu for NO_x limits, but SCR should be required at 0.07 lb/MMBtu.

Response – WAQSR Chapter 6, §9(d)(i)(A) applies to the determination of which sources in Wyoming are subject to BART under the regional haze program, and is not relevant to the determination of *reasonably attributable visibility impairment*. Since adoption of Wyoming's Visibility SIP and visibility regulations to address *reasonably attributable visibility impairment*, neither the Federal Land Managers of any Class I area nor the Division has certified that visibility impairment, attributable to a source or small group of sources, exists in any Wyoming Class I area pursuant to provisions in Chapter 9, Section 2 of the WAQSR. The provisions of Chapter 9, Section 2 of the WAQSR are therefore not relevant to the Division's BART analyses.

VI.4 Section 309 Milestone Program – The Powder River Basin Resource Council, et al. commented that DEQ should impose BART limits for SO₂ because participation in the Section 309 program only excuses DEQ from setting BART limits if the State's 309 SIP is approved by the EPA and if the 309 SIP demonstrates that emissions levels would result in greater visibility improvement than source-specific BART limits.

<u>**Response**</u> – The Regional Haze Rule allows the State of Wyoming to submit a 309 SIP in lieu of establishing BART limits for SO₂. The 309 SIP submittal includes a "Better than BART" demonstration. The entire submittal is currently undergoing EPA review and the State has no

PacifiCorp Naughton Power Plant Decision Document, BART Permit Application, AP-6042 Page 21 of 28

control over how long the EPA takes to review the SIP. The State, however, does not wait for EPA to complete its review before implementing a SIP. All of the 309 states have been participating in the 309 program, collecting SO_2 inventories, allowing independent audits of the information, comparing the regional totals to the milestones, and taking public comment on the regional figures and the comparisons with the milestone figures. The SO_2 levels have shown compliance with the milestones and continue to demonstrate declining SO_2 emissions levels. Also see responses to USDA Forest Service comment II.10 and EPA comment III.11.

VI.5 BART Conclusions for PM₁₀ Controls – The Powder River Basin Resource Council, et al. commented that the Division should require PacifiCorp to meet, at a minimum, a PM limit 0.015 lb/MMBtu at the Naughton plant using full baghouse or polishing baghouse because: 1) the plant is causing reasonably attributable visibility impairment in at least two Class I areas, and 2) because BART is supposed to be the "best system of continuous emission reduction" and the Division's analysis identified fabric filters as the most stringent PM control.

<u>**Response</u>** – The Division established PM/PM₁₀ emission limits for BART at the Naughton plant based on consideration of all five statutory factors, as required by EPA's Appendix Y BART guidance. Various control technologies were evaluated for each source subject to BART, including the most advanced controls, but the BART guidance does not dictate that a state require the control technology with the highest level of control in all cases. Regarding the relevance of *reasonably attributable visibility impairment*, see response to Powder River Basin Resource Council, et al. comment VI.3.</u>

VII. Analysis of Comments from the Sierra Club and Citizens Associated with the Sierra Club:

VII.1 <u>Air Quality Laws and Regulations</u> – The Sierra Club commented that it is important that air quality laws and regulations are strictly complied with to preserve park resources for present and future generations.

<u>Response</u> – The Division followed federal regulations and guidance as well as state regulations in assessing the BART applications and for making the BART determination for all sources eligible for BART in the State of Wyoming. The BART rules and guidance used by the Division included:

- Section 308 of the Regional Haze Rule [40 CFR 51.308(e)]
- Guidelines for BART Determinations Under the Regional Haze Rule [Appendix Y to part 51]
- Chapter 6, Section 9 of the Wyoming Air Quality Standards and Regulations (WAQSR), Best Available Retrofit Technology
- VII.2 <u>Regional Haze Rule</u> The Sierra Club commented that the State of Wyoming can and should do more to protect air quality as the Regional Haze Rule is implemented.

<u>Response</u> – The Division's BART determinations for Wyoming sources, as well as additional air pollution controls that will be required to further reduce regional haze, will be addressed in the Wyoming State Implementation Plan (SIP) for regional haze. The SIP incorporates the emissions reductions associated with the Long-Term Strategy for regional haze.

PacifiCorp Naughton Power Plant Decision Document, BART Permit Application, AP-6042 Page 22 of 28

VII.3 <u>Control of Nitrogen Oxide Emissions</u> – The Sierra Club commented that the State of Wyoming should require the coal plants to install devices that reduce nitrogen oxide emissions.

<u>Response</u> – All of the Division's BART determinations for coal-fired power plants in the State of Wyoming include pollution control equipment that will substantially reduce nitrogen oxide emissions.

VII.4 <u>20-Year Trend</u> – A commenter stated that the amount of air and water pollution has clearly escalated in the past 20 years, with little relief for citizens or for the health of forests and the environment.

<u>**Response**</u> – The Division's BART determinations and other requirements under the regional haze program will result in large, state-wide emission reductions for three visibility-impairing pollutants; nitrogen oxides (NO_x), particulate matter (PM/PM₁₀), and sulfur dioxide (SO₂). As an example, BART controls at the Jim Bridger plant will result in a total annual reduction in potential NO_x emissions of approximately 13,500 tons per year.

VII.5 <u>Wind Power</u> – A commenter stated that Wyoming can readily replace aging coal-fired power plants with wind power to protect public health and to protect our national parks and wilderness areas.

<u>Response</u> – The BART program is designed to assess Best Available Retrofit Technology on existing sources of air pollution, including the existing power plants in the State. The Division's BART determinations will result in significant reductions in air pollutants from several power plants in Wyoming, but complete replacement of the power plants with an alternate source of energy is well beyond the scope of the BART program.

VII.6 <u>Pollution Reduction from Power Plants</u> – A commenter stated that Wyoming has an obligation to protect treasured public spaces by adhering to federal air quality laws. The State must reduce air pollutants from the old coal plants that are federally required to utilize the most advanced technical developments in ensuring that air pollution is minimized.

 $\underline{\text{Response}}$ – The Division determined BART controls based on the five statutory factors developed by the EPA. Various control technologies were evaluated for each source subject to BART, including the "most advanced technical developments", but the ultimate BART determinations were made based on a full consideration of all five statutory factors in their entirety.

VII.7 <u>SCR Controls</u> – Several commenters stated that BART for NO_x control should be SCR for all plants.

<u>Response</u> – See responses to USDA Forest Service comments II.1 and II.6.

PacifiCorp Naughton Power Plant Decision Document, BART Permit Application, AP-6042 Page 23 of 28

VIII. Analysis of Public Comments:

VIII.1 <u>SCR Controls</u> – Several commenters stated that BART for NO_x control should be SCR for all plants.

Response - See responses to USDA Forest Service comments II.1 and II.6.

IX. <u>Decision</u>:

On the basis of comments received during the public comment period, an analysis of those comments, and representations made by PacifiCorp, the Department of Environmental Quality has determined that the permit application filed by PacifiCorp complies with all applicable Wyoming Air Quality Standards and Regulations and that a BART permit will be issued for the Naughton Power Plant. All of the conditions proposed in the Division's analysis will be included in the permit. No permit conditions required revision as a result of the public comment period.

Dated this 31st day of December, 2009.

man

David A. Finley Administrator Wyoming Air Quality Division

ohn V. Corra Director Wyoming Department of Environmental Quality

APPENDIX A

VISIBILITY MODELING RESULTS (Baseline vs. LNB and SCR)

Figure 1 Modeled BART Impacts in Bridger Wilderness Area Naughton and Jim Bridger Power Plants: 98th Percentile (delta-dv)




Figure 2 Modeled BART Impacts in Wind Cave National Park Wyodak, Dave Johnston, and Laramie River Station Power Plants: 98th Percentile (delta-dv)




Figure 3 Modeled BART Impacts in Bridger Wilderness Area Naughton and Jim Bridger Power Plants: # Days > 0.5 delta-dv





Figure 4 Modeled BART Impacts in Wind Cave National Park Wyodak, Dave Johnston, and Laramie River Station Power Plants: # Days > 0.5 delta-dv





Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Dave Freudenthal, Governor

December 31, 2009

Mr. Robert Arambel Managing Director PacifiCorp P.O. Box 158 Point of Rocks, WY 82942

Re:

Air Quality Permit MD-6040 BART Permit: Jim Bridger Power Plant

Dear Mr. Arambel:

The Division of Air Quality of the Wyoming Department of Environmental Quality has enclosed a copy of the Best Available Control Technology (BART) permit for PacifiCorp's Jim Bridger Power Plant, dated December 31, 2009. Comments received during the public comment period and the public hearing were considered in the final permit. A copy of the decision document for the permit is also enclosed. No permit conditions required revision as a result of the public comment period.

If you have any questions, please feel free to contact this office.

Sincerely,

meny

David A. Finley Administrator Air Quality Division

cc: Tony Hoyt/AQD Lander

RECEIVED

JAN 0 7 2010

M.M

