


11-5017



Department of Environmental Quality

To protect, conserve, and enhance the Quality of Wyoming's environment for the benefit of current and future generations



Matthew H. Mead, Governor

John Corra, Director

October 17, 2011

CERTIFIED # 7011 0110 0001 7176 6218

Ron and Yolanda Strand
P.O. Box 155
Alcova, WY 82620

FILED
OCT 24 2011
Jim Ruby, Executive Secretary
Environmental Quality Council


Dear Mr. and Mrs. Strand:

Enclosed you will find a Notice of Violation and Order, Docket Number 4911-11, issued under the provisions of W.S. 35-11-701(c). You are registered as the owners of Sloanes General Store, storage tank facility 0-002201, which is located at 21405 Kortess Road, Alcova, Wyoming.

STP personnel conducted a compliance inspection at this facility on July 22, 2011. During the inspection it was noted that there is not a licensed tank operator, fireproof secondary containment barriers are not installed, emergency shutoff switches are not prominently marked, the sump sensors are not wired to shut the turbines down, the tanks are not properly labeled, and one of the tanks is in direct contact with the ground and is not protected from corrosion. These are violations of Wyoming Water Quality Rules and Regulations, Chapter 17; therefore, the attached Notice of Violation has been issued.

ANY APPEALS TO THE ENVIRONMENTAL QUALITY COUNCIL FROM THE ATTACHED ORDER MUST BE MADE IN WRITING WITHIN THE TEN (10) DAY TIME LIMIT PRESCRIBED BY W.S. 35-11-701(c). Chapter I, Section 3 of the enclosed Department of Environmental Quality Rules of Practice and Procedure sets forth the requirements for the initiation of appeal proceedings. You are urged to review all provisions of the attached Rules of Practice and Procedure as they relate to this action.

If you appeal this order and request a hearing, please file two (2) copies of your written petition. One copy of the petition should go to the Chairman of the Environmental Quality Council at Room 1714, Herschler Building, 1st Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002. The second petition should be sent to John V. Corra, Director, Wyoming Department of Environmental Quality, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002. Both petitions must be sent by certified mail, return receipt requested.



John V. Corra
Director
Department of Environmental Quality



Carl Anderson, PhD
Administrator
Solid and Hazardous Waste Division

JVC/CA/KH/OG/

Enclosure: Notice of Violation and Order, Rules of Practice and Procedure

