



11-5219



Department of Environmental Quality

To protect, conserve, and enhance the Quality of Wyoming's environment for the benefit of current and future generations



Mathew H. Mead, Governor

John Corra, Director

October 18, 2011

CERTIFIED # 7011 0110 0001 7176 6126

Mark Richardson
Hiland Bright Spot
P.O. Box 187
Hiland, WY 82638

FILED
OCT 31 2011
Jim Ruby, Executive Secretary
Environmental Quality Council


Dear Mr. Richardson:


Enclosed you will find a Notice of Violation and Order, Docket Number 4870-11, issued under the provisions of W.S. 35-11-701(c). You are registered as the owner of Hiland Bright Spot storage tank facility 0-001649, which is located at 53650 Highway 20-26, Hiland, Wyoming.

STP personnel conducted a compliance inspection at this facility on July 20, 2011. During the inspection it was discovered that there is no licensed operator, an Operator's Annual Inspection (OAI) has not been performed, and the facility does not have a sign that clearly indicates the location of the emergency shutoff switch. These are violations of Wyoming Water Quality Rules and Regulations (WWQRR), Chapter 17; therefore, the attached Notice of Violation has been issued.

ANY APPEALS TO THE ENVIRONMENTAL QUALITY COUNCIL FROM THE ATTACHED ORDER MUST BE MADE IN WRITING WITHIN THE TEN (10) DAY TIME LIMIT PRESCRIBED BY W.S. 35-11-701(c). Chapter I, Section 3 of the enclosed Department of Environmental Quality Rules of Practice and Procedure sets forth the requirements for the initiation of appeal proceedings. You are urged to review all provisions of the attached Rules of Practice and Procedure as they relate to this action.

If you appeal this order and request a hearing, please file two (2) copies of your written petition. One copy of the petition should go to the Chairman of the Environmental Quality Council at Room 1714, Herschler Building, 1st Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002. The second petition should be sent to John V. Corra, Director, Wyoming Department of Environmental Quality, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002. Both petitions must be sent by certified mail, return receipt requested.


John V. Corra
Director
Department of Environmental Quality


Carl Anderson, PhD
Administrator
Solid and Hazardous Waste Division

JVC/CA/KH/OG/

Enclosure: Notice of Violation and Order, Rules of Practice and Procedure

