




Department of Environmental Quality



John Corra, Director

Matthew H. Mead, Governor

To protect, conserve, and enhance the Quality of Wyoming's environment for the benefit of current and future generations

June 7, 2012

CERTIFIED 7008 1830 0004 7090 9989

Angela Hagler
Alcova Resort, LLC
101 East 2nd Street
Casper, WY 82601

FILED

JUN 08 2012

Jim Ruby, Executive Secretary
Environmental Quality Council


Dear Ms. Hagler:

Enclosed you will find a Notice of Violation and Order, Docket Number 5001-12, issued under the provisions of W.S. 35-11-701(c).


Personnel from the Department of Environmental Quality (DEQ) Storage Tank Program conducted an aboveground storage tank (AST) compliance inspection at the Alcova Lakeside Marina on April 13, 2012. During the inspection it was discovered that Alcova Resort, LLC, failed to: 1) replace single wall steel underground piping with double wall non-corrodible underground piping, 2) install leak proof piping transition sumps, 3) post no smoking signs and product labels on the AST, 4) install an adequate security fence around the AST, 5) submit a Spill Prevention Control and Countermeasures (SPCC) Plan to the DEQ, 6) perform inventory control, 7) perform an operator's annual inspection (OAI), 8) perform an annual function test of the automatic line leak detector, and 9) perform annual line tightness testing. These are all violations of Wyoming Water Quality Rules and Regulations (WWQRR), Chapter 17. For these reasons the attached Notice of Violation has been issued.

ANY APPEALS TO THE ENVIRONMENTAL QUALITY COUNCIL FROM THE ATTACHED ORDER MUST BE MADE IN WRITING WITHIN THE TEN (10) DAY TIME LIMIT PRESCRIBED BY W.S. 35-11-701(c). Chapter I, Section 3 of the enclosed Department of Environmental Quality Rules of Practice and Procedure sets forth the requirements for the initiation of appeal proceedings. Please review all provisions of the attached Rules of Practice and Procedures as they relate to this action.

If you appeal this order and request a hearing, please file two (2) copies of your written petition. One copy of the petition should go to the Chairman of the Environmental Quality Council at Room 1714, Herschler Building, 1st Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002. The second petition should be sent to John V. Corra, Director, Wyoming Department of Environmental Quality, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002. Both petitions must be sent by certified mail, return receipt requested.



John V. Corra
Director
Department of Environmental Quality



Carl Anderson, PhD
Administrator
Solid and Hazardous Waste Division

JVC/CA/KH/OG
Enclosure: Notice of Violation and Order, Rules of Practice and Procedure