

Table D6-16 Distribution of Samples Exceeding EPA MCL for Radium 226+228

Monitored Aquifer	Number of Samples	Number of Samples Exceeding EPA MCL	Percent of Exceedances
DE	16	4	25.00
LFG	28	14	50.00
HJ	28	23	82.14
UKM	28	18	64.29
Total	100	59	59.00